



West Milford Township
1480 UNION VALLEY ROAD
WEST MILFORD, NJ 07480

Date Issued 1/18/2017
Control Number C-09-0600
Permit Number 09-0689
Permit Issue Date 6/24/2009
Certificate Number 09-0689

Certificate

Construction Code Division
(Certificate of Approval)

Identification

Work Site Location: 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421 Block: 3705 Lot: 3 Qual: _____
Owner In Fee: WILEY, RICHARD & THERESA
Owner Address: 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421
Telephone: _____
Contractor: PREMIER ROOFING
Address: 387 NORTH 8TH STREET PROSPECT PARK NJ 07508
Telephone: (973) 831-6099 Fax: _____
License Number or Builders Registration Number: _____ Federal Emp. Number: _____

Home Warranty Number: _____

Type of Warranty Plan: ☐ State ☐ Private

Use Group: R-5 Construction Classification: _____

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: NEW ROOF WITH ICE SHIELD

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent.

☐ Total removal of lead-based paint hazards in scope of work

☐ Partial or limited time period (_____ years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

☐ Total removal of asbestos hazards in scope of work

☐ Partial or limited time period (_____ years); see file

☐ **Certificate of Compliance**


This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than: or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:


Construction Official

Fee: \$0.00

Check Number: _____

Collected By: _____



West Milford Township
1480 UNION VALLEY ROAD
WEST MILFORD, NJ 07480

Date Issued 1/10/2017
Control Number C-16-1898
Permit Number 16-1676
Permit Issue Date 12/13/2016
Certificate Number 16-1676

Certificate

Construction Code Division

(Certificate of Approval)

Identification

Work Site Location: 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421 Block: 3705 Lot: 3 Qual:
Owner In Fee: WILEY, RICHARD & THERESA
Owner Address: 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421
Telephone: [REDACTED]
Contractor: RUSSELL W. ANDERSON, INC.
Address: PO BOX 757 RAMSEY NJ 07446
Telephone: (201) 825-2092 Fax:
License Number or Builders Registration Number: US00904 Federal Emp. Number: 22-3327796

Home Warranty Number:

Type of Warranty Plan: ☐ State ☐ Private

Use Group: U Construction Classification:

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: REMOVE 1-550 GAL UST

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:
This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJACS:17 to the following extent.

☐ Total removal of lead-based paint hazards in scope of work

☐ Partial or limited time period (years); see file.

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

☐ Total removal of asbestos hazards in scope of work

☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than:
or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

Construction Official

Fee: \$0.00

Check Number:

Collected By:



West Milford Township
1480 UNION VALLEY ROAD
WEST MILFORD, NJ 07480

Date Issued 1/10/2017
Control Number C-16-1899
Permit Number 16-1677
Permit Issue Date 12/13/2016
Certificate Number 16-1677

Certificate

Construction Code Division
(Certificate of Approval)

Identification

Work Site Location: 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421 Block: 3705 Lot: 3 Qual:
Owner in Fee: WILEY, RICHARD & THERESA
Owner Address: 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421
Telephone:
Contractor: RUSSELL W. ANDERSON, INC.
Address: PO BOX 757 RAMSEY NJ 07446
Telephone: (201) 825-2092 Fax:
License Number or Builders Registration Number: US00904 Federal Emp. Number: 22-3327796

Home Warranty Number:

Type of Warranty Plan: ☐ State ☐ Private

Use Group: U Construction Classification:

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: INSTALL 1-275 GAL ABOVE GROUND ROTH TANK

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:
This certificate has an expiration date of:
Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent:

- ☐ Total removal of lead-based paint hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent:

- ☐ Total removal of asbestos hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than:
or the owner will be subject to fine or order to vacate:
This certificate has an expiration date of:
Conditions to be met:

Construction Official

Fee: \$0.00
Check Number:
Collected By:



FIRE SUBCODE TECHNICAL SECTION



Date Received 12/13/2016
Control # C-16-1899
Date Issued 12/13/2016
Permit # 16-1677

A. IDENTIFICATION - APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS. NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000
Block 3705 Lot 3 Qualification Code _____

Work Site Location 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421

Owner in Fee: WILEY, RICHARD & THERESA

Tel. _____ e-mail _____

Address 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421

Street Municipality zip code

Contractor: RUSSELL W. ANDERSON, INC. Tel. (201) 825-2092

Address PO BOX 757 RAMSEY NJ 07446 e-mail _____

Fire Protection Equipment, NJ Div of Fire Safety Permit No. _____

Fire Protection Equipment, NJ Div of Fire Safety Installer No. _____

Fire Alarm Contractor No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason(if applicable): _____

Federal Emp. ID No. 22-3327796 Fax. _____

B. FIRE PROTECTION CHARACTERISTICS

Use Group: Present U Proposed U

Constr. Class: Present _____ Proposed _____

Heating Systems: ☐ New or ☐ Modification to Existing
or ☐ Conversion or ☐ Replacement

Fuel Type: ☐ Gas ☐ Oil ☐ Electric ☐ Solar

☐ Other _____

Location: _____

Total Cost of Fire Protection Work \$ \$400

Fuel Storage Tank:

Fuel Type ☐ Flammable or ☐ Combustible
Capacity _____

Fire Alarm System: ☐ New or ☐ Existing
Location of Panel: _____

Fire Suppression/Standpipe System:
☐ New or ☐ Existing
Location of Main Control Valve: _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Applicant's Signature/Contractor's Seal and Signature and Printed Name

☐ Certified Contractor

☐ Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

INSTALL 1-275 GAL ABOVE GROUND ROTH TANK

Water Supply Source _____

Method of Alarm/Suppression System Supervision _____

	NUMBER	FEE (Office Use Only)
Flammable/Combustible Tanks	1	\$80
Alarm Systems		
☐ System		
☐ 110v Interconnected		
☐ CO Detectors/110v		
Alarm Devices (i.e. smoke, heat, pulls, water/flow)		
Supervisory Devices (tamper, low/high air)		
Signaling Devices (i.e., horn/strobes, bells)		
Other Devices		
TOTAL		
Suppression Systems		
Fire Pump _____ GPM Type _____		
Dry Pipe/Alarm Valves		
Pre-action Valves		
Sprinkler Heads (Dry and Wet)		
Standpipes		
Pre-engineered Systems		
Wet Chemical		
Dry Chemical		
CO2 Suppression		
Foam Suppression		
FM200 Suppression		
Other		
Other Systems		
Kitchen Hood Exhaust System		
Smoke Control System		
Fuel-Fired Appliances ☐ Gas ☐ Oil ☐ Solid		
Fireplace Venting/Metal Chimney		
Other		

JOB SUMMARY (Office Use Only)		INSPECTIONS		Dates (Month/Day)	
PLAN REVIEW	Date	Initial	Type:	Failure	Approval
☐ No Plan Required			Alarm System		
☐ Partial Underslab Utilities Approved			Suppression Sys.		
Date: _____ Approved by: _____			Standpipe		
☐ Fire Protection Plans Approved			Fire Pump		
Date: _____ Approved by: _____			Pre-Eng. System		
Joint Plan Review Required			Mechanical		
☐ Bldg. ☐ Elec. ☐ Plumb ☐ Elev.			Smoke Control		
SUBCODE APPROVAL for PERMIT			TCO		
Date: _____			Flam/Cumbust Tank		
Approved by: _____			Fireplace Venting		
SUBCODE APPROVAL for CERTIFICATE			Final		
☐ CO ☐ CCO ☐ CA			Other		
Date: _____					
Approved by: _____					

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____ \$1
TOTAL FEE \$ _____ \$81



MECHANICAL INSPECTION TECHNICAL SECTION



Date Received 11/26/2019
Control # C-19-1750
Date Issued 12/3/2019
Permit # 19-1499

A. IDENTIFICATION - APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block 3705 Lot 3 Qualification Code _____

Work Site Location 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421

Owner in Fee: WILEY, RICHARD & THERESA

Tel. _____ e-mail _____

Address 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421

Street Municipality zip code

Contractor: GRIFFITHS PLUMBING AND HEATING Tel. 973/7280880

Address 12 MILLINGTON AVENUE HEWITT NJ 07421-

e-mail _____

Contractor License No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason _____

Federal Emp. ID No. 22-2672361 FAX _____

B. MECHANICAL CHARACTERISTICS

Use Group Present U

Heating System work: ☐ New or ☐ Modification to Existing or ☐ Conversion or ☐ Replacement

Type: ☐ Hydronic ☐ Hot Air

Fuel Type: ☐ Gas ☐ Oil ☐ Electric ☐ Solar ☐ Other _____

Estimated Cost of Mechanical Work \$ \$7,500

JOB SUMMARY (Office Use Only)

PLAN REVIEW:

☐ No Plan Required

☐ MECHANICAL PLANS APPROVED

Date: _____ Approved by: _____

Joint Plan Review Required

☐ Bldg ☐ Elec. ☐ Plumb ☐ Fire.

☐ Elev.

SUBCODE APPROVAL for PERMIT

Date: _____

Approved by: _____

SUBCODE APPROVAL for CERTIFICATE

☐ CA ☐ CCO

Date: _____

Approved by: _____

INSPECTIONS

Type:	Failure	Failure	Approval	Initial
Water Heater				
Appliance				
Chimney/Vent				
Piping				
Tank				
Cooling/AC				
Generator				
Fireplace				
Chimney Cert.				
Other _____				
Other _____				
Final				

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application. _____

Signature

Print Name Here _____

☐ Licensed Electrical Contractor

☐ Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

REPLACE EXISTING OIL BOILER, INSTALL INDIRECT HOT WATER HEATER, PIPE OWNERS OIL TANK

NO.	FIXTURES/EQUIPMENT	FEE (Office Use Only)
<u>1</u>	Water Heater	\$ <u>\$60</u>
<u>1</u>	Fuel Oil Piping Connections	<u>\$60</u>
	Gas Piping Connections	
	Steam Boiler	
<u>1</u>	Hot Water Boiler	<u>\$60</u>
	Hot Air Furnace	
<u>1</u>	Oil Tank	<u>\$60</u>
	LPG Tank	
	Fireplace	
	Generator	
<u>1</u>	Other BACKFLOW	<u>\$60</u>
Administrative Surcharge \$ _____		
Minimum Fee \$ _____		
State Permit Surcharge Fee \$ _____		<u>\$14</u>
TOTAL FEE \$ _____		<u>\$314</u>



ELECTRICAL SUBCODE TECHNICAL SECTION



Date Received 11/26/2019
Date Issued 12/3/2019
Control # C-19-1750
Permit # 19-1499

A. IDENTIFICATION - APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block 3705 Lot 3 Qualification Code _____

Work Site Location 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421

Owner in Fee. WILEY, RICHARD & THERESA

Tel. [REDACTED] e-mail _____

Address 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421

Street Municipality zip code

Contractor: ABC ELECTRICAL CONT INC Tel. (201) 320-2824 / Cell: [REDACTED]

Address 356 LAKESHORE DRIVE HEWITT NJ 07421

e-mail _____

Contractor License No. 16372 Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason(if applicable): _____

Federal Emp. ID No. _____ FAX _____

B. ELECTRICAL CHARACTERISTICS

Use Group Present U Proposed U

☐ Pole/Pad # _____ ☐ Temporary ☐ Other _____

Building Occupied as _____ Utility Co. _____

Est. Cost of Elec. Work \$ \$300

JOB SUMMARY (Office Use Only)

PLAN REVIEW		INSPECTIONS		Dates (Month/Day)		
☐ No Plan Required		Type:	Failure	Failure	Approval	Initial
☐ Partial-Underslab Approved		Rough				
Date: _____ Approved by: _____		Barrier-Free				
☐ Electrical Plans Approved		Trench				
Date: _____ Approved by: _____		Temp. Serv.				
Joint Plan Review Required:		Constr. Serv.				
☐ Bldg. ☐ Plumb. ☐ Fire. ☐ Elev.		TCO				
		Other				
SUBCODE APPROVAL for PERMIT		Service				
Date: _____		Final				
Approved by: _____		Barrier-Free				
SUBCODE APPROVAL for CERTIFICATE		Temp. Cut-in-Card Date Issued				
☐ CO ☐ CCO ☐ CA		Final Cut-in-Card Date Issued				
Date: _____		Annual Pool Inspection				
Approved by: _____		Date of Grounding and Bonding Certification				

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of the record and am authorized to make this application and perform the work listed on this application.

Applicant's sign/Contractor sign _____
and seal here: Print name here: _____

☐ Licensed Electrical Contractor ☐ Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK
REPLACE EXISTING OIL BOILER. INSTALL INDIRECT HOT WATER HEATER,
PIPE OWNERS OIL TANK

QTY.	SIZE	ITEMS	FEE (Office Use Only)
		Lighting Fixtures	
		Receptacles	
		Switches	
		Detectors	
		Light Poles	
		Motors - Fract. HP	
		Emergency & Exit Lights	
		Communications Points	
		Alarm Devices/F.A.C. Panel	
1		BOILER	
1		TOTAL NUMBERS	\$ \$70
		Pool Permit/with UW Lights	
		Storable Pool/Spa/Hot Tub	
		KW Elec. Range/Receptacle	
		KW Oven/Surface Unit	
		KW Elec. Water Heater	
		KW Elec. Dryer/Receptacle	
		KW Dishwasher	
		HP Garbage Disposal	
		KW Central A/C Unit	
		HP/KW Space Heater/Air Hand	
		KW Baseboard Heat	
		HP Motors 1/+ HP	
		KW Transformer/Generator	
		AMP Service	
		AMP Subpanels	
		AMP Motor Control Center	
		KW Elec. Sign/Outline Light	

Administrative Surcharges
Minimum Fee \$ \$70
State Permit Surcharge Fee \$ \$1
TOTAL FEES \$71



West Milford Township
1480 UNION VALLEY ROAD
WEST MILFORD, NJ 07480

Date Issued 12/3/2019
Control Number C-19-1750
Permit Number 19-1499

Construction Inspection

Identification

Work Site Location: 1902 GREENWOOD LAKE TPKE HEWITT, NJ 07421
Block: 3705
Lot: 3
Owner in Fee: WILEY, RICHARD & THERESA
Owner Address: 1902 GREENWOOD LAKE TPKE HEWITT NJ 07421
Telephone: [REDACTED]

Inspection Details

Start Date: 12/27/2019
Start Time: 00:00
Subcode: Electrical
Inspector: Anthony Dedrick
Inspection Level: Progress inspection
Inspection Type: FINAL REINSPECTION
Result: Fail
Result Comments: bond water piping connector for low voltage on water heater box to small for disconnect switch
Inspection Comment: Agent: GRIFFITHS PLUMBING AND HEATING
Phone: 973/7280880/