



WASHINGTON TOWNSHIP

HEALTH DEPARTMENT

43 SCHOOLEY'S MOUNTAIN ROAD
LONG VALLEY, MORRIS COUNTY, NEW JERSEY

Telephone (908) 876-3650
Fax (908) 876-5138

February 24, 2017

Nancy Baxter
22 Mt. View Drive
Chester, NJ 07930

Address: 22 Mt. View Drive
Block 10.03 Lot 9

Date of sampling: 2/13/2017

PARAMETER	RECOMMENDED LIMITS	YOUR RESULT
Total Coliform bacteria	Negative	Negative

Interpretation of results:

- As tested, your water met standards.

I hope that you have found this information helpful. If you would like more assistance on interpreting your water results, or have questions about other water-related issues, please contact me at (908) 876-3650.

Sincerely,

A handwritten signature in black ink, appearing to read "Kurt Bockbrader".

Kurt Bockbrader
Registered Environmental Health Specialist



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing



ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

APL WORK ORDER NUMBER: 7020409

Washington Township Health Department

Project: None Given

Brian Wood
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or
State specific certifications as applicable.



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

Client: Washington Township Health Department
APL Order ID: 7020409

Contact: Kurt Bockbrader
Received: 02/14/17 16:30

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
7020409-01 (Drinking Water)		Nancy Baxter, 22 Mt View Dr		Collected:	02/13/17 14:45			
Microbiology								
Total Coliform	SM 9223B + UV	02/14/17 17:00	02/14/17 17:00	Negative		N/A	N/A	N/A

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns.
H - Indicates a Hold Time violation

