



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Inspection Activity Report

Inspections for Permit Number 22-1369

Permit Number
22-1369

					Owner				
Inspection Date	Inspection Type	Inspector		Subcode	Result	Location	Work Type	Work Description	Inspection Comments
10/13/2022	FOOTING	Kenneth	Kiseli	Building	Fail	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	ALL HOLES COMPLETEY FILLED w/ WATER RE-INSPECTION
10/25/2022	FOOTING	Kenneth	Kiseli	Building	Fail	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	
11/03/2022	FOOTING	Kenneth	Kiseli	Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	SUBSTANTIAL AMOUNT WATER IN MOST HOLES RE-INSPECTION
12/27/2022	AS-BUILT SURVEY	Kenneth	Kiseli	Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	
01/05/2023	FOUNDATION	John Pinkava InActive		Building	Fail	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	ELEVATION FND SURVEY 1) Need helical log and cert 2) need design professional to comment on anchor bolts that can not be anchored
01/19/2023	FOUNDATION	John Pinkava InActive		Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	
03/15/2023	SLAB	Timothy Skinner		Building	Fail	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	recieved log report and fnd letter No plans on site
03/29/2023	SLAB	Timothy Skinner		Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	
11/15/2023	MECHANICAL CONNECTION	Mark DePalma		Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	Agent: SKYECO CONSTRUCTION Phone: (732) 865-4874/
11/21/2023	FOOTING	Mark DePalma		Building	Pass	KRISTOFFER LEHMAN 28 LENAPE TRAIL	Addition/Alteration	RAISE HOUSE ALTERATION - RESIDENTIAL	