

CONTINUATION SHEET
(For Inspections, Surveys, Audits, etc.)

South Brunswick Township
Health Department
P.O. Box 190
Monmouth Junction, NJ 08852
732-329-4000 Ext. 7237

NAME (Individual, Facility, Establishment, etc.)

DATE

9/29/21

ADDRESS

380 Culver Rd

BLOCK

LOT

TEL.

Item
No.

Remarks


Note for file:

Although a HD UST prior approval was issued, the required Health Dept underground tank removal inspection report is unaccounted (either never inspected or report is missing).

Also, there is no record of the status of the NJDEP spill report # 08-04-30-1455-32 which indicated a leak and clean-up pending.



Signature of Individual Completing Form



Signature of Owner of Facility, Establishment, etc., if required

PAGE

OF

PAGES



State of New Jersey

Department of Environmental Protection

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

40/1 201
40/
12.01
MAY - 5 2008

Stephen J. Papenberg
Monmouth Jct Rd, Municipal Bdg
Monmouth Junction, NJ 08852

May 1, 2008

SUSPECTED HAZARDOUS SUBSTANCE DISCHARGE NOTIFICATION NJDEP CASE
NUMBER: 08-04-30-1455-32

The New Jersey Department of Environmental Protection, Site Remediation Program, has received verbal notification of an incident that may have resulted in a discharge of a hazardous substance within your jurisdiction.

Pursuant to N.J.S.A. 13.1K-15 et seq., (P.L. 1984, c. 210) "Hazardous Substance Discharge - Reports and Notices Act" and N.J.A.C. 7:1E-5.1 et seq., "Hazardous Substance Discharge: Reports and Notices", attached is a copy of our Incident Notification Form which contains details of the suspected discharge. Further information concerning this incident may be obtained by contacting:

CASE ASSIGNMENT SECTION
Site Remediation
609-292-2943

Please refer to the above "NJDEP CASE NUMBER" in all correspondence concerning this incident.

DAVID H. KERR, COMMUNICATIONS OFFICER
BUREAU OF COMMUNICATIONS AND RESPONSE

Attachment

**New Jersey Department of Environmental Protection
COMMUNICATION CENTER NOTIFICATION REPORT**

40/12.01

Received: 4/30/2008 14:55:32

Comm. Center #: 08-04-30-1455-32

Operator: 16

Reviewed By: _____

Reporter Type: Other

Reported By: ED CHONTOFALSKY

Affiliation: SKYLANDS ENERGY SVC

Phone: 908-782-2519

Street Address: P O BOX 437,

Municipality: Readington Twp

State: NJ

Incident Category: Other

Location Description: AT RESIDENCE

Address: 380 CULVER RD

Municipality: South Brunswick Twp

County: Middlesex

State: NJ

Zip Code: 08852

Location Type: Residential

Occurred Date: 04/30/2008

Occurred Time: 01:30 PM

Substance Released: OIL HEATING #2

Amount Released:

Units:

Unknown

ID: Known

State: Liquid

CAS#:

Incident Status at Time of Report: Terminated

Substance Contained: Yes

HAZMAT: Yes

TCPA: No

Haz Waste: No

Incident Type: Underground Storage Tank

Incident Type 2:

Injuries: No

Public Evac: No

Facility Evac: No

Public Exposure: No

Police At Scene: No

Firemen At Scene: No

Dep Requested: No

Road Closure: No

Wind Speed/Direction:

Contamination Of: Land

Watershed:

Other Watershed:

Incident Description: 1/550 GAL UST REMOVED. CLEAN UP PENDING

Responsible Party Name: JAMES DELLOW

Responsible Party Phone: 732-230-3643

Responsible Party Street Address: 380 CULVER RD,

Municipality: South Brunswick Twp

County: Middlesex

State: NJ

Zip Code: 08852

Officials Notified

Name	Affiliation	Phone	Date	Time	Action
	Case Assignment Section		04/30/2008	0:00	Notification - Fax
AL LAIRD	SOUTH BRUNSWICK TWP	732-329-4646	04/30/2008	14:59	Notification - A310

Comments:

**SOUTH BRUNSWICK TOWNSHIP HEALTH DEPARTMENT
UNDERGROUND TANK REMOVAL - PRIOR APPROVAL REVIEW**

FEB 11 2008

ADDRESS: 380 Culver Rd Mon Jct BLOCK 40 LOT 12.01

OWNER: James Dellow TEL.# 732-230-3643

OWNERS MAILING ADDRESS: JAME

LAND USE: ☒ RESIDENTIAL ☐ AGRICULTURAL ☐ Non-Residential (Commercial UST REGISTRATION # _____)

Does the premises have any of the following: ☐ well water ☐ Basement ☐ sump or French drain in basement

TANK SIZE: 550 (gallons) PRODUCT STORED: #2 oil TANK TYPE: steel or fiberglass AGE 30+ (yrs.)

Are there any *known* problems with the tank (water infiltration, odors, stains, loss of product...etc.)? ☒ No ☒ Yes (describe on next line)

REASON FOR REMOVAL: To install 275 Noth in Basement

REMOVAL CONTRACTOR: Skylands Energy TEL.# 732-388-1000

(If applicable, NJDEP CERTIFIED TANK CLOSURE REGISTRATION # _____)

TANK CLEANING CO.: N/A Skylands Energy TEL.# 732-388-1000

ENVIRONMENTAL CLEAN-UP CONTINGENCIES:

Owners are advised to develop a contingency plan to address a possible environmental cleanup in the event that a leak has occurred from the underground tank. Please consider the following: WHO WILL EXCAVATE CONTAMINATED SOIL, IF SOIL WILL BE STORED ON SITE PENDING TEST RESULTS, HOW WILL IT BE STORED, WHO WILL TAKE SOIL SAMPLES, WHAT LABORATORY WILL ANALYZE THE SOIL SAMPLES, and finally WHO WILL PREPARE AND SUBMIT A REPORT FOR THE NJDEP. Owners are responsible for all these aspects but may act through a consultant. If an Environmental Consultant has been selected to assist with any environmental concerns of this removal, please indicate the contractor or company name below (required for commercial tanks):

ENVIRONMENTAL CONTRACTOR: Skylands Energy TEL# 732-388-1000

(If applicable, NJDEP CERTIFIED Subsurface evaluator REGISTRATION # 13VH01)

*** INCLUDE A DIAGRAM OF THE TANK LOCATION (position referenced to BLDGS. & ROADS) ***

An appointment shall be made in advance with the Health Department for an inspection of the removed tank and of the open excavation before backfilling. The owner agrees to comply with NJDEP "Technical Requirements for Site Remediation" (N.J.A.C. 7:26E et seq.) and implement environmental contingencies if a release of stored product to the environment is observed, and provide a copy of all disposal receipts, test data, and remedial investigation reports to the Health Department. If in the opinion of the Township's inspector there is evidence that indicates that a leak may have occurred, the owner agrees to have soil samples taken and analyzed at the owner's expense. Excavations must be secured at all times.

PROPERTY OWNER / Prop. Mgr.: James Dellow print/type name SIGNATURE [Signature] DATE 1/24/08

REMOVAL CONTRACTOR: Skylands Energy print/type name SIGNATURE [Signature] DATE 12/18/07

The above contractor agrees to comply with API, NFPA, EPA, DEP and OSHA standards for underground tank removals and handling of hazardous materials.

HEALTH DEPT. APPROVAL: [Signature] SIGNATURE DATE: 2/13/08

State Of New Jersey
New Jersey Office of the Attorney General
Division of Consumer Affairs

THIS IS TO CERTIFY THAT THE
Division of Consumer Affairs

HAS REGISTERED

Skylands Energy Service, Inc.
Edward A. Miller
2 Thompson Street
Raritan NJ 08869

FOR PRACTICE IN NEW JERSEY AS A(N): Home Improvement Contractor

01/10/2006 TO 12/31/2006
VALID

13VH01695600
LICENSE/REGISTRATION/CERTIFICATION #

Signature of Licensee/Registrant/Certificate Holder

DIRECTOR

PLEASE DETACH HERE
IF YOUR LICENSE/REGISTRATION/
CERTIFICATE ID CARD IS LOST
PLEASE NOTIFY:
Division of Consumer Affairs
P.O. Box 46016
Newark, NJ 07101
PLEASE DETACH HERE


Block 40
Lot 12-A

APPLICATION FOR PERMIT

BOARD OF HEALTH
OF THE
TOWNSHIP OF SOUTH BRUNSWICK

1. Name of Applicant: Everett Moore
2. Address of Applicant: Dayton, N.J.
Custer Rd.
3. Type of Permit sought: Water and Sewage
4. Premises involved: Block 40, Part of Lot 12
5. Premises owned by: Everett Moore

Where applicable give description of facility or equipment to be constructed, type of construction, exact location showing distance from nearest source of water, and lot size giving detailed information and sketch.



Applicant agrees to be personally liable for compliance with all Ordinances of the Township of South Brunswick.

Date: Oct 13, 58

Shelley S. Hunt

Signature of Applicant

(Not to be filled in by applicant)

Fee paid: 10.00

Action taken:

Date: Oct 13, 58

Permit number issued: 231

Shelley S. Hunt

Health Officer