

**CERTIFICATE OF COMPLIANCE
INDIVIDUAL SUBSURFACE SEWAGE DISPOSAL SYSTEMS
COUNTY/MUNICIPALITY OF Morris/Chester**

INSTRUCTIONS: Part A is to be completely filled in for all Certifications. ONLY PART B or C will be completed. Part B will be completed if the administrative authority relies upon the certification signed and sealed by a New Jersey licensed professional engineer that the system has been located, constructed, installed, or altered in compliance with the requirements of N.J.A.C. 7:9A-1 and the Application to Construct/Alter/Repair an Individual Subsurface Sewage Disposal System which was approved by the administrative authority. Part C will be completed if the administrative authority performs the authorization.

Part A - General Information

1. Permitted Activities (Check applicable Categories)

_____	New Construction
<u> x </u>	Alteration/No Expansion or Change in Use
_____	Alteration/Expansion or Change in Use
_____	Alteration/Malfunctioning System
<u> x </u>	Deviation from Standards
_____	Repair in Existing System

2. Location of Project: Block 51.01 Lot 5

Address: 5 Ironia Road

3. Name and Present Address of Applicant:

Leslie Brown, 5 Ironia Road, Flanders, NJ 07836


Applicant Phone #: (973) 229-1111

PART B - Professional Engineer's Certification

I certify, under penalty of law, that the subsurface disposal system identified in Part A has been located, constructed, installed, or altered in compliance with the requirements of N.J.A.C. 7:9A-1 and the Application to Construct/Alter/Repair and Individual Subsurface Sewage Disposal System which was approved by the administrative authority. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.



Mark A. Palus, License # 40354



1/18/2016

Date

SEAL

PART C - Certification by Administrative Authority

I certify, under penalty of law, that the subsurface disposal system identified in Part A has been located, constructed, installed, or altered in compliance with the requirements of N.J.A.C. 7:9A-1 and the Application to Construct/Alter/Repair and Individual Subsurface Sewage Disposal System which was approved by the administrative authority. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Authorized Signature

Type of License Held

Name (Typed of Printed)

License Number

Date

FOR AGENCY USE ONLY

Date Received _____

Date Returned _____

Form Determined to Be: _____ Complete _____ Incomplete

Date Certification Approved _____

Authorized Signature _____



Hunterdon County
Department of Public Safety
Division of Public Health Services

www.co.hunterdon.nj.us/health.htm

SUITABLE FILL CERTIFICATION

For

THE HUNTERDON COUNTY DEPARTMENT OF PUBLIC HEALTH

MUNICIPALITY: Chester, Morris DATE: 1/12/16
BLOCK: 51.01 LOT: 5 DISPOSAL SYSTEM DESIGN RATE: K4

QUARRY NAME: Koz deba

I hereby certify that the fill material used meets the requirements of 7:9A

Date fill material acquired from field: 1/8/16 Date of testing: 1/8/16

	A textural analysis of: Percentage Passing Through:
Between 80-100%	8 Sieve <u>87</u>
Between 50-85%	16 Sieve <u>69</u>
Between 25-60%	30 Sieve <u>37.5</u>
Between 10-30%	50 Sieve <u>19.2</u>
Between 2-10%	100 Sieve <u>8.7</u>

Coarse fragment: _____ Coarse fragment: 13

(Check one) By: _____ Volume (less than 15%) X Weight (less than 20%)

** Fine & Very Fine Sand _____ ** Fine and Very Fine Sand _____

*Engineer's Signature and Seal

And that the fill material after it has been emplaced and compacted to a bulk density equivalent to the design permeability at the level of infiltration set forth in N.J.A.C. 7:9A-6.1(a) determined by: **(Tube permeameter tests shall be performed within the bed area).**

Permeability shall be 6-20 inches per hour for design purposes

Date of fill material acquired from field: _____
Date of testing: _____

Percolation tests, with a result of: _____
Tube permeameter tests, with a result of: _____

I find the compaction and placement of the fill material satisfactory and meets the requirements as set forth in N.J.A.C. 7:9A-10.4(F)3.

*Engineer's Signature and Seal

* Engineer's signature and Seal required in each section.

** Lebanon Township and Readington Township - fine and very fine sand to 25% or less by weight. Or any additional tests required in the engineer's designs.

Physical Address: 314 State RT. 12, County Complex, Bldg. #1, 2nd Floor

Mailing Address: P O Box 2900, Flemington, NJ 08822

Tel (908) 788-1351 Fax (908) 782-7510

SEPTIC TANK
WATER TIGHTNESS TEST CERTIFICATION

Engineer

☒ Manufacturer

Township: CHESTER

Block: 51.01 Lot: 5

Street Address: A 5 IRONIA

Home Owner: LESLIE BROWN

BRIAN PESCA certify that the Septic Tank installed on the above referenced block and lot has passed the Water Tightness Test as described by the ASTM, C-1227, or the National Pre-cast Concrete Association (NPCA) testing criteria as set by N.J.A.C. 7:29A "Standards for Individual Subsurface Disposal Systems".

Brian Pesca
Signature

1-4-16

Date of Test

Type of Tank: ☒ Concrete ☐ Fiberglass ☐ Polyethylene

Type of Test: ☒ Vacuum Testing ☐ Hydrostatic

1-1250 2 comp.

BRIAN PESCA

Name of Tester (Please Print)

Brian Pesca
Signature of Tester

Engineer
Seal

GRANVILLE CONCRETE PRODUCTS
Company Name: **1078 ROUTE 10**
RANDOLPH, NJ 07880

Address

973-584-6653

Phone Number with Area Code

Hudson County Division of Public Health: Approved By

Date