

HEALTH DEPARTMENT
TOWNSHIP OF CHESTER

1 Parker Road ~~Box 398~~, Chester, New Jersey 07930

APPLICATION FOR A CERTIFICATE OF COMPLIANCE
LOCATION AND DESIGN FOR AN INDIVIDUAL WATER SUPPLY SYSTEM

FEE _____

PERMIT NO. _____

DATE SUBMITTED _____

N.J.S.D.E.P. NO. 2500061900

OWNER OF PROPERTY Bell Cottage Design Studio c/o Leslie Brown PHONE _____

ADDRESS 5 Ironia Road, Flanders NJ 07836

ADDRESS AT WHICH INDIVIDUAL WATER SUPPLY IS TO BE LOCATED AND CONSTRUCTED: 5 Ironia Road, Chester Township

BLOCK NO. 51.01 LOT 5

TYPE OF WELL Domestic ESTIMATED DEPTH 300'

DEPTH OF CASING 80' min. DIAMETER OF CASING 6"

METHOD OF SEALING neat cement STORAGE FACILITIES C/A 82 tank

PUMPING EQUIPMENT submersible pump PURIFICATION FACILITIES HTH

ATTACH A SCALED PLOT PLAN OF THE PROPERTY TO BE SERVED, SHOWING THE FOLLOWING:

Size of lot, locations of all buildings, location of proposed individual water supply, location of sewerage facilities, elevations, water courses.

IN CONSIDERATION of such permit, I hereby agree to construct the afore-described individual water supply system in accordance with the provisions of N.J.S.A. 58:11-23 known and may be cited as "The Realty Improvement Sewerage and Facilities Act" (1954) P.L. 1954 Chapter 199, and any higher standards established by the Township Board of Health.

SIGNATURE OF OWNER _____ (SEAL)

SIGNATURE OF PROFESSIONAL ENGINEER _____ (SEAL)

Name of Well Driller Paul Thomas c/o Somerville Well Drilling Phone 732-748-3888

Address 25E Kearney St., Bridgewater NJ License No. J1291
08807

DATE OF APPROVAL: _____
(CERTIFICATE OF COMPLIANCE - LOCATION AND DESIGN)

BY _____

STATE OF NEW JERSEY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
TRENTON, NJPermit No. 2500061900

MAIL TO:

NJDEP
BUREAU OF WATER ALLOCATION
PO BOX 426
TRENTON, NJ 08625-0426

PERMIT TO DRILL WELL

VALID ONLY AFTER APPROVAL BY THE D.E.P.

COORD #:

25.02.787Property Owner Bell Cottage Design StudioDriller Somerville Well Drilling LTD., Inc.Address 5 Ironia Road
Flanders, NJ 07836Address 25E Kearney Street
Bridgewater, NJ 08807

Name of Facility _____



Address 5 Ironia Road
Chester Township

Diameter of Well	6	Inches	Proposed Depth of Well	300	Feet
Proposed Capacity of Pump	10	GPM	Method of Drilling (Cable-tool, Rotary, etc.)	Rotary	
Use of Well (See Reverse)	Domestic				
Drinking Water Supply?	XX	yes (see #7 on reverse)	no		

LOCATION OF WELL

Lot #	Block #	Municipality	County
5	51.01	Chester Twsp	Morris

Draw sketch showing distance and location of well site to nearest public roads, streets, components of the nearest sewage disposal system, etc.

State Atlas Map No. 25PROVIDED WELL LOCATION (NAD 83 HORIZONTAL DATUM)
NJ STATE PLANE COORDINATE IN US SURVEY FEETNORTHING: _____ EASTING: _____
OR
LATITUDE: ____° ____' ____" LONGITUDE: ____° ____' ____"


SEE REVERSE SIDE FOR IMPORTANT PROVISIONS AND REGULATIONS PERTAINING TO THIS PERMIT. APPROVAL OF THIS PERMIT IS MADE SUBJECT TO ACCEPTANCE OF AND COMPLIANCE WITH THE FOLLOWING ADDITIONAL CONDITIONS.

- ☐ PUBLIC COMMUNITY Water Supply Wells shall obtain construction and operation permits from the Bureau of Safe Drinking Water in accordance with N.J.A.C. 7:10-11.1 et seq.
- ☐ INDUSTRIAL SUPPLY - A physical connection control permit shall be obtained pursuant to the provisions of N.J.A.C. 7:10-10.1 et seq.
- ☐ IRRIGATION SUPPLY - A physical connection control permit may be required pursuant to the provisions of N.J.A.C. 7:10-10.1 et seq.
- ☐ REPLACEMENT WELL - Existing well must be sealed by a New Jersey licensed well driller of the proper class upon abandonment.
- ☐ PINELANDS - Well must be drilled and cased to a minimum depth of 100' unless the provisions of N.J.A.C. 7:50-6.84 (a)4.v. are met.
- ☒ MINIMUM distance requirements as per N.J.A.C. 7:9D-2.7 have not been met - see attached condition(s).
- ☐ The well shall be equipped with a totalizing flow meter per N.J.A.C. 7:19-2 et seq.

In compliance with N.J.S.A.58:4A-14, application is made for a permit to drill a well as described above.

Date 6/3/03Signature of Driller Paul ThomasRegistration No. J1291Signature of Property Owner Leslie Brown

COPIES: Water Allocation - White Health Dept. - Yellow Owner - Blue Driller - White



2500061900
PERMIT NUMBER

APPROVAL DATE

THE WELL SHALL BE CONSTRUCTED WITH A MINIMUM OF
80 FEET OF CASING AND BE PROPERLY GROUTED IN
ACCORDANCE WITH N.J.A.C. 7:9D-2.9 and 7:9D-
2.10. ADDITIONALLY, THE CASING MUST EXTEND A
MINIMUM OF 20 FEET INTO UNWEATHERED ROCK.

BOARD OF HEALTH

Township of Chester, Morris County, New Jersey

Application

3668

Date... 6/23 1923

Received of (name)... Leslie Brown

(address)... 5 Fromia Rd

One Hundred Dollars \$ 100.00

Location: Lot... 5 Block... 51.01

- ☒ Construct
- ☐ Alter
- ☐ Repair
- ☐ Sewage
- ☒ Water

This copy for Secretary

agent
Daniel J. Hoff