

When	Item	Class Level	Origin Application	User	Action Type	Description	
	Previous Value	Post Value	Status Reference				
10/12/2021 11:07:22 AM EDT	RTU-4.DPR-O	User Action	MCE	smiller	Command	Release	
All	0.0	Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.DPR-O			
10/12/2021 09:04:07 AM EDT	Rm 108.SUPFLOSP	User Action	MCE	msinesi	Command		
Release 900.0	Present Value	Ok	ADS-001:NAE-2/N2-1.Rm 108.SUPFLOSP				
10/12/2021 08:43:36 AM EDT	Rm 108.COMMONSP	User Action	MCE	msinesi	Command		
Operator Override	75.0	73.0	Ok	ADS-001:NAE-2/N2-1.Rm 108.COMMONSP			
10/12/2021 08:42:39 AM EDT	OCC-MODE	User Action	MCE	msinesi	Command		
Operator Override	5.0	6.0	Ok	ADS-001:NAE-2/N2-1.Rm 108.OCC-MODE			
10/12/2021 07:51:33 AM EDT	Rm 203.COMMONSP	User Action	MCE	msinesi	Command		
Setpoint	75.0	74.0	Ok	ADS-001:NAE-2/N2-1.Rm 203.COMMONSP			
10/12/2021 07:51:21 AM EDT	OCC-MODE	User Action	MCE	msinesi	Command		
Operator Override	7.0	5.0	Ok	ADS-001:NAE-2/N2-1.Rm 203.OCC-MODE			
10/12/2021 07:39:03 AM EDT	Middle School Subsystem	Critical System Event	Device Services				
	Lost communication with Site Director					ADS-001:NAE-2	
10/11/2021 07:12:09 AM EDT	HC 6	User Action	MCE	msinesi	Write	JCI Exception Schedule	
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6						
10/8/2021 07:14:18 AM EDT	HC 6	User Action	MCE	msinesi	Write	JCI Exception Schedule	
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6						
10/7/2021 02:32:04 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	In	
Service On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S					
10/7/2021 01:52:42 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	Out of	
Service On	On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S				
10/7/2021 01:52:21 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	In	
Service On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S					
10/7/2021 01:51:38 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	In	
Service On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S					
10/7/2021 01:51:13 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	In	
Service Off	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S					
10/7/2021 01:47:49 PM EDT	RTU-4.DA-T	User Action	MCE	smiller	Command	Out of	
Service 250.00005	60.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DA-T				
10/7/2021 01:46:55 PM EDT	RTU-4.SDWN-S	User Action	MCE	smiller	Command	Out of	
Service On	Off	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S				

10/5/2021 09:47:39 AM EDT	RTU-1.DAT-SP	User Action	MCE	msinesi Command	
Operator Override	55.0 65.0	Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP		
10/5/2021 09:47:15 AM EDT	RTU-1.DAT-SP	User Action	MCE	msinesi Command	Release
Operator Override 62.0	Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP			
10/5/2021 09:45:50 AM EDT	RTU-2.DAT-SP	User Action	MCE	msinesi Command	
Operator Override	55.0 65.0	Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP		
10/5/2021 09:45:19 AM EDT	RTU-2.DAT-SP	User Action	MCE	msinesi Command	Release
Operator Override 55.0	Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP			
9/23/2021 11:25:33 AM EDT	Science A.COMMONSP	User Action	MCE	smiller Command	
Release Operator Override	74.0	Ok	ADS-001:NAE-2/N2-2.Science A.COMMONSP		
9/23/2021 11:12:27 AM EDT	Science A.COMMONSP	User Action	MCE	msinesi Command	
Temporary Override	75.0 74.0	Ok	ADS-001:NAE-2/N2-2.Science A.COMMONSP		
9/23/2021 11:09:16 AM EDT	Science A.SUPFLOSP	User Action	MCE	msinesi Command	
Operator Override	228.0 550.0	Ok	ADS-001:NAE-2/N2-2.Science A.SUPFLOSP		
9/23/2021 11:08:57 AM EDT	Science A.SUPFLOSP	User Action	MCE	msinesi Command	
Release Operator Override	550.0	Ok	ADS-001:NAE-2/N2-2.Science A.SUPFLOSP		
9/23/2021 10:52:11 AM EDT	RTU-4.DAT-SP	User Action	MCE	smiller Command	Release
All 60.0 Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP			
9/23/2021 10:50:22 AM EDT	RTU-4.SDWN-S	User Action	MCE	smiller Command	In
Service On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S			
9/23/2021 10:50:04 AM EDT	RTU-4.SDWN-S	User Action	MCE	smiller Command	In
Service On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S			
9/23/2021 10:49:03 AM EDT	RTU-4.SDWN-S	User Action	MCE	smiller Command	Out of
Service Off On	Ok	ADS-001:NAE-2/N2-2.RTU-4.SDWN-S			
9/23/2021 10:36:36 AM EDT	RTU-4.DAT-SP	User Action	MCE	msinesi Command	
Operator Override	55.0 60.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP		
9/21/2021 12:24:33 PM EDT	Rm 300.SUPFLOSP	User Action	MCE	msinesi Command	
Release Operator Override	500.0	Ok	ADS-001:NAE-2/N2-1.Rm 300.SUPFLOSP		
9/21/2021 12:23:47 PM EDT	SUPFLOSP	User Action	MCE	msinesi Command	
Operator Override	450.0 200.0	Ok	ADS-001:NAE-2/N2-1.Office.SUPFLOSP		
9/21/2021 12:23:03 PM EDT	RTU-1.DAT-SP	User Action	MCE	msinesi Command	
Operator Override	55.0 62.0	Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP		

9/20/2021 10:03:15 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/19/2021 10:03:12 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/19/2021 10:03:08 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/19/2021 04:02:09 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director			ADS-001:NAE-2
9/18/2021 10:03:05 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/18/2021 10:03:02 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/17/2021 10:01:06 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
9/17/2021 09:17:52 PM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director			ADS-001:NAE-2
9/13/2021 07:51:22 AM EDT	Rm 302.SUPFLOSP	User Action	MCE	smiller Command
Operator Override	300.0 1300.0 Ok	ADS-001:NAE-2/N2-1.Rm 302.SUPFLOSP		
9/13/2021 07:50:19 AM EDT	Rm 302.SUPFLOSP	User Action	MCE	smiller Command
Release Operator Override	300.0	Ok	ADS-001:NAE-2/N2-1.Rm 302.SUPFLOSP	
9/13/2021 07:28:40 AM EDT	Aux Gym	User Action	MCE	msinesi Write JCI Exception
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.Aux Gym Units.Aux Gym		
9/13/2021 07:27:39 AM EDT	RTU-3 (1st&2nd FL)	User Action	MCE	msinesi Write JCI
Exception Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-3 (1st&2nd FL)		
9/13/2021 07:26:52 AM EDT	Choir 233	User Action	MCE	msinesi Write JCI Exception
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Choir 233		
9/12/2021 01:01:45 PM EDT	RTU-3.SF-C	User Action	MCE	ebell Command
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-3.SF-C	
9/12/2021 01:01:09 PM EDT	RTU-3.CLG2-C	User Action	MCE	ebell Command
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-3.CLG2-C	

9/12/2021 01:00:00 PM EDT	RTU-3.CLG1-C	User Action	MCE	ebell	Command	
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-3.CLG1-C			
9/10/2021 08:53:52 AM EDT	RTU-1.DAT-SP	User Action	MCE	msinesi	Command	
Temporary Override	55.0 64.0	Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP			
9/9/2021 02:06:30 PM EDT	RTU-3 CLG%	User Action	MCE	smiller	Write Description	
Cooling Comand %	Ok	ADS-001:NAE-2/N2-2.RTU-3.RTU-3 CLG%				
9/9/2021 02:03:47 PM EDT	RTU-3 CLG%	User Action	MCE	smiller	Create	
Ok	ADS-001:NAE-2/N2-2.RTU-3.RTU-3 CLG%					
9/9/2021 02:00:14 PM EDT	Cooling %	User Action	MCE	smiller	Delete	
Ok	ADS-001:NAE-2/N2-2.RTU-3.Cooling %					
9/9/2021 01:56:50 PM EDT	Cooling %	User Action	MCE	smiller	Create	
Ok	ADS-001:NAE-2/N2-2.RTU-3.Cooling %					
9/9/2021 01:44:26 PM EDT	RTU-3.CLGLK-SP	User Action	MCE	smiller	Command	Release
Operator Override On	Ok	ADS-001:NAE-2/N2-2.RTU-3.CLGLK-SP				
9/9/2021 01:43:54 PM EDT	RTU-3.ECON-C	User Action	MCE	smiller	Command	Release
All Off Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C				
9/9/2021 01:43:18 PM EDT	RTU-3.CLGLK-SP	User Action	MCE	smiller	Command	
Operator Override	Off On Ok	ADS-001:NAE-2/N2-2.RTU-3.CLGLK-SP				
9/9/2021 01:42:20 PM EDT	RTU-3.CLG2-C	User Action	MCE	smiller	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-3.CLG2-C				
9/9/2021 01:40:46 PM EDT	OCC-MODE	User Action	MCE	smiller	Command	Release
All 5.0 Present Value	Ok	ADS-001:NAE-2/N2-2.Teachers Workroom.OCC-MODE				
9/9/2021 01:39:34 PM EDT	COMMONSP	User Action	MCE	smiller	Command	
Temporary Override	71.0 62.0	Ok	ADS-001:NAE-2/N2-2.IMC A.COMMONSP			
9/9/2021 01:39:30 PM EDT	2nd Flr Restroom.COMMONSP	User Action	MCE	smiller		
Command Temporary Override	72.0 62.0	Ok	ADS-001:NAE-2/N2-1.3rd Flr Restroom.COMMONSP			
9/9/2021 01:39:26 PM EDT	RTU-3.RF-C	User Action	MCE	smiller	Command	Release
Operator Override Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.RF-C				
9/9/2021 01:39:26 PM EDT	Lobby.COMMONSP	User Action	MCE	smiller	Command	
Temporary Override	74.0 62.0	Ok	ADS-001:NAE-2/N2-2.Lobby.COMMONSP			
9/9/2021 01:39:22 PM EDT	Supt Office.COMMONSP	User Action	MCE	smiller		
Command Temporary Override	72.0 62.0	Ok	ADS-001:NAE-2/N2-2.Supt Office.COMMONSP			

9/9/2021 01:39:18 PM EDT	Teachers Workroom.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	73.0	62.0	Ok	ADS-001:NAE-2/N2-2.Teachers Workroom.COMMONSP
9/9/2021 01:39:14 PM EDT	Science B.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	75.0	62.0	Ok		ADS-001:NAE-2/N2-2.Science B.COMMONSP
9/9/2021 01:39:09 PM EDT	Science A.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	75.0	62.0	Ok		ADS-001:NAE-2/N2-2.Science A.COMMONSP
9/9/2021 01:39:08 PM EDT	RTU-3.WUCFM-SP	User Action	MCE	smiller	Command
Release Operator Override	55.0	Ok			ADS-001:NAE-2/N2-2.RTU-3.WUCFM-SP
9/9/2021 01:39:05 PM EDT	Vocal.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	75.0	62.0	Ok		ADS-001:NAE-2/N2-2.Vocal.COMMONSP
9/9/2021 01:39:01 PM EDT	Band.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	75.0	62.0	Ok		ADS-001:NAE-2/N2-2.Band.COMMONSP
9/9/2021 01:38:57 PM EDT	2nd Flr Corr.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	74.0	62.0	Ok	ADS-001:NAE-2/N2-2.3rd Flr Corr.COMMONSP
9/9/2021 01:38:53 PM EDT	Office Area B.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	73.0	62.0	Ok	ADS-001:NAE-2/N2-2.Office Area B.COMMONSP
9/9/2021 01:38:49 PM EDT	Office Area A.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	75.0	62.0	Ok	ADS-001:NAE-2/N2-2.Office Area A.COMMONSP
9/9/2021 01:38:44 PM EDT	Control 175.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	68.0	62.0	Ok	ADS-001:NAE-2/N2-2.Control 176.COMMONSP
9/9/2021 01:38:39 PM EDT	TV Studio.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	67.0	62.0	Ok		ADS-001:NAE-2/N2-2.TV Studio.COMMONSP
9/9/2021 01:38:35 PM EDT	Nurses.COMMONSP	User Action	MCE	smiller	Command
Temporary Override	73.0	62.0	Ok		ADS-001:NAE-2/N2-2.Nurses.COMMONSP
9/9/2021 01:38:32 PM EDT	1st Flr Corr.COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	74.0	62.0	Ok	ADS-001:NAE-2/N2-2.2nd Flr Corr.COMMONSP
9/9/2021 01:38:28 PM EDT	Main Office Work Rm B COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	75.0	62.0	Ok	ADS-001:NAE-2/N2-2.Conference.COMMONSP

9/9/2021 01:38:24 PM EDT	Main Office A Lobby COMMONSP	User Action	MCE	smiller	
Command	Temporary Override	73.0	62.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.COMMONSP
9/9/2021 01:32:52 PM EDT	Supt Office.COMMONSP	User Action	MCE	smiller	
Command	Setpoint	75.0	72.0	Ok	ADS-001:NAE-2/N2-2.Supt Office.COMMONSP
9/9/2021 01:28:49 PM EDT	RTU-3.RF-C	User Action	MCE	smiller	Command
Operator Override	On Off	Ok			ADS-001:NAE-2/N2-2.RTU-3.RF-C
9/9/2021 10:53:53 AM EDT	Rm 300.COMMONSP	User Action	MCE	smiller	Command
Setpoint	73.0	72.0	Ok		ADS-001:NAE-2/N2-1.Rm 300.COMMONSP
9/9/2021 10:53:10 AM EDT	Rm 300.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	225.0 500.0	Ok			ADS-001:NAE-2/N2-1.Rm 300.SUPFLOSP
9/9/2021 09:25:01 AM EDT	RTU-3.WUCFM-SP	User Action	MCE	smiller	Command
Operator Override	72.0 55.0	Ok			ADS-001:NAE-2/N2-2.RTU-3.WUCFM-SP
9/9/2021 09:24:05 AM EDT	Trend - Present Value	User Action	MCE	smiller	Create
Ok					ADS-001:NAE-2/N2-2.RTU-3.RF-C.Trend1
9/9/2021 08:49:31 AM EDT	RTU-4.DAT-SP	User Action	MCE	smiller	Command Release
Operator Override	64.0	Ok			ADS-001:NAE-2/N2-2.RTU-4.DAT-SP
9/9/2021 08:45:55 AM EDT	Rm 301.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	800.0 900.0	Ok			ADS-001:NAE-2/N2-1.Rm 301.SUPFLOSP
9/9/2021 08:38:36 AM EDT	Rm 301.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	1000.0 800.0	Ok			ADS-001:NAE-2/N2-1.Rm 301.SUPFLOSP
9/9/2021 08:32:59 AM EDT	Rm 301.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	150.0	Ok			ADS-001:NAE-2/N2-1.Rm 301.SUPFLOSP
9/9/2021 08:30:16 AM EDT	Rm 301.COMMONSP	User Action	MCE	smiller	Command
Setpoint	73.0	72.0	Ok		ADS-001:NAE-2/N2-1.Rm 301.COMMONSP
9/9/2021 08:22:17 AM EDT	Rm 210.COMMONSP	User Action	MCE	smiller	Command
Setpoint	72.0	70.0	Ok		ADS-001:NAE-2/N2-1.Rm 210.COMMONSP
9/9/2021 08:19:34 AM EDT	Rm 205.COMMONSP	User Action	MCE	smiller	Command
Setpoint	72.0	70.0	Ok		ADS-001:NAE-2/N2-1.Rm 205.COMMONSP
9/9/2021 08:15:28 AM EDT	Rm 304.COMMONSP	User Action	MCE	smiller	Command
Setpoint	71.0	72.0	Ok		ADS-001:NAE-2/N2-1.Rm 304.COMMONSP
9/9/2021 08:14:47 AM EDT	Rm 305.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	300.0	Ok			ADS-001:NAE-2/N2-1.Rm 305.SUPFLOSP

9/9/2021 08:14:25 AM EDT	Rm 305.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 305.COMMONSP				
9/9/2021 08:12:09 AM EDT	Rm 307.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 73.0	71.0 Ok	ADS-001:NAE-2/N2-1.Rm 307.COMMONSP				
9/9/2021 08:11:07 AM EDT	Rm 309.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 309.COMMONSP				
9/9/2021 08:10:00 AM EDT	Rm 310.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 74.0	72.0 Ok	ADS-001:NAE-2/N2-1.Rm 310.COMMONSP				
9/9/2021 08:09:00 AM EDT	Rm 311.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 74.0	72.0 Ok	ADS-001:NAE-2/N2-1.Rm 311.COMMONSP				
9/9/2021 08:04:11 AM EDT	RTU-2.DAT-SP	User Action	MCE	smiller	Command	
Operator Override	65.099976 55.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP				
9/9/2021 08:03:48 AM EDT	RTU-2.DAT-SP	User Action	MCE	smiller	Command	Release
Operator Override	65.099976 Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP				
9/9/2021 08:03:20 AM EDT	RTU-2.DAT-SP	User Action	MCE	smiller	Command	Release
All 65.099976 Present Value Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP					
9/8/2021 02:41:14 PM EDT	Rm 205.COMMONSP	User Action	MCE	khigginbotham		
Command Setpoint	72.0 72.0 Ok	ADS-001:NAE-2/N2-1.Rm 205.COMMONSP				
9/8/2021 02:40:46 PM EDT	Rm 205.COMMONSP	User Action	MCE	khigginbotham		
Command Setpoint	75.0 72.0 Ok	ADS-001:NAE-2/N2-1.Rm 205.COMMONSP				
9/1/2021 08:08:55 AM EDT	HC-7.ZNT-SP	User Action	MCE	msinesi	Command	
Setpoint 76.0	74.0 Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP				
9/1/2021 08:08:31 AM EDT	HC-6.ZNT-SP	User Action	MCE	msinesi	Command	
Setpoint 76.0	74.0 Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP				
9/1/2021 08:03:23 AM EDT	HC 6	User Action	MCE	msinesi	Write	Weekly Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
8/30/2021 07:45:14 AM EDT	Aux Gym	User Action	MCE	msinesi	Write	Weekly Schedule
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.Aux Gym Units.Aux Gym				
8/30/2021 07:44:24 AM EDT	Aux Gym	User Action	MCE	msinesi	Write	Weekly Schedule
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.Aux Gym Units.Aux Gym				
8/30/2021 07:43:20 AM EDT	HC 3	User Action	MCE	msinesi	Write	Weekly Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Cafe.HC 3					

8/30/2021 07:42:52 AM EDT	Room 311	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.Room 311			
8/30/2021 07:41:15 AM EDT	Rm 304	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.Rm 304			
8/30/2021 07:40:46 AM EDT	VAV Units	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.VAV Units			
8/30/2021 07:40:10 AM EDT	RM 212 Play SAT	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 212 Play SAT			
8/30/2021 07:39:41 AM EDT	play rooms	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.play rooms			
8/30/2021 07:39:00 AM EDT	206 Teachers Lounge	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.206 Teachers Lounge			
8/30/2021 07:38:24 AM EDT	RM 204	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 204			
8/30/2021 07:37:40 AM EDT	VAV Units	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.VAV Units			
8/30/2021 07:37:06 AM EDT	Guidance	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.Guidance			
8/30/2021 07:36:39 AM EDT	MS RM 111	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.room 111.MS RM 111			
8/30/2021 07:36:09 AM EDT	Rm 109	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 109			
8/30/2021 07:34:29 AM EDT	STEM clases	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.STEM clases			
8/30/2021 07:33:50 AM EDT	Rm 105 Steam	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 105 Steam			
8/30/2021 07:33:19 AM EDT	VAV Units	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.VAV Units			
8/30/2021 07:32:49 AM EDT	Rm 101 Tech	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 101 Tech			
8/30/2021 07:32:17 AM EDT	RTU-4 (3rd FL)	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-4 (3rd FL)			
8/30/2021 07:31:52 AM EDT	RTU-3 (1st&2nd FL)	User Action	MCE	msinesi Write	Weekly Schedule
	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-3 (1st&2nd FL)			

8/30/2021 07:31:23 AM EDT	IMC VAV A-D	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.3rd Floor VAV.IMC VAV A-D			
8/30/2021 07:30:51 AM EDT	Science Rm A-239	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Science Rm A-239			
8/30/2021 07:30:17 AM EDT	Choir 233	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Choir 233			
8/30/2021 07:29:49 AM EDT	Band rm 232	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Band rm 232			
8/30/2021 07:29:15 AM EDT	Supervisor 235	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Supervisor 235			
8/30/2021 07:28:22 AM EDT	Special S	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Special S			
8/30/2021 07:27:57 AM EDT	Conference Rm	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Conference Rm			
8/30/2021 07:27:32 AM EDT	Main Office 169-170	User Action	MCE	msinesi Write	Weekly
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Main Office 169-170			
8/27/2021 08:18:24 AM EDT	ZNT-SP	User Action	MCE	smiller Command	Out of Service
71.000946 74.0	Ok	ADS-001:NAE-2/N2-1.AC-2320.ZNT-SP			
8/27/2021 08:15:13 AM EDT	RTU-4.OCC-C	User Action	MCE	smiller Command	
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-C		
8/27/2021 08:12:52 AM EDT	RTU-3.OCC-C	User Action	MCE	smiller Command	
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-3.OCC-C		
8/24/2021 02:23:11 PM EDT	RM 212 Play SAT	User Action	MCE	msinesi Write	JCI
Exception Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 212 Play SAT			
8/24/2021 02:22:35 PM EDT	play rooms	User Action	MCE	msinesi Write	JCI Exception
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.play rooms			
8/24/2021 02:22:01 PM EDT	206 Teachers Lounge	User Action	MCE	msinesi Write	JCI
Exception Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.206 Teachers Lounge			
8/24/2021 02:21:26 PM EDT	RM 204	User Action	MCE	msinesi Write	JCI Exception Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 204				
8/24/2021 02:20:49 PM EDT	VAV Units	User Action	MCE	msinesi Write	JCI Exception
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.VAV Units			

8/23/2021 05:42:17 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/23/2021 05:41:38 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/20/2021 08:40:44 AM EDT	AUX GYM S.OCC-C	User Action	MCE	khigginbotham		
Command	Temporary Override	Off	On	Ok	ADS-001:NAE-2/N2-2.AUX GYM S.OCC-C	
8/20/2021 08:40:17 AM EDT	AUX GYM N.OCC-C	User Action	MCE	khigginbotham		
Command	Temporary Override	Off	On	Ok	ADS-001:NAE-2/N2-2.AUX GYM N.OCC-C	
8/20/2021 08:39:42 AM EDT	BMNE3.OCC-C	User Action	MCE	khigginbotham	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.BMNE3.OCC-C			
8/20/2021 08:39:19 AM EDT	BMNW2.OCC-C	User Action	MCE	khigginbotham	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.BMNW2.OCC-C			
8/20/2021 08:38:51 AM EDT	BMNW1.OCC-C	User Action	MCE	khigginbotham	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.BMNW1.OCC-C			
8/19/2021 03:49:06 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 71.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/19/2021 03:48:34 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 71.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/19/2021 03:09:55 PM EDT	HC-4.SF-S	User Action	MCE	smiller	Command	In
Service Off	Ok	ADS-001:NAE-2/N2-1.HC-4.SF-S				
8/19/2021 12:33:25 PM EDT	Auditorium HC-7.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.HC-7.OCC-C			
8/19/2021 12:33:03 PM EDT	Auditorium HC-6.OCC-C-	User Action	MCE	smiller		
Command	Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.HC-6.OCC-C		
8/19/2021 12:32:21 PM EDT	135 Boys Locker Rm OCC-C	User Action	MCE	smiller		
Command	Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-2.AC-2025.OCC-C		
8/19/2021 12:31:58 PM EDT	133 Girls Locker OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-2.AC 1920.OCC-C			
8/19/2021 12:31:32 PM EDT	Cafe HC-4.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.HC-4.OCC-C			
8/19/2021 12:30:57 PM EDT	RTU-4.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-C			

8/19/2021 12:30:37 PM EDT	RTU-3.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.OCC-C			
8/19/2021 12:30:14 PM EDT	Tech Deptment OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.AC-2320.OCC-C			
8/19/2021 12:29:49 PM EDT	RTU-2.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.RTU-2.OCC-C			
8/19/2021 12:29:28 PM EDT	RTU-1.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On Off	Ok	ADS-001:NAE-2/N2-1.RTU-1.OCC-C			
8/19/2021 07:15:30 AM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Lost communication with Site Director					ADS-001:NAE-2
8/18/2021 06:05:19 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/18/2021 06:04:48 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/16/2021 05:55:13 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/16/2021 05:54:33 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/16/2021 09:42:06 AM EDT	HC 6	User Action	MCE	msinesi Write	JCI Exception Schedule	
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
8/16/2021 08:52:58 AM EDT	Nurses.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override	275.0 325.0	Ok	ADS-001:NAE-2/N2-2.Nurses.SUPFLOSP			
8/16/2021 08:39:24 AM EDT	RTU-3.MINPOSSP	User Action	MCE	smiller	Command	
Setpoint	20.0 100.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.MINPOSSP			
8/16/2021 08:38:59 AM EDT	RTU-3.DPR-O	User Action	MCE	smiller	Command	Release
All 20.0 Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-3.DPR-O				
8/16/2021 08:38:32 AM EDT	RTU-3.MINPOSSP	User Action	MCE	smiller	Command	
Release Operator Override	20.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.MINPOSSP			
8/16/2021 08:35:55 AM EDT	RTU-4.DAT-SP	User Action	MCE	smiller	Command	
Operator Override	55.0 64.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP			
8/16/2021 08:10:57 AM EDT	Rm 109-OCC-C	User Action	MCE	msinesi	Command	
Temporary Override	Unoccupied	Occupied	Ok	ADS-001:NAE-2/N2-1.Rm		
109.OCC-C						
8/12/2021 04:01:53 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			

8/12/2021 04:00:47 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/11/2021 02:53:15 PM EDT	HC-6.MINPOSSP	User Action	MCE	khigginbotham		
Command Setpoint	100.0 25.0	Ok	ADS-001:NAE-2/N2-1.HC-6.MINPOSSP			
8/11/2021 02:53:02 PM EDT	HC-6.MINPOSSP	User Action	MCE	khigginbotham		
Command Adjust	100.0 25.0	Point is under Local Control	ADS-001:NAE-2/N2-1.HC-6.MINPOSSP			
8/11/2021 02:52:46 PM EDT	HC-6.MINPOSSP	User Action	MCE	khigginbotham		
Command Adjust	100.0 25.0	Point is under Local Control	ADS-001:NAE-2/N2-1.HC-6.MINPOSSP			
8/11/2021 02:51:19 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 71.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/11/2021 02:50:19 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/11/2021 09:33:03 AM EDT	RTU-3.ECON-C	User Action	MCE	ebell	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C				
8/11/2021 09:32:43 AM EDT	RTU-3.ECON-C	User Action	MCE	ebell	Command	Off
On Off Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C					
8/11/2021 07:52:18 AM EDT	Cafe HC-3.OCC-C	User Action	MCE	msinesi	Command	
Operator Override	On Off	Ok	ADS-001:NAE-2/N2-1.HC-3.OCC-C			
8/11/2021 07:47:30 AM EDT	HC-4.CLG1-C	User Action	MCE	msinesi	Command	
Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-1.HC-4.CLG1-C			
8/11/2021 07:45:12 AM EDT	HC 3	User Action	MCE	msinesi	Write	Weekly Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Cafe.HC 3					
8/11/2021 07:43:15 AM EDT	HC-4.ZNT-SP	User Action	MCE	msinesi	Command	
Operator Override	75.0 73.0	Ok	ADS-001:NAE-2/N2-1.HC-4.ZNT-SP			
8/10/2021 05:51:35 PM EDT	HC-7.MINPOSSP	User Action	MCE	khigginbotham		
Command Setpoint	100.0 25.0	Ok	ADS-001:NAE-2/N2-1.HC-7.MINPOSSP			
8/10/2021 05:51:02 PM EDT	HC-7.DPR-O	User Action	MCE	khigginbotham	Command	
Release Operator Override	100.0	Ok	ADS-001:NAE-2/N2-1.HC-7.DPR-O			
8/10/2021 05:50:43 PM EDT	HC-7.MINPOSSP	User Action	MCE	khigginbotham		
Command Release Operator Override	100.0	Ok	ADS-001:NAE-2/N2-1.HC-7.MINPOSSP			
8/10/2021 05:50:34 PM EDT	HC-7.MINPOSSP	User Action	MCE	khigginbotham		
Command Adjust	100.0 25.0	Point is under Local Control	ADS-001:NAE-2/N2-1.HC-7.MINPOSSP			

8/10/2021 05:47:45 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 70.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/10/2021 05:47:10 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.0	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/10/2021 03:30:39 PM EDT	RTU-3.ECON-S	User Action	MCE	ebell	Command	In
Service Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-S				
8/10/2021 03:30:29 PM EDT	RTU-3.ECON-S	User Action	MCE	ebell	Command	
Temporary Out of Service	Off On	Invalid Time of zero	ADS-001:NAE-2/N2-2.RTU-3.ECON-S			
8/10/2021 03:27:06 PM EDT	RTU-3.DPR-O	User Action	MCE	ebell	Command	Adjust
100.0 50.0	Point is under Local Control	ADS-001:NAE-2/N2-2.RTU-3.DPR-O				
8/10/2021 03:26:53 PM EDT	RTU-3.DPR-O	User Action	MCE	ebell	Command	Adjust
100.0 50.0	Point is under Local Control	ADS-001:NAE-2/N2-2.RTU-3.DPR-O				
8/10/2021 03:18:34 PM EDT	RTU-3.ECON-S	User Action	MCE	ebell	Command	
Temporary Out of Service	On Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-S			
8/10/2021 03:16:53 PM EDT	RTU-3.SF-A	User Action	MCE	ebell	Command	In
Service Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.SF-A				
8/10/2021 08:13:17 AM EDT	Cafe HC-3.OCC-C	User Action	MCE	khigginbotham		
Command	Temporary Override	Off On	Ok	ADS-001:NAE-2/N2-1.HC-3.OCC-C		
8/9/2021 05:55:02 PM EDT	HC-6.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 72.5	Ok	ADS-001:NAE-2/N2-1.HC-6.ZNT-SP			
8/9/2021 05:54:29 PM EDT	HC-7.ZNT-SP	User Action	MCE	khigginbotham	Command	
Temporary Override	76.0 74.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP			
8/9/2021 08:40:55 AM EDT	HC 6	User Action	MCE	msinesi	Write	JCI Exception Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
8/2/2021 01:44:45 PM EDT	HC 6	User Action	MCE	msinesi	Write	JCI Exception Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
8/2/2021 01:43:50 PM EDT	HC 6	User Action	MCE	msinesi	Write	JCI Exception Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
8/2/2021 01:42:11 PM EDT	HC 6	User Action	MCE	msinesi	Write	Weekly Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Auditorium.HC 6					
7/29/2021 02:07:50 PM EDT	Nurses.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override	250.0 275.0	Ok	ADS-001:NAE-2/N2-2.Nurses.SUPFLOSP			

7/29/2021 02:06:51 PM EDT	Main Office A Lobby	SUPFLOSP	User Action	MCE	smiller	
Command	Operator Override	250.0 325.0	Ok	ADS-001:NAE-2/N2-2.Main		
Office B.SUPFLOSP						
7/29/2021 02:06:34 PM EDT	Conference Rm	SUPFLOSP	User Action	MCE	smiller	
Command	Operator Override	300.0 250.0	Ok	ADS-001:NAE-2/N2-2.Main		
Office A.SUPFLOSP						
7/20/2021 01:46:41 AM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Lost communication with Site Director			ADS-001:NAE-2		
7/20/2021 12:37:22 AM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Lost communication with Site Director			ADS-001:NAE-2		
7/20/2021 12:37:01 AM EDT	Middle School	Critical System Event	Alarm & Event			
Subsystem	Unable to forward one or more events to the ADS.					
ADS-001:NAE-2						
7/12/2021 08:58:54 AM EDT	Guidance	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.Guidance				
7/12/2021 08:58:42 AM EDT	IMC VAV A-D	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.3rd Floor VAV.IMC VAV A-D				
7/12/2021 08:57:44 AM EDT	RTU-4 (3rd FL)	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-4 (3rd FL)				
7/12/2021 08:57:34 AM EDT	RTU-3 (1st&2nd FL)	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-3 (1st&2nd FL)				
7/12/2021 08:57:21 AM EDT	Supervisor 235	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Supervisor 235				
7/12/2021 08:57:10 AM EDT	Special S	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Special S				
7/12/2021 08:56:58 AM EDT	Conference Rm	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Conference Rm				
7/12/2021 08:56:48 AM EDT	Main Office 169-170	User Action	MCE	msinesi Write	Weekly	
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Link Offices.Main Office 169-170				
7/11/2021 11:24:45 PM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Lost communication with Site Director			ADS-001:NAE-2		
7/11/2021 11:24:26 PM EDT	Middle School	Critical System Event	Alarm & Event			
Subsystem	Unable to forward one or more events to the ADS.					
ADS-001:NAE-2						

7/5/2021 01:48:08 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
7/5/2021 12:47:21 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
7/5/2021 12:47:02 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	
7/2/2021 07:55:01 AM EDT	Rm 300.SUPFLOSP	User Action	MCE	smiller Command
Release Operator Override	160.0	Ok	ADS-001:NAE-2/N2-1.Rm 300.SUPFLOSP	
6/30/2021 12:12:01 PM EDT	OCC-MODE	User Action	MCE	msinesi Command
Setpoint	7.0 6.0	Ok	ADS-001:NAE-2/N2-1.Office.OCC-MODE	
6/28/2021 01:07:37 PM EDT	Main Office A Lobby	OCC-MODE	User Action	MCE msinesi
Command	Release Operator Override	7.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.OCC-MODE
6/28/2021 01:05:28 PM EDT	Main Office A Lobby	OCC-MODE	User Action	MCE msinesi
Command	Operator Override	6.0 7.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.OCC-MODE
6/28/2021 01:04:57 PM EDT	Conference Rm	OCC-MODE	User Action	MCE msinesi
Command	Operator Override	7.0 5.0	Ok	ADS-001:NAE-2/N2-2.Main Office A.OCC-MODE
6/28/2021 12:59:10 PM EDT	Main Office A Lobby	COMMONSP	User Action	MCE msinesi
Command	Setpoint	75.0 73.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.COMMONSP
6/28/2021 12:58:38 PM EDT	Main Office A Lobby	OCC-MODE	User Action	MCE msinesi
Command	Operator Override	5.0 6.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.OCC-MODE
6/28/2021 12:57:45 PM EDT	RTU-3.ECON-C	User Action	MCE	msinesi Command
Operator Override	Off On	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C	
6/28/2021 12:57:23 PM EDT	RTU-3.ECON-C	User Action	MCE	msinesi Command
Operator Override	Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C	Release
6/28/2021 12:07:31 PM EDT	RTU-4.OCC-S	User Action	MCE	msinesi Command
Service Off	Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-S		In
6/27/2021 08:20:30 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
6/27/2021 08:20:10 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	

6/22/2021 01:01:26 PM EDT	RTU-4.OCC-S	User Action	MCE	ebell	Command	Out of Service
On Off Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-S					
6/22/2021 12:55:50 PM EDT	RTU-4.OCC-S	User Action	MCE	ebell	Command	
Temporary Out of Service On On Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-S					
6/22/2021 12:54:09 PM EDT	RTU-4.RA-T	User Action	MCE	ebell	Command	Adjust
71.915405 75.0	Point is under Local Control					
ADS-001:NAE-2/N2-2.RTU-4.RA-T						
6/22/2021 12:52:57 PM EDT	RTU-4.WUCFM-SP	User Action	MCE	ebell	Command	
Adjust 72.0 75.0	Point is under Local Control					
ADS-001:NAE-2/N2-2.RTU-4.WUCFM-SP						
6/18/2021 08:15:14 AM EDT	Science Rm A-239	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Science Rm A-239					
6/18/2021 08:15:01 AM EDT	Choir 233	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Choir 233					
6/18/2021 08:14:47 AM EDT	Band rm 232	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/LINK SCHEDULES.2nd Floor VAV.Band rm 232					
6/18/2021 08:14:28 AM EDT	Aux Gym	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.Aux Gym Units.Aux Gym					
6/18/2021 08:14:12 AM EDT	HC 3	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.Cafe.HC 3					
6/18/2021 08:13:52 AM EDT	Room 311	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.Room 311					
6/18/2021 08:13:38 AM EDT	Rm 304	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.Rm 304					
6/18/2021 08:13:26 AM EDT	VAV Units	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.3rd Floor.VAV Units					
6/18/2021 08:13:10 AM EDT	RM 212 Play SAT	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 212 Play SAT					
6/18/2021 08:12:57 AM EDT	play rooms	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.play rooms					
6/18/2021 08:12:43 AM EDT	206 Teachers Lounge	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.206 Teachers Lounge					
6/18/2021 08:12:32 AM EDT	RM 204	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.RM 204					
6/18/2021 08:12:20 AM EDT	VAV Units	User Action	MCE	msinesi	Write	Weekly
Schedule Ok	ADS-001:NAE-2/MS SCHEDULES.2nd Floor.VAV Units					

6/18/2021 08:11:59 AM EDT	MS RM 111	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.room 111.MS RM 111
6/18/2021 08:11:43 AM EDT	Rm 109	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 109
6/18/2021 08:11:30 AM EDT	STEM clases	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.STEM clases
6/18/2021 08:11:18 AM EDT	Rm 105 Steam	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 105 Steam
6/18/2021 08:11:04 AM EDT	Rm 101 Tech	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 101 Tech
6/18/2021 08:10:50 AM EDT	VAV Units	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.VAV Units
6/18/2021 08:10:35 AM EDT	Rm 101 Tech	User Action	MCE	msinesi Write	Weekly Schedule	Ok	ADS-001:NAE-2/MS SCHEDULES.1st Floor.Rm 101 Tech
6/10/2021 11:37:34 AM EDT	Middle School Subsystem	Critical System Event	Device Services	Lost communication with Site Director			ADS-001:NAE-2
6/10/2021 09:33:22 AM EDT	Middle School Subsystem	Critical System Event	Alarm & Event	Unable to forward one or more events to the ADS.			ADS-001:NAE-2
6/10/2021 09:31:22 AM EDT	Middle School Subsystem	Critical System Event	Device Services	Lost communication with Site Director			ADS-001:NAE-2
6/9/2021 12:30:00 PM EDT	Office Area B.COMMONSP Command	Setpoint	74.0	73.0	Ok	User Action	MCE msinesi ADS-001:NAE-2/N2-2.Office Area B.COMMONSP
6/9/2021 12:19:58 PM EDT	Office Area B.SUPFLOSP Release Operator Override	350.0		Ok	User Action	MCE msinesi Command	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP
6/9/2021 09:10:34 AM EDT	Office Area B.COMMONSP Command	Setpoint	76.0	74.0	Ok	User Action	MCE msinesi ADS-001:NAE-2/N2-2.Office Area B.COMMONSP
6/9/2021 09:09:47 AM EDT	OCC-MODE 7.0	6.0	Ok	User Action	MCE	msinesi Command	Adjust ADS-001:NAE-2/N2-2.Office Area A.OCC-MODE
6/9/2021 08:19:44 AM EDT	OCC-MODE Temporary Override	5.0	6.0	Ok	User Action	MCE msinesi Command	ADS-001:NAE-2/N2-1.Rm 311.OCC-MODE
6/9/2021 08:18:27 AM EDT	Rm 311.SUPFLOSP Release Operator Override	175.0		Ok	User Action	MCE msinesi Command	ADS-001:NAE-2/N2-1.Rm 311.SUPFLOSP

6/8/2021 02:55:55 PM EDT	SGI and Speech Rm.CDPR-C	User Action	MCE	khigginbotham	
Command Release Operator Override	Open	Ok	ADS-001:NAE-2/N2-1.SGI and Speech Rm.CDPR-C		
6/8/2021 02:55:48 PM EDT	SGI and Speech Rm.CDPR-C	User Action	MCE	khigginbotham	
Command Close	Open Close Point is under Local Control		ADS-001:NAE-2/N2-1.SGI and Speech Rm.CDPR-C		
6/8/2021 10:30:31 AM EDT	Rm 212.SUPFLOSP	User Action	MCE	msinesi	Command
Release Operator Override	600.0	Ok	ADS-001:NAE-2/N2-1.Rm 212.SUPFLOSP		
6/8/2021 10:28:00 AM EDT	Rm 212.SUPFLOSP	User Action	MCE	msinesi	Command
Operator Override	800.0 600.0 Ok		ADS-001:NAE-2/N2-1.Rm 212.SUPFLOSP		
6/8/2021 10:15:09 AM EDT	AC-2	User Action	MCE	msinesi	Command
True Ok	ADS-001:NAE-2/N2-1.RTU-2		Enable True		
6/7/2021 12:18:46 PM EDT	SGI and Speech Rm.CDPR-C	User Action	MCE	smiller	
Command Operator Override	Close Open	Ok	ADS-001:NAE-2/N2-1.SGI and Speech Rm.CDPR-C		
6/7/2021 12:14:12 PM EDT	RTU-1.DAT-SP	User Action	MCE	smiller	Command
Operator Override	60.0	Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP		Release
6/7/2021 12:11:45 PM EDT	RTU-3.DAT-SP	User Action	MCE	smiller	Command
Operator Override	60.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.DAT-SP		Release
6/7/2021 07:49:55 AM EDT	AC-2	User Action	MCE	smiller	Command
True Ok	ADS-001:NAE-2/N2-1.RTU-2		Enable False		
6/7/2021 07:49:30 AM EDT	AC-2	User Action	MCE	smiller	Command
False Ok	ADS-001:NAE-2/N2-1.RTU-2		Enable True		
6/7/2021 07:48:53 AM EDT	RTU-2.DAT-SP	User Action	MCE	smiller	Command
All 60.0 Present Value	Ok		ADS-001:NAE-2/N2-1.RTU-2.DAT-SP		Release
6/4/2021 10:19:51 AM EDT	RTU-4.OCC-C	User Action	MCE	smiller	Command
All On Present Value	Ok		ADS-001:NAE-2/N2-2.RTU-4.OCC-C		Release
6/4/2021 10:15:19 AM EDT	AC-4 LINK	User Action	MCE	smiller	Command
True True Ok	ADS-001:NAE-2/N2-2.RTU-4		Enable		
6/4/2021 10:13:34 AM EDT	RTU-4.OCC-C	User Action	MCE	smiller	Command
Temporary Override	On On Ok		ADS-001:NAE-2/N2-2.RTU-4.OCC-C		
6/4/2021 10:11:44 AM EDT	RTU-4.OCC-C	User Action	MCE	smiller	Command
All On Present Value	Ok		ADS-001:NAE-2/N2-2.RTU-4.OCC-C		Release
6/4/2021 10:08:45 AM EDT	RTU-4.PRHTLCM	User Action	MCE	smiller	Command
Release All On	Present Value Ok		ADS-001:NAE-2/N2-2.RTU-4.PRHTLCM		

6/4/2021 10:07:54 AM EDT	RTU-4.CLG2-C	User Action	MCE	smiller	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.CLG2-C				
6/4/2021 10:07:43 AM EDT	RTU-4.CLG1-C	User Action	MCE	smiller	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.CLG1-C				
6/4/2021 10:07:05 AM EDT	RTU-4.CLG2-C	User Action	MCE	smiller	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.RTU-4.CLG2-C			
6/4/2021 10:05:05 AM EDT	RTU-4.CLG1-C	User Action	MCE	smiller	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.RTU-4.CLG1-C			
6/4/2021 10:02:46 AM EDT	RTU-4.PRHTLCM	User Action	MCE	smiller	Command	
Release On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.PRHTLCM				
6/4/2021 10:00:20 AM EDT	RTU-4.DAT-SP	User Action	MCE	smiller	Command	
Temporary Override	60.0 60.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP			
6/4/2021 09:59:11 AM EDT	RTU-4.CLG1-C	User Action	MCE	smiller	Command	Release
On Present Value	Ok	ADS-001:NAE-2/N2-2.RTU-4.CLG1-C				
6/4/2021 09:57:57 AM EDT	RTU-4.OCC-C	User Action	MCE	smiller	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-2.RTU-4.OCC-C			
6/4/2021 06:58:26 AM EDT	HC 3	User Action	MCE	msinesi	Write JCI Exception Schedule	
Ok	ADS-001:NAE-2/MS SCHEDULES.Cafe.HC 3					
5/27/2021 12:58:55 PM EDT	RTU-2.OCC-C	User Action	MCE	ebell	Command	
Temporary Override	On On	Ok	ADS-001:NAE-2/N2-1.RTU-2.OCC-C			
5/27/2021 12:48:27 PM EDT	RTU-2.CLG1-C	User Action	MCE	ebell	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-1.RTU-2.CLG1-C				
5/27/2021 12:48:05 PM EDT	RTU-2.OCC-C	User Action	MCE	ebell	Command	Release
All On Present Value	Ok	ADS-001:NAE-2/N2-1.RTU-2.OCC-C				
5/27/2021 12:47:35 PM EDT	RTU-2.DPR-O	User Action	MCE	ebell	Command	Release
All 15.0 Present Value	Ok	ADS-001:NAE-2/N2-1.RTU-2.DPR-O				
5/27/2021 12:46:54 PM EDT	RTU-2.CLG1-C	User Action	MCE	ebell	Command	
Operator Override	On On	Ok	ADS-001:NAE-2/N2-1.RTU-2.CLG1-C			
5/27/2021 12:46:09 PM EDT	RTU-2.DPR-O	User Action	MCE	ebell	Command	Adjust
15.0 100.0	Point is under Local Control	ADS-001:NAE-2/N2-1.RTU-2.DPR-O				
5/27/2021 12:45:54 PM EDT	RTU-2.DPR-O	User Action	MCE	ebell	Command	Adjust
15.0 100.0	Point is under Local Control	ADS-001:NAE-2/N2-1.RTU-2.DPR-O				
5/27/2021 12:42:41 PM EDT	RTU-2.DPR-O	User Action	MCE	ebell	Command	
Operator Override	100.0 15.0	Ok	ADS-001:NAE-2/N2-1.RTU-2.DPR-O			

5/27/2021 12:41:29 PM EDT	RTU-2.DAT-SP	User Action	MCE	ebell	Command	
Operator Override	60.0 60.0	Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP			
5/27/2021 12:41:03 PM EDT	RTU-2.DAT-SP	User Action	MCE	ebell	Command	Adjust
60.0 55.0	Point is under Local Control		ADS-001:NAE-2/N2-1.RTU-2.DAT-SP			
5/27/2021 12:39:53 PM EDT	RTU-2.DAT-SP	User Action	MCE	ebell	Command	Release
60.0 Present Value	Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP				
5/27/2021 12:37:57 PM EDT	RTU-2.OCC-C	User Action	MCE	ebell	Command	On
On On Ok	ADS-001:NAE-2/N2-1.RTU-2.OCC-C					
5/27/2021 12:36:58 PM EDT	RTU-2.DA-T	User Action	MCE	ebell	Command	In
Service 82.14316	Ok	ADS-001:NAE-2/N2-1.RTU-2.DA-T				
5/27/2021 12:35:28 PM EDT	RTU-2.OCC-C	User Action	MCE	ebell	Command	
Operator Override	On On	Ok	ADS-001:NAE-2/N2-1.RTU-2.OCC-C			
5/27/2021 12:10:50 PM EDT	Rm 210.COMMONSP	User Action	MCE	msinesi	Command	
Setpoint 75.0	72.0	Ok	ADS-001:NAE-2/N2-1.Rm 210.COMMONSP			
5/19/2021 02:32:07 PM EDT	RTU-4 (3rd FL)	User Action	MCE	msinesi	Write	JCI Exception
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.Roof Units.RTU-4 (3rd FL)				
5/19/2021 02:31:39 PM EDT	IMC VAV A-D	User Action	MCE	msinesi	Write	JCI Exception
Schedule	Ok	ADS-001:NAE-2/LINK SCHEDULES.3rd Floor VAV.IMC VAV A-D				
5/19/2021 11:17:32 AM EDT	Main Office A Lobby OCC-MODE	User Action	MCE	msinesi		
Command Operator Override	7.0 5.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.OCC-MODE			
5/19/2021 11:17:21 AM EDT	Main Office A Lobby SUPFLOSP	User Action	MCE	msinesi		
Command Operator Override	350.0 250.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.SUPFLOSP			
5/19/2021 11:16:20 AM EDT	Main Office A Lobby SUPFLOSP	User Action	MCE	msinesi		
Command Release Operator Override	250.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.SUPFLOSP			
5/14/2021 05:13:23 PM EDT	Middle School	Critical System Event	Alarm & Event			
Subsystem	Unable to forward one or more events to the ADS.					
ADS-001:NAE-2						
5/14/2021 03:55:48 PM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Lost communication with Site Director					
ADS-001:NAE-2						
5/14/2021 03:55:43 PM EDT	Middle School	Critical System Event	Device Services			
Subsystem	Checkin with Site Director failed.					
ADS-001:NAE-2						
5/14/2021 12:18:41 PM EDT	Middle School	User Action	System Securitypweisgerber			
Subsystem	User Does Not Exist	10.1.254.241	ADS-001:NAE-2			

5/14/2021 12:17:05 PM EDT	Middle School	User Action	System Security	pweisgerber
Subsystem	User Does Not Exist	10.1.254.241	ADS-001:NAE-2	
5/14/2021 12:16:21 PM EDT	Middle School	User Action	System Security	MetasysSysAgent
Subsystem	User Login Failed	10.1.254.241	ADS-001:NAE-2	
5/14/2021 12:06:45 PM EDT	Middle School	User Action	MCE	MetasysSysAgent
Command	Security Database Backup		Ok	ADS-001:NAE-2
5/14/2021 12:06:32 PM EDT	Middle School	User Action	System Security	MetasysSysAgent
Subsystem	User Login Failed	10.1.254.241	ADS-001:NAE-2	
5/14/2021 12:06:16 PM EDT	Middle School	User Action	MCE	MetasysSysAgent
Command	Upload	Ok	ADS-001:NAE-2	
5/14/2021 12:05:59 PM EDT	Middle School	User Action	System Security	MetasysSysAgent
Subsystem	User Login Failed	10.1.254.241	ADS-001:NAE-2	
5/14/2021 12:05:50 PM EDT	Middle School	User Action	System Security	MetasysSysAgent
Subsystem	User Login Failed	10.1.254.241	ADS-001:NAE-2	
5/14/2021 11:21:48 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
5/14/2021 11:19:43 AM EDT	Middle School	User Action	MCE	MetasysSysAgent
Command	Route Samples	Ok	ADS-001:NAE-2	
5/14/2021 10:20:53 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
5/14/2021 09:13:01 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	
5/14/2021 05:12:04 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	
5/13/2021 05:11:34 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	
5/13/2021 05:10:34 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	
5/12/2021 05:07:06 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.		ADS-001:NAE-2	
5/12/2021 10:24:09 AM EDT	Middle School	Critical System Event	Device Services	
Subsystem	Lost communication with Site Director		ADS-001:NAE-2	

5/12/2021 03:24:57 AM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/10/2021 08:00:59 AM EDT IMC VAV A-D User Action MCE msinesi Write JCI Exception
Schedule Ok ADS-001:NAE-2/LINK SCHEDULES.3rd Floor VAV.IMC VAV A-D

5/10/2021 07:58:42 AM EDT MINPOSSP User Action MCE smiller Command
Setpoint 100.0 20.0 Ok ADS-001:NAE-2/N2-1.AC-2320.MINPOSSP

5/10/2021 07:57:55 AM EDT HC-3.MINPOSSP User Action MCE smiller Command
Setpoint 100.0 15.0 Ok ADS-001:NAE-2/N2-1.HC-3.MINPOSSP

5/10/2021 07:57:30 AM EDT MINPOSSP User Action MCE smiller Command
Setpoint 100.0 15.0 Ok ADS-001:NAE-2/N2-2.AC 1920.MINPOSSP

5/10/2021 07:57:11 AM EDT MINPOSSP User Action MCE smiller Command
Setpoint 100.0 15.0 Ok ADS-001:NAE-2/N2-2.AC-2025.MINPOSSP

5/9/2021 10:42:36 PM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/9/2021 10:34:57 AM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/8/2021 10:30:40 PM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/8/2021 10:18:09 AM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/7/2021 10:15:13 PM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/7/2021 10:15:09 AM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/7/2021 12:10:26 AM EDT Middle School Critical System Event Device Services
Subsystem Lost communication with Site Director ADS-001:NAE-2

5/6/2021 10:12:05 PM EDT Middle School Critical System Event Alarm & Event
Subsystem Unable to forward one or more events to the ADS.
ADS-001:NAE-2

5/6/2021 09:59:31 AM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
5/5/2021 09:55:27 PM EDT	Middle School	Critical System Event	Alarm & Event	
Subsystem	Unable to forward one or more events to the ADS.			
ADS-001:NAE-2				
5/5/2021 12:50:31 PM EDT	RTU-4.DAT-SP	User Action	MCE	smiller Command
Operator Override	55.0 60.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP	
5/5/2021 12:50:13 PM EDT	RTU-3.DAT-SP	User Action	MCE	smiller Command
Operator Override	55.0 60.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.DAT-SP	
5/5/2021 12:45:34 PM EDT	Office Area A.SUPFLOSP	User Action	MCE	smiller Command
Operator Override	100.0 50.0	Ok	ADS-001:NAE-2/N2-2.Office Area A.SUPFLOSP	
5/5/2021 12:43:56 PM EDT	Office Area B.SUPFLOSP	User Action	MCE	smiller Command
Operator Override	700.0 350.0	Ok	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP	
5/5/2021 09:19:07 AM EDT	MINPOSSP	User Action	MCE	smiller Command
Setpoint 15.0	100.0	Ok	ADS-001:NAE-2/N2-1.AC-2320.MINPOSSP	
5/5/2021 09:17:41 AM EDT	MINPOSSP	User Action	MCE	smiller Command
Setpoint 0.0	100.0	Ok	ADS-001:NAE-2/N2-2.AC-2025.MINPOSSP	
5/5/2021 09:17:00 AM EDT	MINPOSSP	User Action	MCE	smiller Command
Setpoint 15.0	100.0	Ok	ADS-001:NAE-2/N2-2.AC 1920.MINPOSSP	
5/5/2021 09:16:23 AM EDT	HC-3.MINPOSSP	User Action	MCE	smiller Command
Setpoint 30.0	100.0	Ok	ADS-001:NAE-2/N2-1.HC-3.MINPOSSP	
5/5/2021 09:14:50 AM EDT	HC-7.MINPOSSP	User Action	MCE	smiller Command
Setpoint 15.0	100.0	Ok	ADS-001:NAE-2/N2-1.HC-7.MINPOSSP	
5/5/2021 09:14:31 AM EDT	HC-7.ZNT-SP	User Action	MCE	smiller Command
Setpoint 73.0	76.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP	
5/5/2021 09:14:09 AM EDT	HC-7.ZNT-SP	User Action	MCE	smiller Command
Setpoint 70.0	73.0	Ok	ADS-001:NAE-2/N2-1.HC-7.ZNT-SP	
5/5/2021 09:13:32 AM EDT	HC-6.MINPOSSP	User Action	MCE	smiller Command
Setpoint 15.0	100.0	Ok	ADS-001:NAE-2/N2-1.HC-6.MINPOSSP	
5/5/2021 09:13:18 AM EDT	HC-6.DPR-O	User Action	MCE	smiller Command
Operator Override 100.0		Ok	ADS-001:NAE-2/N2-1.HC-6.DPR-O	
5/5/2021 09:13:06 AM EDT	HC-6.DPR-O	User Action	MCE	smiller Command
Operator Override 15.0	100.0	Ok	ADS-001:NAE-2/N2-1.HC-6.DPR-O	

5/5/2021 08:45:08 AM EDT	Rm 300.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	360.0 160.0 Ok	ADS-001:NAE-2/N2-1.Rm 300.SUPFLOSP			
5/5/2021 08:11:26 AM EDT	Rm 305.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	600.0 300.0 Ok	ADS-001:NAE-2/N2-1.Rm 305.SUPFLOSP			
5/5/2021 08:11:12 AM EDT	Rm 305.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 305.SUPFLOSP			
5/5/2021 08:10:55 AM EDT	Rm 305.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	0.0 Ok	ADS-001:NAE-2/N2-1.Rm 305.SUPFLOSP			
5/5/2021 08:10:32 AM EDT	Rm 305.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	750.0 Ok	ADS-001:NAE-2/N2-1.Rm 305.SUPFLOSP			
5/5/2021 08:10:14 AM EDT	RTU-1.DAT-SP	User Action	MCE	smiller	Command
Operator Override	55.0 60.0 Ok	ADS-001:NAE-2/N2-1.RTU-1.DAT-SP			
5/5/2021 08:09:49 AM EDT	Rm 304.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	600.0 300.0 Ok	ADS-001:NAE-2/N2-1.Rm 304.SUPFLOSP			
5/5/2021 08:09:29 AM EDT	Rm 302.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	600.0 300.0 Ok	ADS-001:NAE-2/N2-1.Rm 302.SUPFLOSP			
5/5/2021 08:09:00 AM EDT	Rm 301.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	400.0 150.0 Ok	ADS-001:NAE-2/N2-1.Rm 301.SUPFLOSP			
5/5/2021 08:07:26 AM EDT	Rm 311.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	200.0 175.0 Ok	ADS-001:NAE-2/N2-1.Rm 311.SUPFLOSP			
5/5/2021 08:06:34 AM EDT	RTU-2.MINPOSSP	User Action	MCE	smiller	Command
Setpoint 10.0	100.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.MINPOSSP			
5/5/2021 08:06:17 AM EDT	RTU-2.MINPOSSP	User Action	MCE	smiller	Command
Release Operator Override	95.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.MINPOSSP			
5/5/2021 08:06:00 AM EDT	RTU-1.MINPOSSP	User Action	MCE	smiller	Command
Setpoint 15.0	100.0 Ok	ADS-001:NAE-2/N2-1.RTU-1.MINPOSSP			
5/4/2021 02:33:54 PM EDT	Rm 310.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	350.0 250.0 Ok	ADS-001:NAE-2/N2-1.Rm 310.SUPFLOSP			
5/4/2021 02:33:08 PM EDT	RTU-2.MINPOSSP	User Action	MCE	smiller	Command
Operator Override	100.0 95.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.MINPOSSP			
5/4/2021 02:28:32 PM EDT	RTU-2.DAT-SP	User Action	MCE	smiller	Command
Operator Override	55.0 60.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.DAT-SP			
5/4/2021 02:26:18 PM EDT	RTU-2.MINPOSSP	User Action	MCE	smiller	Command
Operator Override	10.0 100.0 Ok	ADS-001:NAE-2/N2-1.RTU-2.MINPOSSP			

5/4/2021 02:22:08 PM EDT	Rm 311.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	300.0 200.0 Ok	ADS-001:NAE-2/N2-1.Rm 311.SUPFLOSP			
5/4/2021 02:21:19 PM EDT	Rm 311.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	600.0 300.0 Ok	ADS-001:NAE-2/N2-1.Rm 311.SUPFLOSP			
5/3/2021 08:40:17 AM EDT	HC 3	User Action	MCE	msinesi	Write JCI Exception Schedule
Ok	ADS-001:NAE-2/MS SCHEDULES.Cafe.HC 3				
4/30/2021 08:44:53 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	100.0 300.0 Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP			
4/30/2021 08:44:26 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Release All 100.0	Present Value Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP			
4/30/2021 08:43:56 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Release 100.0	Present Value Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP			
4/30/2021 08:43:36 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	200.0	Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP		
4/30/2021 08:43:16 AM EDT	Rm 104.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	225.0 125.0 Ok	ADS-001:NAE-2/N2-1.Rm 104.SUPFLOSP			
4/30/2021 08:42:54 AM EDT	Rm 310.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	500.0 350.0 Ok	ADS-001:NAE-2/N2-1.Rm 310.SUPFLOSP			
4/30/2021 08:42:30 AM EDT	Rm 310.SUPFLOSP	User Action	MCE	smiller	Command
Release All 500.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 310.SUPFLOSP			
4/30/2021 08:41:59 AM EDT	Rm 310.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 310.SUPFLOSP			
4/30/2021 08:41:30 AM EDT	Rm 310.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	550.0	Ok	ADS-001:NAE-2/N2-1.Rm 310.SUPFLOSP		
4/30/2021 08:38:40 AM EDT	ZNT-SP	User Action	MCE	smiller	Command
71.387695 73.0	Ok	ADS-001:NAE-2/N2-2.AC-2025.ZNT-SP			
4/30/2021 08:34:42 AM EDT	Nurses.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	348.0 250.0 Ok	ADS-001:NAE-2/N2-2.Nurses.SUPFLOSP			
4/30/2021 08:33:53 AM EDT	Nurses.SUPFLOSP	User Action	MCE	smiller	Command
Release Operator Override	500.0	Ok	ADS-001:NAE-2/N2-2.Nurses.SUPFLOSP		
4/30/2021 08:32:39 AM EDT	Office Area B.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	500.0 700.0 Ok	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP			
4/30/2021 08:32:20 AM EDT	Office Area A.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	236.0 100.0 Ok	ADS-001:NAE-2/N2-2.Office Area A.SUPFLOSP			

4/30/2021 08:31:23 AM EDT Main Office Work Rm B SUPFLOSP User Action MCE smiller
 Command Operator Override 44.0 200.0 Ok ADS-001:NAE-2/N2-
 2.Conference.SUPFLOSP

4/30/2021 08:31:08 AM EDT Main Office Work Rm B SUPFLOSP User Action MCE smiller
 Command Release Operator Override 180.0 Ok ADS-001:NAE-2/N2-
 2.Conference.SUPFLOSP

4/30/2021 08:30:52 AM EDT Main Office A Lobby SUPFLOSP User Action MCE smiller
 Command Operator Override 350.0 250.0 Ok ADS-001:NAE-2/N2-2.Main
 Office B.SUPFLOSP

4/30/2021 08:30:36 AM EDT Conference Rm SUPFLOSP User Action MCE smiller
 Command Operator Override 400.0 300.0 Ok ADS-001:NAE-2/N2-2.Main
 Office A.SUPFLOSP

4/30/2021 08:28:46 AM EDT Band.SUPFLOSP User Action MCE smiller Command
 Operator Override 450.0 350.0 Ok ADS-001:NAE-2/N2-2.Band.SUPFLOSP

4/30/2021 08:28:15 AM EDT Science B.SUPFLOSP User Action MCE smiller Command
 Operator Override 900.0 600.0 Ok ADS-001:NAE-2/N2-2.Science B.SUPFLOSP

4/30/2021 08:27:53 AM EDT Science A.SUPFLOSP User Action MCE smiller Command
 Operator Override 700.0 550.0 Ok ADS-001:NAE-2/N2-2.Science A.SUPFLOSP

4/29/2021 08:07:56 PM EDT Middle School Critical System Event Device Services
 Subsystem Lost communication with Site Director ADS-001:NAE-2

4/29/2021 08:07:41 PM EDT Middle School Critical System Event Alarm & Event
 Subsystem Unable to forward one or more events to the ADS.
 ADS-001:NAE-2

4/29/2021 08:56:08 AM EDT RTU-4.DAT-SP User Action MCE smiller Command Release
 Operator Override 64.0 Ok ADS-001:NAE-2/N2-2.RTU-4.DAT-SP

4/29/2021 08:23:49 AM EDT IMC D.COMMONSP User Action MCE msinesi Command
 Setpoint 75.0 71.0 Ok ADS-001:NAE-2/N2-2.IMC D.COMMONSP

4/29/2021 08:23:34 AM EDT IMC C.COMMONSP User Action MCE msinesi Command
 Setpoint 75.0 71.0 Ok ADS-001:NAE-2/N2-2.IMC C.COMMONSP

4/29/2021 08:23:15 AM EDT IMC B.COMMONSP User Action MCE msinesi Command
 Setpoint 75.0 71.0 Ok ADS-001:NAE-2/N2-2.IMC B.COMMONSP

4/29/2021 08:23:05 AM EDT COMMONSP User Action MCE msinesi Command
 Setpoint 75.0 71.0 Ok ADS-001:NAE-2/N2-2.IMC A.COMMONSP

4/28/2021 10:17:34 AM EDT Middle School Critical System Event Alarm & Event
 Subsystem Unable to forward one or more events to the ADS.
 ADS-001:NAE-2

4/28/2021 09:03:03 AM EDT	PUMP 5.P-C	User Action	MCE	smiller	Command	
Operator Override	On Off	Ok	ADS-001:NAE-2/N2-1.PUMP 5.P-C			
4/28/2021 09:01:53 AM EDT	PUMP 4.HWV-O	User Action	MCE	smiller	Command	
Release All 75.0	Present Value	Ok	ADS-001:NAE-2/N2-1.PUMP 4.HWV-O			
4/28/2021 09:00:59 AM EDT	PUMP 4.P-C	User Action	MCE	smiller	Command	
Operator Override	On Off	Ok	ADS-001:NAE-2/N2-1.PUMP 4.P-C			
4/28/2021 09:00:40 AM EDT	PUMP 2.P-C	User Action	MCE	smiller	Command	
Operator Override	On Off	Ok	ADS-001:NAE-2/N2-1.PUMP 2.P-C			
4/28/2021 09:00:19 AM EDT	Tertiary Pump D.PUMP-C	User Action	MCE	smiller		
Command Operator Override	On Off	Ok	ADS-001:NAE-2/N2-1.Tertiary Pump D.PUMP-C			
4/27/2021 10:14:07 PM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/27/2021 10:12:55 AM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/26/2021 10:11:54 PM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/26/2021 10:00:36 AM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/25/2021 09:59:48 PM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/19/2021 05:06:22 PM EDT	Middle School Subsystem	Critical System Event	Alarm & Event			
	Unable to forward one or more events to the ADS.					
	ADS-001:NAE-2					
4/19/2021 05:03:12 PM EDT	Middle School Subsystem	Critical System Event	Device Services			
	Lost communication with Site Director					ADS-001:NAE-2
4/19/2021 10:38:22 AM EDT	RTU-3.ECON-C	User Action	MCE	smiller	Command	
Operator Override	On Off	Ok	ADS-001:NAE-2/N2-2.RTU-3.ECON-C			
4/19/2021 10:36:11 AM EDT	Office Area B.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override	400.0 500.0	Ok	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP			
4/19/2021 10:35:12 AM EDT	RTU-3.DAT-SP	User Action	MCE	smiller	Command	Release
Operator Override	64.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.DAT-SP			

4/15/2021 10:57:10 AM EDT	RTU-3.DAT-SP	User Action	MCE	smiller	Command
Operator Override	56.1875	64.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.DAT-SP	
4/15/2021 10:55:00 AM EDT	Nurses.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	348.0	500.0	Ok	ADS-001:NAE-2/N2-2.Nurses.SUPFLOSP	
4/15/2021 10:36:10 AM EDT	Office Area B.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	350.0	400.0	Ok	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP	
4/15/2021 10:35:51 AM EDT	Office Area B.SUPFLOSP	User Action	MCE	smiller	Command
Release All	350.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Office Area B.SUPFLOSP	
4/15/2021 10:35:08 AM EDT	principal setpt	User Action	MCE	smiller	Command
Setpoint	65.0	70.0	Ok	ADS-001:NAE-2/N2-2.Breezeway.principal setpt	
4/15/2021 10:33:33 AM EDT	Main Office A Lobby SUPFLOSP	User Action	MCE	smiller	Command
Release All	225.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Main Office B.SUPFLOSP	
4/15/2021 10:31:47 AM EDT	Science B.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	400.0	900.0	Ok	ADS-001:NAE-2/N2-2.Science B.SUPFLOSP	
4/15/2021 10:31:31 AM EDT	Science B.SUPFLOSP	User Action	MCE	smiller	Command
Release All	700.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Science B.SUPFLOSP	
4/15/2021 10:29:53 AM EDT	RTU-4.DAT-SP	User Action	MCE	smiller	Command
Operator Override	62.0	64.0	Ok	ADS-001:NAE-2/N2-2.RTU-4.DAT-SP	
4/13/2021 09:50:07 AM EDT	RTU-3.DAT-SP	User Action	MCE	msinesi	Command
Temporary Override	59.791656	63.0	Ok	ADS-001:NAE-2/N2-2.RTU-3.DAT-SP	
4/13/2021 09:46:38 AM EDT	Science A.SUPFLOSP	User Action	MCE	msinesi	Command
Operator Override	456.0	700.0	Ok	ADS-001:NAE-2/N2-2.Science A.SUPFLOSP	
4/13/2021 09:46:24 AM EDT	Science A.SUPFLOSP	User Action	MCE	msinesi	Command
Release All	700.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Science A.SUPFLOSP	
4/1/2021 10:57:37 AM EDT	AUX GYM N.ZNT-SP	User Action	MCE	msinesi	Command
Setpoint	70.0	73.0	Ok	ADS-001:NAE-2/N2-2.AUX GYM N.ZNT-SP	
4/1/2021 10:57:24 AM EDT	AUX GYM S.ZNT-SP	User Action	MCE	msinesi	Command
Setpoint	71.0	73.0	Ok	ADS-001:NAE-2/N2-2.AUX GYM S.ZNT-SP	
3/29/2021 10:13:28 AM EDT	Rm 111.COMMONSP	User Action	MCE	smiller	Command
Setpoint	75.0	73.0	Ok	ADS-001:NAE-2/N2-1.Rm 111.COMMONSP	
3/29/2021 10:08:15 AM EDT	Rm 204.COMMONSP	User Action	MCE	smiller	Command
Setpoint	75.0	73.0	Ok	ADS-001:NAE-2/N2-1.Rm 204.COMMONSP	
3/29/2021 10:03:34 AM EDT	Rm 307.COMMONSP	User Action	MCE	smiller	Command
Setpoint	74.0	73.0	Ok	ADS-001:NAE-2/N2-1.Rm 307.COMMONSP	

3/29/2021 10:02:13 AM EDT	Rm 306.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 73.0	72.0	Ok	ADS-001:NAE-2/N2-1.Rm 306.COMMONSP			
3/29/2021 10:00:56 AM EDT	Rm 304.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 70.0	71.0	Ok	ADS-001:NAE-2/N2-1.Rm 304.COMMONSP			
3/29/2021 09:23:14 AM EDT	Nurses.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 75.0	73.0	Ok	ADS-001:NAE-2/N2-2.Nurses.COMMONSP			
3/29/2021 09:22:18 AM EDT	Teachers Workroom.BBHTG-O	User Action	MCE	smiller	Command	
Operator Override 0.4166937	100.0	Ok	ADS-001:NAE-2/N2-2.Teachers Workroom.BBHTG-O			
3/29/2021 09:19:52 AM EDT	Office Area B.HTG-O	User Action	MCE	smiller	Command	
Release All 100.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Office Area B.HTG-O			
3/29/2021 09:19:21 AM EDT	Office Area B.COMMONSP	User Action	MCE	smiller	Command	
Setpoint 79.0	76.0	Ok	ADS-001:NAE-2/N2-2.Office Area B.COMMONSP			
3/29/2021 09:18:52 AM EDT	Office Area A.SUPFLOSP	User Action	MCE	smiller	Command	
Release All 200.0	Present Value	Ok	ADS-001:NAE-2/N2-2.Office Area A.SUPFLOSP			
3/29/2021 09:17:45 AM EDT	Main Office A Lobby SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 150.0	225.0	Ok	ADS-001:NAE-2/N2-2.Main Office B.SUPFLOSP			
3/29/2021 09:17:20 AM EDT	Conference Rm SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 350.0	400.0	Ok	ADS-001:NAE-2/N2-2.Main Office A.SUPFLOSP			
3/29/2021 09:15:58 AM EDT	1st Flr Corr.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 300.0	200.0	Ok	ADS-001:NAE-2/N2-2.2nd Flr Corr.SUPFLOSP			
3/29/2021 09:14:49 AM EDT	Science A.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 600.0	700.0	Ok	ADS-001:NAE-2/N2-2.Science A.SUPFLOSP			
3/29/2021 09:14:23 AM EDT	Science B.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 600.0	700.0	Ok	ADS-001:NAE-2/N2-2.Science B.SUPFLOSP			
3/29/2021 09:13:47 AM EDT	Band.SUPFLOSP	User Action	MCE	smiller	Command	
Operator Override 400.0	450.0	Ok	ADS-001:NAE-2/N2-2.Band.SUPFLOSP			
3/29/2021 09:03:29 AM EDT	Rm 104.SUPFLOSP	User Action	MCE	smiller	Command	
Release Operator Override 500.0		Ok	ADS-001:NAE-2/N2-1.Rm 104.SUPFLOSP			
3/29/2021 09:01:51 AM EDT	Rm 109.SUPFLOSP	User Action	MCE	smiller	Command	
Release All 0.0	Present Value	Ok	ADS-001:NAE-2/N2-1.Rm 109.SUPFLOSP			
3/29/2021 09:00:33 AM EDT	Rm 108.SUPFLOSP	User Action	MCE	smiller	Command	
Release All 0.0	Present Value	Ok	ADS-001:NAE-2/N2-1.Rm 108.SUPFLOSP			

3/29/2021 09:00:15 AM EDT	Rm 106.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 106.SUPFLOSP			
3/29/2021 09:00:00 AM EDT	Rm 105.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 105.SUPFLOSP			
3/29/2021 08:57:58 AM EDT	Rm 104.SUPFLOSP	User Action	MCE	smiller	Command
Temporary Override	50.0 500.0 Ok	ADS-001:NAE-2/N2-1.Rm 104.SUPFLOSP			
3/29/2021 08:57:33 AM EDT	Rm 104.SUPFLOSP	User Action	MCE	smiller	Command
Temporary Override	225.0 50.0 Ok	ADS-001:NAE-2/N2-1.Rm 104.SUPFLOSP			
3/29/2021 08:57:03 AM EDT	Rm 104.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 104.SUPFLOSP			
3/29/2021 08:56:01 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Operator Override	453.76788 200.0 Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP			
3/29/2021 08:55:27 AM EDT	Speech 101.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Speech 101.SUPFLOSP			
3/29/2021 08:50:07 AM EDT	Rm 201.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 201.COMMONSP			
3/29/2021 08:49:48 AM EDT	Rm 201.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 201.SUPFLOSP			
3/29/2021 08:49:27 AM EDT	Rm 202.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 202.COMMONSP			
3/29/2021 08:48:37 AM EDT	Rm 202.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 202.SUPFLOSP			
3/29/2021 08:47:47 AM EDT	Rm 203.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 203.SUPFLOSP			
3/29/2021 08:46:51 AM EDT	Rm 204.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 204.SUPFLOSP			
3/29/2021 08:45:24 AM EDT	Rm 205.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 205.SUPFLOSP			
3/29/2021 08:44:36 AM EDT	Rm 208.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 208.SUPFLOSP			
3/29/2021 08:43:52 AM EDT	Rm 209.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 209.SUPFLOSP			
3/29/2021 08:42:29 AM EDT	Rm 210.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 210.SUPFLOSP			

3/29/2021 08:41:32 AM EDT	Rm 212.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 212.COMMONSP			
3/29/2021 08:41:10 AM EDT	Rm 212.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 212.SUPFLOSP			
3/29/2021 08:40:16 AM EDT	Rm 213.COMMONSP	User Action	MCE	smiller	Command
Setpoint 76.0	74.0 Ok	ADS-001:NAE-2/N2-1.Rm 213.COMMONSP			
3/29/2021 08:39:49 AM EDT	Rm 213.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 213.SUPFLOSP			
3/29/2021 08:39:22 AM EDT	Rm 300.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 300.COMMONSP			
3/29/2021 08:38:47 AM EDT	Rm 302.COMMONSP	User Action	MCE	smiller	Command
Setpoint 73.0	72.0 Ok	ADS-001:NAE-2/N2-1.Rm 302.COMMONSP			
3/29/2021 08:37:04 AM EDT	Rm 306.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 306.COMMONSP			
3/29/2021 08:36:33 AM EDT	Rm 307.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	74.0 Ok	ADS-001:NAE-2/N2-1.Rm 307.COMMONSP			
3/29/2021 08:35:10 AM EDT	Rm 310.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	74.0 Ok	ADS-001:NAE-2/N2-1.Rm 310.COMMONSP			
3/29/2021 08:34:45 AM EDT	Rm 311.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	74.0 Ok	ADS-001:NAE-2/N2-1.Rm 311.COMMONSP			
3/29/2021 08:34:17 AM EDT	Rm 313.BBHTG-O	User Action	MCE	smiller	Command
Release All 100.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 313.BBHTG-O			
3/29/2021 08:33:30 AM EDT	Rm 300.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 300.SUPFLOSP			
3/29/2021 08:33:14 AM EDT	Rm 301.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 301.COMMONSP			
3/29/2021 08:32:52 AM EDT	Rm 301.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 301.SUPFLOSP			
3/29/2021 08:32:32 AM EDT	Rm 302.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	73.0 Ok	ADS-001:NAE-2/N2-1.Rm 302.COMMONSP			
3/29/2021 08:32:01 AM EDT	Rm 302.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 302.SUPFLOSP			
3/29/2021 08:30:30 AM EDT	Rm 304.COMMONSP	User Action	MCE	smiller	Command
Setpoint 72.0	70.0 Ok	ADS-001:NAE-2/N2-1.Rm 304.COMMONSP			

3/29/2021 08:29:11 AM EDT	Rm 304.COMMONSP	User Action	MCE	smiller	Command
Setpoint 75.0	72.0 Ok	ADS-001:NAE-2/N2-1.Rm 304.COMMONSP			
3/29/2021 08:28:45 AM EDT	Rm 304.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 304.SUPFLOSP			
3/29/2021 08:28:17 AM EDT	Rm 306.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 306.SUPFLOSP			
3/29/2021 08:27:17 AM EDT	Rm 307.SUPFLOSP	User Action	MCE	smiller	Command
Release All 0.0	Present Value Ok	ADS-001:NAE-2/N2-1.Rm 307.SUPFLOSP			