


**HOWELL,
TOWNSHIP OF
(BUILDING DEPT.)**

**PERMIT WITHOUT
A JACKET**

BUILDING
PERMIT

\$65.82

DATE 3-16 1983 PERMIT NO. 5812APPLICANT Owner ADDRESS _____
(NO.) (STREET) (CONTR'S LICENSE)PERMIT TO Addition (TYPE OF IMPROVEMENT) (NO.) STORY One Family (PROPOSED USE) NUMBER OF DWELLING UNITS _____AT (LOCATION) 57 Maxim Southard Rd. ZONING ARE-3
(NO.) (STREET) DISTRICT
BETWEEN Lanes Mill Rd. AND Alexander Ave.
(CROSS STREET) (CROSS STREET)SUBDIVISION _____ LOT 4 BLOCK 26 LOT SIZE 4.98BUILDING IS TO BE 18 FT. WIDE BY 26 FT. LONG BY 12 FT. IN HEIGHT AND SHALL CONFORM IN CONSTRUCTIONTO TYPE 4B USE GROUP R-3 BASEMENT WALLS OR FOUNDATION Masonry
(TYPE)REMARKS: Addition to a one family, Duplex not permitted.AREA OR VOLUME _____ ESTIMATED COST \$ 12,000 PERMIT FEE \$ 65.82
(CUBIC/SQUARE FEET)OWNER _____
ADDRESS Same as above
BUILDING DEPT. BY 

INSPECTION RECORD

[illegible]

Howell Township Inspection Dept.

App.

Block

26

No.

Lot

4

APPLICATION FOR ELECTRICAL INSPECTION
PLEASE PRINT OR TYPE (CLEAR APPLICATIONS HELP GET THE JOB DONE)

THIS SECTION TO BE COMPLETED BY APPLICANT

DATE: April 7 1983

City, Town or Township Howell County Monmouth State N.J.
Street Location: No. 57 Street Maxim Southard Pole No. _____
(If Located in Rural Area - Please Attach Directions)
Owner's P.O. Address _____
Occupied As Residence Building - New ☐ Old ☐
Occupant Same Work - New ☐ Additional ☒

App. for - Rough Wiring ☒ Fixtures ☐ or Ready for Inspection April 12 19 83
Fee Remitted - \$ 40.00 By Check ☒ Money Order ☐ Make Payable to Agency

LIST ALL EQUIPMENT AND WIRING

Number of Rough Wiring Outlets		Miscellaneous Equipment																																															
Switches <u>15</u>		<table border="1"> <tr> <td>Elect. Heat</td> <td></td> <td>500</td> <td>750</td> <td>1000</td> <td>1250</td> <td>1500</td> <td>1750</td> <td>2000</td> <td>2250</td> <td>2500</td> <td>2750</td> <td>3000</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>																Elect. Heat		500	750	1000	1250	1500	1750	2000	2250	2500	2750	3000																			
Elect. Heat		500	750	1000	1250	1500	1750	2000	2250	2500	2750	3000																																					
Lighting <u>12</u>		<table border="1"> <tr> <td>Amp. Service</td> <td></td> <td>Surface Unit</td> <td></td> <td>Dishwasher</td> <td></td> <td>Range</td> <td></td> </tr> <tr> <td>Water Heater</td> <td></td> <td>Air Conditioner</td> <td></td> <td>Dryer</td> <td></td> <td>Pump</td> <td></td> </tr> <tr> <td>Oven</td> <td></td> <td>Garbage Disposal</td> <td></td> <td>Wiring and Controls for</td> <td></td> <td>Burner</td> <td></td> </tr> <tr> <td>Amp. Receptacles</td> <td></td> <td>Fractional H.P. Vent Fans</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>																Amp. Service		Surface Unit		Dishwasher		Range		Water Heater		Air Conditioner		Dryer		Pump		Oven		Garbage Disposal		Wiring and Controls for		Burner		Amp. Receptacles		Fractional H.P. Vent Fans					
Amp. Service		Surface Unit		Dishwasher		Range																																											
Water Heater		Air Conditioner		Dryer		Pump																																											
Oven		Garbage Disposal		Wiring and Controls for		Burner																																											
Amp. Receptacles		Fractional H.P. Vent Fans																																															
Receptacles <u>24</u>		Other Equipment: <u>Sump Pump</u>																																															

MOTORS H.P.	1/20	1/12	1/10	1/8	1/6	1/4	1/3	1/2	3/4	1	1 1/2	2	3	5	7 1/2	10	15	20	25	30	40	50	75	100
Mark Number of Each Size																								

Applicant's Signature _____ License # _____ Permit # _____
T/A Home owner Name of Utility J.C.P. & L
Applicant's Address Same as above Office to be Notified _____
& Phone No. _____ City Howell State N.J. Zip Code 07731

SPACE BELOW FOR AGENCY'S USE ONLY

Date Received 4-8-83 Date Inspected 4-13-83

Rough Wiring Outlets		K.W. Surface Unit		K.W. Oven	
<u>10 sw</u>	Outlets	<u>1</u>	K.W. Range		H.P. Garbage Disposal
<u>12</u>	Receptacles		K.W. Water Heater		K.W. Dishwasher
<u>12</u>	Fixtures		H.P. Air Conditioner		K.W. Dryer
	Amp. Service Equipment		Burner, Wiring & Controls for	<u>1-20 Amp @ Camp</u>	Receptacle
	Amp. Service Conductors		H.P. Pump		Frac. H.P. Vent Fans

MOTORS H.P.	1/20	1/12	1/10	1/8	1/6	1/4	1/3	1/2	3/4	1	1 1/2	2	3	5	7 1/2	10	15	20	25	30	40	50	75	100
Mark Number of Each Size																								

APPARATUS	Elect. Heat	500	750	1000	1250	1500	1750	2000	2250	2500	2750	3000

Corrected Location

CERTIFICATIONS	PROGRESS: Inc. ☐ Lkd. ☐	NOTIFIED	RE-PORT	CARD	NEW	OLD	FEE PAID
☒ Rough Wiring <u>4-13-83</u>	<u>O.K. TO COVER 4-13-83</u>	Contractor					Check # <u>166</u>
☐ Fixture Approval	VIOLETION: Work Comp. ☐ Inc. ☐	Owner					Cash
☒ Elec. Certificate	<u>FINAL 5-18-83</u>	Occupant					M.O. #
☐ Letter of Approval	<u>ADDITIONAL</u>	Agent					
☐ In-Plant Approval	Other Side ☐	Elec. Lt. Co.					
Date Issued <u>5-18-83</u>							

(Temp.) Cut-in Card # _____ (Final) Cut-in Card # _____
Inspector's Signature Vasily Serge

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

DATE		INSPECTOR	
PRESENT STATUS		NOTIFIED	
1. ☐ R.W. REQUESTED 2. ☐ FIXTURE APPROVAL 3. ☐ ELEC. CERTIFICATE 3. ☐ LETTER OF APPROVAL 4. ☐ IN-PLANT APPROVAL PROGRESS: 7. ☐ N.C. 7. ☐ N.S. 8. ☐ LKD. 7. ☐ U.L. ☐ OK. TO COVER* ☐ TEMP. 9. ☐ DEFECTIVE*		C O T U M N I L I N T I L I R I T Y R C	
• (NOTES)			

BUILDING INSPECTORS REPORT

BUILDING PERMIT NO: 5812

DATE: 3-16-83

BUILDER OR OWNER: [REDACTED]

JOB NO: Add

ADDRESS: 57 Maxin Sutherland

BLOCK # 26 LOT # 4

PLEASE NOTE: Builder's copy must be retained by the builder and presented at each & every inspection for certification by the Building Inspector.

	App.	Rej.		App.	Rej.
1. FOOTING INSPECTION			B. First level framing		
A. Type of footing			1. Sheathing		
1. Trench 16"x8" plus continuous monolithic type			2. Studding		
2. Form trench with 3x4 Rebar OK.			C. Second Deck Framing		
B. Depth also 3 per spec approved.			1. Double beams under non-bearing partitions		
C. Width note: had pump pumping water out of			D. Second Level Framing		
D. Reinforcing 3 ft. deep trench.			1. Blocking		
E. Type of soil on site			2. Studding		
at footing grade clay, sand, iron,			3. Sheathing		
Date: <u>22 Nov. 83</u>			4. Wall ties		
Inspector: <u>GB. S. Brown Jr.</u>			E. Ceiling Beams		
2. SECOND INSPECTION			1. Species		
Foundation			2. Strong backs		
A. Block work MUST fill open joints on inside			3. Gable ties		
B. Pile-asters of block work			F. Rafters		
C. Cap block			1. Species		
D. Bolts			2. Spacing		
E. Cove			3. Collar ties		
F. Plaster			Date: <u>4/20/83</u>		
G. Water proofing			Inspector: <u>RM</u>		
Date: <u>3/25/83</u>			6. INSULATION INSPECTION		
Inspector: <u>RM</u>			<u>R-11 walls</u>		
3. THIRD INSPECTION-Slab			<u>R-19 ceiling</u>		
A. Gravel			<u>4/20/83 RM</u>		
B. Polyethylene			7. FIFTH INSPECTION		
C. Perimeter Insulation			A. Exterior wall finish		
D. Reinforcing Wire			B. Exterior trim		
Date:			C. Roof shingles		
Inspector:			D. Porch posts		
4. GARAGE FLOOR			E. Miscellaneous (flashings, etc.)		
A. Thickness			Date:		
Date:			Inspector:		
Inspector:			8. FINAL INSPECTION		
BASEMENT FLOOR			A. Trim		
A. Gravel			B. Doorstops, saddles, etc.		
1. Thickness			C. Fire wall & fire door		
Date:			D. Appliances		
Inspector:			E. Gas shut-offs		
5. FOURTH INSPECTION			F. Handrails, etc.		
A. Basement			G. Accessories:		
1. Termite Prevention					
2. Girder					
3. First floor beams					
4. Blocking and Bridging					
5. Species of material					
6. Double beams under non-bearing partitions					

10/27/83 Final incomplete: needs handrails/guardrails for porch steps. 2nd fire approval of 8-29-83. Violation closed 1 Nov. 83 First OK 9-29-83.

PLUMBING INSPECTION

PRELIMINARY

FINAL DATE 5/17/83

DATE:

INSPECTOR:

INSPECTOR: DAVE GOWEN

ELECTRICAL INSPECTION

PRELIMINARY

FINAL DATE: 5/18/83

DATE:

INSPECTOR:

INSPECTOR: VASILY SARG

HOWELL TOWNSHIP
DEPARTMENT OF INSPECTIONS
PLUMBING CERTIFICATE OF COMPLIANCE

ISSUED TO.....*R. Vesi*.....⁶
Name of Contractor

.....*[Redacted]*.....
Address

THIS IS TO CERTIFY, That the Plumbing system installed by

.....*Above*.....At Block No. *26*.....Lot No. *4*.....
Installed

or.....*57 Main Street*.....In the Township has been
No. Street

constructed or altered in accordance with the provisions of an ordinance entitled "AN ORDINANCE establishing a code regulating the installation, maintenance, repair and control of plumbing and connection thereof with outside sewers, cesspools or other receptacles: Regulating the practice of plumbing and the issuance of licenses to practice plumbing and providing penalties for violation thereof:" as amended and adopted by the Township Committee on December 27, 1976, and as described in the Application for Permit to install a Plumbing System

No. *1431*.....Dated.....*4-7-83*.....or as the Township Committee of Howell has directed.

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily nor shall it in any way restrict the powers or responsibilities of the Dept. of Inspections in enforcement of any law or ordinance relating to public health.

Department of Inspections
Howell Township

.....*5-17-83*.....
Date

.....*[Signature]*.....
Plumbing Sub-Code Official

HOWELL TOWNSHIP
DEPARTMENT OF INSPECTIONS
PLUMBING CERTIFICATE OF COMPLIANCE

ISSUED TO.....*R. Vese*
Name of Contractor.....

.....*[Redacted]* Address.....

THIS IS TO CERTIFY, That the Plumbing system installed by:

.....*above* At Block No. *26* Lot No. *4*
Installer.....

or.....*57 Main Street* In the Township has been
No. Street.....

constructed or altered in accordance with the provisions of an ordinance entitled "AN ORDINANCE establishing a code regulating the installation, maintenance, repair and control of plumbing and connection thereof with outside sewers, cesspools or other receptacles: Regulating the practice of plumbing and the issuance of licenses to practice plumbing and providing penalties for violation thereof:" as amended and adopted by the Township Committee on December 27, 1976, and as described in the Application for Permit to install a Plumbing System

No. *1431* Dated *4-7-83* or as the Township Committee of Howell has directed.

The issuance of this certificate shall not be construed as a guarantee that the system will function satisfactorily nor shall it in any way restrict the powers or responsibilities of the Dept. of Inspections in enforcement of any law or ordinance relating to public health.

Department of Inspections
Howell Township

.....*5-17-83*
Date

.....*[Signature]*
Plumbing Sub-Code Official



TOWNSHIP OF HOWELL

Post Office Box 530

Howell, New Jersey 07731

201-938-4500

For Home Owners Use Only

DATE Mar 14 1983

AFFIDAVIT, STATE OF New Jersey COUNTY OF Monmouth SS:

[REDACTED] being duly sworn states that the electrical construction was installed by himself, (the signer of said application) in a dwelling referred to on the attached application that is occupied solely as a residence for himself or for a member or members of his immediate family.

Sworn and subscribed before me

at Town Hall

the date aforesaid

[REDACTED]
NOTARY PUBLIC OF NEW JERSEY

KATHLEEN F. BONGIOVI
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires April 19, 1984

This affidavit must be signed, notarized and attached to your application before inspection can be made.

M E M O

DATE: APRIL 20, 1983
TO: SIGMUND SHUPACK, CONSTRUCTION OFFICIAL
FROM: RICHARD MEGILL, BUILDING INSPECTOR
SUBJ: [REDACTED]
57 SOUTHARD MAXIM RD., BLOCK-26 LOT-4

I made a inspection at the above mentioned premises.

Upon inspection of the addition [REDACTED] she has a woodburning stove installed in her living room, and the stove pipe, is inserted into the same chimney as the furnace.

e
a

R Megill

10/27/83 Woodburning stove disconnected. 94.9. 94.9.