

Fire Code Violations

Registration No.

Date 5/22/2010

Print Name TURKELIN

TFH
85 W SYLVANIA

- Owner or agent:

☐ If box is checked, a New Jersey State Uniform Construction Code Permit is required.

Violations cited on the above premises are as follows:

No.	Location	Nature & Description	Code Reference N.J.A.C. 5:70- 3.1(a) / 3.2(a) / 4.	Abate By Time/Date	U/A	U/A	U/A
		NO VIOLATIONS					

☐ If box is checked, see additional page(s) for violations _____ to _____

KEY: "A" - Violation corrected.
"U" - Violation uncorrected.

N.J.A.C. 5:70-3.2(a), Modifications, additions and deletions to the BOCA National Fire Prevention Code made by the Department of Community Affairs.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements

Fire Code Violations

Registration No.

Print Name _____

☒ Maintenance
☐ Continuation Sheet
☐ Retrofit


☐ If box is checked, a New Jersey State Uniform Construction Code Permit is required.

No.	Location	Nature & Description	Code Reference N.J.A.C. 5:70- 3.1(a) / 3.2(a)/4.	Abate By Time/Date	U/A	U/A	U/A
		NO VIOLATIONS					

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements

5:71-3.7(b)3.

BUREAU OF FIRE PREVENTION
106 West Sylvania Avenue
Neptune City, NJ 07753
(732) 776-7224



Page 1 of 1

FIRE CODE VIOLATIONS

Registration No: 65349-001

Date: 10/30/08

Owner/Agent: John Collazo

☒ Maintenance

☐ Retrofit

☐ Continuation
Sheet

Print Name: Robert C. Kesler Jr

Premises: TFH Publication / Nylabone

Robert C. Kesler Jr
Inspector's Signature

85 WEST SYLVANIA AVE

NEPTUNE CITY, N.J. (732) 988-8400 Ext. 352

☐ If box is checked, a New Jersey State Uniform
Construction Code Permit is required.

Inspector Name &
Reinspection Date >

U/A1 _____

U/A2 _____

U/A3 _____

Violations cited in the above premises are as follows:

No.	Location	Nature & Description of Violation & Action Required for Abatement	Code Reference N.J.A.C. 5:70- 3.1(a) / 3.2(a)	Abate By Time/Date	U/A1	U/A2	U/A3
NO VIOLATIONS							

*I acknowledge that on this date the above
reinspection was performed with the above
noted results.

* U/A1 _____

* U/A2 _____

* U/A3 _____

*Owner or Agent Signature & Reinspection Date >>

Key: "A" Violation Corrected
"U" Violation Uncorrected


☐ If box is checked, see additional page(s) for violations _____ to _____

NOTE: The numbering of violations is for identification purposes only and
shall not be construed as bearing in any way on the seriousness
of any violation.

N.J.A.C. 5:70-3.1(a), BOCA National Fire Prevention Code
1996, which has been adopted by reference.

N.J.A.C. 5:70-3.2(a), Modifications, additions and deletions
to the BOCA National Fire Prevention Code made by
Department of Community Affairs

BUREAU OF FIRE PREVENTION
106 West Sylvania Avenue
Neptune City, NJ 07753
(908) 776-7224



FIRE CODE VIOLATIONS

Page 1 of 1

Registration No: 65349-001

Date: 11/2/07

Owner/Agent: John Collazo 732-245-3662

☐ Maintenance

Print Name: Robert C. Kepler Jr

☐ Retrofit

Premises: TFH Publications / Nylabone

☐ Continuation
Sheet

Robert C. Kepler Jr
Inspector's Signature

85 WEST SYLVANIA AVE

Neptune City, N.J. 732-988-8400 Ext. 352

☐ If box is checked, a New Jersey State Uniform
Construction Code Permit is required.

Inspector Name &
Reinspection Date >

U/A1 _____

U/A2 _____

U/A3 _____

Violations cited in the above premises are as follows:

No.	Location	Nature & Description of Violation & Action Required for Abatement	Code Reference N.J.A.C. 5:70- 3.1(a) / 3.2(a)	Abate By Time/Date	U/A1	U/A2	U/A3
1	South Door	Exit Light out	N.J.A.C. 5:70-3.2(a) F-610.2	11/17/07 15 Days			
2	Throughout Building	Extension Cords Used As Permanent Wiring	N.J.A.C. 5:70-3.1(a) F-310.5	12/3/07 30 Days			

*I acknowledge that on this date the above
reinspection was performed with the above
noted results.

* U/A1 _____

* U/A2 _____

* U/A3 _____

*Owner or Agent Signature & Reinspection Date >>

☐ If box is checked, see additional page(s) for violations _____ to _____


Key: "A" Violation Corrected
"U" Violation Uncorrected

NOTE: The numbering of violations is for identification purposes only and
shall not be construed as bearing in any way on the seriousness
of any violation.

N.J.A.C. 5:70-3.1(a), BOCA National Fire Prevention Code
1996, which has been adopted by reference.

N.J.A.C. 5:70-3.2(a), Modifications, additions and deletions
to the BOCA National Fire Prevention Code made by
Department of Community Affairs

BUREAU OF FIRE PREVENTION
106 West Sylvania Avenue
Neptune City, NJ 07753
(908) 776-7224



FIRE CODE VIOLATIONS

Page 1 of 1

Registration No: 1335-65349-00

Date: 11/28/05

Owner/Agent: TFH NYLARBONE

☐ Maintenance
☐ Retrofit
☐ Continuation
Sheet

Print Name: TURATKIN

Premises: 85 W. SYLVANIA AVE

NEPTUNE CITY

Inspector's Signature [Signature]

☐ If box is checked, a New Jersey State Uniform Construction Code Permit is required.

Inspector Name &
Reinspection Date >

U/A1 [Signature]

U/A2 _____

U/A3 _____

Violations cited in the above premises are as follows:

No.	Location	Nature & Description of Violation & Action Required for Abatement	Code Reference N.J.A.C. 5:70- 3.1(a) / 3.2(a)	Abate By Time/Date	U/A1	U/A2	U/A3
1	Fire Suppression Systems	NOT INSPECTED	FS01-	1/13/06	A	[Signature]	
2	Fire Suppression Systems	NO LOCKS ON VALVES (3)	FS01-	1/13/06	A		
3	Fire Suppression System.	MORE HEAD BOX TO BETTER LOCATION NEED MORE HEADS	FS01	1/13/06	A		

*I acknowledge that on this date the above reinspection was performed with the above noted results.

* U/A1 _____

* U/A2 _____

*U/A3 _____

*Owner or Agent Signature & Reinspection Date >>

☐ If box is checked, see additional page(s) for violations _____ to _____

Key: "A" Violation Corrected
"U" Violation Uncorrected

NOTE: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

N.J.A.C. 5:70-3.1(a), BOCA National Fire Prevention Code 1996, which has been adopted by reference.

N.J.A.C. 5:70-3.2(a), Modifications, additions and deletions to the BOCA National Fire Prevention Code made by Department of Community Affairs



Page _____ of _____

BUREAU OF FIRE PREVENTION

BORO HALL • 106 W. SYLVANIA AVENUE
MAIL ADDRESS P.O. BOX 2098, NEPTUNE CITY, NJ 07753
TELEPHONE: (732) 776-7224

Registration No. 1335-65349-001-01

Date 12/3/07

Inspector K. Meyer

FIRE CODE VIOLATIONS

PREMISES: TF12 - NY1A BONE
85 W. SYLVANIA

REINSPECTIONS

DATE: / /

Inspector

The violations cited on the above premises are as follows:

[illegible]

COMMENTS

☐ If box is checked, see additional page(s) for violations _____ to _____

KEY: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violations.

violations.
 "a" Refers to NJAC 5:18-3.2a State amendments to the Building Officials and Code Administrators, Inc., Basic National Fire Prevention Code/1984
 BOCA

"F" Refers to articles in BOCA.

³"U" Unabated—Violation uncorrected.

"A" Abated—Violation corrected.

NOTE: A copy of the BOCA Index has been printed on the back of this form for your reference.