

Medford Farms Fire
76 HAWKINS RD
TABERNACLE, NJ 08088

Copy of Violation Notice

Tuesday February 6, 2024

REDMOND GARDEN CENTER
1360 RT. 206
TABERNACLE, NJ 08088

An inspection of your facility on Wednesday July 15, 2020 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on Friday November 18, 2022 at 14:48:15

If you fail to comply with this notice before the reinspection date listed, you may be liable for the penalties provided for by law for such violations.

Violation Code	Article	Division	Page	Count
906.2 General requirements			0	0
PORTABLE EXTINGUISHERS REQUIRE ANNUAL TESTING - THROUGHOUT				

"Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.Exceptions:1.The distance of travel to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.2.Thirty-day inspections shall not be required and maintenance shall be allowed to be once every 3 years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:2.1.Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.2.2.Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.2.3.The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.2.4.Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.2. 5.A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.3.In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations."

Repaired 01/04/2021

605.1 Abatement of electrical hazards			0	0
OPEN BREAKER SPACES MUST BE PLUGGED / HEATER ROOM				

Medford Farms Fire
76 HAWKINS RD
TABERNACLE, NJ 08088

Copy of Violation Notice

Tuesday February 6, 2024

REDMOND GARDEN CENTER
1360 RT. 206
TABERNACLE, NJ 08088

"Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the electrical subcode of the Uniform Construction Code Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used. All electrical wiring, devices, appliances and other equipment shall be maintained in accordance with the provisions of the electrical subcode of the New Jersey Uniform Construction Code and this subchapter."

Repaired 01/04/2021

5303.5.3 Securing compressed gas containerscylinder tanks	0	0
---	---	---

SECURE COMPRESSED CYLINDERS FROM FALLING - SHOP AND EXT|IOR STORAGE

"Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not accessible to the public. Nesting shall be allowed provided the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing."

Repaired 01/04/2021

1010.1.9 Door operations	0	0
--------------------------	---	---

EXIT DOORS MUST OPEN IN PROPER DIRECTION - WHERE REQUIRED

"Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort."

Repaired 01/04/2021

Medford Farms Fire
76 HAWKINS RD
TABERNACLE, NJ 08088

Copy of Violation Notice

Tuesday February 6, 2024

REDMOND GARDEN CENTER
1360 RT. 206
TABERNACLE, NJ 08088

803.1 General

0 0

MATERIAL OF WALLS AND HANGING FROM CEILING MUST MEET STANDARDS - ENTIRE NURSERY
AREA USED FOR MERCENTILE

"The interior finish and trim shall be maintained in accordance with the
requirements of N.J.A.C. 5:23, the Uniform Construction Code or N.J.A.C. 5:70-4
the Uniform Fire Code, Fire Safety Code as applicable. Any interior finish or
trim installed without a permit issued in accordance with N.J.A.C. 5:23 the
Uniform Construction Code shall be removed. Exceptions: 1. Materials having a
thickness less than 0.036 inch (0.9 mm) applied directly to the surface of walls
and ceilings. 2. Exposed portions of structural members complying with the
requirements of buildings of Type IV construction in accordance with the
International Building Code shall not be subject to interior finish requirements"

1010.1 Doors

0 0

INSTALL EXIT DOORS TO MEET THE UCC CODE
WHERE REQUIRED

"Means of egress doors shall meet the requirements of this section. Doors serving
a means of egress system shall meet the requirements of this section and Section
1022.2. Doors provided for egress purposes in numbers greater than required by
this code shall meet the requirements of this section. Means of egress doors shall
be readily distinguishable from the adjacent construction and finishes such that
the doors are easily recognizable as doors. Mirrors or similar reflecting
materials shall not be used on means of egress doors. Means of egress doors shall
not be concealed by curtains, drapes, decorations or similar materials."

Boegly, Ernie
Inspector

X
JOHN REDMOND
Occupant/Owner