

**County of Monmouth
Department of Health and Human Services**



Monmouth County Board of County Commissioners

Thomas A. Arnone, *Director*
Susan M. Kiley, *Deputy Director*
Dominick "Nick" DiRocco
Ross F. Licitra
Erik Anderson

Peter-Donnell Boynton
Director
Dept. of Health and Human Services

Christopher P. Merkel
Public Health Officer
Dept. of Health and Human Services

50 East Main Street
Freehold, NJ 07728
Telephone 732-431-7456
Fax 732-409-7579

Chaim Dahari

Lakewood, NJ 08701

MCHD LOG # HO-2735
August 29, 2025

Re: Application for an Individual Subsurface Sewage Disposal System
in: Howell
Municipality

Dear Sir,

Your application for Permit to Construct an Individual Subsurface Sewage System at: 729 Lakewood-Farmingdale Road, Howell Block: 42 Lot: 43 has been approved with the following condition(s):

- Engineer must certify the permeability, compaction and elevation of the replacement fill material.
- System is approved for a **Special Needs School,(24 Students Max), 4,310 Square Feet of office space and Visitors per day.**
- **No food preparation or Food Service** of any kind is permitted.
- Excavation shall be to an elevation of 94.5 or approximately 3.0 feet plus a 3' wick to elevation 89.0 or 8.5 feet.
- System **IS NOT** designed for a sewage ejector pump.
- Existing septic tank and seepage pit must be pumped, crushed and filled.

All septic tanks must be certified as watertight. The septic tank must have an effluent filter installed. This approval is good for 5 years.

It is important that the septic system be installed according to the provisions of N.J.A.C. 7:9A-1.1 et seq. and standards thereto. Failure to do this will result in the withholding of final approval and could lead to the need for costly alterations and/or legal action.


The installer of the above-mentioned system must contact this office for inspection, at the following construction stages:

- 1. After excavation work is completed.**
- 2. After septic tank and disposal field have been installed. (no cover)**
- 3. After the septic system is covered and landscaping is completed.**

This office must be contacted for an inspection (24) hours prior to the installation of the system. If, upon final inspection, the individual subsurface sewage disposal system has been installed according to the specifications given in your application, a Certificate of Compliance will be issued to you by mail.

Building inspectors are prohibited from issuing a Certificate of Occupancy prior to their receiving a copy of our Certificate of Compliance.

Sincerely,



**Christopher R Luberto
Principal Registered Environmental
Health Specialist**

:CRL

**cc: Howell Construction Office
Lortech**