

VIOLATIONS

Premises: SOUTHERN PAWS INC.
1159 GREENWOOD LAKE TPK.
UNIT -
Ringwood, New Jersey 07456

Registration No. 3-03C
Inspection Date: December 6, 2022
Initial Inspector:
Print Name: Scott Conley
Page number: 1

Owner/Agent: TAMI JO FALLER /SOUTHERN PAWS INC.
P.O. BOX 174
RINGWOOD, N.J. 07456

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 0 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Office Nature: Means of Egress - Exit signs/directional signs - 2 EXIT LIGHTS NEED BATTERIES Code Section: N.J.A.C. 5:70-3,1013.1	ABATED			
2.	Location: Office Nature: Carbon Monoxide Detectors - INSTALL CARBON MONOXIDE DETECTOR IN OFFICE AREA Code Section: N.J.A.C. 5:70-4.9	ABATED			
3.	Location: Basement Nature: Sprinkler System Accessibility - REMOVE STORAGE AROUND FIRE SPRINKLER SYSTEM Code Section: NFPA - 25 4.1.3	ABATED			
4.	Location: Basement Nature: General Conditions - Accumulation of combustible materials - REMOVE STORAGE AROUND FURNACE. Code Section: N.J.A.C. 5:70-3,304.1	ABATED			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.