

VIOLATIONS

Premises: THE COMFY PUPPY
1159 GREENWOOD LAKE TPK
2ND FLOOR
Ringwood, New Jersey 07456

Registration No. 3-03B
Inspection Date: December 9, 2022
Initial Inspector: _____
Print Name: Scott Conley
Page number: 2

Owner/Agent: STEPHANIE FOREST

STEPHANIEAFOREST@YAHOO.COM
RINGWOOD NJ 07456

Date:

12/13	1/6	
		

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 3 Retrofit: 1)	Abate by	U/A	U/A	U/A
1.	Location: Stairwell - STAIRWELL TO SECOND FLOOR Nature: Means of Egress - Egress Lighting - NEEDS BATTERY Code Section: N.J.A.C. 5:70-3,1008.2	12/29/2022		A	
2.	Location: Floor #2 - TWO EGRESS LIGHTS IN MAIN ROOM Nature: Means of Egress - Egress Lighting - NEEDS BATTERIES Code Section: N.J.A.C. 5:70-3,1008.2	12/29/2022		A	
3.	Location: Front Door Nature: Fire Extinguishers - Proper mounting - MUST BE MOUNTED TO WALL Code Section: N.J.A.C. 5:70-3,906.9	12/29/2022		A	
4.	Location: Floor #2 Nature: Carbon Monoxide Detectors - INSTALL A CO DETECTOR IN MAIN ROOM Code Section: N.J.A.C. 5:70-4.9	12/29/2022	A		

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.