

BRICK UTILITIES

Work Order #: 13-26256 Open

Account Id: 3292800-0
 Owner: WALSH, THOMAS J SR
 Tenant: WALSH, J. THOMAS SR.
 Property Loc: 56 BROWER DR.
 Service Loc: 56 BROWER DR
 Book/Page: 1 2260

Entered By: Michele Shea
 Call Received From: MS (732)451-1178
 Call Rcvd Date: 10/11/19
 Appt. Date: 10/11/19
 Assigned To:
 Block/Lot/Qual: BRCK- 88.01 4.

WORK TO BE PERFORMED

Description	Inside Read	Outside Read	Meter Num	Serial Num	Sensus MXU
EMERGENCY 300m 330m	514820		B07742698		
SEALED ☒ N BROKEN Y / N RESEALED Y / N	Last Read: 506	07/18/19	Location: LEFT FRONT PAD		
	498	04/18/19			
	490	01/25/19			
	481	10/22/18			

IO# 84889134
 NM0000 P

WO#	Act Code	Reading	Comp Code	Emp	Completed	Comments
11742090	TP DEF	204	OK	SRVC-FM	03/17/09	NO WELL, SYS OK, T/PD WORKING, NH
405586	MM	0	OK	CONV	01/29/08	NO WELL, SYS OK, NH
351957	MM	0	OK	CONV	01/09/06	NO WELL, SYS OK, NH
284056	MM	0	OK	CONV	03/27/03	NO WELL SYSTEM OK
203319	MB	0	OK	CONV	11/10/98	SYS OK. VACANT
185912	TFW	0	OK	CONV	11/12/97	TURNED OFF & WINTERIZED
179285	MB	0	OK	CONV	08/11/97	CONV. TO T/RD MTR. IN BACKWARDS
174587	MB	0	OK	CONV	05/06/97	SYS OK SEALD MTR
135629	FLSH	0	OK	CONV	08/15/95	SYS OK. FLSHD SERV. HOOKD NEW MAIN

NOTES

LEAK AT METER

broken F/P. Replaced 3/4
 house meter

CHARGES

- | | | |
|---|--|-------------------------------------|
| ☒ REG | ☐ TURN ON/OFF | ☐ INSPECTION |
| ☐ OT | ☐ FROST PLATE | ☐ REJECTION |
| ☐ DBL | ☐ TOUCH PAD | ☐ CURB BOX |
| ☐ ERS | ☐ REPLACE METER | ☐ SEARCH |
| | ☐ TAMPERING | ☐ OTHER |

Homeowner/Tenant

Date

Completed By

Date

10-11-19

BRICK TOWNSHIP MUNICIPAL UTILITIES AUTHORITY
1000 BLOOMING ROAD • BRICK TOWN, NEW JERSEY 08723

WATER SERVICE PERMIT

NR 819

NAME _____

MAILING ADDRESS _____

PROPERTY LOCATION _____

BLOCK _____ LOT# _____ TAX MAP PAGE _____

ACCOUNT # _____ METER # _____ METER MFG. _____

SIZE OF SVC LINE 3/4" _____ METER SIZE 3/4" _____

CONNECTION FEE \$ 75.00 _____

INSPECTIONS

	Inst. 1st	Inst. 2nd	Comments	Inspector
A. Service Line				
B. Curb Connection				
C. House Conn & Mtr				
D. Cross-Connection				

x Dena Jorkey

Inspector

THE BRICK TOWNSHIP MUNICIPAL UTILITIES AUTHORITY
888 MANTOLOKING ROAD BRICK TOWN, NEW JERSEY 08724

SEWER SERVICE PERMIT

GROUP # 0512-3

PAGE # 119

CONTRACT NO. 5-6
SEC 6-3

BLOCK # 88-1

LOT # 4

56 BROWER DR

JUHASZ, NICHOLAS M
701 FERNMERE
INTERLAKEN, N J

07712

R01-001

ACCOUNT # C292800 03-001

SIZE OF SVC LINE _____

CONNECTION FEE \$ _____

INSPECTION FEE \$ 15.00
P.D.

6-24.5 DIST: 6-24.6
LENGTH 21.0 DEPTH 3.0

STREET NAME BROWER DR.

INSPECTIONS

	Date 1st	Date 2nd	Comments	Inspector
A. Lateral	<u>6/30/78</u>			
B. Curb Connection	<u>6/30/78</u>		<u>OK</u>	
C. House Connections	<u>6/30/78</u>	<u>1988</u>		

SDR 35 4"

6-30-78
Homeowner/Applicant
Date

Lic. No.

THE BRICK TOWNSHIP MUNICIPAL UTILITIES AUTHORITY

COLLECTION/DISTRIBUTION DIVISION WORK ORDER

JOBN NO. 48193
DATE: _____
CLERK: _____
APPL. PHONE _____
ACCT. NO. C292800
Yur 2
Wares 10.5
Thn - 3

ENTERED

UTILITIES MARKED: GAS _____ TEL. _____ V ELECTRIC _____ CATV _____

TRIANGULATIONS			MATERIALS USED 010		LABOR	HOURS
	WATER	SEWER				
	CORP	CBOX	QUAN			
			TONS			
LEFT				002-000 COLD PATCH		
RIGHT				003-000 FABC MIX #5		
LNQTH				004-000 ROAD GRAVEL		
DEPTH				005-000 STAB BASE		
SIZE				TACK OIL		
POS						

EQUIPMENT USED: HOE 580K DUMP CM/SLR PICKUP 573 COMP _____ ROLLER _____ COMPACTOR _____
MOLE _____ B100 _____ CORER _____ D-5 _____ WETCUT _____ POWER DR. _____

HOMEOWNER'S LINE TIED IN: WATER SEWER PAVING REQUIRED

JOB LAYOUT COMMENTS	DATE	CREW CHIEF	MARKED DRY LINE	
			Y	N

JOB COMPLETION COMMENTS 1 DATE 8/5/78 CREW CHIEF A. Marshall

Put good strong backing of concrete up to old one
Put in electric, install pump, top man, and
saw, pump moved, pump? and so and so on. See
Shirley Smith, with a lot of other men, for the
P.P. work.

I	N	S	T	A	L	K		W		S	E	R							
---	---	---	---	---	---	---	--	---	--	---	---	---	--	--	--	--	--	--	--

179285

B.T.M.U.A SERVICE ORDER

CLERK PAE

SAME READ

-----CUSTOMER INFORMATION-----\

SCHEDULED: 8/08/97

UHASZ, IRMA

56 BROWER DR.

PHONE# 531-9408

COUNTR NUMBER C292800 ROUTE: 001

SEALED ☒ Y N
BROKEN ☒ AN N
RESEALED ☒ NBLOCK
OUT LOT88-01
4-

-----HISTORICAL INFORMATION-----\

DATE READ	READ	CONSP	/--RATE CODES--\
8/01/96	518K	14	WATER R01-A- 1
1/01/96	K 532	14	SEWER R01-A- 1
2/03/97	K 536	4	FIRE --
5/01/97	Z 536		

METER# 32789606 DIGLS: 24
LOCATION: LEFT FRONT
MTR INSTRUCT:
N.M. - 0000

-----SPECIAL INSTRUCTIONS-----\

-----HISTORY-----\

D#	ACT CODE	COMP CODE	INIT	/--COMMENTS--\	DATE COMPLETE
4587			INSIDE READ	536.190 OUTSIDE- 536	
4587	MB	OK	DS	SYS OK SEALD MTR	5/06/97
5629	FLSH	OK	BG	SYS OK, FLSHD SERV. HOOKD NEW MAIN	8/15/95
5019	MM	OK	JD	SYSTEM OK	7/20/94
2804	MB	OK	DS	METER BOOK SERVICE ORDER	2/07/92
4841	MM	OK	MB	SYSTEM OK	3/21/91

=====REMARKS=====

INIT ! START ! STOP ! IN READ ! OUT READ ! TEST RESULTS
 JD. 11:24am 11:54 531,000 536 FT. 6% ST. 6%
 COMMENTS CONVERTED TO TOUCHREAD, RENTER UNCERTAIN HOW METER WAS PUT
 IN BACKWARDS, METER WAS PROBABLY PUT IN BACKWARDS BEFORE 5/6/97
 BECAUSE IT WAS STILL SEALED

AFTER TESTING METER I FOUND METER TO BE VERY SLOW + FOUND CRACKED
 CHAMBER IN METER

--READ SCHEDULED --

-----TRIANGULATIONS-----\

ATER	POS	LEFT	RIGHT	LENGTH	DEPTH
	F	43.0	27.6	8.0	3.0
EWER	F	41.0	19.0	21.0	3.0

COMMENTS:

CHARGES
☒ REG ☐ TURN ON/OFF
☐ OT ☐ FROST PLATE
☐ DBL ☐ REMOTE
☐ STBY ☒ REPLACE METER
☐ TAMPERING
☐ REJECTION
☐ CURB BOX
☐ OTHER

CUSTOMER SIGNATURE

DATE 8/11/97

F.T. - 0%
 S.T. - 0%

remove some
 chrg
 tampering
 quick
 error!

23 94.004
 26 250.004
 92

THE BRICK TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY

1551 HIGHWAY 88 WEST

BRICK, NEW JERSEY 08724

PHONE 732-458-7000

8/12/97

JUHASZ, IRMA
701 FERNMERE AVE.
INTERLAKEN, NJ 07712-4346

ROUTE 001 ACCOUNT C292B00
BLOCK- 88-01 LOT- 4
S/L-56 BROWER DR.

SUBJECT: DAMAGED METER SEAL


DEAR CUSTOMER,

ON May 7, 1997 YOU WERE NOTIFIED IN WRITING THAT THE WATER METER SEAL AT THE ABOVE REFERENCED PROPERTY WAS FOUND TO BE DAMAGED/BROKEN UPON OUR ARRIVAL. AT THE SAME TIME YOU WERE ADVISED THE SEAL WAS REPLACED, AND THE METER WAS TAGGED ACCORDINGLY BY OUR SERVICE REPRESENTATIVE. YOU WERE FURTHER ADVISED THAT IF THERE WAS A SPECIFIC NEED FOR WORK TO BE PERFORMED IN THE METER AREA, AND/OR IF IT WAS NECESSARY TO REMOVE THE METER, THAT YOU SHOULD CONTACT OUR CUSTOMER ACCOUNTS DIVISION SO THAT A SERVICE REPRESENTATIVE COULD BE SCHEDULED TO PERFORM THIS WORK. PLEASE NOTE THERE IS NO CHARGE FOR THIS.

DURING THIS MOST RECENT INSPECTION OUR SERVICE REPRESENTATIVE AGAIN FOUND THAT THE METER SEAL HAD BEEN DAMAGED/BROKEN, AND AGAIN REQUIRED REPLACEMENT. AS INDICATED TO YOU PREVIOUSLY THE ESTABLISHED TAMPERING FEE MUST NOW BE CHARGED AGAINST YOUR ACCOUNT, IN ACCORDANCE WITH AND AS IS SET FORTH IN THE CURRENT RATE SCHEDULE, FOR UNAUTHORIZED ACTIVITIES AFFECTING AUTHORITY EQUIPMENT. PLEASE BE ADVISED THAT A FEE OF \$250.00 WILL BE CHARGED TO YOUR ACCOUNT.

IF YOU HAVE ANY QUESTIONS REGARDING THIS ACTION AND ASSOCIATED CHARGES, PLEASE CONTACT OUR CUSTOMER ACCOUNTS DIVISION, 8:00 AM TO 5:00 PM, MONDAY-FRIDAY AND ASK TO SPEAK TO THE CUSTOMER ACCOUNTS SUPERVISOR.

RESPECTFULLY YOURS,


ROBERT A. KOBLANSKI
CUSTOMER ACCOUNTS SUPERVISOR

LTR120

*remove seal
if possible
if not possible
then replace
if not possible
then replace
if not possible
then replace*

26

250.00+

174587

CLERK PAE

B.T.M.U.A SERVICE ORDER

GAME READ

CUSTOMER INFORMATION

JHASZ, IRMA

56 BROWER DR.

PHONE# 477-2414

COUNT NUMBER C292800 ROUTE: 001

SCHEDULED: 5/06/97

SEALED Y

BROKEN IN

RESEALED Y

OUT

OUT

N

BLOCK

LOT

88-01

4-

HISTORICAL INFORMATION

DATE READ	READ	CONSP	/--RATE CODES--	METER#	32783606	DIALS:	3
5/01/96	504K	10	WATER R01-A-	1	LOCATION:	LEFT FRONT	
3/01/96	K 518	14	SEWER R01-A-	1	MTR INSTRUCT:		
1/01/96	K 532	14	FIRE				
2/03/97	K 536	4					

SPECIAL INSTRUCTIONS

HISTORY

DATE	ACT CODE	COMP CODE	INIT	COMMENTS	DATE COMPLETE
5629			INSIDE READ	479.270	479
5629	FLSH	OK	BG	SYS OK, FLSHD SERV. HOOK	8/15/95
5019	MM	OK	JD	NEW MAIN	7/20/94
2804	MB	OK	DS	METER BOOK SERVICE ORDER	2/07/92
4841	MM	OK	MB	SYSTEM OK	3/21/91

REMARKS

INIT ! START ! STOP ! IN READ ! OUT READ ! TEST RESULTS

D.S. 10:57AM 11:10 536/90 536 FT ST
 COMMENTS *sealed inside, part time resident, OK*

READ SCHEDULED

POS	LEFT	RIGHT	LENGTH	DEPTH
ATER F	43.0	27.6	8.0	3.0
EWER F	41.0	19.0	21.0	3.0

COMMENTS:

CHARGES
(X) REG
() OT
() DBL
() STBY
() TURN ON/OFF
() FROST PLATE
() REMOTE
(X) REPLACE METER
() TAMPERING
() REJECTION
() CURB BOX
() OTHER

CUSTOMER SIGNATURE

Irma Jhasz

DATE 5-6-97

BRICK
THE BRICK TOWNSHIP



UTILITIES
MUNICIPAL UTILITIES AUTHORITY

1551 Highway 88 West • Brick, New Jersey 08724-2399
(908) 458-7000 • FAX (908) 458-7725

KEVIN F. DONALD
Executive Director

COMMISSIONERS
PATRICK BOTTAZZI
Chairman
BRIAN MACFIE
Vice Chairman
THOMAS MAJORINE
Secretary
WILLIAM MILLER
Treasurer
JOHN EKARIUS
Asst. Sec./Treas.

May 7, 1997

Ms. Irma Juhasz
701 Fernmere Avenue
Interlaken, NJ 07712-4346

RE: Damaged Meter Seal
Account #
Service Location:

C292800
56 Brower Drive

Dear Ms. Juhasz:

During a recent metering equipment inspection at the above referenced property, our service representative discovered that the water meter seal was damaged/broken. The meter has now been resealed and tagged accordingly.

Since the charges for water usage are based on the actual meter readings it is essential that the integrity of the metering system be maintained to protect both you, the consumer, and the Authority. At the time of this inspection our service representative could not confirm how this seal was damaged, however, we would appreciate your assistance to assure this does not recur. If for any reason it becomes necessary to work in the area of the meter, or if the meter must be removed for specific work to be accomplished in the home/building, please contact our Customer Accounts Division and we will arrange for a service representative to visit your home and assist you. Please note there is no charge for this type of service call.

We trust in the future you will take the necessary precautions to prevent any damage, and/or breakage of the meter seal. Please be advised only authorized agents of the Authority may perform work on the meter equipment in your home. In the event such conditions are again discovered by our service representative the Authority may be forced to impose the established tampering fee, as is set forth in the current rate schedule, related to unauthorized activities affecting Authority equipment.

If you have any questions, and/or require further clarification, please contact our Customer Accounts Division, 8:30 a.m. to 4:30 p.m., Monday through Friday, and request to speak to the Customer Accounts Supervisor.

Respectfully,

A handwritten signature in cursive script, appearing to read "Robert J. Roblenski".
Robert J. Roblenski
Customer Accounts Supervisor