

BLOCK 114 LOT 34.01 QUALIFICATION CODE C12.08 ADDRESS (SITE) 147 Bretonian dr PERMIT NO. 03-5556



CONSTRUCTION PERMIT APPLICATION

Application Completes: Sections I, II, III (optional), IV, VI, and VII

I. IDENTIFICATION

1. Proposed Work Site at: 147 Bretonian dr
2. Name of Owner in Fee: John Palmer
Address 147 Bretonian dr Brick 08923
street municipality zip code
3. Ownership in Fee: Public _____ Private ☒
4. Principal Contractor: John Palmer Tel. ()
Address 147 Bretonian dr
License No. OR, if new home, Builder Reg. No. _____ Exp. Date _____
Federal Employee No. _____ FAX: ()
5. Architect or Engineer
Address FRANK ANGELLO - 732-567-5156 Tel. ()
6. Responsible Person in Charge of Work John Palmer

2ND STORY
ADDITION

V. FEE SUMMARY (for office use only)

		Update	Update
1. Building	\$ <u>240</u>		
2. Electrical	\$ <u>49</u>		
3. Plumbing	\$ <u>105</u>		
4. Fire Protection	\$ <u>35</u>		
5. Elevator Devices			
6. Subtotal	\$		
7. Less 20% for State Plan Review			
8. Subtotal	\$		
9. DCA Training Fee	\$ <u>26</u>		
10. Subtotal	\$ <u>46</u>		
11. Cert. of Occupancy	\$ <u>30</u>		
12. Other			
13. TOTAL	\$ <u>519</u>	<u>20</u>	<u>160</u>

VI. BUILDING/SITE CHARACTERISTICS

		(office use only)
1. Number of Stories	<u>2</u>	
2. Height of Structure	<u>34 ft</u>	ft
3. Area - Largest Floor	<u>252</u>	sq. ft
4. New Building Area	<u>1026</u>	sq. ft
5. Volume of New Structure	<u>9594</u>	cu. ft
6. Construction Classification		
7. Total Land Area Disturbed		sq.
8. Flood Hazard Zone		
9. Base Flood Elevation		ft.
10. Wetlands	yes _____ no _____	
11. Max. Live Load		
12. Max. Occupancy Load		

OPTIONAL (for office use only)

II. PROPOSED WORK

1. ☐ Minor Work
2. ☐ New Building
3. ☐ Addition
4. ☐ Alteration
5. ☐ Fire Protection
6. ☐ Plumbing
7. ☒ Electrical
8. ☐ Elevator Devices
9. ☐ Asbestos Abat. Subch. 8
10. ☐ Lead Hazard Abatement
11. ☐ Demolition

TOTAL COSTS

III. DO YOU WANT: (optional)

1. ☐ Partial Releases
2. ☐ Prototype Processing

IV. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

1. ☐ Elevators/Escalators/Lifts/
Dumbwaiters/Moving Walks
2. ☐ High Pressure Boilers
3. ☐ Pressure Vessels
4. ☐ Refrigeration Systems
5. ☐ Cross-Connections/Backflow Preventers
6. ☐ Hazardous Uses/Places of Assembly
7. ☐ Sprinklers
8. ☐ Smoke Control Systems in Open Wells
9. ☐ Underground Storage Tanks

VII. DESCRIPTION OF BUILDING USE

A. RESIDENTIAL

1. ☐ Hotels (R-1)
2. ☐ Multi-Family (R-2)
3. ☐ Two-Family (R-3) BOCA
4. ☐ Two-Family (R-4) CABO
5. ☐ One-Family (R-3) BOCA
6. ☐ One-Family (R-4) CABO

No. of dwelling units:

Before Construction

After Construction

Net Gain or Loss

B. NON-RESIDENTIAL

1. State Specific Use:

2. Use Group:

3. Change in Use Group, Indicate Former:

CERTIFICATION IN LIEU OF OATH

I. OWNER SECTION (to be completed if the applicant is the owner in fee)

I hereby certify that I am the owner in fee of the property listed on Page 1.

Mark the following applicable boxes:

- A. ☐ I further certify that a new home (private residence) will be constructed on this property for my own use and occupancy. This dwelling is to be occupied by myself and is not to be used for any purpose other than single family residential use. I attest that all construction, plumbing, or electrical work will be done, in whole or in part, by me or by subcontractors under my supervision, in accordance with all applicable laws; and, I further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.S.A. 46:3B-1 et seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.

I UNDERSTAND THAT IN MARKING BOX A, I ACKNOWLEDGE THAT I AM ASSUMING RESPONSIBILITY FOR THE WORK DONE ON SAID PROPERTY, THE CONDITION OF THE PROPERTY PRIOR TO, DURING, AND AFTER ANY WORK PERFORMED, AND FOR THE PERFORMANCE OF THE SUBCONTRACTORS I HIRE, EMPLOY, OR OTHERWISE CONTRACT OR WITH WHOM I MAKE AGREEMENTS TO PERFORM WORK. I AM VOLUNTARILY AND KNOWINGLY ASSUMING THIS RESPONSIBILITY.

- B. ☐ I further certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)1.vii:

I personally prepared the plans submitted for: 1) the new home referred to in A.; or, 2) an addition, alteration, renovation, or repair to an existing single family residence owned and occupied by myself and located on the property listed on Page 1; or, 3) a new structure that will be physically separate from, but that will be deemed part of, an existing single family residence that is owned and occupied by myself and located on the property listed on Page 1.

- C. ☐ I further certify that I will perform or supervise the following work:

C.1. ☒ Building C.2. ☐ Fire Protection

I further certify that I will perform the following work:

C.3. ☒ Electrical C.4. ☒ Plumbing

- D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I understand that if any of the above statements are willfully false, I am subject to punishment.

Signature Joe Pal Date 6-21-03

II. AGENT SECTION (to be completed if the applicant is not the owner in fee)

I hereby certify the following as required by the Uniform Construction Code, N.J.A.C. 5:32-2.15(d): the proposed work is authorized by the owner in fee; and I have been authorized by the owner in fee to make this application as his agent.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

- ☐ Check if contractor.

Agent Name Joe Pal
Address 147 Bretonian dr.
Briar, N.J. 08223
Telephone (232) 472-5964
Signature Joe Pal



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Date Issued 01/07/2009
Control Number _____
Permit Number 03-5556
Permit Issue Date 12/18/2003
Certificate Number 03-5556

Certificate

Construction Code Division

(Certificate of Occupancy)

Identification

Work Site Location: 147 BRETONIAN DR ADDITION, NJ Block: 114 Lot: 34.01 Qual: _____
Owner in Fee: PALMER, JOHN
Owner Address: SAME BRICK NJ 08723-
Telephone: [REDACTED]
Contractor PALMER, JOHN
Address SAME BRICK NJ 08723-
Telephone: [REDACTED] Fax: _____
License Number or Builders Registration Number: _____ Federal Emp. Number: _____

Home Warranty Number: _____

Type of Warranty Plan: ☐ State ☐ Private

Use Group: R-5 Construction Classification: _____

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: _____

Certificate Comments: _____

☒ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☐ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent.

- ☐ Total removal of lead-based paint hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

- ☐ Total removal of asbestos hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**


This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than: or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:


Construction Official

Date Printed: 01/07/2009 U.C.C. F260 (rev. 88/05)

Fee: \$35.00
Check Number: 999
Collected By: _____

NJ UCCARS 5.24E
TOWNSHIP OF BRICK
401 CHAMBERS BRIDGE RD
DIVISION OF INSPECTIONS

UCC NEW JERSEY
BUILDING
SUBCODE
TECHNICAL SECTION

Date Received 08/08/2003
Date Issued 12/18/03
Control # C12-08
Permit # 03-5556

A. IDENTIFICATION-APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block 114 Lot 34.01 Qual

Work Site Location 147 BRETONIAN DR

ADDITION

Owner in Fee PALMER, JOHN

Address SAME

BRICK, NJ 08723-

Contractor [REDACTED]

Address FRANK ANGELO

732-567-5156

Tele. () Fax ()

Lic. No. or Bldrs. Reg. No.

Federal Emp. No. HO-

JOB SUMMARY (Office Use Only)

PLAN REVIEW Date Initial

[] No Plans Req.

[X] All 12-17-03 FM

[] Footing

[] Foundation

[] Frame

[] Other

Joint Plan Review Required:

[] Elect [] Plumb [] Fire

SUBCODE APPROVAL [] Elev

[X] CO [] CCO [] CA

Date: 12/31/01

Approved By: PER-Acting

INSPECTIONS

Dates (Month/Day)

Type Failure Failure Approval Initial

Footing-over 01/12/04 01/14/04 KKK

Foundation

Slab

Frame-over

BarrierFree

Insulation 4/8/08

Finishes

Energy

Mechanical

TCO

Other

Final over 06/2/07 12/20/08 M

BarrierFree

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner
of record and am authorized to make this application.

Signature

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

2ND STORY ADDITION

Attic For Storage only

As BOLT Foundation Survey Require

TYPE OF WORK

[] New Building

[X] Addition

[] Alteration

[] Roofing

[] Siding

[] Fence 0 Height (exceeds 6')

[] Sign 0 Sq. Ft.

[] Pool

[] Asbestos Abatement Subchapter 8

[] Lead Haz. Abatement NJAC 5:17

[] Other

Other

[] Demolition

FEE (Office Use Only)

\$ 0

240

0

0

0

0

0

0

0

0

0

0

0

B. BUILDING CHARACTERISTICS

Use Group Present R-5 Proposed R-5

Constr. Class Present Proposed

No. of Stories 2

Height of Structure 34 Ft.

Area Largest Floor 252 Sq. Ft.

New Bldg. Area/All Floors 1,026 Sq. Ft.

Volume of New Structure 9,594 Cu. Ft.

Total Land Area Disturbed 0 Sq. Ft.

Est. Cost of Bldg. Work:

1. New Bldg. \$ 24,000

2. Alteration \$ 0

3. Total (1+2) \$ 24,000

Industrialized Building:

[] State Approved

[] HUD

Administrative Surcharge

Paid [] Check # Minimum Fee \$ 0

Collected by: TOTAL FEE \$ 240

DCA State Permit Fee \$ 25

DIVISION OF INSPECTIONS
401 CHAMBERS BRIDGE RD.
TOWNSHIP OF BRICK
NJ 08804-2348

01/12/04. NEED TO CONNECT SIDE FTG AT BACK WITH REAR FTG.
IN AREA BENEATH REAR PORCH CORNER PIER.
ALSO EXTEND FTG @ BILCO DOOR TO BACK WALL.
01/14/04 - DONE - O.K. ~~EEH~~

04/05/04. FOUNDATION ANCHOR STRAPS ALONG REAR MUD ROOM WALL
INSTALLED IMPROPERLY & NOT FASTENED TO SILL PLATE.
POINT LOADS FROM 2nd FL (SEVERAL PLACES) REQUIRE SOLID
BLOCKING DOWN TO FOUNDATION.

03/02/07. RAILINGS NOT DONE SEVERAL PLACES. RE-INSPECT ALL
LANDING @ REAR DOOR.
COMBUSTION AIR - 2nd FL DRYER.
COUNTERTOPS (KITCHEN) INCOMPLETE.

(B) tech ↑

01/18/07

TECHNICAL SECTION

SUBCODE

BUILDING

800 NEW JERSEY

Permit #

Control # 013-08

Date Issued

Date Received 08/08/2003

TOWN OF BRICK
 CHAMBERS BRIDGE RD
 DIVISION OF INSPECTIONS

UCC NEW JERSEY
 PLUMBING
 SUBCODE
 TECHNICAL SECTION

Date Received 08/08/2003
 Date Issued 12/18/03
 Control # C12-08
 Permit # 03-5556

A. IDENTIFICATION-APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS. NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block 114 Lot 34.01 Qual
 Work Site Location 147 BRETONIAN DR
 ADDITION

Owner in Fee PALMER, JOHN
 Address SAME
 BRICK, NJ 08723-

Contractor JOHN PALMER PLUMBING
 Address 147 BRETONIAN DR
 BRICK, NJ 08723-

Tele. (732) 477-5964
 Lic. No. or Bldrs. Reg. No. 9184
 Federal Emp. No. 26-1573562

B. PLUMBING CHARACTERISTICS

Use Group Present R-5 Proposed R-5
 Building Sewer Size [] Public Sewer [] Private Septic
 Water Sewer Size [] Public Water [] Private Well
 Estimated Cost of Plumbing Work \$ 2,000

JOB SUMMARY (Office Use Only)

PLAN REVIEW

[] No Plans Required

Joint Plan Review Required:

[] Bldg [] Elect

[] Fire [] Elevator

[] Plumb. Plans Approved

Date: 12/14/03

Approved By: [Signature]

SUBCODE APPROVAL

[] CO [] CCO [] CA

Approved By: [Signature]

Date: 1-30-01

INSPECTIONS

Type Failure Failure Approval Initial

Slab

Rough

Water 22-01 3-31-04 [Signature]

Sewer 22-07 10-22-07 [Signature]

Fixtures 22-07 1-30-08 [Signature]

Gas Equip. 22-07 2-31-04 [Signature]

Gas Piping

Solar

TCO

Yok 10-22-07 [Signature]

D. TECHNICAL SITE DATA (List all fixtures.)

NO.	PICTURE/EQUIPMENT	FEE (Office Use Only)
2	Water Closet	20
0	Urinal / Bidet	0
1	Bath Tub	10
2	Lavatory	20
2	Shower	20
0	Floor Drain	0
0	Sink	0
0	Dishwasher	0
0	Drinking Fountain	0
0	Washing Machine	0
0	Hose Bib	0
0	Water Heater	0
0	Fuel Oil Piping	0
0	Gas Piping	0
0	Steam Boiler	0
0	Hot Water Boiler	0
0	Sewer Pump	0
0	Interceptor / Separator	0
0	Backflow Preventer	0
0	Greasetrap	0
0	Sewer Connection	0
0	Water Service Connection	0
0	Stacks	0
0	Other A/C	35
0	Other	0

Administrative Surcharge \$ 0
 Paid [] Check # Minimum Fee \$ 0
 Collected by: TOTAL FEE \$ 105
 DCA State Permit Fee \$ 0

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Signature/Contractor Seal

[] Licensed Plumbing Contractor [] Exempt Applicant

① Update for 2 gas

② Dryer room needs a self closing
door & gasket & make up air

③ 1" H₂O needed

④ tech



Date Received
Date Issued
Control #
Permit #

03-555671
10-19-07

C07-004683

Block 114 Lot 34.01
Work Site Location 149 Betonian dr.
Brick, NJ 08723
Owner in Fee/Occupant John Palmer
Address _____
Tele. (____) _____
Contractor _____
Address _____
DAMION ELECTRIC, LLC
P.O. Box 31 Howell, NJ 07731
Tel: 732-370-4967 Fax: 732-370-3859
Lic. No. LIC #: 14746 FEIN#: 20-2995474
Federal Emp. No. _____

Use Group Present _____ Proposed _____
☐ Pole/Pad # _____ ☐ Temporary ☐ Other _____
 Building Occupied as _____ Utility Co. _____
 Est. Cost of Elec. Work \$ _____

PLAN REVIEW		Date	Initial	INSPECTIONS		Dates (Month/Day)			
☒	No Plans Required			Type:	Failure	Failure	Approval	Initial	
Joint Plan Review Required:				Rough	_____	_____	_____	_____	
☐	Building	☐	Plumbing	Temp. Serv.	_____	_____	_____	_____	
☐	Fire	☐	Elevator	Constr. Serv.	_____	_____	_____	_____	
☐	Elec. Plans Approved			TCO	_____	_____	_____	_____	
Date:	92607			Other	_____	_____	_____	_____	
Approved by:	[Signature]			Service	_____	_____	_____	_____	
				Final	_____	_____	_____	_____	

[] CO [] CCO [] CA
Date: 402607
Approved by: [Signature]

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature

☒ Licensed Electrical Contractor ☐ Exempt Applicant

QTY.	SIZE	ITEMS
		Lighting Fixtures
		Receptacles
		Switches
		Detectors
		Light Poles
		Motors—Fract. HP
		Emergency & Exit Lights
		Communications Points
		Alarm Devices/F.A.C. Panel
		
		TOTAL NUMBERS
		Pool Permit/with UW Lights
		Storable Pool/Spa/Hot Tub
		KW Elec. Range/Receptacle
		KW Oven/Surface Unit
		KW Elec. Water Heater
		KW Elec. Dryer/Receptacle
		KW Dishwasher
		HP Garbage Disposal
		KW Central A/C Unit
1		HP/KW Space Heater/Air Handler
		KW Baseboard Heat
		HP Motors 1/+ HP
		KW Transformer/Generator
		AMP Service
		AMP Subpanels
		AMP Motor Control Center
		KW Elec. Sign/Outline Light
1	90	Sub Panel

FEE (Office Use Only)

Administrative Surcharge	\$ _____
Minimum Fee	\$ _____
DCA Training Fee	\$ _____
TOTAL FEE	\$ _____

10 26 07 Owner To Sheet Rock Above Panel

↖ (E) tech + D

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

34.01

H11

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002

10 26 07 LEILA 30-5002



ELECTRICAL SUBCODE TECHNICAL SECTION



Date Received
Control #

Date Issued
Permit #

2/2/07
03-5556+B

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 114 Lot 34.01 Qualification Code _____
Work Site Location 147 Bretonian Dr.

Owner in Fee John Palmer
Address 147 Bretonian Dr.
BRICK, NJ 08733

Tel. [REDACTED]
Contractor _____
Address _____

Tel. (_____) _____ FAX (_____) _____
Contractor License No. _____
Federal Emp. No. _____

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____
[] Pole/Pad # _____ [] Temporary [] Other _____
Building Occupied as _____ Utility Co. _____
Est. Cost of Elec. Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW		INSPECTIONS		Dates (Month/Day)			
Date	Initial	Type:	Failure	Failure	Approval	Initial	
[] No Plans Required		Rough	_____	_____	_____	_____	
Joint Plan Review Required:		Barrier-Free	_____	_____	_____	_____	
[] Building	[] Plumbing	Trench	_____	_____	_____	_____	
[] Fire	[] Elevator	Temp. Serv.	_____	_____	_____	_____	
[] Elec. Plans Approved		Constr. Serv.	_____	_____	_____	_____	
Date: _____		TCO	_____	_____	_____	_____	
Approved by: _____		Other	_____	_____	_____	_____	
		Service	_____	_____	_____	_____	
		Final	_____	_____	_____	_____	10/26/07
		Barrier-Free	_____	_____	_____	_____	to
SUBCODE APPROVAL		Temp. Cut-in-Card Date Issued	_____	_____	_____	_____	
[] CO	[] CCO	Final Cut-in-Card Date Issued	_____	_____	_____	_____	
Date: <u>10/26/07</u>		Annual Pool Inspection	_____	_____	_____	_____	
Approved by: <u>mw</u>		Date of Grounding and Bonding Certification	_____	_____	_____	_____	

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature _____
[] Licensed Elec. Contractor [] Certif'd Landscape Irrigation Contr'r [] Exempt Applicant

D. TECHNICAL SITE DATA

QTY.	SIZE	ITEMS
_____		Lighting Fixtures
_____		Receptacles
_____		Switches
_____		Detectors
_____		Light Poles
_____		Motors—Fract. HP
_____		Emergency & Exit Lights
_____		Communications Points
_____		Alarm Devices/F.A.C. Panel
_____		TOTAL NUMBERS
_____		Pool Permit/with UW Lights
_____		Storable Pool/Spa/Hot Tub
_____		KW Elec. Range/Receptacle
_____		KW Oven/Surface Unit
_____		KW Elec. Water Heater
_____		KW Elec. Dryer/Receptacle
_____		KW Dishwasher
_____		HP Garbage Disposal
_____		KW Central A/C Unit
_____		HP/KW Space Heater/Air Handler
_____		KW Baseboard Heat
_____		HP Motors 1/+ HP
_____		KW Transformer/Generator
_____		AMP Service
_____		AMP Subpanels
_____		AMP Motor Control Center
_____		KW Elec. Sign/Outline Light

FEE (Office Use Only)

\$ _____

Reinstate expired permit

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____

102607 owner to sheet rock above panel

 (E) tech + B

TOWNSHIP OF BRICK
401 CHAMBERS BRIDGE RD
DIVISION OF INSPECTIONS

M 7
UCC NEW JERSEY
Electrical
S
ELECTRICAL
SUBCODE
TECHNICAL SECTION

Date Received 08/08/2003
Date Issued *12/18/03*
Control # C12-08
Permit # *03-5556*

A. IDENTIFICATION-APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS. NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block *114* Lot *34.01* Qual _____

Work Site Location *147 BRETONIAN DR*

ADDITION _____

Owner in Fee *PALMER, JOHN*

Address *SAME*

BRICK NJ 08723-

Tel *[REDACTED]*

Contractor *DAMION ELECTRIC*

Address *44 LEXINGTON RD*

HOWELL, NJ 07731-

Tele. *(732) 370-4967*

Lic. No. or Bldrs. Reg. No. *14746*

Federal Emp. No. _____

B. ELECTRICAL CHARACTERISTICS

Use Group - Present *R-5* Proposed *R-5*

☐ Pole/Pad # _____ ☐ Temporary ☐ Other _____

Building Occupied as _____ Utility Co. _____

Estimated Cost of Electrical Work \$ *1,500*

JOB SUMMARY (Office Use Only)

PLAN REVIEW

☐ No Plans Required

Joint Plan Review Required:

☐ Bldg ☐ Plumb

☐ Fire ☐ Elevator

☒ Elect Plans Approved

Date: *11/26/03* *over PAR RW 1st Floor 11/16/03 over*

Approved By: *WM*

SUBCODE APPROVAL

☐ CO ☒ CCO ☒ CA

Date: *10/26/07*

Approved By: *WM*

INSPECTIONS Dates (Month/Day)

Type Failure Failure Approval Initial

Rough *PAR RW 11/16/03 over*

Temp Serv _____

Const Serv _____

TCO _____

Service _____

Final *2207* *10/26/07* *to*

Temp. Cut-in-Card Date Issued _____

Final Cut-in-Card Date Issued _____

D. TECHNICAL SITE DATA

NO.	SIZE	ITEM	FEE (Office Use Only)
8		Lighting Fixtures	
20		Receptacles	
11		Switches	
4		Detectors	
0		Light Poles	
0		Motors-Fract HP	
0		Emergency & Exit Lights	
0		Communications Points	
0		Alarm Devices/F.A.C. Panel	
43		TOTAL NUMBERS	40
0		Pool Permit/with UW Lights	0
0		Storable Pool/Spa/Hot Tub	0
0	0	KW Elect Range/Receptacle	0
0	0	KW Oven/Surface Unit	0
0	0	KW Elect Water Heater	0
0	0	KW Elect Dryer/Receptacle	0
0	0	KW Dishwasher	0
0	0	HP Garbage Disposal	0
1	7	KW Central A/C Unit	0
0	0	HP/KW Space Heater/Air Handler	0
0	0	Baseboard Heat	0
0	0	HP Motors 1/+ HP	0
0	0	KW Transformer/Generator	0
0	0	AMP Service	0
0	0	AMP Subpanels	0
0	0	AMP Motor Control Center	0
0	0	KW Elect Sign/Outline Light	0
0	0	Other	0
0	0	Other	0

Administrative Surcharge \$ _____

Paid ☐ Check # _____ Minimum Fee \$ _____

Collected by: _____ TOTAL FEE \$ *49*

DCA State Permit Fee \$ _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature

☐ Licensed Electrical Contractor ☐ Exempt Applicant

OK

102607

2-2-07

UP DATE Permit AIR handler, sub panel
mixed Breakers to sub panel
with SPAC near stair way means Reconnect
owner to Sheetrock about panel

COVERS

②

Fill in Bar All work + covers

OK

①

1st Floor (Additional work) RW
11/04 SEVERE WIND WORK DUE TO
WEATHER MODIFICATIONS REQUESTED

INSPECTOR

CANCELLED

9-10-04

RETRY

③

Fill in Bar 1st Floor with

②

Fill in Bar work, covers

4/10 2nd + 3rd Floor RW OK

**13 SEER HIGH EFFICIENCY
SUPER QUIET
SPLIT SYSTEM
AIR CONDITIONING
2 THRU 5 TON**
[7.00 to 17.56kw]

**BEST
VALUE**



\$400.00 second through fifth year compressor labor allowance for only \$20.00 with received registration. Ask your dealer for details!

Description / Application

- CLT outdoor condensing section designed for ground level or rooftop mounting application.

Designed to be matched with:

- AR & AER indoor section is a versatile up, horizontal, or counterflow air handler. These units may be located in closet, utility room, attic or basement
- AW & AWB vertical wall mounted air handler is designed for installation with a water heater or recessed in a wall.
- U, UC, H, HT fan-less indoor coils designed to fit our gas furnaces for add-on heat pump or cooling applications.
- AC, Ceiling Mounted Air Handler.

Accessories

- Standard room thermostat with 1-stage cool – 1-stage heat, Model CHT18-60.
- Digital room thermostat with 1-stage cool – 1-stage heat, Model CHTD18-60.
- Outdoor thermostats for stage – multi-stage indoor heating units, OT18-60.

**Standard Equipment Features
For Super Quiet Operation**

- Attractive, two-piece louvered guard protects coil from damage and strengthens the unit.
- Vertical discharge, four bladed condenser fan and top grille guard provides quiet operation.
- Totally enclosed and permanently lubricated PSC 8 pole (840 RPM) condenser motor for quiet, efficient operation.
- Hermetically sealed compressor with internal pressure relief valve.
- Latest technology compressor sound blanket.
- Copper tube, aluminum finned coil construction.
- Brass suction and liquid shut off valve with sweat connections.
- Fully charged for 15' [4.57m] feet of tubing length.
- High capacity large diameter liquid line filter drier, factory installed.

Cabinet Construction Features

- New polyester powder paint provides premium durability and improved UV protection.
- Heavy gauge, zinc-clad, G90 galvanized steel.
- Bottom pan rails elevating unit above slab.

Made in the USA by:

Goodman Manufacturing Company, L.P.

GMC-338

2550 North Loop West, Suite 400 - Houston, Texas 77092


www.gmcproducts.com

CLT SERIES 10/01

Physical Data

Model	Liquid Connection	Suction Connection	Type	Approx. Shipping Weight
CLT24-1	3/8 [9.5mm]	3/4 [19mm]	Sweat	173 [78.5kg]
CLT30-1	3/8 [9.5mm]	3/4 [19mm]	Sweat	208 [94.3kg]
CLT36-1	3/8 [9.5mm]	7/8 [22.2mm]	Sweat	209 [94.8kg]
CLT42-1	3/8 [9.5mm]	7/8 [22.2mm]	Sweat	258 [117.0kg]
CLT48-1	3/8 [9.5mm]	7/8 [22.2mm]	Sweat	270 [122.5kg]
CLT60-1	3/8 [9.5mm]	7/8 [22.2mm]	Sweat	271 [122.9kg]

DIMENSIONAL DATA CLT24-60 MODELS



Electrical Data

Model	Volts	PH	+Minimum Circuit Ampacity	*Maximum Overcurrent Protection	Maximum Volts	Minimum Volts	Compressor		Cond. Fan	
							RLA	LRA	FLA	HP
CLT24-1	208/230	1	11.5	20	253	197	8.5	48	0.9	1/6
CLT30-1	208/230	1	14.5	20	253	197	10.9	59	0.9	1/6
CLT36-1	208/230	1	20.1	30	253	197	14.8	74	1.6	1/4
CLT42-1	208/230	1	21.6	30	253	197	16.0	90	1.6	1/4
CLT48-1	208/230	1	24.1	40	253	197	18.0	87	1.6	1/4
CLT60-1	208/230	1	26.5	50	253	197	19.9	137	1.6	1/4

*May use fuses or HACR type Circuit Breakers of the same size as noted.

+Wire size should be determined in accordance with National Electrical Codes. Extensive wire runs will require larger wire sizes.

Performance Ratings

Condenser Model	Evaporator Model	Total BTUH [Kw]		Sensible BTUH [Kw]		(1) SEER	(2) EER	SRN/ BELS
CLT24-1	AR24-1/AC24-XX/AW24-XX	21000	[6.1]	15500	[4.5]	12.00	11.00	7.4
	AWB24-XX	22000	[6.4]	16500	[4.8]	12.00	11.00	
	HT1830/U29/UC29/H24F+EEP	21000	[6.1]	15500	[4.5]	12.00	11.00	
	U31+EEP	22000	[6.4]	16500	[4.8]	13.00	11.80	
	HT3236/U32/UC32/H36F+EEP	22000	[6.4]	16500	[4.8]	13.00	11.80	
	AWB36-XX/AR32-1	22000	[6.4]	16500	[4.8]	13.00	11.80	
	HT4248/U42/UC42/H49F+EEP	22400	[6.6]	16800	[4.9]	13.00	11.80	
	AER24-1/AE24-XX	22400	[6.6]	16800	[4.9]	14.00	13.00	
	H36F+GMPE075-3	22000	[6.4]	16500	[4.8]	14.00	13.00	
	U32/UC32+GMPE075-3	22000	[6.4]	16500	[4.8]	14.00	13.00	
	HT3236+GMPE075-3	22000	[6.4]	16500	[4.8]	14.00	13.00	
	U42/UC42+GMPE075-3	22400	[6.6]	16800	[4.9]	14.00	13.00	
	H49F+GMPE075-3	22400	[6.4]	16800	[4.9]	14.00	13.00	
	HT4248+GMPE075-3	22400	[6.4]	16800	[4.9]	14.00	13.00	
CLT30-1	AWB30-XX/AR30-1/AW30-XX	25600	[7.5]	18000	[5.3]	12.00	11.00	7.4
	AC30-XX	26000	[7.6]	19250	[5.6]	12.60	11.50	
	AWB36-XX/AR36-1	26000	[7.6]	18400	[5.4]	12.50	11.50	
	HT3236/U32/UC32/H36F+EEP	26600	[7.8]	20100	[5.9]	13.00	11.80	
	AR32-1	26600	[7.8]	20100	[5.9]	13.00	11.80	
	HT4248/U42/UC42/H49F+EEP	27000	[7.9]	20250	[5.9]	13.00	11.80	
	AER36-1/AE36-XX	28000	[8.1]	21000	[6.1]	14.00	13.00	
	U42/UC42+GMPE075-3	27000	[7.9]	20250	[5.9]	14.00	13.00	
	H49F+GMPE075-3	27000	[7.9]	20250	[5.9]	14.00	13.00	
	HT4248+GMPE075-3	27000	[7.9]	20250	[5.9]	14.00	13.00	
CLT36-1	AC36-XX	33800	[9.9]	25000	[7.3]	12.00	11.00	7.4
	U36/UC36+EEP	34000	[10.0]	23800	[7.0]	12.00	11.00	
	AWB36-XX/AR36-1	34000	[10.0]	23800	[7.0]	12.00	11.00	
	AR42-1	35000	[10.2]	24800	[7.3]	12.50	11.40	
	HT4248+EEP	33800	[9.9]	23600	[6.9]	12.50	11.40	
	U42/UC42/H49F+EEP	35000	[10.2]	24800	[7.3]	12.50	11.40	
	U47/UC47+EEP	36000	[10.5]	26200	[7.7]	13.00	11.80	
	AR48-1	36000	[10.5]	26200	[7.7]	13.00	11.80	
	HT4860/U49/UC49/H60F+EEP	36000	[10.5]	26200	[7.7]	13.00	11.80	
	AER36-1/AE36-XX	36000	[10.5]	26000	[7.6]	14.00	13.00	
	U49/UC49+GMPE075-3	36000	[10.5]	26000	[7.6]	13.50	12.50	
	H60F+GMPE075-3	36000	[10.5]	26000	[7.6]	13.50	12.50	
	HT4860+GMPE075-3	36000	[10.5]	26000	[7.6]	13.50	12.50	
	U49/UC49+GMPE100-4	36000	[10.5]	26000	[7.6]	14.00	13.00	
	H60F+GMPE-4	36000	[10.5]	26000	[7.6]	14.00	13.00	
	HT4860+GMPE100-4	36000	[10.5]	26000	[7.6]	14.00	13.00	
	U49/UC49+GMPE125-5	36000	[10.5]	26000	[7.6]	14.00	13.00	
	H60F+GMPE125-5	36000	[10.5]	26000	[7.6]	14.00	13.00	
	HT4860+GMPE125-5	36000	[10.5]	26000	[7.6]	14.00	13.00	
 CLT42-1	HT4248/U42/UC42/H49F+EEP	39000	[11.4]	28000	[8.2]	12.00	11.00	7.6
	AR42-1	39000	[11.4]	28000	[8.2]	12.00	11.00	
	AR48-1	40000	[11.7]	29000	[8.5]	12.50	11.50	
	HT4860/U60/UC60/H60F+EEP	40000	[11.7]	29000	[8.5]	12.50	11.50	
	AR49-1	41000	[12.0]	30000	[8.8]	13.00	11.80	
	HT61/U61/UC61/H61F+EEP	41000	[12.0]	30000	[8.8]	13.00	11.80	
	U62/UC62+EEP	41000	[12.0]	30000	[8.8]	13.00	11.80	
	AER48-1/AE48-XX	41000	[12.0]	30000	[8.8]	14.00	13.00	
	U61/UC61+GMPE100-4	41000	[12.0]	30000	[8.8]	14.00	13.00	
	U62/UC62+GMPE100-4	41000	[12.0]	30000	[8.8]	14.00	13.00	
	H61F+GMPE100-4	41000	[12.0]	30000	[8.8]	14.00	13.00	
	HT61+GMPE100-4	41000	[12.0]	30000	[8.8]	14.00	13.00	
	U61/UC61+GMPE125-5	41000	[12.0]	30000	[8.8]	14.00	13.00	
	H61F+GMPE125-5	41000	[12.0]	30000	[8.8]	14.00	13.00	
	HT61+GMPE125-5	41000	[12.0]	30000	[8.8]	14.00	13.00	

Performance Ratings Cont.

Condenser Model	Evaporator Model	Total BTUH [Kw]		Sensible BTUH [Kw]		(1) SEER	(2) EER	SRN/ BELS
CLT48-1	U49/UC49/H49F+EEP	43000	[12.6]	31000	[9.0]	12.50	11.50	7.6
	AR48-1	43500	[12.7]	32000	[9.4]	12.50	11.50	
	AR49-1	44000	[12.9]	33000	[9.7]	13.00	11.80	
	HT4860/U60/UC60/H60F+EEP	44000	[12.9]	33000	[9.7]	12.50	11.50	
	AER48-1/AE48-XX	44500	[13.0]	33200	[9.7]	13.50	12.50	
	U62/UC62+EEP	44500	[13.0]	33400	[9.8]	13.00	11.80	
	HT61/U61/UC61/H61F+EEP	45000	[13.2]	33700	[9.9]	13.00	11.80	
	U61/UC61+GMPE100-4	45000	[13.2]	33700	[9.9]	13.50	12.50	
	H61F+GMPE100-4	45000	[13.2]	33700	[9.9]	13.50	12.50	
	HT61+GMPE100-4	45000	[13.2]	33700	[9.9]	13.50	12.50	
	U61/UC61+GMPE125-5	45000	[13.2]	33700	[9.9]	13.50	12.50	
	H61F+GMPE125-5	45000	[13.2]	33700	[9.9]	13.50	12.50	
	HT61+GMPE125-5	45000	[13.2]	33700	[9.9]	13.50	12.50	
CLT60-1	U62/UC62+EEP	52000	[15.2]	39700	[11.6]	12.50	11.50	7.6
	AR60-1	52000	[15.2]	39700	[11.6]	12.00	11.00	
	HT61/U61/UC61/H61F+EEP	52000	[15.2]	39700	[11.6]	13.00	11.80	
	AR61-1	53000	[15.5]	40200	[11.8]	12.50	11.50	
	AER60-1/AE60-XX	53000	[15.5]	40200	[11.8]	13.00	12.00	
	U61/UC61+GMPE125-5	53000	[15.5]	40200	[11.8]	13.00	12.00	
	U62/UC62+GMPE125-5	53000	[15.5]	40200	[11.8]	13.00	12.00	
	H61F+GMPE125-5	53000	[15.5]	40200	[11.8]	13.00	12.00	
	HT61+GMPE125-5	53000	[15.5]	40200	[11.8]	13.00	12.00	

- 1) Seasonal Energy Efficiency Ratio
- 2) Energy Efficiency Ratio @ 80°F/67°F Inside - 95°F
- 3) When matching the outdoor unit to the indoor unit, use the piston supplied with the outdoor unit or that specified on the piston kit chart supplied with the indoor unit.
- 4) Note: XX Of A Model Designate Electric Heat Quantity.
- 5) EEP - Order From Service Dept. Part No. B13707-38. The Goodman Gas Furnace contains the EEP cooling time delay.

NOTE: SPECIFICATIONS AND PERFORMANCE DATA LISTED HEREIN ARE SUBJECT TO CHANGE WITHOUT NOTICE.

Quality Makes the Difference!

All of our systems are designed and manufactured with the same high quality standards regardless of size or efficiency. Our designs virtually eliminate the most frequent causes of product failure. They are simple to service and forgiving to operate. We use the highest quality materials and components available because if a part fails then the unit fails. Finally, every unit is run tested before it leaves the factory. That's why we know...

There's No Better Quality.

Visit our web site at www.gmcproducts.com for information on:

- GMC products
- Warranties
- Customer services
- Parts
- Contractor programs and training
- Financing options