



City of Plainfield
515 Watchung Ave
Plainfield, NJ 07060
Phone: (908) 753-3386

Page 1 of 1

Division of Inspections

NOTICE OF CODE VIOLATIONS

Name: CYCLONE WEST 84 LLC Block: 762 Lot: 3 Qual:
Address: 37 STEWART ST
HEWLETT, NY 11557 Site Address: 501-15 W 7TH ST
PLAINFIELD, NJ
Phone:

Reference: 2022-002056 Notice Date: September 15, 2022
Violation: 2022-01575

Pleased be advised that a recent inspection of the above premises revealed violations. Listed below are the code violations that were found on this property. Enclosed please find the inspection report for your review.

Please abate/correct those violations on or before the Comply By Date listed below. If violations are abated/corrected within the compliance time period, you may contact the City of Plainfield to make an appointment for re-inspection.

Please contact the Division of Inspections at (908) 753-3386 to determine whether a permit is required to correct any of the violations found in the report.

Thank you for your kind and considerate attention to this matter.

VIOLATION LISTINGS				Number of Violations Listed: 3
Violation Number	Violation Date	Comply By Date	Corrected or Closed On Date	Violation
001	9/15/2022	9/25/2022		<u>2.11 WALLS AND CEILINGS</u> Floors, walls, including windows and doors, ceilings, and other interior surfaces shall be maintained in good, clean, and sanitary condition. Peeling paint, cracked or loose plaster, decayed wood, and other defective surface conditions shall be eliminated. Infraction: INTERIOR- APARTMENT 205 (WALLS AND CEILINGS) Correction: REPAIR/REPLACE ALL DAMAGED WALLS AND CEILINGS THROUGHOUT APARTMENT 205
002	9/15/2022	9/25/2022		<u>2.07 SANITATION AND SAFETY</u> All parts of the structure shall be kept in a clean and sanitary condition, free of nuisance, and free from health, safety, and fire hazards. Infraction: APARTMENT 205 BATHROOM Correction: REGLAZE TUB (ELIMINATING RUST)
003	9/15/2022	9/25/2022		<u>2.07 SANITATION AND SAFETY</u> All parts of the structure shall be kept in a clean and sanitary condition, free of nuisance, and free from health, safety, and fire hazards. Infraction: APARTMENT 205 BATHROOM Correction: RECAULK MOLDING AROUND TUB

Matthew Dillingham, Code Enforment Officer
E-MAIL: xxxxxxxx.xxxxxxxxxxxx@xxxxxxxxxxxxx.xxx