

VIOLATIONS

Premises: AMK - USA Inc.
131 W. Commercial Avenue

Moonachie, New Jersey 07074

Registration No. 0237-46300-002-01
Inspection Date: February 26, 2019
Initial Inspector: _____
Print Name: Fred Dressel IV
Page number: 1

Inspector/Agent: Anand Shukla
131 W. Commercial Avenue
Moonachie N.J. 07074

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 2 Retrofit: 1)	Abate by	U/A	U/A	U/A
1.	Location: Building Nature: Sprinkler system annual semiannual and quarterly test required, Code Section: N.J.A.C. 5:70-3,901.6	12/19/2018			
2.	Location: Building Nature: Fire alarm annual test required Code Section: N.J.A.C. 5:70-3,907.6	12/19/2018			
3.	Location: Entire premises Nature: Carbon Monoxide detection required Code Section: N.J.A.C. 5:70-4.9(d)	12/19/2018			
4.	Location: Warehouse Nature: Idle pallets: arranged stacks of 4 with 8' of clear space or 25' of product Code Section: NFPA 13 chapter 12.12.3.1	12/19/2018			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.