

Collingswood School District - November 2024

Senior High	Square Feet	Age	Type	Ply	Condition	Install
Academic Wing	18,400	20	SBS Modified	3	Fair	2004
Science Wing	14,800	5	SBS Modified	3	Good	2019
Café	6,000	13	SBS Modified	3	Good	2011
Main Gym	11,200	32	Hypalon	1	Fair	1992
Gym Class Rooms	5,200	13	SBS Modified	3	Good	2011
Weight Room	3,400	17	SBS Modified	3	Good	2007
Training Room	900	17	SBS Modified	3	Good	2007
Coursen Building	4,600	8	Shingle	1	Good	2016
Coursen Stairwells	600	38	Rubber	1	Bad	1986
HazMat Building	1,600	36	Metal	1	Fair	1988
Elevator/Mechanical	350	New	SBS Modified	3	New	2024
Maintenance Office		20	Metal		Fair	2000

Total 67,050

Middle School

Main Roof	21,000	21	SBS Modified	3	Fair	2003
Office	1,200	21	SBS Modified	3	Fair	2003
Attic	1,000	21	Shingle	1	Fair	2003
Ben Mark Gym	13,700	12	SBS Modified	3	Good	2012

Total 36,900

Zane North

New Building	4,600	20	SBS Modified	3	Fair	2004
Office/Halls	5,400	8	SBS Modified	2	Good	2016
Classrooms 107-111	6,500	8	SBS Modified	2	Good	2016
Classrooms Kindergarten	300	20	SBS Modified	3	Fair	2004
AP Room	500	20	SBS Modified	3	Fair	2004
Board Office Entrance	250	20	SBS Modified	3	Fair	2004
Classrooms 123-125	3,000	8	SBS Modified	2	Good	2016

Total 20,550

Tatem

New Building	6,600	7	Hypalon	2	Good	2013
Old Building	10,200	35	SBS Modified	3		1989

Total 16,800

Garfield

Main Roof	<u>4,700</u>	24	Rubber	1	Fair	2000
-----------	--------------	----	--------	---	------	------

Newbie

Old Building	4,300	35	Shingle	1	Poor	1989
New Building	8,600	26	EPDM	1	Poor	1998

Total	<u>12,900</u>					
-------	---------------	--	--	--	--	--

Sharp

Old Building	7,500	15	SBS Modified	3	Good	2009
New Building	3,300	15	SBS Modified	3	Good	2009

Total	<u>10,800</u>					
-------	---------------	--	--	--	--	--