

VIOLATIONS

Premises: OTT'S BAR & Bottle Stop
656 STOKES ROAD

MEDFORD, NEW JERSEY 08055

Registration No. 032041890
Inspection Date: December 23, 2021
Initial Inspector: _____
Print Name: Brian Widmann
Page number: 1

Owner/Agent:

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 0 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: General Nature: Fire alarm annual test required Code Section: N.J.A.C. 5:70-3,907.8.2	ABATED			
2.	Location: Kitchen Nature: Cooking suppression system requires 6 month inspection (wet system) Code Section: N.J.A.C. 5:70-3,904.5	ABATED			
3.	Location: General Nature: Exit and Emergency lighting shall work in D/C, provide letter stating all are operational. Code Section: N.J.A.C. 5:70-3,604.4.1.1	ABATED			
4.	Location: Service Island(s) Nature: Fire extinguisher shall be inspected Code Section: N.J.A.C. 5:70-3,906.2	ABATED			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.



Medford Township

Department of Fire & EMS

1 Firehouse Lane, Medford, NJ 08055-2432

Tel. (609) 953-3291 Fax (609) 654-1069

EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: OTT'S BAR & Bottle Stop
656 STOKES ROAD
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

December 1, 2023

Expires

032041890

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date



**Medford Township
Department of Fire & EMS**

1 Firehouse Lane, Medford, NJ 08055-2432
Tel. (609) 953-3291 Fax (609) 654-1069
EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: OTT'S BAR & Bottle Stop
656 STOKES ROAD
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

October 9, 2024

Expires

032041890

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date

VIOLATIONS

Premises: OTT'S BAR & Bottle Stop
656 STOKES ROAD
MEDFORD, NEW JERSEY 08055

Registration No. 032041890
Inspection Date: February 28, 2025
Initial Inspector: _____
Print Name: Brian Widmann
Page number: 1

Owner/Agent:

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 0 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Ott's and Bottle Stop Nature: Fire Extinguishers - Outdated or discharged Code Section: N.J.A.C. 5:70-3,906.2	ABATED			
2.	Location: building Nature: Fire protection-Test on fire alarm Code Section: N.J.A.C. 5:70-3,907.8	ABATED			
3.	Location: Kitchen Nature: Cooking Areas - Wet chemical - 6 mo. Inspection Code Section: N.J.A.C. 5:70-3,904.5.1	ABATED			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.

VIOLATIONS

Premises: OTT'S BAR & Bottle Stop
656 STOKES ROAD
MEDFORD, NEW JERSEY 08055

Registration No. 032041890
Inspection Date: June 6, 2025
Initial Inspector: _____
Print Name: Brian Widmann
Page number: 1

Owner/Agent:

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 2 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Trouble alarm for dialer Nature: Fire Protection System - Maintenance Code Section: N.J.A.C. 5:70-3,901.6.1	07/06/2025			
2.	Location: Room next to alarm panel detector hanging Nature: Fire protection - Maintenance on smoke detectors Code Section: N.J.A.C. 5:70-3,907.8.1	07/06/2025			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.



Medford Township

Department of Fire & EMS

1 Firehouse Lane, Medford, NJ 08055-2432

Tel. (609) 953-3291 Fax (609) 654-1069

EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: ALENCO FENCE & LUMBER CORP.
167-B ROUTE 70
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

November 5, 2021

Expires

032066761

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date



Medford Township
Department of Fire & EMS
1 Firehouse Lane, Medford, NJ 08055-2432
Tel. (609) 953-3291 Fax (609) 654-1069
EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: ALENCO FENCE & LUMBER CORP.
167-B ROUTE 70
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

September 24, 2022

Expires

032066761

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date



Medford Township
Department of Fire & EMS
1 Firehouse Lane, Medford, NJ 08055-2432
Tel. (609) 953-3291 Fax (609) 654-1069
EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: ALENCO FENCE & LUMBER CORP.
167-B ROUTE 70
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

August 29, 2024

Expires

032066761

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date



Medford Township

Department of Fire & EMS

1 Firehouse Lane, Medford, NJ 08055-2432

Tel. (609) 953-3291 Fax (609) 654-1069

EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To:

ALENCO FENCE & LUMBER CORP.
167-B ROUTE 70
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

October 1, 2025

Expires

032066761

Registration No.

Brian D. Widmann

Brian Widmann, Fire Official

06/06/2025

Date



Medford Township

Department of Fire & EMS

1 Firehouse Lane, Medford, NJ 08055-2432

Tel. (609) 953-3291 Fax (609) 654-1069

EMERGENCY 9-1-1



Registration No.: 320-076166
Municipality: Medford
County: Burlington County
Inspector: Cliff Rickards
Inspected: February 6, 2025
Page: 1

To: Anytime Fitness
200 TUCKERTON ROAD STORE 26
VILLAGE OF TAUNTON FORGE
MEDFORD, NEW JERSEY 08055

NOTICE OF VIOLATIONS and ORDER TO CORRECT

Premises: Anytime Fitness
Address: 200 TUCKERTON ROAD STORE 26, VILLAGE OF TAUNTON FORGE
MEDFORD, NEW JERSEY 08055
Phone: _____ Type of use: Fitness Center
Block/Lot: 3201-32.02

	<u>BUILDING OWNER</u>	<u>AGENT</u>	<u>TENANT/OPERATOR</u>
Name:	JOSEPH DE PETRIS		
Address:	LEGEND PROPERTIES, INC 521 PLYMOUTH RD, SUITE 118 PLYMOUTH MEETING, PA 19462		
Phone:	856-912-1165		

YOU ARE HEREBY NOTIFIED THAT an inspection by the Township of Medford Division of Fire disclosed violations of the Uniform Fire Code (N.J.A.C. 5:70-1 et. seq.), promulgated pursuant to the New Jersey Uniform Fire Safety Act (N.J.S.A. 52:27D-192 et. seq.). The violations are specified on the accompanying "Violations Report" page(s).

YOU ARE HEREBY ORDERED by the FIRE OFFICIAL to correct the violations listed on the accompanying "Violations Report" page(s) within the time, or by the date specified. If a reinspection discloses that violations have not been corrected, and an extension has NOT been requested and granted, you will be subject to penalties of up to \$5,000 per violation per day, or as otherwise authorized by the Act and Division Regulations.

IN ADDITION, the ACT imposes liability on the owner for the actual costs of fire suppression where a violation directly or indirectly results in fire.

If you do not understand this order, need assistance, or desire further information about this order, please call the Department of Fire & EMS at (609) 953-3291.

BY ORDER OF THE FIRE OFFICIAL

Fire Official

APPEAL RIGHTS-EXTENSIONS

See the attached page of information concerning your administrative appeal rights, authorized penalties and the procedure for requesting an extension of time in which to correct violations.

Signature of Owner or Representative

Printed Name of Owner or Representative

Date

VIOLATIONS

Premises: Anytime Fitness
200 TUCKERTON ROAD STORE 26
VILLAGE OF TAUNTON FORGE
MEDFORD, NEW JERSEY 08055

Registration No. 320-076166
Inspection Date: February 6, 2025
Initial Inspector:
Print Name: Cliff Rickards
Page number: 2

Owner/Agent:

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 0 Retrofit: 0)	Abate by	U/A	U/A	U/A
-	NO APPARENT VIOLATIONS AT THIS TIME N/A				

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.



Medford Township
Department of Fire & EMS
1 Firehouse Lane, Medford, NJ 08055-2432
Tel. (609) 953-3291 Fax (609) 654-1069
EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: Old Nelson Food Company
617 STOKES ROAD PINELAND'S PLAZA
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

November 10, 2024	0976		06/06/2025
Expires	Registration No.	Brian D. Widmann	Date
		Brian Widmann, Fire Official	



Medford Township
Department of Fire & EMS
1 Firehouse Lane, Medford, NJ 08055-2432
Tel. (609) 953-3291 Fax (609) 654-1069
EMERGENCY 9-1-1



CERTIFICATE OF INSPECTION

Issued To: Old Nelson Food Company
617 STOKES ROAD PINELAND'S PLAZA
MEDFORD, NEW JERSEY 08055

This certifies that the referenced property has been inspected pursuant to the Uniform Fire Safety Act and satisfies minimum requirements of the New Jersey Uniform Fire Code.

This certificate must be posted in a conspicuous location in the above premises.

November 16, 2024	0976		06/06/2025
Expires	Registration No.	Brian D. Widmann	Date
		Brian Widmann, Fire Official	