



Summit Fire Department

Station: **HQ**
Shifts Or Platoon: **C**

Location:
32 WALNUT ST
SUMMIT NJ 07901

Lat/Long:
N 40° 42' 50.02"
W 74° 21' 21.7"

Zone:
E - East
Location Type: **1 - Street address**

Incident Type:
116 - Fuel burner/boiler
malfunction, fire confined

FDID: **20018**
Incident #: **2021-02040**
Exposure ID: **62380404**
Exposure #: **0**
Incident Date: **11/17/2021**
Dispatch Run #: **F213210018**

Report Completed by: EVERS, CLINT **ID:** 2838 **Date:** 11/17/2021

Report Reviewed by: EVERS, ERIC **ID:** 2649 **Date:** 12/07/2021

Report Printed by: Thomas-Pierce, Sharlynn **ID:** **Date:** 12/15/2021 **Time:** 14:47

Structure Type: Property Use: **429 - Multifamily dwelling**

Automatic Extinguishment System Present: ☐ Detectors Present: ☐ Cause of Ignition: **Failure of equipment or heat source**

Aid Given or Received: **None** Primary action taken: **86 - Investigate**

Additional actions: **82 - Notify other agencies, -**

Losses	Pre-Incident Values		
Property:	Property:	Civilian Injuries: 0	Fire Service Injuries: 0
Contents:	Contents:	Civilian Fatalities: 0	Fire Service Fatalities: 0
Total:	Total:	Total Casualties: 0	Total Fire Service Casualties: 0

Total # of apparatus on call: **3** Total # of personnel on call: **5**

Special Studies

COVID 19 was a factor in this incident. Unknown.

NARRATIVE (2)

Narrative Title: n/a

Narrative Author: EVERS, CLINT

Narrative Date: 11/17/2021 22:29:24

Narrative Apparatus ID: n/a

Narrative:

Responded on a report of a building fire caller saw flames in the basement. Arrived on scene and observed nothing showing. Proceeded to the rear of the structure and saw Bilco doors leading to the basement. FD personnel went to the basement and found a malfunctioning furnace. Gas and electric to the unit was secured and PSE&G was notified to respond. The structure was metered for carbon monoxide and found elevated readings. FD personnel ventilated the structure. PSE&G arrived and released the FD, command was terminated.

Member Making Report (BC CLINT EVERS): _____

Incident Reviewer (CH ERIC EVERS): _____