

Incident Report

Incident Number
260002660

Dispatch - Call Created Date/Time
06/05/2026 07:51:33

Officer in Charge
--

Dispatch - Call Answered Date/Time
06/05/2026 07:51:33

Command Established Date/Time

Dispatch - Call Arrival Date/Time
06/05/2026 07:51:33

Incident Types
Fire - Structure Fire - Structural Involvement, Fire -
Structure Fire - Confined Cooking / Appliance Fire

Exposure Type

Exposure Item

Incident Address
8 PROGRESS ST, EDISON TWP, NJ, 08817

County
--

Fire Zone
--

Property Type
Warehouse. Includes all general storage facilities.
Excludes refrigerated storage (839).

Property Status
In normal use

Dispatch Information

Alarm Date/Time 06/05/2026 07:51:33

Notification Type 911 Call

Number of Alarms 1

Incident Location Information

Total Acres Burned	0.0	Structure Type	Enclosed building
Property Status	In normal use	Construction Type	Type II - Noncombustible
Monitored Alarm	Yes	Location In Use	Yes
Primary Nature of Fire Incident	Structure Fire	Location used as intended	Yes

Products and Materials on Property

Type of Products or Materials on Property	Cereals, grains; packaged	Storage/use of Products or Materials on Property	Packaged goods for sale
--	---------------------------	---	-------------------------

Apparatus**Department Unit 1 of 2**

Apparatus Name	Car7	Dispatch Date/Time	06/05/2026 07:55:01
Type	--	Acknowledge Date/Time	--
# of Crewmembers	1	En Route Date/Time	06/05/2026 07:57:11
Use	Suppression	Arrive Date/Time	06/05/2026 07:59:47
ALS Support Capable	No	Clear Date/Time	06/05/2026 09:05:51
Location at Dispatch	Assigned station	Back in Service Date/Time	--
Crewmembers	Novia, Patrick	Apparatus Arrived Patient Date/Time	--
		Apparatus Transfer of Care Date/Time	--

Apparatus**Department Unit 2 of 2**

Apparatus Name	Engine12	Dispatch Date/Time	06/05/2026 07:55:01
Type	Engine	Acknowledge Date/Time	--
# of Crewmembers	0	En Route Date/Time	06/05/2026 07:56:52
Use	Suppression	Arrive Date/Time	06/05/2026 07:59:49
ALS Support Capable	No	Clear Date/Time	06/05/2026 09:05:51
Location at Dispatch	Assigned station	Back In Service Date/Time	--

Crewmembers

Apparatus Arrived Patient Date/Time	--
Apparatus Transfer of Care Date/Time	--

XXXXXXX XXXX

Person 1 of 1 - Demographic Information

Incident Involvement	Involved Person, Property Owner	Primary Phone	XXXXX XXXXXXXXX
Gender	XXXX		

Weather Information

Temperature	69.8 °F	Wind Speed	1 mph
Wind Direction	Northwest	Humidity	64%
Weather Type	Broken clouds, 6/10 to 9/10 cloud cover		

Fire Information

Extent of Fire Involvement on Arrival	No flame or smoke showing	# of Buildings Involved	1
Floor of Origin	1	# of Rooms Damaged	1
Amount of Flame Damage		Cause of Ignition	Cause undetermined after investigation
Heat Source	Undetermined	Fire Spread	Confined to room of origin
Item first Ignited	Appliance housing or casing	Type of Material	Plastic
Equipment Involved in Ignition	No	Vehicle Involved in Incident?	No
Suppression Appliance		Water Supply	None
Fire Extension	Fire Out Upon Arrival	Fire Damage	Minor (Limited Smoke / Fire / Water Damage, No Occupant Displacement)
Room of Origin	Kitchen	Investigation Need	No
Investigation Type Needed	Investigated by Formal Arson / Fire Investigator	Structure Cause of Ignition	Unable to be Determined

Hazardous Materials Information

HazMat Released	None
------------------------	------

Actions Taken**Department**

Command And Control - Establish Incident Command	Provide Services - Shut Down Sprinkler System
--	---

Narratives

Department Fire Incident Narrative

Engine 12 and car 7 were dispatched to the above address for a report of a broken sprinkler head. Upon arrival incident command was established followed by an investigation. Members found an appliance fire that was extinguished by the suppression system sometime during the night. The alarm systems failed to notify the fire department. Members secured the valves to the sprinkler system and awaited the arrival of the Fire Marshal. The scene was turned over to the Fire Marshal for further investigation. No further fire department actions were required and command was terminated.

Last update on 06/05/2026 at 23:11:31 by Patrick Novia

Narratives

Car7

Provided incident command

Last update on 06/05/2026 at 23:12:44 by Patrick Novia

Narratives

Engine12

Provided scene stabilization

Last update on 06/05/2026 at 23:13:43 by Patrick Novia

Fire Prevention

Presence of Detectors	Present	Detector Type	Other Chemical Detector
Smoke Alarm Operation	Failed to Operate	Presence of Smoke Alarm	Present
Fire Alarm Presence	Present	Fire Alarm Operation	Failed to Operate
Presence of Sprinkler System	Present	Sprinkler System Type	Dry-Pipe Sprinkler System
Fire Suppression Operation	Operated - Effective	Cooking Fire Suppression Presence	Not Applicable

Impediment Narratives

Alarm failure to notify fire department of an actual fire.

Last update on 06/04/2026 at 23:12:16 by Patrick Novia