

Elevator Inspection

Identification

Name: Hard Rock Hotel & Casino Date: **April 3, 2019** Type of Inspection/Test
 Address: 1000 Boardwalk BLDG.REG #: 0102-00159-001 FA: 3Yr: Alteration:
 City/State/Zip: Atlantic City N.J 08401 Elevator #: **S-16** 6Mo:XX 5Yr: **Passenger:X**
 Capacity: 4500 lbs STOPS: 42 1Yr: Re-inspection: Freight:
 If FA, Permit No.: **Traction: X** Rope\H: Hydro:
 Block #: 61 Lot #: 7 **5 Year. Test: 2020**
 Year Built: 1986 MFGR: Otis Orig. Code:1981 Mod. Year: Certification Expires: NO CERTIFICATION

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents				
2. Machine/Brake/Gears/Motor				
3. Hydro Power Motor Unit				
4. Motor Generator Set/SCR Drive				
5. Controller/Selector				
6. Governor(s)				
7. Relief & Check Valves				
8. Required Disconnects				
9. Oil/Hydro Fluid, Leaks, Level				
10. Hydro Fluid Hoses or Pipe				
11. Seals, Plates, Labels, Unit ID, Tags, Signs				
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring				
2. Guide Shoes/Rollers				
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)				
4. Car Gate or Door Operator				
5. Car Lighting/Standard & Emergency				
6. Rope Hitches/Platen Hitch				
7. Top-of-Car Operating Station/Stop Switch				
8. Car Operating Station/Stop Switch/Indicators				
9. Emergency Signals & Communication				
10. Emergency Exits/Top/Side				
11. Safeties & Accessories				
12. Seals, Plates, Labels, Unit ID, Tags, Signs				
13. Firefighter Service PHI & II				
14. Counterweight/Car & Counterweight Sheaves				
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure				
2. Door, Closers & Accessories				
3. Door Interlocks/Emergency Key/Access Keys				
4. Guide Rails: Main & Counterweight				
5. Switches and Cams				
6. Pit/Stop Switch/Light/Ladder				
7. Counterweight Guard				
8. Buffers: Spring or Oil				
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail				
10. Traveling Cable and Wiring				
11. Plunger, Cylinder and Gland				
12. Governor Rope Tension Sheave & Assembly				
13. Compensating Sheave or Chain				

14. Clearances and Runby				
15. Seals, Plates, Labels, Tags				
16. Hall Station/Hall Position Indicator (if required), Hall Lantern				
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates			X	
2. Balustrade/Handrails			X	
3. Shear Points Protection			X	
4. Emergency Stop Switches			X	
5. Steps, Rollers & Tracks			X	
6. Chains & Sprockets			X	
7. Safety Devices			X	
8. Kiosk/Wellway/Safety Zone			X	
9. Clearances			X	
10. Protection of Trusses & Machinery Space (Fire)			X	
11. Skirt & Steps Clearance			X	
12. Machinery Access Space & Lighting			X	
13. Escalator Brakes			X	
14. Machine/Brakes/Gears/Motor			X	
15. Starting & Switches			X	
16. Speed Governor			X	
17. Rolling Shutter Device			X	
18. Signs, Seals, Planks, Labels, Unit ID, Tags			X	
19. Step Lighting			X	
20. Required Disconnect			X	
21. Routine Maintenance			X	
22. Tests			X	
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number S-16				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)			X	
1. Car Registration Number			X	
2. Working Pressure			X	
3. Relief Pressure			X	
4. Capacity			X	
5. Tags			X	
F. APPLICABLE CODES	X			
A17.1-1981	X			
ACTION TAKEN				
1. Device Number S-16	X			
2. Recommended Type of Certification (Cyclical Inspections Only)				NO CERTIFICATION
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached.

Robert Quaile #8626

Inspector's Name (print) and License No.

Robert Quaile

Inspector's Signature

Sub Code's Signature

City of Atlantic City
LICENSE & INSPECTIONS
DIVISION OF CONSTRUCTION
ELEVATOR SAFETY UNIT

Notice of Violation and Order to Terminate

Date: April 3, 2019

Inspector: Robert Quaile

Owner Name: Hard Rock Hotel & Casino

Device Registration: 0102-00159-001

Owner Address: 1000 Boardwalk.

Atlantic City N.J. 08401

Project Location: Same

Name of Person, Contractor/Maintenance Co. Performing Tests: SCHINDLER ELEVATOR CO.

Be advised that during today's inspection/test, the following irregularities/nonconformances/violations were noted, and you are Required to ensure that they be corrected before:

Unit ID # S-16

☐

(X) The elevator device may be operated during repairs/corrections

() The elevator device is locked out until the repairs/corrections are satisfactorily completed, the device is re-inspected, and applicable certificate is received

Penalty Item	Repeat Item	ASME A17.1-1981	BOCA _____	NJAC 5:23-2009
		ELEVATOR NOT IN SERVICE< GENERATOR & CONTROLS REMOVED. AWAITING COMPLETE MODERNIZATION		

A penalty item indicates that a violation is in penalty. A repeat item indicates the amount of times a violation has been repeated. **FAILURE TO COMPLY WITH THIS ORDER WILL SUBJECT YOU TO A PENALTY OF \$500 to \$2000 PER VIOLATION.**

If you wish to contest the validity of the above action, you may request a hearing before the Construction Board of Appeals of the County of Atlantic, within 20 business days of the receipt of these orders. The Application to the Construction Board of Appeals may be used for this purpose. Your application for you appeal must be in writing, stating your name and address, the address of the violation, the specific reason for your appeal and the nature of the relief sought by you. Forward to Board of Appeals, 1333 Atlantic Ave. 8th floor, Atlantic City, NJ 08401

When work to abate the violations requires a construction permit, the owner is responsible for securing such a permit. Maintenance violation (Part 12) can be found in the newest adopted code.

If you have any questions concerning this matter, please call the Elevator Safety Unit at (609) 347-6126.

Our mailing address is:

City of Atlantic City, Division of Construction, Elevator Safety,
1301 Bacharach Blvd.
Atlantic City, NJ 08401

SIGNATURE OF SUBCODE OFFICIAL _____