

Elevator Inspection

Identification

Name: Hard Rock Hotel & Casino	Date 5/2/18	Type of Inspection\Test
Address: 1000 Boardwalk	Bldg Registration #: 0102-00159-001	FA: 3Yr: Alteration:
City/State/Zip: Atlantic City N.J	Elevator #: S-13	6Mo: XX 5Yr: Passenger: X
08401	Capacity: 4500 lbs Stops: 42	1Yr: Reinspection: Freight:
If FA, Permit No.:		Traction: X Rope\H: Hydro:
Block #: 61	Lot #: 7 5 Year. Test: 2020	Certification Expires: 5/2/19
Year Built: 1986	MFGR.: Otis Orig. Code: 1981	Cont. Mod. Year:

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT				S	U	NA	
1. Enclosure/Lighting/Vents	X						
2. Machine/Brake/Gears/Motor	X						
3. Hydro Power Motor Unit			X				
4. Motor Generator Set/SCR Drive	X						
5. Controller/Selector	X						
6. Governor(s)	X						
7. Relief & Check Valves			X				
8. Required Disconnects	X						
9. Oil/Hydro Fluid, Leaks, Level			X				
10. Hydro Fluid Hoses or Pipe			X				
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X						
12. Routine Maintenance							
13.							
B. ELEVATOR CAR AND COUNTERWEIGHT							
1. Car Enclosure/Platform/Sling/Flooring	X						
2. Guide Shoes/Rollers	X						
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X						
4. Car Gate or Door Operator	X						
5. Car Lighting/Standard & Emergency		X					Repair car emergency lights
6. Rope Hitches/Platen Hitch	X						
7. Top-of-Car Operating Station/Stop Switch	X						
8. Car Operating Station/Stop Switch/Indicators	X						
9. Emergency Signals & Communication		X					No alarm bell 4X
10. Emergency Exits/Top/Side	X						
11. Safeties & Accessories			X				
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X						
13. Firefighter Service PHI & II			X				
14. Counterweight/Car & Counterweight Sheaves	X						
15. Routine Maintenance							
16.							
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT							
1. Enclosure		X					Cleandown hatch
2. Door, Closers & Accessories	X						
3. Door Interlocks/Emergency Key/Access Keys	X						
4. Guide Rails: Main & Counterweight	X						
5. Switches and Cams	X						
6. Pit/Stop Switch/Light/Ladder		X					Clean pit
7. Counterweight Guard	X						
8. Buffers: Spring or Oil	X						
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X						
10. Traveling Cable and Wiring	X						
11. Plunger, Cylinder and Gland			X				
12. Governor Rope Tension Sheave & Assembly	X						
13. Compensating Sheave or Chain	X						

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates			X	
2. Balustrade/Handrails			X	
3. Shear Points Protection			X	
4. Emergency Stop Switches			X	
5. Steps, Rollers & Tracks			X	
6. Chains & Sprockets			X	
7. Safety Devices			X	
8. Kiosk/Wellway/Safety Zone			X	
9. Clearances			X	
10. Protection of Trusses & Machinery Space (Fire)			X	
11. Skirt & Steps Clearance			X	
12. Machinery Access Space & Lighting			X	
13. Escalator Brakes			X	
14. Machine/Brakes/Gears/Motor			X	
15. Starting & Switches			X	
16. Speed Governor			X	
17. Rolling Shutter Device			X	
18. Signs, Seals, Planks, Labels, Unit ID, Tags			X	
19. Step Lighting			X	
20. Required Disconnect			X	
21. Routine Maintenance			X	
22. Tests			X	
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)	X			
1. Device Number S-13	X			
2. Car Rated Speed 500	X			
3. Overspeed Switch 550	X			
4. Tripping Speed 610	X			
5. Capacity 4500	X			
HYDRO ELEVATOR DEVICES (Pass or Fail)			X	
1. Car Registration Number			X	
2. Working Pressure			X	
3. Relief Pressure			X	
4. Capacity			X	
5. Tags			X	
F. APPLICABLE CODES A17.1 1981	X			
ACTION TAKEN				
1. Device Number S-13	X			
2. Recommended Type of Certification (Cyclical Inspections Only)	X			TCC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached.

City of Atlantic City
LICENSE & INSPECTIONS
DIVISION OF CONSTRUCTION
ELEVATOR SAFETY UNIT

Notice of Violation and Order to Terminate

Date: 5/2/18

Inspector: Robert Guiliano

Building Registration # 0102-00159-001

Owner Name: Hard Rock Hotel & Casino

Owner Address: 1000 Boardwalk.

Atlantic City N.J. 08401

Project Location: Same

Name of Person, Contractor/Maintenance Co. Performing Tests: OTIS

Be advised that during today's inspection/test, the following irregularities/nonconformances/violations were noted, and you are Required to ensure that they be corrected before: 11/2/18

Unit ID # S-13



(X)The elevator device may be operated during repairs/corrections

()The elevator device is locked out until the repairs/corrections are satisfactorily completed, the device is reinspected, and applicable certificate is received

Penalty Item	Repeat Item	ASME A17.1-1981	BOCA _____	NJAC 5:23-2009
		B5: Repair car emergency lights. A17.1---Rule 204.7a(3)(a)		
	4X	B9: Emergency alarm bell is not working. Repair same. A17.1---Rule 211.1[a][1]		
		C6 Clean Pit and Cleandown Hatch		

****A PENALTY ITEM INDICATES THAT A VIOLATION IS IN PENALTY. A REPEAT ITEM INDICATES THE AMOUNT OF TIMES A VIOLATION HAS BEEN REPEATED. FAILURE TO COMPLY WITH THIS ORDER WILL SUBJECT YOU TO A PENALTY OF \$500 TO \$2000 PER VIOLATION.****

If you wish to contest the validity of the above action, you may request a hearing before the Construction Board of Appeals of the County of Atlantic, within 20 business days of the receipt of these orders. The Application to the Construction Board of Appeals may be used for this purpose. Your application for you appeal must be in writing, stating your name and address, the address of the violation, the specific reason for your appeal and the nature of the relief sought by you. Forward to Board of Appeals, 1333 Atlantic Ave. 8th floor, Atlantic City, NJ 08401

When work to abate the violations requires a construction permit, the owner is responsible for securing such a permit. Maintenance violation (Part 12) can be found in the newest adopted code.

If you have any questions concerning this matter, please call the Elevator Safety Unit at (609) 347-6126.

Our mailing address is:

City of Atlantic City, Division of Construction, Elevator Safety,
1301 Bacharach Blvd.
Atlantic City, NJ 08401

SIGNATURE OF SUBCODE OFFICIAL *Robert Guiliano*