



Ocean County Health Department
Daniel E. Regenye, MHA, Public Health Coordinator/Health Officer
175 Sunset Avenue, PO Box 2191 Toms River, NJ 08754
Telephone: (732) 341-9700 Fax: (732) 286-1495
E-Mail: xxxxxxxxxxxx@xxxx.xxx
www.ochd.org



Complaint Memorandum

Insp Date: 1/8/18 **Business ID:** 101152
Business: Carrabba's Italian Grill
990 Cedarbridge Ave.
Brick, NJ 08723

Inspection: OU000280
File Number: 13934
Phone: 7322623470
REHS: B-102062 George McCoy
Reason: 06. COMPLAINT
Results: Complete

Complaint Number: C-201801080834-OU

Time In / Time Out

Date	In	Out	Insp	Travel	Total	Mileage	Notes
01/09/18	08:00 AM	08:35 AM	0:35	0:00	0:35	0	
Total:			0:35	0:00	0:35	0	

Complaint Information

Type Food Complaint Date Received 01/08/18 Received By England, Lynn
Complaint Origin Public Date Assigned 01/08/18 Assigned Inspector McCoy, George
Establishment Municipality 1506 Brick Date Finalized _____
Location _____
Owner, Agent of Responsible Person _____

Complainant Information

Complainant Phone
Address City State Zip
Occupation Employer

Nature of Complaint: No running water in ladies room. No signs posted.

Complaint Investigation Narratives

Narrative Date 01/09/18 Narrative Author McCoy, George

1-8-18, I SPOKE WITH THE COMPLAINANT. [REDACTED] STATED THAT THERE WAS NO RUNNING WATER IN THE WOMENS REST ROOM .ALLEGEDLY FEMALE GUESTS AND STAFF WERE TOLD TO USE A SINK IN THE REAR OF THE KITCHEN TO WASH THEIR HANDS. I STATED THAT I WOULD BE ONSITE TODAY TO INVESTIGATE.

1-8-18, ONSITE . I MET WITH ANDREW GILL, SHIFT MANAGER HE STATED THAT CERTAIN PIPES HAD FROZEN TO TO THE EXTREME COLD. THESE PIPES ARE LOCATED AT THE END OF THE RUN SO ICE FROM OTHER AREAS HAD ACCUMULATED AT THE WOMENS ROOM FINAL SINK. PIPES HAVE BEEN THAWED AND SINKS HAVE BEEN LEFT RUNNING TO PREVENT FURTHER FREEZING. WE VISITED THE WOMENS ROOMS NEAR THE DINING AREA. THERE ARE TWO SINKS. BOTH SINKS CURRENTLY HAVE HOT RUNNING WATER. ALL TOILETS FLUSH. THE MENS ROOM IS SAT. EMPLOYEE REST ROOMS LOCATED IN THE REAR KITCHEN ARE WERE ALSO OBSERVED TO BE SAT. ALL SINKS HAVE HOT RUNNING WATER AND ALL TOILETS FLUSH.WE WERE JOINED BY ED BOND, [REDACTED], PARTNER. WE REVIEWED THE COMPLAINT. ALL ISSUES HAVE BEEN RESOLVED

1-9-18, I PHONED THE COMPLAINANT, CURRENTLY NOT AVAILABLE. I LEFT A MESSAGE INFORMING HER THAT ALL ISSUES HAVE BEEN RESOLVED, THERE IS CURRENTLY RUNNING WATER IN ALL REST ROOMS ETC. NO FURTHER CAUSE FOR ACTION AT THIS TIME BY THE OCHD.