

Complaint Memorandum

Insp Date: 11/22/2021 **Business ID:** 99875
Business: Mcdonald's #5475
 106 Chambersbridge Rd & Rt. 70
 Brick, NJ 08724

Inspection: OW001299
File Number: 2167
Phone: 7324774280
Inspector: B-102062 George McCoy
Reason: 06. COMPLAINT
Results: Complete

Complaint Number: C-202111221046-OW

Complaint Information

Type Food Complaint Date Received 11/22/21 Received By Rice, Cynthia

Complaint Origin Public Date Assigned 11/22/21 Assigned Inspector McCoy, George

Establishment Municipality _____ Date Finalized 11/29/21

Location _____

Owner, Agent of Responsible Person _____

Complainant Information

Complainant [REDACTED] Phone [REDACTED]
Address _____ City _____ State _____ Zip _____
Occupation _____ Employer _____

Nature of Complaint: Fryer fire.

Complaint Investigation Narratives

Narrative Date 11/29/21 Narrative Author McCoy, George

11-22-21, Onsite, I met with management. The store was voluntarily closed. We visited the deep fryer area. I observed dry chemical on the floor and fryer equipment. As per management a fire ball was created in the fryer area, a staff member had extinguished it. The ansul system did not deploy. I instructed management to have the area cleaned up and to contact the necessary parties to service the hood ansul system. Brick Fire Marshall Sansone was onsite and discussed his requirements for re opening. I furnished my contact info. for management to contact me once all issues were corrected. Offsite.

11-22-21, I received a call from the store owner stating that clean up and system checks had been completed..

11-22-21, Onsite, I met with the Brick Fire Marshall. and the store owner. Clean up was satisfactory and the hood service contractors were still onsite, and the hood system was satisfactory. The requirement for fire and the OCHD were met and the establishment was approved to reopen.

No further action at this time by the OCHD.