

Ronald G. Rios
County Commissioner Director

Shanti Narra
County Commissioner Deputy Director

Claribel A. Azcona-Barber
Charles Kenny
Leslie Koppel
Chanelle Scott McCullum
Charles E. Tomaro
County Commissioners



DEPARTMENT OF PUBLIC SAFETY & HEALTH
Bureau of the Fire Marshal

Shanti Narra
Chairperson,
Public Safety & Health

John A. Pulomena
County Administrator

Joseph W. Krisza
Department Head

Michael Gallagher
Fire Marshal

Re: OPRA Request# 129
150 Forest Glen Dr. Highland Park, NJ 08904

April 13, 2026

To Whom It May Concern:

We are in receipt of your Open Public Records Act request. The above property has open fire code violations. See attached for a list of said open fire code violations.

If we can be of any further assistance, please don't hesitate to contact us.
Eugene.Perelman@co.middlesex.nj.us or (732) 486-6121.

Cordially,

Yevgeny (Eugene) Perelman
Deputy Fire Marshal
Middlesex County Fire Marshal's Office

1001 Fire Academy Drive
Sayreville, NJ 08872
Phone Number: (732) 316-7171
Fax: (732) 721-7486
firemarshal@co.middlesex.nj.us
www.middlesexcountynj.gov



VIOLATIONS

Premises: FOREST GLEN APARTMENTS (MULTI-FAMILY DWELLING)
150 Forest Glen Dr

Highland Park, NJ 08904

Registration No. 1626
Inspection Date: October 4, 2023
Initial Inspector: _____
Print Name: Jennifer Awad
Page number: 1

Inspector/Agent:

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 8 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Premise Nature: Provide doc of the testing of the 110(Hardwired) Smoke detectors by a licensed electrician Code Section: N.J.A.C. 5:70-3, 907.11	11/30/2023			
2.	Location: Dryers Nature: Provide letter attesting to proper cleaning of dryer ducts and vents Code Section: N.J.A.C. 5:70-3,603.5.2	11/30/2023			
3.	Location: Apartments Nature: Provide letter atesting to testing Smoke/CO detectors and are under 10 years old. Code Section: N.J.A.C. 5:70-3, 907.11.2	11/30/2023			
4.	Location: 109, 65, 17, 15, 21 Nature: Remove all LP-Gas containers Code Section: N.J.A.C. 5:70-3,6109.7	11/30/2023			
5.	Location: 14,46,54,74,90,98,110,114,122 Nature: Maintenance of safeguards repair smoke detector Code Section: N.J.A.C. 5:70-3,104.1	11/30/2023			
6.	Location: 28,37,42,54,58,70 Nature: Remove any storage from under the stairs/hallway Code Section: N.J.A.C. 5:70-3, 102.1.1	11/30/2023			
7.	Location: Leasing Office Nature: Exit signs must be illuminated Code Section: N.J.A.C. 5:70-3,1013.1	11/30/2023			
8.	Location: Leasing office Nature: Emergency lighting must be maintained Code Section: N.J.A.C. 5:70-3,604.4	11/30/2023			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.