

WOID	Description	Priority	Status	Craft	Assigned To	Location	Area Number	Request Date	Action Taken
13776	Air conditioning does not work. The room is very hot and humid.	Medium	Closed Work Orders	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	130	9/6/2018	
15379	the air conditioning in the back of the room will all of a sudden start making a horrific screeching noise. It comes and goes but is quite the distraction.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	9/6/2019	Replaced blower motor TS 10/1
15608	Mold in heating/air conditioning unit. Unhealthy environment.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	125	9/30/2019	TS 9/30
15629	PLEASE turn off the A/C or at least the vent that is right over my desk-freezing air pumps out throughout the day!!! Thank you!	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	132	10/3/2019	10/8 TS
15729	Air conditioning is full blast in room. No heat. Room is extremely cold.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	208	10/24/2019	TS 10/30
15848	It is very cold in room 110 and the cold air is constantly blowing. Can it be made warmer in here please? Thanks.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	110	11/20/2019	TS 12/3
15963	Hi, very hot in room 107. Thanks.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	110	12/13/2019	
15976	Actually, it is still really cold in room 110. It's constantly blowing cold air.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	110	12/16/2019	
15992	Heat is not working	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	12/18/2019	
16088	Heater is making very load noise and smells like burning crayons.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	201	1/17/2020	TS 1/17
16115	The heater is rumbling and vibrating louder than usual. It sounds like something might be stuck in there.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	210	1/24/2020	TS 1/29
16141	Vent in room 104 is making a shrieking sound. Not exactly sure how long I am in the room one block every other day but it is very distracting.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	104	1/30/2020	2/4
16312	The heater is broken.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	104	3/2/2020	TS 3/9
16379	Still making noises and blowing out cold air.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	104	3/11/2020	TS 3/11
13725	The AP office is so hot and humid. Cold air is not coming out of the vent.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	125 AP office	9/4/2018	
13940	If it is possible, can the AC be turned down in here? It was originally turned up high to stop the mold from growing in a hot, humid environment, but now that the mold is treated, if it could be turned down, it would be appreciated.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	129B	9/20/2018	
	Thank you!								
13973	The air inside the classroom is too warm. Sometimes extremely hot and humid. is it possible to turn the temperature down 2 or 3 degrees ?	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	211	9/26/2018	
14214	We have no HEAT!!! We do have cold air pumping out from the vent even though the thermostat is set at 85! Please help!!!	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	132	11/15/2018	

14314	Please check the heat in the music room and music office. It is blowing cold air and is cold in the room.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	115	12/10/2018	checked gas valve operation Replaced Gas valve ok
14339	The heat in room 133 is extremely high for the past 2 days. Could you please adjust it to be lower. Thank you.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	133	12/13/2018	
14381	The heating system is not working properly. Cold air is blowing from vents. It only gets colder in there on cold days.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	FACULTY ROOM	1/3/2019	1/8 adjusted set pt
14449	The heat blower has started to sing, loudly, when it turns on.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	216	1/22/2019	Blower motor removed and replaced 1/23 - 1/24 TS
14843	the unit toward the back of the room was making a horrific noise until it was turned off.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	5/1/2019	Unit was repaired in May and emptied of debris etc By Tom Servon TS 5/6
14853	The temperature in Room 214 is extremely cold early in the day.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	214	5/3/2019	
14880	Follow up of work order placed in Mrs. Pich's name. The unit at the rear of 112 was making a terrible noise. A repair was attempted unsuccessfully. The unit was shut off. There is no AC in room 112 now. This unit needs to be repaired and turned back on before temperatures become uncomfortable.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	5/9/2019	1 unit WAS REPAIRED IN MAY WHERE DEBRIS WAS REMOVED 2 WEEKS LATER MORE DEBRIS WAS REMOVED AND UNIT WAS RESTARTED
14884	Air vent is not working. Making an extremely loud noise.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	117	5/10/2019	ts 5/13 replaced blower motor and speed control
14892	There is no heat in Rooms 127 and 137.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	Room 137 & Room 127	5/13/2019	TS 5/13 ADJUSTED SETPOINT
14941	No Air conditioning in the gym at all	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	gym	5/29/2019	
14952	Please clean both air conditioning units before August 1, 2019	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	Athletic Training Office/113C	5/30/2019	
14988	The air conditioning unit in the back of room 112 does not work at all.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	6/6/2019	TS STUDENTS PLACING DEBRIS INSIDE BLOWER OUTLETS DAMAGING BLOWER WHEEL
15294	Metal things that hide wires for the ac/heating unit are not installed correctly and are falling off the heater.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	143	9/3/2019	
15305	The AC unit at the rear of room 112 is still not fixed.	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	112	9/3/2019	new motor installed TS

15325	The AC in Room 208 is putting out hot air. This was also the situation yesterday and was fixed	Medium	Complete	Heating/Ventilation /Air Conditioning	Servon, Tom	South River High School	208	9/4/2019
-------	--	--------	----------	---------------------------------------	-------------	-------------------------	-----	----------