

Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
202	UV-01	5	7901

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING, SWITCH BROKEN
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	RIB ON, FAN NOT WORKING
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
204	UV-02	6	7902

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
206	UV-03	7	7903

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
208	UV-04	8	7904

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
212	UV-06	10	7906

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING, MAKING CLICKING NOISE
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	RIB ON, FAN NOT WORKING
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
210	UV-05	9	7905

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING, WEIRD NOISE FROM COVER
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	FAN NOT WORKING, RIB ON
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
214	UV-07	11	7907

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
216	UV-08	12	7908

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
215	UV-09	13	7909

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING, MAKING CLICKING NOISE
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	RIB ON, FAN NOT WORKING
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
213	UV-10	14	7910

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
209	UV-11	15	7911

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
207	UV-12	16	7912

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
Room 205	UV-13	17	7913

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
Room 203	UV-14	18	7914

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
201	UV-15	19	7915

Tag	Comment
	Checked and working
	Problem, not working
	In process

