

Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
	AO OUT-9	UV	FBYP-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
402	FCU-1	20	7916

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
	AO OUT-9	UV	FBYP-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
404	FCU-2	21	7917

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
	AO OUT-9	UV	FBYP-O	DAMPER STUCK, ACTUATOR IS WORKING FINE
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
406	FCU-3	406	7918

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
408	UV-19	23	7919

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
302	UV-20	24	7920

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
304	UV-22	26	7922

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
409	UV-23	27	7923

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	FAN WORKING BUT WITH WEIRD SOUND
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
407	UV-24	28	7924

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
405	UV-25	29	7925

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
403	UV-26	30	7926

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	NOT INSTALLED YET
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
401	UV-27	31	7931

Tag	Comment
	Checked and working
	Problem, not working
	In process

