

Tag	Point Type	System Name	Object Name	Comment
		UV	DA-T	
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
606	UV-28	32	7928

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	DAMPER IS STUCK, NOT WORKING
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
608	UV-29	33	7929

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
610	UV-30	34	7930

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
612	UV-31	35	7931

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	FAN IS WORKING, BUT WITH WEIRD SOUND
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
614	UV-05	36	7932

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
618	UV-33	37	7933

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		NO POWER TO CONTROLLER (STRADDICK)
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
620	UV-34	38	7934

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
623	UV-35	39	7935

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	FAN NOT WORKING
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
621	UV-36	40	7936

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
619	UV-37	41	7937

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN WORKING BUT WITH WEIRD SOUND
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
617	UV-38	42	7938

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
615	UV-39	43	7939

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	HTG-O	
		UV	CLG-O	
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
613	UV-40	44	7940

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	FBYP-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
611	UV-41	45	7941

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV		
	BO OUT-3	UV		
	CO OUT-4	UV	HTG-O	Actuator working, no flow to check polarity
	CO OUT-5	UV	CLG-O	Actuator working, no flow to check polarity
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	DAMPER IS STUCK, ACTUATOR WORKING FINE
	AO OUT-9	UV	FBYP-O	DAMPER IS STUCK, ACTUATOR WORKING FINE
		UV		
		UV		
	STAT	UV	ZN-T	

Room	Name	Address	Instance
607	FCU-4	25	7921

Tag	Comment
	Checked and working
	Problem, not working
	In process

