

Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Have 24V, compressor doesn't wanna run, pressure switch is broken
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	CHECKED
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-06	17	7343

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	FAN NOT WORKING
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	HAVE 24V ON RIB, FAN NOT WORKING. Motor is vibrating. Can be bad switch or bad motor
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	CHECKED
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-06	18	7344

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Changed , checked
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-07	19	7345

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-08	20	7346

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV	UV-09	
		UV	UV-09	
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-09	21	7347

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-10	22	7348

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV	HTG-C	24V open/close
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV		
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-11	23	7349

Tag	Comment
	Checked and working
	Problem, not working
	In process

Valve working, but there is no hot water in the building to check polarity



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	CHANGED, CHECKED
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV	HTG-O	Valve working, but there is no hot water in the building to check polarity
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-12	24	7350

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	Checked
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	Checked
	BI IN-8	UV	LT-A	Checked
	BO OUT-1	UV	SF-C	Checked
	BO OUT-2	UV	CLG-C	Fixed, checked
	BO OUT-3	UV		
	CO OUT-4	UV		
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	Working not in full range , but enough to keep unit operational safe
	AO OUT-9	UV	HTG-O	VALVE DO NOT EXIST
		UV		
		UV		
	STAT	UV	ZN-T	Checked

Name	Address	Instance
UV-13	25	7342

Tag	Comment
	Checked and working
	Problem, not working
	In process



Tag	Point Type	System Name	Object Name	Comment
		UV		
		UV		
	UI IN-1	UV	DA-T	
	UI IN-2	UV		
	UI IN-3	UV		
	UI IN-4	UV		
	UI IN-5	UV		
	UI IN-6	UV		
	BI IN-7	UV	SF-S	
	BI IN-8	UV	LT-A	
	BO OUT-1	UV	SF-C	
	BO OUT-2	UV	CLG-C	
	BO OUT-3	UV		
	CO OUT-4	UV		TRANSFORMER NEED TO BE CHANGED
	CO OUT-5	UV		
	CO OUT-6	UV		
	CO OUT-7	UV		
	AO OUT-8	UV	MAD-O	
	AO OUT-9	UV	HTG-O	
		UV		
		UV		
	STAT	UV	ZN-T	

Name	Address	Instance
UV-14	26	7341

Tag	Comment
	Checked and working
	Problem, not working
	In process

