

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
RTU-1	A-6	9	7337



Tag	Comment
	Checked and working
	Problem, not working
	In process

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
RTU-2	A-7	10	7338



Tag	Comment
	Checked and working
	Problem, not working
	In process

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
RTU-3	A-8	11	7339



Tag	Comment
	Checked and working
	Problem, not working
	In process

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
RTU-4	A-9	12	7340



Tag	Comment
	Checked and working
	Problem, not working
	In process

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	**Not reading, Jumped wires and point read as active
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
ACU-3	E-12	6	7332



Tag	Comment
	Checked and working
	Problem, not working
	In process

Tag	Point Type	Object Name	Controller Details	Coment
	W	HTG	TEC300	
	Y	CLG	TEC300	
	Fan-C	Fan Command	TEC300	
	BI-1	Fan Status	TEC300	
	SAT	Supply Air Tem	TEC300	

Name	Room	Address	Instance
ACU-4	E-11	12	7336



Tag	Comment
	Checked and working
	Problem, not working
	In process