

B1 4402 / Lot 3

BERNARDS TOWNSHIP HEALTH DEPARTMENT

262 S. Finley Avenue

Basking Ridge, New Jersey 07920

(908) 204-3070

CONTRACTUAL HEALTH AGENCY FOR:

Bedminster Twp/Bernardsville Boro

Far Hills Boro/Peapack & Gladstone Boro

Chester Boro/Mendham Boro/Mendham Twp

BERNARDS TOWNSHIP PERMIT

1806

Type of Permit

Fee

Location

New Septic System

☐

Block

4402

Repair or Alter Existing System

☒

100.00

Lot

3

New Well & Pump

☐

Street Address

Percolation & Soil Log

☐

521 Mine Brook Road

Total Fees 100.00

Paid 100.00

Date January 23, 2012

19

Applicant's Name Peach Brothers

Address P.O. Box 280, Succasunna, NJ 07876

Tele. No. 1-973-584-4343

SEPTIC

BL. 4402

Lot 3

Lucy A. Forgione

Health Officer

Lucy A. Forgione

SEPTIC AND WELL INSPECTIONS

NAME: _____

DATE: 2/14/12

MUNICIPALITY: Bot

BLOCK: 4402

LOCATION: 521 Minbrook Rd

LOT: 3

SEPTIC

WELL

NEW: _____

CASING: _____

ALTERATION: _____

PITLESS: _____

REPAIR: P

SEALING: _____

ENGINEER: _____

WELL

CONTRACTOR: Peach Bros

DRILLER: _____

DATE INSPECTOR FINDINGS

2/14/12 (P) replacing inlet baffle
~~to~~ riser to grade
manhole cover (locking)
stand pipe on inlet

2/15/12 (P) inlet baffle replaced
"T" on top for access port
tank pumped out in good
condition. riser to grade
high on top of area

(FC)



BERNARDS TOWNSHIP HEALTH DEPARTMENT

262 South Finley Avenue Basking Ridge, New Jersey 07920 (908) 204-3070 Fax (908) 204-3075

February 21, 2012

TO: Whom It May Concern

FROM: Cynthia Lee, Sr. REHS

RE: Anderson
521 Minebrook Road
Block 4402 Lot 3
Septic System Repair

A representative of the health department has witnessed a repair to the septic system on the above referenced property. The inlet baffle on the septic tank was replaced. In addition, a riser and locking manhole cover to grade were added over the septic tank. All work was backfilled and graded.

Please contact me at 908-204-3072 if you have any questions regarding this matter.

**CONTRACTUAL HEALTH AGENCY FOR:
BERNARDS TOWNSHIP, BERNARDSVILLE BOROUGH,
CHESTER BOROUGH, LONG HILL TOWNSHIP, MENDHAM BOROUGH,
MENDHAM TOWNSHIP, PEAPACK AND GLADSTONE BOROUGH**

BERNARDS TOWNSHIP HEALTH DEPT., BOX 437, COLLYER LN., BASKING RIDGE, NJ 07920
766-2510

☐ Bedminster Township

☒ Bernards Township

☐ Bernardsville Borough

☐ Far Hills Borough

☐ Peapack-Gladstone Borough

Application for Permit to Locate and Construct an Individual Sewage System

Street Address 521 Mine Brook Rd

Block 4402 Lot No. 3

Owner Bill Anderson

Phone 908-766-3780

Address 521 Mine Brook Rd, Far Hills.

Contractor Peach Brothers

Phone 973-584-4343

Address P.O. Box 280 Succasunna

NJ 07876

Date January 20, 2012

☐ New Construction

☒ Repair or Alteration

(If repair, please provide sketch on back with details.)

Install new inlet baffle on
Ex. Tank.

Type of Building to be Served:



☒ Residential

☐ Commercial

Note: All applications must be accompanied by an approved plot plan. This plan must include such things as the size of the lot, boundary lines, contours, locations of wells, specifications of sewage disposal systems, distances, materials, etc. An approved perc test and soil log shall also be submitted.

Signature of Applicant

Paul Peach
Peach Brothers



4" sch. 40 PVC
sanitary Tee
Inlet Baffle