

CARLTON N. FROST
P.E., L.S. & P.P.

HARRY F. METZLER
L.S. & P.P.

(908) 879-6400
Fax: (908) 879-8577

**ASSOCIATED
CONSULTANTS**

**ENGINEERS AND LAND SURVEYORS INC.
PROFESSIONAL PLANNERS**

530 EAST MAIN STREET
P.O. BOX 383
CHESTER, N.J. 07930-0383

Boundary & Title Surveys
Roads & Storm Sewers
Feasibility Reports
Topography Surveys
Land Subdivisions
Percolation Tests
Sewerage Systems
Septic Systems
Water Systems
Flood Control
Wetlands

Our File No: 2928

March 6, 2002

Chester Township Board of Health
One Parker Road
Chester, NJ 07930

Re: Lot 12.04 Block 16
Select Fill Compaction
Class Rating Test
Perc Testing

To Whom it May Concern:

On February 27, 2002, we took a sample of select fill from the above referenced site for class rating analysis. The results were as follows:


12.3% Course fragment
87.7% Sand
2.2% Clay
10.1% Silt
31.5% Fine to very fine sand
K4 Permeability Class

This is to certify that on March 1, 2002, Associated Consultants witnessed the compaction of select fill in the disposal bed in 1-foot lift. Additionally, upon completion, we performed two perc tests in the select fill with the following results:

4.1 Minutes/inch
4.2 Minutes/inch

Should you have any questions, please do not hesitate to call.

Very truly yours,



Carlton N. Frost, P.E., L.S. & P.P.
ASSOCIATED CONSULTANTS

CNF/jq
Cc: Elite Homes