



TOWNSHIP OF IRVINGTON

DEPARTMENT OF HOUSING SERVICES
MUNICIPAL BUILDING - CIVIC SQUARE
IRVINGTON, NEW JERSEY 07111
(201) 397-6704

CI: EMC

Sara B. Bost
Mayor

PLUMBING

VIOLATIONS

ALDO BARATTO
Director

Brenda Cobbs
168 Park Place
Irvington, New Jersey 07111
Telephone Number: _____
Re 168 Park Place
Block: 329 Lot: 25 Units: 1
Original Inspection Date: 5/19/95 Inspector: Strillacci No. of Viols: 6
3rd Re-Insp. Date: _____ Inspector Signature _____
2nd Re-Insp. Date: _____ Inspector Signature _____
1st Re-Insp. Date: 6-2-95 Inspector Signature *James Byrne*

Meanings of Symbols "O" Not Completed "A" Work Completed "NE" No-Entry

CODE NUMBERS	LOCATION AND DESCRIPTION	1st	2nd	3rd
	<u>2ND FLOOR</u>			
	NO VIOLATIONS FOUND			
	<u>1st FLOOR</u>			
503.1	1. Make washing machine discharge hose tight to underside of counter top	A		
503.1	2. Install restriction in lavatory waste outlet		A	
503.1	3. Snake out lavatory waste piping		A	
	<u>BASEMENT</u>			
504.1	4. Install full flow valve on house side of water meter	A		
504.1	5. Remove relief valve and cup-off piping (over lavatory)	A		
504.2	6. Install an anti syphontype ballcock in water closet	A		



TOWNSHIP OF IRVINGTON

DEPARTMENT OF HOUSING SERVICES
MUNICIPAL BUILDING — CIVIC SQUARE
IRVINGTON, NEW JERSEY 07111
(201) 399-6784

Sara B. Bost
Mayor

ONE and TWO DWELLING HOUSING VIOLATIONS

ALDO BARATTO
Director

Brenda Cobbs Telephone Number: _____
168 Park Place Re: 168 Park Place
Irvington, New Jersey 07111 Block: 329 Lot: 25 Units: 1
Original Inspection Date: 5/19/95 Inspector: G. Harper No. of Viol. 7
3rd Re-Insp. Date: _____ Inspector Signatures: _____
2nd Re-Insp. Date: _____ Inspector Signatures: _____
1st Re-Insp. Date: _____ Inspector Signatures: _____

Meanings of Symbols "O" Not Completed "A" Completed "NE": No-Entry

CODE NUMBERS	LOCATION AND DESCRIPTION	1st	2nd	3rd
	*** PUBLIC SAFETY LAW *** *** CHAPTER 92-C-52-27D-198.1 ***			
C-52-27D-198.1	1A. REQUIRES BATTERY OPERATED SMOKE DETECTORS IN ONE & TWO FAMILY DWELLINGS. SUCH SMOKE SENSITIVE DEVICES SHALL BE LOCATED ON EACH LEVEL OF THE STRUCTURE AND IN THE IMMEDIATE VICINITY OF THE BEDROOMS. <u>EXTERIOR</u>			
301.5	1. Replace damage sidewalk _____ <u>GARAGE</u> NO VIOLATIONS			
	<u>HOUSE</u>			
302.41	2. Make window weathertight in building _____ a. replace damage screens _____ b. replace crack window panes _____ <u>LIVING ROOM, DINING ROOM</u> NO VIOLATIONS			
	<u>KITCHEN, BATHROOM</u>			
692.2	3. Install outlet GFI (permit required) _____ <u>BATHROOM</u>			
602.2	4. Remove illegal pull chain _____ a. install switch (permit required) _____			

BACKSHEET FOR		CERTIFICATE OF OCCUPANCY REPORT		PAGE 2 OF			
CODE NUMBER	DESCRIPTION OF VIOLATION CITED	1st Re:	2nd Re:	3rd Re:	4th Re:		
303.3	<u>REAR PORCH</u>						
	5. Paint all trimming						
	<u>BASEMENT</u>						
	<u>RECREATION ROOM</u>						
602.2	NO VIOLATIONS						
	<u>BATHROOM</u>						
	6. Remove illegal pull chain						
	a. install switch (permit required)						
602.2	b. Install outlet GFI (permit required)						
	<u>FRONT HALLWAY, FRONT BEDROOM LT., FRONT BEDROOM RT.</u>						
	NO VIOLATIONS						
	<u>BATHROOM</u>						
602.2	7. Install outlet GFI (permit required)						
	<u>BEDROOM, REAR BEDROOM</u>						
	NO VIOLATIONS						



TOWNSHIP OF IRVINGTON

DEPARTMENT OF HOUSING SERVICES
MUNICIPAL BUILDING - CIVIC SQUARE
IRVINGTON, NEW JERSEY 07111
(201) 399-6784

Sara B. Bost
Mayor

ONE and TWO DWELLING HOUSING VIOLATIONS

ALDO BARATTO
Director

Brenda Cobbs
168 Park Place
Irvington, New Jersey 07111
Original Inspection Date: 5/19/95
3rd Re-Insp. Date: _____
2nd Re-Insp. Date: 6/7/95
1st Re-Insp. Date: 6/2/95
Telephone Number: _____
Re: 168 Park Place
Block: 329 Lot: 25 Units: 1
Inspector: G. Harper No. of Viol. 7
Inspector Signatures: _____
Inspector Signatures: _____
Inspector Signatures: _____

Meanings of Symbols "O" Not Completed "A" Completed "NE": No-Entry

CODE NUMBERS	LOCATION AND DESCRIPTION	1st	2nd	3rd
	*** PUBLIC SAFETY LAW *** *** CHAPTER 92-C-52-27D-198.1 ***			
C-52-27D-198.1	1A. REQUIRES BATTERY OPERATED SMOKE DETECTORS IN ONE & TWO FAMILY DWELLINGS. SUCH SMOKE SENSITIVE DEVICES SHALL BE LOCATED ON EACH LEVEL OF THE STRUCTURE AND IN THE IMMEDIATE VICINITY OF THE BEDROOMS. <u>EXTERIOR</u> 301.5 1. Replace damage sidewalk	A		
	<u>GARAGE</u> NO VIOLATIONS			
	<u>HOUSE</u> 302.41 2. Make window weathertight in building	O	A	
	a. replace damage screens	O	A	
	b. replace crack window panes	O	A	
	<u>LIVING ROOM, DINING ROOM</u> NO VIOLATIONS			
	<u>KITCHEN, BATHROOM</u> 692.2 3. Install outlet GFI (permit required)	A		
	<u>BATHROOM</u> 602.2 4. Remove illegal pull chain	A		
	a. install switch (permit required)	A		

BACKSHEET FOR		CERTIFICATE OF OCCUPANCY REPORT		PAGE 2 OF			
CODE NUMBER	DESCRIPTION OF VIOLATION CITED	1st Re:	2nd Re:	3rd Re:	4th Re:		
303.3	<u>REAR PORCH</u>						
	5. Paint all trimming	A					
	<u>BASEMENT</u>						
	<u>RECREATION ROOM</u>						
602.2	NO VIOLATIONS						
	<u>BATHROOM</u>						
	6. Remove illegal pull chain	A					
	a. install switch (permit required)	A					
602.2	b. Install outlet GFI (permit required)	A					
	<u>FRONT HALLWAY, FRONT BEDROOM LT., FRONT BEDROOM RT.</u>						
	NO VIOLATIONS						
	<u>BATHROOM</u>						
602.2	7. Install outlet GFI (permit required)	A					
	<u>BEDROOM, REAR BEDROOM</u>						
	NO VIOLATIONS						



TOWNSHIP OF IRVINGTON

DEPARTMENT OF HOUSING SERVICES
MUNICIPAL BUILDING — CIVIC SQUARE
IRVINGTON, NEW JERSEY 07111
(201) 399-6784

CI: EMC

ra B. Bost
Mayor

PLUMBING

VIOLATIONS

ALDO BARATTO
Director

Brenda Cobbs
168 Park Place
Irvington, New Jersey 07111
Telephone Number: _____
Re 168 Park Place
Block: 329 Lot: 25 Units: I
Original Inspection Date: 5/19/95 Inspector: Strillacci No. of Viols: 6
rd Re-Insp. Date: _____ Inspector Signature _____
nd Re-Insp. Date: _____ Inspector Signature _____
st Re-Insp. Date: _____ Inspector Signature _____

anings of Symbols "O" Not Completed "A" Work Completed "NE" No-Entry

DE NUMBERS

LOCATION AND DESCRIPTION

1st 2nd 3rd

2ND FLOOR

NO VIOLATIONS FOUND

1st FLOOR

503.1 1. Make washing machine discharge hose tight to
to underside of counter top

503.1 2. Install restriction in lavatory waste outlet

503.1 3. Snake out lavatory waste piping

BASEMENT

504.1 4. Install full flow valve on house
side of water meter

504.1 5. Remove relief valve and cup-off
piping (over lavatory)

504.2 6. Install an anti syphontype ballcock
in water closet