



Burlington City
525 High St.,
Burlington, NJ 08016
(609) 386-0200

Construction Permits

- - 65/2

Permit Number	Tracking Number	Work Type	Application Date	Permit Issue Date	Application Status	Subcodes	Closed
25-00228	C-25-00077	Alteration	1/29/2025 1:31:29 PM	6/17/2025	Open	B P E M	
HOME RENOVATION REHAB, REPLACE GARAGE DOOR, REPLACE FRONT PORCH, REMODEL BATHROOM TO POWDER ROOM, REPAIR KITCHEN FLOOR, ADD FLOOR JOIST TO BASEMENT, REPLACE WATER HEATER, NEW DUCT WORK, PLUMBING ALTERATIONS, ELECTRICAL ALTERATIONS, INSTALL NEW 80% GAS FIRED FURNACE & 3 TON A/C COIL							



Burlington City
525 High St.,
Burlington, NJ 08016

Inspection Activity Report

Inspections for Permit Number 25-00228

Tracking Number

C-25-00077

Inspection Date	Inspection Type	Inspector	Subcode	Result	Owner Location	Work Type	Work Description	Inspection Comments
07/15/2025	FOOTING	Jody Mazeall	Building	Pass	WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
07/15/2025	ROUGH	Walter Kennerup	Electrical	Pass	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
07/15/2025	ROUGH	Jody Mazeall	Plumbing		821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
07/31/2025	ROUGH	Jody Mazeall	Plumbing	Pass	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
08/05/2025	FRAMING	Jody Mazeall	Building	Fail	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
09/03/2025	FRAMING	Jody Mazeall	Building	Pass	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration		Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)



Burlington City
525 High St.,
Burlington, NJ 08016

Inspection Activity Report

Inspections for Permit Number 25-00228

C-25-00077

09/03/2025	ROUGH	Jody Mazeall	Mechanical	Fail	WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 (BACK DOOR)
10/07/2025	Final	Walter Kennerup	Electrical	Fail	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 At AC unit install UL listed connector for romex entering back of disconnect. At heater unit romex has to be protected feeding heater
10/08/2025	Final	Jody Mazeall	Building	Fail	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 guard rail loose must hold 200 lb in any direction at front porch
10/08/2025	Final	Jody Mazeall	Mechanical	Fail	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 no trap at condensate seal up unit
10/08/2025	Final	Jody Mazeall	Plumbing	Fail	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	seal up all duct work longitude and transverse seams minimal air flow on second floor Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721 no water pressure at second floor lav
11/18/2025	Final	Walter Kennerup	Electrical	Pass	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721



Burlington City
525 High St.,
Burlington, NJ 08016

Inspection Activity Report

Inspections for Permit Number 25-00228

C-25-00077	11/24/2025	Final	Jody Mazeall	Building	WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721
	11/24/2025	Final	Jody Mazeall	Mechanical	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721
	11/24/2025	Final	Jody Mazeall	Plumbing	821 SALEM RD WINCHRIS DEVELOPERS, LLC	Alteration	Agent: PREMIUM QUALITY HOME IMPROVEMENT Phone: (856) 287-6268/ LBX 0721