

Brick

Permit Without a Jacket

Permit Number A-2167

Construction Permit # A-2107

Dec. 1, 1978 19

Owner Walker, Robert

Location 681 Rolling Hills Ct.

Rolling Hills

Block 1385-A Lot 16

Contractor same

Fee \$ 515.04 Use dwelling

C/O R20A
6-18-79

BUILDING SUB-CODE INSPECTIONS

Footing Trench 12-21-78 J.K.

Slab

Foundation 1-25-79 J.K.

Framing 3-14-79 J.K.

Insulation 3-27-79 J.K.

Final 6-13-79 J.K.

C. O. Issued

VIOLATIONS

F.R. 150

F.R. 150

R-3 1hr

Wotthrell 1-18-79

PLUMBING SUB-CODE INSPECTIONS

Slab

Rough O.K. D.M.

Septic/Sewer

Water

Final 6/13/79

Electrical Final

Use reverse side for additional remarks


Certificate of Occupancy

Name Robert Walker

THIS IS TO CERTIFY that the building erected at 681 Rolling Hills Ct.
Lot No. 16 Block No. 1385-A in Brick Township, under Permit No. A-2107
issued December 1, 1978, has been inspected and approved in
accordance with the Zoning and Building Ordinances of the Township of Brick.
Use Group R-3 Maximum Live Load _____
Fire Grading 1 hour Occupancy Load _____

By the issuance of this certificate, neither the Township nor any of its officers or
employees assumes any liability, either express or implied, in connection therewith.

 No 820 A


CONSTRUCTION OFFICIAL

Date June 18, 1979

A. Cottrell
11-29-78

CONSTRUCTION PERMIT APPLICATION
BRICK TOWNSHIP, NEW JERSEY

11/3/78

IMPORTANT — Complete ALL items. Mark boxes where applicable.

I. LOCATION OF BUILDING

Number and street: Rolling Hills Ct (Lt 16)
Section: Polting Halls
Lot: 16
Block: 1385-A
N S
N S
E W side of NW on Col-de-sac 330 feet E W from intersection of Rolling Hills Ct and Rolling Hills Dr
(Other local geographic, political, or legal subdivision identification)

II. TYPE AND COST OF BUILDING — All applicants complete Parts A-D

A. TYPE OF IMPROVEMENT

- 1 ☒ New buildings
2 ☐ Addition (If residential, enter number of new housing units added, if any, in Part D, 13)
3 ☐ Alteration (See 2 above)
4 ☐ Repair, replacement
5 ☐ Demolition
6 ☐ Moving (relocation)
7 ☐ Garage
☐ Swim Pool ☐ In ☐ out
☐ Fence

D. PROPOSED USE — For "Wrecking" most recent use

Residential

- 12 ☒ One family
13 ☐ Two or more family — Enter number of units
14 ☐ Transient hotel, motel, or dormitory — Enter number of units
15 ☐ Garage
16 ☐ Carport
17 ☐ Other — Specify (Basement)

Nonresidential

- 18 ☐ Amusement, recreational
19 ☐ Church, other religious
20 ☐ Industrial
21 ☐ Parking garage
22 ☐ Service station, repair garage
23 ☐ Hospital, institutional
24 ☐ Office, bank, professional
25 ☐ Public utility
26 ☐ School, library, other educational
27 ☐ Stores, mercantile
28 ☐ Tanks, towers
29 ☐ Other - Specify

B. OWNERSHIP

- 8 ☒ Private (individual, corporation, nonprofit institution, etc.)
9 ☐ Public (Federal, State, or local government)

C. COST

10. Cost of Improvement 105,695
To be installed but not included in the above cost
a. Electrical (# Fixtures, Outlets) 1,500.00
b. Plumbing (# of Fixtures) 2,500.00
c. Heating, air conditioning 2,800.00
d. Other (elevator, etc.)
11. TOTAL COST OF IMPROVEMENT \$42,800.00

(Omit cents)

\$36,000.00

1,500.00

2,500.00

2,800.00

\$42,800.00

Nonresidential — Describe in detail proposed use of buildings, e.g., food processing plant, machine shop, laundry building at hospital, elementary school, secondary school, college, parochial school, parking garage for department store, rental office building, office building at industrial plant. If use of existing building is being changed, enter proposed use.

Plumbing \$ 60
Septic \$ 25

III. SELECTED CHARACTERISTICS OF BUILDING —

For new buildings and additions, complete Parts E-I; for wrecking, complete only Part H, for all others skip to IV.

E. PRINCIPAL TYPE OF FRAME

- ☐ Masonry (wall bearing)
☒ Wood frame
☐ Structural steel
☐ Reinforced concrete
☐ Other - Specify

H. DIMENSIONS

Number of stories 1
Total square feet of floor area, all floors, based on exterior dimensions 1,691
Total land area, sq. ft. 33,000

FEE COMPUTATIONS

VOLUME OF BUILDING 290.14
BUILDING SUB CODE 290.14
ELECTRICAL CODE 85.01
PLUMBING CODE 38.01
PLAN REVIEW 57.05
CERTIFICATE OF OCCUPANCY 24.87
STATE TRAINING FUND 15.00
CONSTRUCTION 5-10.04
PERMIT FEE 715.00

F. TYPE OF HEATING SYSTEM

Specify Oil-hot air

Air Cond. Yes ☒ No ☐

I. RESIDENTIAL BUILDING ONLY

Number of bedrooms 3
Number of bathrooms { Full 2
Partial 0

G. TYPE OF SEWERAGE DISPOSAL

- ☐ Public
☒ Individual

SEE REVERSE

A-2107

534.44

SUB CONTRACTORS

NAME	TRADE	ADDRESS	ZIP CODE	PHONE #
1. P.M. Lopicolo	Excavation	Lakewood 1066 River Ave	08701	367-3868
2. M. Dixon	Carpenter			
3. Coastal Septic	Septic	Forge Pond Rd BT	08723	892-3628
4. W. Hargrove	Mason	Center St Lakewood	08701	367-3390
5. BJ Meyer	Plumbing	Mohawk Pl Lakewood	08701	364-3078
6. Central Jersey H&C	Heating	Lanes Mill Rd BT	08723	458-8383
7. Cardinal Roofing	Roof & Siding	BT Industrial Pk	08723	458-9222
8. Sam&Paul Drywall	Sheet rk&Insul	Jackson Whitesville Rd		363-8035
Town&Country Carpet	Flooring	BT Shopping Ctr		899-8400

PERSON TO BE IN CHARGE OF CONSTRUCTION

NAME

Robert G. Walker

ADDRESS

1200 Central Ave Lakewood; NJ 08701

IV. IDENTIFICATION — To be completed by all applicants

Name	Mailing address — Number, street, city, and State	ZIP code	Tel. No.
1. Owner <i>Robert G. Walker</i>	Robert G. Walker 1200 Central Ave Lakewood, NJ	08701	367-7155 899-1820
2. Contractor	Same		
3. Architects			

The owner of this building and the undersigned agree to conform to all applicable laws of Township of Brick and that all required state, county and local prior approvals have been given.

Signature of applicant

Address

1200 Central Ave Lakewood, NJ

Application date

DO NOT WRITE IN THIS SPACE — FOR OFFICE USE ONLY

Approved by

Date permit issued

Permit Number

I agree to construct said building in conformity with the plans and specifications filed with the Construction Official and in compliance with the provisions of the Building Code whether shown on plans or not.



Brick Top
OCEAN COUNTY ELECTRICAL BUREAU
COURT HOUSE
TOMS RIVER, NEW JERSEY

GENTLEMEN:

FOR MUNICIPAL RECORDS

PREMISES OWNED BY

WALKER

OCCUPIED BY

LOCATION

BW 1385 ALor 16 (Remodeling) CT.

"Installation in the above premises has been inspected and is in accordance with the current edition of the National Electrical Code, Regulations and Orders of the Board of Public Utility Commissioners and requirements of the utility company as filed with the Board."

SERVICE

200amp

RANGE

Final

HEATER

✓

FIXTURES

10

RECEPTACLES

50

MISC

2x200amp

APPLICATION #

5415

MI#57

ELEC. 107

A-2107

**THE BRICK TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY**

1551 Hwy. 88 W. ~~XXXXXXXXXXXXXXXXXXXX~~
BRICK TOWNSHIP, NEW JERSEY 08723

CERTIFICATE OF COMPLIANCE

Date.....JUNE 4, 1979.....

NAME.....WALKER, ROBERT.....

ADDRESS.....BAY AVE., PT. PLEASANT, NJ.....

PROPERTY LOCATION.....681 ROLLING HILLS CT.....

Account No.....T188055 02-088.....Block.....1385-A.....Lot.....16.....

I hereby certify that the above applicant has complied with all Rules
and Regulations of this Authority and has paid all required fees and charges.

For the Authority.....Karen Surden.....

**THE BRICK TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY**

1551 HIGHWAY 88 WEST
BRICK TOWN, NEW JERSEY 08723

CERTIFICATE OF AVAILABILITY OF UTILITY SERVICES

Date: NOVEMBER 2, 1978

To: Township of Brick

The following is the status of the availability of utilities for the property listed hereon.

Block: 1385-A Lot: 16

Location: ROLLING HILLS COURT

Name ROBERT WALKER

Address 1200 CENTRAL AVENUE, LAKEWOOD, NJ.


1. Utility is available for use.
2. Utility is not available, and will not be constructed in the foreseeable future. Individual system may be used.
3. Utility is in design or under construction and is projected to be available by 1980. Individual system may be used in interim.

Water	Sewer
X	
	X

NOTE: This form is only a statement of availability of utilities and should not be construed as an application for such utilities. Application should be submitted to the BTMUA as soon as possible after issuance of a building permit, but in no case less than 4 weeks before anticipation of a Certificate of Occupancy.

For the BTMUA

Callean M. Bradley



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

January 24, 1984


681 Rolling Hills Court
Brick, New Jersey 08724
Block 1385-A, Lot 16

To whom it may concern:

Please be advised that the septic system for the above address had complied with the Township of Brick in requirements, and design.

The approval was given in the later part of 1978.

The area is equipped for sewer installation at the present time.


Donald H. Metcalf
Plumbing Inspector

DHM/mks

cc: Division of Inspections

June 7, 1979

Inspection Department
Township of Brick
Chambersbridge Road
Bricktown, NJ

RE: New Home-681 Rolling Hills Ct.

Gentlemen,


Please be advised that construction on the above captioned home is complete. Final inspection by your department has revealed a few minor violations which I have given my immediate attention. The remaining violations to be corrected are as follows;

1. Tape and spackle garage-to be completed 6/8/79.
2. Installation of meter yoke at water pipe- to be completed 6/8/79.
3. Removal of plywood form under hearth-to be completed 6/7/79.

We were required to evacuate our existing dwelling as of 6/1/79. I was able to gain a few days grace but have now been forced to place my belongings in our new home. In as much as I have no place to go, I would appreciate issuance of a temporary Certificate of Occupancy with the above violations to be corrected and reinspected within 5 days from the above date. I agree to hold the township of Brick and your department harmless in the event of loss of any nature.

Your anticipated understanding and compliance are greatly appreciated.

Very truly yours,



Robert G. Walker

Brick Township Construction Permit Application for Plumbing

1. LOCATION

NUMBER and STREET	SECTION	LOT	BLOCK
<i>Rolling Hills Ct</i>	<i>Herbertswood</i>	<i>16</i>	<i>1385-A</i>

PROPOSED USE

2. TYPE of IMPROVEMENT ___ NEW BUILDING ☒ ALTERATION ___ ADDITIONAL FIXTURES

___ WELL ☒ SEPTIC ___ SEWER (B.T.M.U.A.) ☒ WATER (B.T.M.U.A.)

3. PLUMBING FIXTURES

	NUMBER OF	FEE
1. WATER CLOSET	<i>2</i>	<i>10</i>
2. LAVATORIES	<i>2</i>	<i>10</i>
3. BATH TUB	<i>1</i>	<i>5</i>
4. SHOWER STALL or DRAIN	<i>1</i>	<i>5</i>
5. KITCHEN SINK	<i>1</i>	<i>5</i>
6. SLOP SINK		
7. LAUNDRY TRAY		
8. DISHWASHER	<i>1</i>	<i>5</i>
9. WASHING MACHINE	<i>1</i>	<i>5</i>
10. URINALS		
11. FLOOR DRAIN		
12. DRINKING FOUNTAIN		
13. FOOD WASTE GRINDER		
14. SEWER PUMP or EJECTOR		
15. GREASE TRAP		
16. OIL SAND SEPARATOR		
17. AIR CONDITIONER REFRIGERATOR WATER COOLED		
18. HOT WATER HEATER ___ OIL ___ GAS ☒ ELECTRIC	<i>1</i>	<i>5</i>
19. DENTAL UNIT		
20. LAWN SPRINKLERS NO. OF HEADS		
21. WELL (PRIVATE)		
22. WELL PUMP		
23. SEPTIC	<i>1</i>	<i>25</i>
24. PLUMBING STACKS		<i>10.00</i>

4. MATERIAL SPECIFICATIONS

BUILDING SEWER	<i>ABS</i>
WATER SERVICE	<i>Aluminum 3/4 K</i>
BUILDING DRAIN	<i>ABS</i>
WASTE	<i>ABS</i>
VENTS	<i>ABS</i>
WATER PIPE	<i>1/2 Copper</i>

5. INSPECTIONS

	DATE	INSPECTOR
SLAB		
ROUGH		
WATER		
SEWER		
FINAL		

6. COMMENTS

PLUMBER

B. J. Meyer

LICENSE

4543


PLUMBING FEE \$

85.00

PERMIT #

A-2107

DM 10/20/78



ROOM FINISH SCHEDULE

MATERIALS

FLOOR

OAK	A
TILE	B
CARPET	C
CERAMIC TILE	D
Linoleum	E
	F

BASE

WOOD	G
SANITARY COVE	H
VINYL	I

WAINSCOT

J
K

WALL

PAINT	L
WALLCOVERING	M
PANELLING	N
CERAMIC TILE	O
	P

COVE

WOOD	Q
	R

CEILING

PAINT	S
HUNG	T

APPLICABLE		FLOOR	BASE	WAINSCOT	WALL	COVE	CEILING	REMARKS
/	FOYER	F	G		L	Q	S	
/	LIVING ROOM	C	G		L	Q	S	
/	DINING ROOM	C	G		L	Q	S	
/	KITCHEN	F	G		M	Q	S	
/	FAMILY ROOM	C	G		L	Q	S	
	RECREATION							
/	BATH	E	G		M	Q	S	Formica 202 In tub area
/	1/2 BATH	E	G		M	Q	S	
	DEN							
	UTILITY							
/	MASTER BEDROOM	C	G		L	Q	S	
/	BEDROOM #2	C	G		L	Q	S	
/	BEDROOM #3	C	G		L	Q	S	
	BEDROOM #4							
	BEDROOM #5							

CONNECTIONS

Nailed connections to comply with the recommended nailing schedule, appendix "M" of the BOCA Basic Building Code 1975.

DOORS

All exterior doors to be 6'-8" high x 1 3/4 " thick.

All interior doors to be 6'-8" high x 1 3/8" thick or as noted on plans.

FRAMING

All framing lumber to be hem-fir No. 2 unless otherwise noted. $\left\{ \begin{array}{l} f=1150 \\ E=1,400,000 \end{array} \right.$

All other lumber to be douglas fir No. 2 unless otherwise noted. $\left\{ \begin{array}{l} f=1450 \\ E=1,700,000 \end{array} \right.$

ELECTRIC SERVICE

Service _____ amps
 Furnace _____ amps
 D.W. _____ amps
 Reg. outlet _____ amps
 Dryer _____ amps
 A.C. _____ amps
 App. outlet _____ amps
 H.W. _____ amps
 Range _____ amps
 Switches _____ amps

All bath outlets to be on circuit with ground fault interrupter.

DIVISION OF INSPECTIONS
TOWNSHIP OF BRICK
401 Chambers Bridge Road
Brick Town, New Jersey 08723

TOWNSHIP OF BRICK
DIVISION OF HEALTH
~~XXXXXXXXXX~~

PLANS SUBMITTED BY Walker - Bob Powers Eng. ^{899 1800}

T/A _____ FOR APPROVAL OF A SEPTIC SYSTEM ON

LOT 16 BLOCK 1385A STREET Rolling Hill Ct

LOCATION Rolling Hills

WERE REJECTED ON THE SEPTIC SYSTEM FOR THE FOLLOWING:

SECTION 10.7 WATER TABLE _____

13.8 WATER TABLE _____

10.9 FILL _____

3.2 DISTANCE _____

NUMBER OF BEDROOMS _____

SIZE OF SEEPAGE AREA _____

OTHER REMARKS Percolation Rf

DATE 11/30/76

J. M. DeCal
AUTHORIZED AGENT
Plumbing Inspector
TITLE

TOWNSHIP OF BRICK
DIVISION OF INSPECTION

PLUMBING PLANS SUBMITTED BY _____ and PLUMBER _____

LOT _____ BLOCK _____

STREET _____

WERE REJECTED:

1. PLUMBER NAME & LIC. # _____

2. ISOMETRIC PLANS OF PLUMBING _____

3. PIPE SIZE _____

4. MATERIAL SPECIFICATIONS _____

5. _____ VENT _____

6. _____ SOIL _____


7. _____ WASTE _____

8. OTHER REMARKS _____

CALLED _____

PLUMBING INSPECTOR

DATE _____



OK
 H. Cottrell
 11-29-18

DIVISION OF HEALTH OF THE TOWNSHIP OF BRICK
APPLICATION FOR PERMIT TO LOCATE AND CONSTRUCT AN INDIVIDUAL
SEWAGE DISPOSAL SYSTEM

Date October 11, 1978Rolling Hill CourtRolling HillsBlock No. 1385A Lot No. 16

Street

Location

Owner (print) Robert Walker

If corporate owner or developer list names and position of individual applying for permit.

Present Address 1200 Central Ave Lakewood, NJ

Name and Address of Contractor (print)

Type of Building to be served single family family room xDwelling Unit - No. of Bedrooms 3 ~~Expansion~~ Yes No

Other Type of Building

Gals. per person

Type of Facilities

Size of Lot 151+ x 250+ Area sq. ft. 33000+Septic Tank - Liquid Capacity 1000 gal Shape Hexagonal Material Precast conc.Width 6' 1 1/2" Length 7' 1" DiameterLiquid depth 4' 11" Distance from liquid to underside of top 9"

Liquid Disposal Disposal Trenches

sq. ft. Disposal Bed

sq. ft. Seepage Pits 330 sq. ft.

Disposal Trenches - Width

Depth

Lin. Ft. of Pipe

Distance between lines

Type of Pipe

Disposal Bed - Width

Length

Area sq. ft.

Lin. ft. of Pipe

Type of Pipe

Distance between lines

Seepage Pits - Number 2 Width

Length

Diameter 6' 6"Depth below inlet 8' 4" Distance between pits 20'Shape of Pits cylindrical Construction material precast conc.Depth of permeable material to be penetrated all

Percolation Tests Results

(as performed according to specifications
set forth in P. L. 199, Sec. 9-B)

I certify that the proposed sewerage facilities for the proposed realty improvement are in compliance with the provisions of Chapter 199, P. L. 1959 Revised 1963 and these standards.

Dated October 11, 1978

	Time in Min. per in.	Number of Tests to Determine Saturation	Depth	Type of Soil Encountered, Depth of Each Type
Ground Water at <u>none</u>			1	Gray sand
			2	
			3	
			4 SW	
			5	Brown sand
			6	
			7	
			8	
Source of Boring			9	
			10	
			11	
			12	
			13 SW	Red & Brown sand
			14	
			15	
			16	
9/15/78 Date			17	
			18	
			19	
			20	
			21	
			22	
			23	
			24	
			25	
			26	
			27	
			28	
			29	
			30	

SEE ATTACHED DRAWING

Make an accurate sketch or attach plot plan showing the following - lot dimensions, location of house, location of each unit of disposal system, all buildings and large trees in disposal area. Include distances from house, side and rear lots lines, auxiliary buildings, large trees and sewerage units and water supply.

The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of the Laws of the State of New Jersey and Standards adopted by the State Commissioner of Health pursuant thereto and applicable ordinances of the Township of Brick.

Owner.....

Contractor.....


Approved by

Plumbing Inspector

J. D. Spivey 11/14/78
Date

Engineer for the Board.....
Date

Remarks:



ORIGINAL
ILLEGIBLE

NOTE:
ELEVATIONS ON USC&GS DATUM
57.0 = EXISTING ELEVATION.
PUBLIC WATER AVAILABLE
10' MINIMUM BETWEEN SP. & 'A' LINE

LOT 16 BLOCK 1385-A
TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY

CENTURY ENGINEERS, INC.
1182 Ocean Avenue
Lakewood, N.J. 08701

SCALE 1" = 40'
DATE




TAGELUS

HI-RATE SAND FILTERS


TA SERIES WITH MULTIPORT VALVE

MODEL	A DIM.		B DIM.		C DIM.		D DIM.		E DIM.		F DIM.		G DIM.	
	Inches	Metric	Inches	Metric	Inches	Metric	Inches	Metric	Inches	Metric	Inches	Metric	Inches	Metric
TA-30	27"	686mm	22 1/4"	565mm	19 7/8"	505mm	19"	483mm	15 3/8"	390mm	15 3/4"	400mm	32 1/4"	819mm
TA-40	31 5/8"	803mm	26 7/8"	683mm	24 1/2"	622mm	23 5/8"	600mm	15 3/8"	390mm	18 3/4"	476mm	41 5/8"	1057mm
TA-50	34"	864mm	29 1/4"	743mm	26 7/8"	683mm	26"	660mm	15 3/8"	390mm	21 1/4"	540mm	46"	1168mm
TA-60	37"	940mm	32 1/4"	820mm	29 7/8"	759mm	29"	737mm	15 3/8"	390mm	24"	610mm	51 3/4"	1315mm



FILTER OPERATIONAL DATA

MODEL	FILTER AREA		FLOW RATE		TURNOVER IN (HOURS)							
					6		8		10		12	
	Sq. Ft.	M2	G.P.M.	Liters	Gallons	Liters	Gallons	Liters	Gallons	Liters	Gallons	Liters
TA-30	1.3	.120	30	114	10,800	40,878	14,400	54,504	18,000	68,130	21,600	81,756
TA-40	1.8	.167	40	151	14,400	54,504	19,200	72,672	24,000	90,840	28,800	109,008
TA-50	2.3	.214	50	189	18,000	68,130	24,000	90,840	30,000	113,550	36,000	136,260
TA-60	3.1	.288	60	227	22,680	85,843	30,240	114,458	37,800	143,073	45,360	171,688



ORIGINAL
ILLEGIBLE

Approved 11/4/81 JPK
ROLLING HILLS DRIVE (50')

ROLLING HILLS COURT (50')

NOTES:
ELEVATIONS ON USC & GS DATUM
57.1 = EXISTING ELEVATION
PUBLIC WATER AVAILABLE
10' MINIMUM BETWEEN S.P. & WATER LINE

PLOT PLAN
LOT 16 BLOCK 1385-A
TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY

A8966

CENTRAL JERSEY ENGINEERS, INC.
1182 Ocean Avenue
Lakewood, N.J. 08701

SCALE: 1" = 40'
DRAWN BY: L.S. CH'D BY: L.W.
JOB NO. 1595
DATE: OCT. 11, 1981

Rolling Hills Drive
US 9330