

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 1

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
11/06/2019	12/23/2019	0046.02	P	R&S Landscaping	18 Birch Street
		Violation:		Fire Protection System - Records of all tests Smoke Alarm Report	Abate by: 12/23/2019
		Violation:		Means of Egress - Emergency Lighting	Abate by: 12/23/2019
10/24/2019	11/29/2019	0014	P	Jacobsen Landscaping	41 Birch Street
		Violation:		Fire Extinguishers - Outdated or discharged	Abate by: 11/29/2019
10/24/2019	12/16/2019	0013	P	D.T. Allen	11-15 Birch Street
		Violation:		Fire Extinguishers - Outdated or discharged (Dated 2017)	Abate by: 12/16/2019
		Violation:		Fire Protection System - Records of all tests (Smoke)	Abate by: 12/16/2019
		Violation:		Means of Egress - Locks Barrel Bolt needs to be removed	Abate by: 12/16/2019
		Violation:		Means of Egress - Emergency Lighting	Abate by: 12/16/2019
		Violation:		General Conditions - Storage of flammable and combustible materials (Fuel Tank next to Building)	Abate by: 12/16/2019
10/24/2019	11/29/2019	0015	P	Legends Pub	11 Central
		Violation:		Fire Protection System - Records of all tests (Smoke Alarm/ Pull Station)	Abate by: 11/29/2019
12/13/2019	01/31/2020	0072	P	The DePhilips Center	50 Dairy St.
		Violation:		Means of Egress - Emergency Lighting & Exit Light Battery Back Up's	Abate by: 01/31/2020
		Violation:		Installation of Carbon Monoxide Detectors	Abate by: 01/31/2020
		Violation:		Means of Egress - Readily openable	Abate by: 01/31/2020
		Violation:		Electrical - Clearance (Electrical Panels Blocked)	Abate by: 01/31/2020
		Violation:			Abate by: 01/31/2020
10/21/2019	11/29/2019	0024	P	Wendy's Hamburger	31 Godwin Ave
		Violation:		Means of Egress - Emergency Lighting (By entrance of Corral)	Abate by: 11/29/2019
		Violation:		Means of Egress - Exit signs/directional signs (Appears to be out.)	Abate by: 11/29/2019
10/21/2019	11/22/2019	0025.02	P	Dutch Girl Cleaners	80 Godwin Ave
		Violation:		Electrical - Improper electrical (Cord connected to wall mounted fan)	Abate by: 11/22/2019
		Violation:		Fire Doors - Opening in walls, ceilings	Abate by: 11/22/2019
10/21/2019	11/22/2019	0026.04	P	Pizzaiolo by Brothers	85 Godwin Ave Unit 17
		Violation:		Means of Egress - Emergency Lighting	Abate by: 11/22/2019
10/18/2019	11/22/2019	0026.02	P	Midland Park Cleaners	85 Godwin Ave. AKA 105 Godwin Ave. Unit 23
		Violation:		General Conditions - General Conditions Contributing to fire- Basement/ Lint Behind Dryers	Abate by: 11/22/2019

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 2

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
10/21/2019	11/22/2019	0026.05	P	Unleashed by Petco #5829	85 Godwin Ave. Unit 16
			Violation:	Fire Protection System - Records of all tests Smoke/Strobes/Pull Stations	Abate by: 11/22/2019
03/13/2019	04/15/2019	0026.10	R	AT&T Wireless c/o Prime Communication	85 Godwin Ave. Unit 3
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/12/2019
			Violation:	Means of Egress - Readily openable. Inappropriate hardware on door. All components to be removed.	Abate by: 04/12/2019
			Violation:	Failure to Register Fire Prevention/ Building Department for Zoning Certificate	Abate by: 04/12/2019
10/28/2019	11/29/2019	0043	P	Midland Park Library	250 Godwin Ave.
			Violation:	Means of Egress - Emergency Lighting (Inoperable)	Abate by: 11/27/2019
			Violation:	Installation of Carbon Monoxide Detectors (Inoperable)	Abate by: 11/27/2019
			Violation:	Means of Egress - Readily accessible	Abate by: 11/27/2019
11/12/2019	12/30/2019	0078.01	P	Midland Park Boro Hall	280 Godwin Ave.
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 12/30/2019
			Violation:	Means of Egress - Emergency Lighting	Abate by: 12/30/2019
			Violation:	Means of Egress - Readily openable (Inappropriate Hardware)	Abate by: 12/30/2019
			Violation:	Installation of Carbon Monoxide Detectors	Abate by: 12/30/2019
10/29/2019	11/29/2019	0036.06	P	Tassel Toppers LLC	445 Godwin Ave. Suite D
			Violation:	Means of Egress - Egress obstructed	Abate by: 11/28/2019
			Violation:	Electrical - Clearance (Curcuit Panel Box)	Abate by: 11/28/2019
10/29/2019	11/29/2019	0036.07	P	Kessler	445 Godwin Ave. Suite E
			Violation:	Fire Protection System - Records of all tests (Smoke Alarm)	Abate by: 11/28/2019
10/29/2019	11/29/2019	0036.09	P	Lan Associates	445 Godwin Ave. Suite 2A (Mailbox 9)
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 11/29/2019
			Violation:	General Conditions - General Conditions Contributing to fire (Cardboard Stacked)	Abate by: 11/29/2019
			Violation:	Fire Doors - Opening in walls, ceilings (Melt away Tiles)	Abate by: 11/29/2019
			Violation:	General Conditions - General Conditions Contributing to fire (Overabundance of paper on	Abate by: 11/29/2019
01/31/2019	02/28/2019	0040.01	P	Domino's Pizza	648 Godwin Ave. Unit 16-18
			Violation:	Means of Egress - Locks (Two Barrel Bolts have to be removed from door.)	Abate by: 02/28/2019
			Violation:	Means of Egress - Readily openable (Rear Door Closure unit needs to be repaired or replaced)	Abate by: 02/28/2019

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 3

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Cooking Areas - Kitchen (Hood Maintenance Report of being serviced.)	Abate by: 02/28/2019
			Violation:	Fire Protection System - Records of all tests (Smoke Alarm, Pull Stations, Audible Alarm)	Abate by: 02/28/2019
			Violation:	Installation of Carbon Monoxide Detectors	Abate by: 02/28/2019
12/13/2019	01/16/2020	0111.01	P	Tire Discount Center	12 Godwin Avenue
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 01/16/2020
			Violation:	General Conditions - General Conditions Contributing to fire (Needs to be cleaned)	Abate by: 01/16/2020
			Violation:	Means of Egress - Readily accessible (Maintain 30" aisles)	Abate by: 01/16/2020
			Violation:	General Conditions - General Conditions Contributing to fire (Remove all tires outside)	Abate by: 01/16/2020
12/16/2019	01/31/2020	0120	P	Seven Eleven	118 Godwin Avenue
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 01/15/2020
			Violation:	Fire Extinguishers - General location (Require one additional)	Abate by: 01/15/2020
			Violation:	Electrical - Clearance (Remove all in front of Circuit Boxes)	Abate by: 01/15/2020
			Violation:	Means of Egress - Egress obstructed	Abate by: 01/15/2020
			Violation:	Electrical - Multi plug adapters	Abate by: 01/15/2020
			Violation:	Means of Egress - Emergency Lighting & Exit Lights Battery Back up inoperable	Abate by: 01/15/2020
			Violation:	Electrical - Improper electrical	Abate by: 01/15/2020
			Violation:	Fire Doors - Opening in walls, ceilings	Abate by: 01/15/2020
11/08/2019	12/30/2019	0126.02	P	C.R.C. of Midland Park Youth Group	179 Godwin Avenue
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 12/08/2019
11/08/2019	12/30/2019	0126.03	P	Christian Reformed Church of Midland Park(school)	183 Godwin Avenue
			Violation:	Electrical - Clearance (Electrical Panel Blocked)	Abate by: 12/30/2019
12/06/2019	01/13/2020	0156	P	Midland Park United Methodist Church	269 Godwin Avenue
			Violation:	Fire Protection System - Records of all tests (Smoke Alarm Report)	Abate by: 01/13/2020
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 01/13/2020
			Violation:	Means of Egress - Emergency Lighting Same as Exit Lights	Abate by: 01/13/2020
			Violation:	Cooking Areas - Kitchen Hood	Abate by: 01/13/2020
02/24/2020	03/27/2020	0139.01	P	One Body Matrix LLC	291 Godwin Avenue Unit #1
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/27/2020
			Violation:	General Conditions - General Conditions Contributing to fire. Possible water leak near	Abate by: 03/27/2020
			Violation:	Electrical - Improper electrical. Water leak in ceiling of bathroom near light fixture.	Abate by: 03/27/2020
02/25/2020	03/27/2020	0139.03	P	Zenaida Fabrics	291 Godwin Avenue
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/27/2020
			Violation:	Means of Egress - Emergency Lighting (Battery Back inoperable)	Abate by: 03/27/2020

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 4

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/15/2019	06/26/2019	0224	P	Midland Park Ambulance Corps, Inc.	471 Godwin Avenue
			Violation:	Test Records Per Fire Code- Smoke Detectors & Sprinkler System.	Abate by: 06/26/2019
			Violation:	Means of Egress - Emergency Lighting	Abate by: 06/26/2019
09/18/2019	10/18/2019	0128	P	Atlantic Stewardship	612 Godwin Avenue
			Violation:	Test Records Per Fire Code- Sprinkler/Smoke/Generator Test reports	Abate by: 10/18/2019
			Violation:	Emergency Lighting- Battery Back up inoperable)	Abate by: 10/18/2019
09/18/2019	10/18/2019	0171	P	Columbia Bank	630 Godwin Avenue
			Violation:	Test Records Per Fire Code- Sprinkler/Smoke alarm Generator, Test reports	Abate by: 10/18/2019
			Violation:	Fire Protection System - Maintenance Sprinkler heads to maintain proper clearance	Abate by: 10/18/2019
			Violation:	Electrical - Clearance Maintain clearance around electrical panels.	Abate by: 10/18/2019
			Violation:	Means of Egress - Exit signs/directional signs (Battery Back up inoperable)	Abate by: 10/18/2019
03/08/2019	04/08/2019	0177	P	Midland Park Veterinary Hospital	70 Goffle Road
			Violation:	Means of Egress - Exit signs/directional signs, inoperable.	Abate by: 04/08/2019
			Violation:	Means of Egress - Emergency Lighting, inoperable, battery back up not working.	Abate by: 04/08/2019
			Violation:	Fire Extinguishers - Outdated or discharged. Not inspected looking to purchase new.	Abate by: 04/08/2019
			Violation:	Electrical - Open electrical junction boxes. Ceramic fixtures hanging from wires & open junction	Abate by: 04/08/2019
			Violation:	Installation of Carbon Monoxide Detectors. Need battery replacements.	Abate by: 04/08/2019
12/12/2019	12/31/2019	0055.01	R	Grainview Designs Inc.	231 Greenwood Ave
			Violation:	Means of Egress - Emergency Lighting (Inoperable)	Abate by: 12/23/2019
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 12/23/2019
			Violation:	Means of Egress - Egress obstructed	Abate by: 12/23/2019
11/07/2019	12/23/2019	0046.01	P	R&S Landscaping	27 Greenwood Ave.
			Violation:	Fire Protection System - Records of all tests Smoke Alarm Report	Abate by: 12/23/2019
			Violation:	Fire Extinguishers - Proper mounting (Cannot be sitting on floor)	Abate by: 12/23/2019
10/31/2019	12/16/2019	0049.10	P	McGinley Packaging	80 Greenwood Ave. Suite 8
			Violation:	Means of Egress - Egress obstructed	Abate by: 11/30/2019
			Violation:	General Conditions - MSDS sheets	Abate by: 11/30/2019
10/29/2019	11/29/2019	0042	P	Trim Auto Body (Quality Corp)	139 Greenwood Ave.
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 11/29/2019
			Violation:	Fire Protection System - Records of all tests (Sprinkler)	Abate by: 11/29/2019
			Violation:	Means of Egress - Egress obstructed	Abate by: 11/29/2019

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 5

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
10/29/2019	11/29/2019	0054.01	P	Godwin Tool and Hardware	189 Greenwood Ave. 1st Floor
			Violation:	Means of Egress - Readily accessible	Abate by: 11/29/2019
			Violation:	Fire Protection System - Records of all tests (Smoke Alarm Report)	Abate by: 11/29/2019
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 11/29/2019
			Violation:	Means of Egress - Emergency Lighting	Abate by: 11/29/2019
			Violation:	Means of Egress - Egress obstructed (Maintain 42" aisle spacing)	Abate by: 11/29/2019
10/28/2019	12/16/2019	0058	P	Greg's Coachworks LLC	278 Greenwood Ave.
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 12/16/2019
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 12/16/2019
			Violation:	Means of Egress - Egress obstructed	Abate by: 12/16/2019
			Violation:	General Conditions - Storage of flammable and combustible materials	Abate by: 12/16/2019
11/06/2019	12/23/2019	0059.03	P	Office Concepts Group, Inc.	301 Greenwood Ave.
			Violation:	Means of Egress - Emergency Lighting (Back up Battery inoperable)	Abate by: 12/23/2019
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 12/23/2019
			Violation:	Distance Between Heater Units (Materials too close to heaters)	Abate by: 12/23/2019
			Violation:	Means of Egress - Storage (48" between aisles)	Abate by: 12/23/2019
10/28/2019	11/29/2019	0060	P	Bob's Friendly Auto Repairs	312 Greenwood Ave.
			Violation:	Means of Egress - Egress obstructed (Aisles)	Abate by: 11/29/2019
10/31/2019	12/23/2019	0049.12	P	Pattman Plumbing, Heating & A.C.	80 Greenwood Ave.- Suite 10
			Violation:	Means of Egress - Emergency Lighting	Abate by: 12/23/2019
			Violation:	Distance Between Heater Units	Abate by: 12/23/2019
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 12/23/2019
10/31/2019	12/16/2019	0048.03	P	Game Seven Marketing & Productions	59 Greenwood Ave.- Unit 10
			Violation:	General Conditions - General Conditions Contributing to fire (Overloading aisles)	Abate by: 11/30/2019
			Violation:	Electrical - Improper electrical (Hanging warehouse fan in unsafe condition)	Abate by: 11/30/2019
10/31/2019	12/09/2019	0048.04	P	Wyckoff YMCA	59 Greenwood Ave.- Unit 2
			Violation:	Means of Egress - Emergency Lighting inoperable	Abate by: 12/09/2019
			Violation:	Means of Egress - Egress obstructed	Abate by: 12/09/2019
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 12/09/2019
10/31/2019	12/16/2019	0048.06	P	Bevcon Group	59 Greenwood Ave.- Unit 5
			Violation:	Means of Egress - Emergency Lighting-(2 Inoperable)	Abate by: 11/30/2019
			Violation:	Means of Egress - Readily openable (Door Jam Swelled)	Abate by: 11/30/2019
			Violation:	Fire Protection System - Maintenance (Stand Pipe System missing shut off Wheel)	Abate by: 11/30/2019
			Violation:	Electrical - Clearance (30 Width x 36 Depth x 78	Abate by: 11/30/2019

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 6

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Height must be maintained)	
11/06/2019	12/23/2019	0055.03	P	The Hitting Zone LLC	231 Greenwood Avenue Tenant
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 12/23/2019
03/04/2019	04/04/2019	0145	C	Elzahra Education Foundation	218 Irving Street
			Violation:	Means of Egress - Egress obstructed (2 locations)	Abate by: 01/31/2019
			Violation:	Fire Extinguishers - General location (Obstructed)	Abate by: 01/31/2019
			Violation:	Emergency Lighting	Abate by: 01/31/2019
			Violation:	Fire Protection System - Maintenance (Missing smoke head)	Abate by: 01/31/2019
			Violation:	Means of Egress - Readily openable (Barrel Bolts) 2 locations	Abate by: 01/31/2019
			Violation:	Fire Protection System - Records of all tests (Smoke Alarm Report)	Abate by: 01/31/2019
			Violation:	Maintaining of Fire Access Roads. Owners responsibility to maintain keep open.	Abate by: 04/04/2019
10/24/2019	12/30/2019	0063	P	Acme #1054	136 Lake St.
			Violation:	Test Records Per Fire Code- Smoke/Sprinkler/Emergency Lights/Generator	Abate by: 12/30/2019
			Violation:	Aisle spacing for Storage & restocking (42" clearance in aisles)	Abate by: 12/30/2019
			Violation:	Means of Egress - Egress obstructed	Abate by: 12/30/2019
			Violation:	Means of Egress - Readily accessible (Fire Door to rear exit off of storage area)	Abate by: 12/30/2019
			Violation:	General Conditions - General Conditions Contributing to fire- (Exterior Display must be	Abate by: 12/30/2019
08/16/2019	10/16/2019	0064.01	P	Kuiken Lumber	145 Lake St. Lumberyard
			Violation:	Fire Protection System - Maintenance (Pull Stations blocked/obstructed)	Abate by: 10/16/2019
			Violation:	Fire Extinguishers - Outdated or discharged (on Majority Expiration date 9/2018)Others outdated.	Abate by: 10/16/2019
			Violation:	Electrical - Improper electrical (Broken Ceramic fixture)	Abate by: 10/16/2019
			Violation:	Means of Egress - Storage (Bales of insulation impeding aisle movement)	Abate by: 10/16/2019
			Violation:	General Conditions - Storage of flammable and combustible materials (Blocking flammable cabinet)	Abate by: 10/16/2019
			Violation:	General Conditions - Securing of compressed gas containers (propane & gas containers)	Abate by: 10/16/2019
			Violation:	Electrical - Improper electrical (broken bulb in fixture)	Abate by: 10/16/2019
			Violation:	Storage Piles of Finished Wood (Not to exceed 20 feet in height)	Abate by: 10/16/2019
			Violation:	Means of Egress - Readily openable (Safety Gates Left in Open Position in 2 locations)	Abate by: 10/16/2019
10/22/2019	11/29/2019	0184.21	P	Fairway Estates	11 Paterson Avenue Unit 19
			Violation:	Electrical - Open electrical junction boxes	Abate by: 11/29/2019

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 7

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
10/22/2019	11/29/2019	0184.22	P	Fairway Estates	11 Paterson Avenue Unit 20
		Violation:	Electrical - Open electrical junction boxes	Abate by: 11/29/2019	
		Violation:	Electrical - Extension cords	Abate by: 11/29/2019	
01/23/2019	02/25/2019	0212.01	P	Cochran Associates, LLC	174 Paterson Avenue Basement
		Violation:	Means of Egress - Readily accessible. Shelving unit on landing before floor in basement.	Abate by: 02/22/2019	
01/23/2019	02/28/2019	0212.02	P	The Emmanuel Cancer Foundation	174 Paterson Avenue 1st Floor
		Violation:	Fire Protection System - Maintenance (Hardwired system may require new heads installed)	Abate by: 02/28/2019	
		Violation:	Fire Doors - Opening in walls, ceilings (Attic door cover missing)	Abate by: 02/28/2019	
		Violation:	Electrical - Multi plug adapters (Multi plug to extension cord to light)Has to be removed &	Abate by: 02/28/2019	
		Violation:	Electrical - Open electrical junction boxes (Rear wall where A/C unit plugged in)	Abate by: 02/28/2019	
		Violation:	Means of Egress - Locks (Hasp/padlock hardware has to be removed. Door lock prohibiting egress.	Abate by: 02/28/2019	
06/25/2019	07/31/2019	0213	P	The Kentshire	187 Paterson Avenue Common Area
		Violation:	Emergency Lighting	Abate by: 07/31/2019	
		Violation:	Means of Egress - Readily accessible	Abate by: 07/31/2019	
		Violation:	Electrical - Open electrical junction boxes	Abate by: 07/31/2019	
		Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/31/2019	
		Violation:	Electrical - Lighting in electrical rooms- Switch in not functioning properly.	Abate by: 07/31/2019	
		Violation:	Fire Extinguishers - Size and distribution- Missing extinguisher from Hook	Abate by: 07/31/2019	
		Violation:	Means of Egress - Storage- Debris stored under staircase.	Abate by: 07/31/2019	
		Violation:	Operating Requirements / Dryer Vents Lint	Abate by: 07/31/2019	
		Violation:	Fire Protection System - Maintenance/ Missing Cap on Stand Pipe Connection	Abate by: 07/31/2019	
		Violation:	Means of Egress - Exit signs/directional signs- Missing	Abate by: 07/31/2019	
		Violation:	Fire Doors - Opening in walls, ceilings/ Fire Doors Missing 2 hour ratable	Abate by: 07/31/2019	
05/16/2019	06/26/2019	0067.01	P	Paradigm Therapeutic Day School	311 Prospect St. AKA 323 Prospect St.
		Violation:	Means of Egress - Exit signs/directional signs	Abate by: 06/26/2019	
		Violation:	Means of Egress - Emergency Lighting	Abate by: 06/26/2019	
10/28/2019	11/29/2019	0085.03	P	Metfab Metals, LLC	16 West Street
		Violation:	Fire Extinguishers - General location (Blocked)	Abate by: 11/29/2019	
		Violation:	Electrical - Clearance (Disconnect Blocked)	Abate by: 11/29/2019	
		Violation:	Means of Egress - Egress obstructed. (create aisle)	Abate by: 11/29/2019	

Midland Park Fire Prevention Bureau
Condensed Inspection Reports
01/01/2019 to 03/31/2020
Printed: 03/04/2020 Page: 8

-----Dates-----

<u>Insp.</u>	<u>Due</u>	<u>Local</u>	<u>Type</u>	<u>Property name</u>	<u>Property address</u>
--------------	------------	--------------	-------------	----------------------	-------------------------

Summary of Inspections for the period:

Periodic Inspections:	48	Time:	09:49
Re-inspections:	2	Time:	0:19
Complaint Investigations:	1	Time:	0:13
Follow-up after Complaint:	0	Time:	0:00