

**Passaic Fire Department
(NJ)**Station: **WS**
Shifts Or Platoon: **Tour 2**Location:
102 MAIN AVE
Passaic NJ 07055Lat/Long:
N 40° 50' 35.04"
W 74° 7' 47.73"Zone:
Engine 4 - E4
Location Type: **1 - Street address**Incident Type:
100 - Fire, otherFDID: **16070**
Incident #: **2024-2709**
Exposure ID: **81115203**
Exposure #: **0**
Incident Date: **08/06/2024**
Dispatch Run #: **24-2709**

Report Completed by:	Kovacs , James	ID: 191	Date: 08/07/2024
Report Reviewed by:	Kovacs , James	ID: 191	Date: 08/07/2024
Report Printed by:	Failla, Toni	ID: ADMIN	Date: 10/2/2024 Time: 10:53

Structure Type:	Property Use: 549 - Specialty shop		
Automatic Extinguishment System Present: ☐	Detectors Present: ☐	Cause of Ignition: Cause under investigation	
Aid Given or Received: None	Primary action taken: 87 - Investigate fire out on arrival		
Additional actions: 51 - Ventilate , 63 - Restore fire alarm system			
Losses	Pre-Incident Values		
Property:	Property:	Civilian Injuries: 0	Fire Service Injuries: 0
Contents:	Contents:	Civilian Fatalities: 0	Fire Service Fatalities: 0
Total:	Total:	Total Casualties: 0	Total Fire Service Casualties: 0
Total # of apparatus on call: 4		Total # of personnel on call: 10	

NARRATIVE (1)**Narrative Title:** LT. J.IVANICKI**Narrative Author:** Ivanicki, Joseph**Narrative Date:** 08/06/2024 12:56:21**Narrative Apparatus ID:** E1**Narrative:**

At 1100 hrs. E-1 responded to 102 Main ave. for a fire alarm activation. Upon arrival members investigated and found a shop vac had caught fire and was put out by the person working in the shop. There was no extension and we used our fan to vent out any smoke from the shop till the system read normal. Command terminated at 1120 hrs.

NARRATIVE (2)**Narrative Title:** BC J. Kovacs**Narrative Author:** Kovacs, James**Narrative Date:** 08/06/2024 15:23:49**Narrative Apparatus ID:** 93**Narrative:**

24-2709: @ 1100 hours Battalion 2 was dispatched to 102 Main Avenue for an activated fire alarm. Battalion 2 established Main Avenue command and investigated with Ladder 1. Light smoke was showing from front door of dental office. Minor fire found out on arrival involving a portable shop vacuum. No extension of fire to the structure confirmed by Ladder 1 with thermal imager. Store front was ventilated with PPV fan. Fire Prevention was notified to respond. Insp. Rios was on scene and will follow-up. FF. J. Wood completed origin and cause investigation. Alarm system was reset to normal mode. Business will remain open for the day. Command terminated all units available @ 1120 hours.

BC J. Kovacs

NARRATIVE (3)**Narrative Title:** Capt J Tuohy**Narrative Author:** Tuohy, John**Narrative Date:** 08/06/2024 16:37:39**Narrative Apparatus ID:** L1**Narrative:**

Incident# 242709- Dispatched to 102 Main Ave for a reported activated fire alarm. Upon arrival found a shop vac on fire that was extinguished. It was removed to the outside and no extension was found using a TIC. The C/O was conducted on scene. Electric fan was used to remove the smoke. The alarm system was reset. R/C @ 1120.

Capt J Tuohy

NARRATIVE (4)**Narrative Title:** Lt. Martinez**Narrative Author:** Martinez, Jorge**Narrative Date:** 08/06/2024 20:31:41**Narrative Apparatus ID:** E2**Narrative:**

At 1100 hours responded to 102 Main Ave for an activated fire alarm. Upon arrival staged on Mass Ct and Main Ave near a hydrant. Members assisted with investigation of a vacuum that caught fire in the business. Area was checked with a TIC and was clear. Released by command and available at 1120 hours.

Lt. Martinez

APPARATUS

Unit	E1	Unit	93
Type:	Engine	Type:	Chief officer car
Use:	Suppression	Use:	Suppression
Response Mode:	Lights and Sirens	Response Mode:	Lights and Sirens
# of People	3	# of People	1
Alarm	08 /06/2024 10:59:00	Alarm	08 /06/2024 10:59:00
Dispatched	08 /06/2024 11:00:00	Dispatched	08 /06/2024 11:00:00
Enroute	-- / -- / -- -- : -- : --	Enroute	-- / -- / -- -- : -- : --
Arrived	08 /06/2024 11:05:00	Arrived	08 /06/2024 11:05:00
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	08 /06/2024 11:20:00	Cleared Scene	08 /06/2024 11:20:00
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	-- / -- / -- -- : -- : --	In Service	-- / -- / -- -- : -- : --
Unit	L1	Unit	E2
Type:	Truck or aerial	Type:	Engine
Use:	Suppression	Use:	Suppression
Response Mode:	Lights and Sirens	Response Mode:	Lights and Sirens
# of People	3	# of People	3
Alarm	08 /06/2024 10:59:00	Alarm	08 /06/2024 10:59:00
Dispatched	08 /06/2024 11:00:00	Dispatched	08 /06/2024 11:00:00
Enroute	-- / -- / -- -- : -- : --	Enroute	-- / -- / -- -- : -- : --
Arrived	08 /06/2024 11:05:00	Arrived	08 /06/2024 11:05:00
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	08 /06/2024 11:20:00	Cleared Scene	08 /06/2024 11:20:00
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	-- / -- / -- -- : -- : --	In Service	-- / -- / -- -- : -- : --

Number Of People not on apparatus: 0

FIRE

Acres Burned	None or Less Than One	Acres Burn From Wildland Form	False
Area Of Fire Origin	Processing/manufacturing area, workroom	Heat Source	Hot ember or ash
Item First Ignited	Appliance housing or casing	Fire Is Confined To Object Of Origin	
Type Of Material	Plastic	Cause Of Ignition	Cause under investigation
Factor Contributing To Ignition	Cutting, welding too close to combustible		
Human Factors Contributing	None		

ARSON

Agency Name	Agency Address	Agency Phone
Passaic Fire Prevention Bureau	330 Passaic Street	

CUSTOM FIELDS FORM**Is this response related to a Lithium-Ion battery fire / explosion / incident?**

NO

COVID-19 (Coronavirus) presumptive related incident/response?

UNKNOWN

Is this CIVIL UNREST / PROTEST / RIOT Related?

NO, this is NOT attributed to a CIVIL UNREST / PROTEST / RIOT situation

Were FIRE HYDRANT(s) blocked at this fire/emergency scene? (If yes, notify police immediately).

No

If this was a restaurant, bar, night club or any other place of gathering, was HOOKAH (or any other tobacco product) being smoked?

NO

Were CO (Carbon Monoxide) levels present?

NO

Member Making Report (Battalion Chief James Kovacs): _____

Incident Reviewer (Battalion Chief James Kovacs): _____