

#25-1726

OPRA

From: Nathan Stallone <opra+request-81182-61640ccd@requests.opramachine.com>
Sent: Monday, September 22, 2025 10:52 AM
To: OPRA
Subject: OPRA request - Opra Request

Dear Bayonne City,

Please accept this electronic request for public records made under OPRA and the common law right of access. I am not required to fill out an official form or use a particular software platform to submit my request per NISA 47:1A-6(f), which states that an email from a requestor including all of the information required on the adopted form shall suffice in place of a completed form as a valid government record request.

I HAVE NOT been convicted of any indictable offense under the laws of New Jersey, any other state, or the United States.

33 pages attached
9/23/25

I WILL use the requested government records for a commercial purpose.

I AM NOT seeking records in connection with a legal proceeding.

Records requested:

Tax Delinquent

- A list of all property addresses that have an unpaid property tax bill for [redacted] or separately a list of properties whose property tax bill was lien[redacted] again[redacted]

Water Shut Off / Utility Liens

- A list of all property addresses that have had their water bill lien[redacted] against the property, have failed to pay their water bill, or have had the water shut off at any point in the last 6 months.

RECEIVED
CLERK'S OFFICE
BAYONNE, NJ 07002
SEP 23 2025

Fire Damage List

- A list of all property addresses that the fire department has received an emergency call to in the last 90 days.

23.1

Code Violation

- A list of property addresses that have received any code violations in the last 6 months

Vacant List

- A list of all properties that the city deems to be currently vacant or abandoned.

My preferred delivery method for response(s) to this request is by E-mail as attachments. Please confirm you have received this request. If you are not the custodian of records, please forward my request to that person and provide their email address to me for future reference.

Yours faithfully,

Nathan

Please deliver records electronically via email to the below UNIQUE address for all replies to this request:

opra+request-81182-61640ccd@requests.opramachine.com

Is oprarequest@baynj.org the wrong address for OPRA requests to Bayonne City? If so, please contact us using this form:
https://opramachine.com/change_request/new?body=bayonne_city

Disclaimer: This message and any reply that you make will be published on the internet. Our privacy and copyright policies:

<https://opramachine.com/help/officers>

View this OPRA request & responses online:

https://opramachine.com/request/opra_request_1153619

RECEIVED
CITY CLERK'S OFFICE
BAYONNE, NJ 07001

SEP 27 2010

VACANT PROPERTIES

System ID#	Occupancy Name	Address	State Reg#
11560	Vacant	420 Avenue C,BLDG	
11491	THE HAGDORN REAL ESTATE GROUP	737 Broadway,STREET	BUSINESS / OFFICE
11275	Superior-MPM, LLC	70 Hobart Ave	
11239	Synagogue/Offices 1012-1020 AVENUE C	1012 Avenue C,BLDG	OFFICE / SYNAGOGUE
11238	Synagogue (1022 AVENUE C)	1022 Avenue C,BLDG	SYNAGOGUE
10964	136 W 54TH STR	136 W 54th St,BLDG	2 Family
9443	Queen House	1055 Avenue C,1	BUSINESS / SALON
8068	C Steam	538 Kennedy Blvd,A	BUSINESS / FOOD
6402	The Palace Entertainment	473 Broadway,313	BUSINESS / OFFICE
6400	S & S Limousine	473 Broadway,205	BUSINESS / OFFICE
6398	Broadway Podiatry	473 Broadway,203	BUSINESS / OFFICE
3845	Madame Amelia Makeup Artistry & Photography LLC	1091 Avenue C,STREET	OOB - OPEN REG FEES
2926	62-64 W 2nd St	62 W 2nd St	BUSINESS / INDUSTRIAL
2780	95 W 9th St	35 W 20th St	1 Family
1577	Safety Supplies Unlimited	200 Broadway	BUSINESS / STORE
1290	Furniture Store 484-486 Avenue C	484 Avenue C	BUSINESS / STORE
319	Assumption Church	91 W 23rd St	PLACARD / VACANT
180	89 W 19th Str	89 W 19th St	4 UNITS LEA-
38	86 West 13th Street	86 W 13th St,BLDG	3 UNITS LEA-

Please be advised some of these may have updated or sold

Incident Date	Incident#	Location	CFS	Incident Type
9/19/2025 4:41:18 PM	2025003971	812 Broadway, Bayonne, NJ 07002	F1	Building fire
9/15/2025 2:45:03 AM	2025003904	1080 Kennedy Blvd,BSMT, Bayonne, NJ 07002	F1W	Building fire
8/31/2025 4:50:13 PM	2025003676	41 W 44th St, Bayonne, NJ 07002	F1	Building fire
8/12/2025 10:17:04 AM	2025003384	180 Avenue C, Bayonne, NJ 07002	F1	Building fire
7/24/2025 1:37:44 AM	2025003112	W 48th St/, Bayonne, NJ 07002	F1W	Building fire
7/20/2025 2:08:42 PM	2025003056	94 W 22nd St,1, Bayonne, NJ 07002	F1W	Building fire
6/27/2025 11:00:07 PM	2025002666	48 W 53rd St,2FLR, Bayonne, NJ 07002	F1	Building fire
6/24/2025 5:03:39 AM	2025002588	12 E 49th St,2, Bayonne, NJ 07002	F1W	Building fire

VIOLATIONS				
EnteredDate	Category	Action	ViolationCode	Status Occupancy
09/04/2025			N.J.A.C. 5:70-3, 901.6	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 315.3.1	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 604.3	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 604.4	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 906.2	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 904.5	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 604.1	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 604.4	New 1 Flagship St
09/04/2025			N.J.A.C. 5:70-3, 5003.1.4	New 1 Flagship St
05/30/2025			N.J.A.C.5:70-2.6	Unabated 1 Flagship St,APT 1
07/14/2025		Kitchen suppression	N.J.A.C. 5:70-3, 904.5	Unabated 400 Route 440 N
08/05/2025		State LHU Fees	N.J.A.C.5:70-2.6	New 400 Route 440 N,BLDG
06/09/2025			N.J.A.C. 5:70-3, 903.5	New 100 Carl Brashear Dr,BLDG
07/11/2025			N.J.A.C. 5:70-3, 505.1	Unabated 99 Avenue E,BLDG
07/11/2025			N.J.A.C. 5:70-3, 1008.2	Unabated 99 Avenue E,BLDG
07/11/2025			N.J.A.C. 5:70-3, 1031.3	Unabated 99 Avenue E,BLDG
07/11/2025			N.J.A.C. 5:70-3, 604.6	New 99 Avenue E,BLDG
07/11/2025			N.J.A.C. 5:70-3, 1031.7.3	New 99 Avenue E,BLDG
07/11/2025			N.J.A.C.5:70-4.7	New 99 Avenue E,BLDG
09/12/2025			N.J.A.C. 5:70-3, 907.8	New 154 Avenue E,BLDG
09/12/2025			N.J.A.C. 5:70-3, 903.5	New 154 Avenue E,BLDG
09/12/2025			N.J.A.C. 5:70-3, 905.11	New 154 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 1031.7.3	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C.5:70-4.7	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 1031.2	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 1031.2	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 1031.2	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 907.8.5	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 1013.3	New 235 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 907.8.1	Unabated 478 Avenue E,2FLR
09/19/2025			N.J.A.C. 5:70-3, 315.3.2	Unabated 478 Avenue E,2FLR
09/19/2025			N.J.A.C.5:70-2.16	New 478 Avenue E,2FLR
09/05/2025			N.J.A.C. 5:70-3, 904.5	Unabated 478 Avenue E,BLDG
09/05/2025			N.J.A.C. 5:70-3, 1031.10	Unabated 478 Avenue E,BLDG
09/05/2025			N.J.A.C. 5:70-3, 901.4.1	Unabated 478 Avenue E,BLDG
09/05/2025			N.J.A.C. 5:70-3, 604.1	Unabated 478 Avenue E,BLDG
09/05/2025			N.J.A.C. 5:70-3, 5303.5.3	Unabated 478 Avenue E,BLDG
09/05/2025			N.J.A.C. 5:70-3, 604.5	Unabated 478 Avenue E,BLDG
09/19/2025			N.J.A.C. 5:70-3, 907.8.5	New 478 Avenue E,BLDG
09/19/2025			N.J.A.C.5:70-2.16	New 478 Avenue E,BLDG
06/13/2025			N.J.A.C. 5:70-3, 917.1	Unabated 318 Avenue E,BLDG
06/13/2025			N.J.A.C. 5:70-3, 1203.4.2.1	Unabated 318 Avenue E,BLDG
07/14/2025			N.J.A.C. 5:70-3, 903.5	New 258 Avenue E
07/14/2025			N.J.A.C. 5:70-3, 907.8	New 258 Avenue E
07/02/2025			N.J.A.C. 5:70-3, 907.10.1	New 797 Avenue E
07/03/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated 320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 604.4	Unabated 320 Avenue A,BLDG

07/03/2025			N.J.A.C. 5:70-3, 915.6	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 907.8	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 907.8	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 907.8	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 907.8	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 604.1	Unabated	320 Avenue A,BLDG
07/03/2025			N.J.A.C. 5:70-3, 1031.3	Unabated	320 Avenue A,BLDG
09/11/2025		Exit sign light battery out	N.J.A.C. 5:70-3, 1031.8	New	92 Avenue A,BLDG
06/27/2025			N.J.A.C. 5:70-3, 901.6	New	175 Avenue A,1
06/27/2025			N.J.A.C. 5:70-3, 901.6	New	175 Avenue A,2
09/15/2025			N.J.A.C. 5:70-3, 304.1.2	New	752A Avenue E,BLDG
07/02/2025			N.J.A.C. 5:70-3, SECTION 607	New	667 Avenue A
06/30/2025		Fire alarm system	N.J.A.C. 5:70-3, 901.6	New	672 Avenue A,BLDG
06/30/2025		Alarm shstem reports	N.J.A.C. 5:70-3, 901.6.3	New	672 Avenue A,BLDG
09/12/2025			N.J.A.C. 5:70-3, SECTION 906	New	304 Avenue C,BLDG
07/10/2025		Combustible waste Storage	N.J.A.C. 5:70-3, 304.1.1	New	321 Avenue C,BLDG
07/10/2025		Electrical	N.J.A.C. 5:70-3, 604.1	New	321 Avenue C,BLDG
08/20/2025			N.J.A.C. 5:70-3, 1010.1.9.5	New	326 Avenue C,BLDG
08/20/2025			N.J.A.C. 5:70-3, SECTION 915	New	326 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 907.8.1	New	336 Avenue C,2
09/17/2025			N.J.A.C.5:70-2.6	New	336 Avenue C,2
09/17/2025			N.J.A.C. 5:70-3, 901.6	New	336 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 1031.7.3	New	336 Avenue C,BLDG
09/17/2025			N.J.A.C.5:70-4.7	New	336 Avenue C,BLDG
07/11/2025			N.J.A.C. 5:70-3, 1031.2	Unabated	352 Avenue C,BLDG
07/11/2025			N.J.A.C. 5:70-3, 509.1.1	Unabated	352 Avenue C,BLDG
07/11/2025			N.J.A.C. 5:70-3, 604.4	Unabated	352 Avenue C,BLDG
07/11/2025			N.J.A.C. 5:70-3, 907.10.1	Unabated	352 Avenue C,BLDG
08/12/2025			N.J.A.C.5:70-4.7	New	352 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 311.2.2	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 901.6	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 703.1	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 311.2.2	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 1010.1.9	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 1031.7.3	New	383 Avenue C,BLDG
09/17/2025			N.J.A.C. 5:70-3, 906.2	New	383 Avenue C,BLDG
08/28/2025			N.J.A.C. 5:70-3, 917.1	New	392 Avenue C
07/30/2025		Fire Alarm Reports	N.J.A.C. 5:70-3, 907.8.5	New	393 Avenue C,BLDG
07/30/2025		Roof access	N.J.A.C. 5:70-3, 1031.1	New	393 Avenue C,BLDG
07/30/2025		Fire alarm system	N.J.A.C. 5:70-3, 901.6	New	393 Avenue C,BLDG
08/28/2025			N.J.A.C. 5:70-3, 903.5	New	413 Avenue C,BLDG
08/28/2025			N.J.A.C. 5:70-3, 315.3.2	New	413 Avenue C,BLDG
08/28/2025			N.J.A.C. 5:70-3, 315.3.2	New	413 Avenue C,BLDG
08/28/2025			N.J.A.C. 5:70-3, 703.1	New	413 Avenue C,STREET
08/28/2025			N.J.A.C. 5:70-3, 304.1	New	413 Avenue C,STREET
08/28/2025			N.J.A.C. 5:70-3, 604.3.1	New	413 Avenue C,STREET
08/28/2025			N.J.A.C. 5:70-3, 604.4	New	413 Avenue C,STREET
08/28/2025			N.J.A.C. 5:70-3, 604.1	New	413 Avenue C,STREET
05/14/2025		All emergency lighting in business not operational	N.J.A.C. 5:70-3, 1031.10	Unabated	482 Avenue C,BLDG

08/06/2025			N.J.A.C. 5:70-3, 307.1.1	New	630 Avenue C,1FLR
08/06/2025			N.J.A.C.5:70-4.7	New	630 Avenue C,1FLR
08/13/2025		Up to date alarm test report needed	N.J.A.C. 5:70-3, 901.6	New	464 Avenue C
08/14/2025			N.J.A.C. 5:70-3, 304.1	New	727 Avenue C,BLDG
05/20/2025			N.J.A.C.5:70-4.7	Unabated	1075 Avenue C,BLDG
09/12/2025			N.J.A.C. 5:70-3, 1031.4	New	183 Broadway
05/22/2025		Monitored Fire alarm	N.J.A.C. 5:70-3, 907.6.6	Unabated	1053 Avenue C,BLDG
08/01/2025		Electrical Hazards	N.J.A.C. 5:70-3, 604.1	New	1053 Avenue C,BLDG
05/22/2025		Fire Alarm System	N.J.A.C. 5:70-3, 907.8.5	Unabated	1053 Avenue C,BLDG
05/22/2025		Fire alarm systems	N.J.A.C. 5:70-3, 907.8.2	Unabated	1053 Avenue C,BLDG
05/22/2025		Means of Egress	N.J.A.C. 5:70-3, 1031.3	Unabated	1053 Avenue C,BLDG
06/23/2025			N.J.A.C. 5:70-3, 903.5	Unabated	372 Broadway
07/09/2025			N.J.A.C. 5:70-3, 907.8.2	Unabated	375 Broadway,1
07/09/2025			N.J.A.C. 5:70-3, 506.1	Unabated	375 Broadway,1
07/09/2025			N.J.A.C. 5:70-3, 315.3.1	Unabated	375 Broadway,1
07/09/2025			N.J.A.C. 5:70-3, 907.8.2	Unabated	375 Broadway,BLDG
07/09/2025			N.J.A.C. 5:70-3, 506.1	Unabated	375 Broadway,BLDG
07/09/2025			N.J.A.C. 5:70-3, 315.3.1	Unabated	375 Broadway,BLDG
09/05/2025		System shall be Operational at all times. Fire Alarm Systems- Tested annually	N.J.A.C. 5:70-3, 907.8.5	New	394 Broadway,1
09/05/2025		Carbon monoxide alarms shall be maintained in accordance with NFPA 720	N.J.A.C. 5:70-3, SECTION 915	New	394 Broadway,1
09/05/2025			N.J.A.C. 5:70-3, 604.5	New	394 Broadway,1
08/19/2025			N.J.A.C. 5:70-3, SECTION 315	Unabated	394 Broadway,BLDG
09/18/2025			N.J.A.C. 5:70-3, 901.7	New	387 Broadway
08/15/2025		Means of egress	N.J.A.C. 5:70-3, 1001.2.1	New	460 Broadway,BLDG
08/15/2025		Windoless basement	N.J.A.C.5:70-4.7	New	460 Broadway,STREET
09/08/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	801 Broadway
04/21/2025			N.J.A.C.5:70-2.9	New	631 Broadway,BLDG
05/08/2025			N.J.A.C.5:70-2.6	Unabated	1028 Avenue C
06/13/2025			N.J.A.C.5:70-2.6	Unabated	1028 Avenue C
07/09/2025			N.J.A.C. 5:70-3, 907.8.2	New	537 Broadway,BLDG
07/09/2025			N.J.A.C. 5:70-3, 903.5	New	537 Broadway,BLDG
07/18/2025			N.J.A.C. 5:70-3, 1031.10	New	552 Broadway,BLDG
08/12/2025			N.J.A.C. 5:70-3, 903.5	Unabated	906 Broadway,BLDG
08/12/2025			N.J.A.C. 5:70-3, 901.6	Unabated	906 Broadway,BLDG
06/30/2025		Combustible waste material	N.J.A.C. 5:70-3, 304.1	New	911 Broadway,2
06/30/2025		Means of egress	N.J.A.C. 5:70-3, 1031.1.1	New	911 Broadway,2
06/18/2025		Kitchen suppression shstem	N.J.A.C. 5:70-3, 904.5.1	Unabated	911 Broadway,2
06/18/2025		Hood cleaning	N.J.A.C. 5:70-3, 607.3.3.3	Unabated	911 Broadway,2
06/18/2025		Hood cleaning	N.J.A.C. 5:70-3, 607.3.3.2	Unabated	911 Broadway,2
06/18/2025		Extension cords	N.J.A.C. 5:70-3, 604.5	Unabated	911 Broadway,2
09/19/2025			N.J.A.C.5:70-2.6	New	906 Broadway,STREET
06/23/2025			N.J.A.C. 5:70-3, 907.8	New	1011 Broadway,2FLR
06/23/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	1011 Broadway,BLDG
06/23/2025			N.J.A.C. 5:70-3, 403.15.4.4	Unabated	1011 Broadway,BLDG
05/12/2025		No entry		New	37 Dodge St
08/25/2025		Egress doors	N.J.A.C. 5:70-3, 1010.4	Unabated	5 Kelly Pkwy,BLDG
08/25/2025		Fire extinguishers	N.J.A.C. 5:70-3, 906.2	Unabated	5 Kelly Pkwy,BLDG
08/25/2025		Exterior grounds maintenance	N.J.A.C. 5:70-3, 304.1.2	Unabated	5 Kelly Pkwy,BLDG
08/25/2025		Combustible waste storage	N.J.A.C. 5:70-3, 304.2	Unabated	5 Kelly Pkwy,BLDG

05/02/2025		Extinguishers	N.J.A.C. 5:70-3, 906.2	New	45 Kelly Pkwy,BLDG
05/02/2025		Alarm system	N.J.A.C. 5:70-3, 907.8	New	45 Kelly Pkwy,BLDG
05/02/2025		Alarm system	N.J.A.C. 5:70-3, 907.8.1	New	45 Kelly Pkwy,BLDG
05/02/2025		Windowless basement	N.J.A.C.5:70-4.7	New	41-43 Kelly Pkwy
05/02/2025		Fire extonguishers	N.J.A.C. 5:70-3, 906.2	New	41-43 Kelly Pkwy
05/02/2025			N.J.A.C. 5:70-3, 907.8.5	New	41-43 Kelly Pkwy
05/02/2025		Alarm system	N.J.A.C. 5:70-3, 907.8.5	New	41-43 Kelly Pkwy
05/02/2025		Dryer exhast	N.J.A.C. 5:70-3, 610.1.2	New	41-43 Kelly Pkwy
08/15/2025		Fire alarm system	N.J.A.C. 5:70-3, 907.8.5	Unabated	40 Kennedy Blvd
08/15/2025		Gas meters	N.J.A.C. 5:70-3, 603.1.7	Unabated	40 Kennedy Blvd
08/15/2025		Unsafe storage	N.J.A.C. 5:70-3, 304.1	Unabated	40 Kennedy Blvd
08/15/2025		Sprinkler/Standpipe access	N.J.A.C. 5:70-3, 509.2	Unabated	40 Kennedy Blvd
08/15/2025		Back up generators	N.J.A.C. 5:70-3, 907.11	Unabated	40 Kennedy Blvd
08/06/2025			N.J.A.C. 5:70-3, 604.1	New	49 Humphrey Ave
08/21/2025		Outdoor cooking	N.J.A.C. 5:70-3, 308.1.4	Unabated	40 Kennedy Blvd
08/15/2025		Fire rated assemblies	N.J.A.C. 5:70-3, 703.1	Unabated	50 Kennedy Blvd
08/15/2025		Fire alarm system	N.J.A.C. 5:70-3, 907.8.5	Unabated	50 Kennedy Blvd
08/15/2025		Fire rated door maintenance	N.J.A.C. 5:70-3, 705.2	Unabated	50 Kennedy Blvd
08/15/2025		Multiplug adapters/extension cords	N.J.A.C. 5:70-3, 604.1	Unabated	50 Kennedy Blvd
08/15/2025		Storage conditions	N.J.A.C. 5:70-3, 304.2	Unabated	50 Kennedy Blvd
08/15/2025		Back up generators	N.J.A.C. 5:70-3, 907.11	Unabated	50 Kennedy Blvd
08/21/2025		Outdoor cooking	N.J.A.C. 5:70-3, 308.1.4	Unabated	50 Kennedy Blvd
08/12/2025			N.J.A.C. 5:70-3, 5303.7.2	New	77 Kennedy Blvd,BLDG
08/12/2025			N.J.A.C. 5:70-3, 3304.2.1	New	77 Kennedy Blvd,BLDG
06/25/2025			N.J.A.C. 5:70-3, 304.1	Unabated	77 Kennedy Blvd,BLDG
06/25/2025			N.J.A.C. 5:70-3, 5303.7.2	Unabated	77 Kennedy Blvd,BLDG
09/15/2025			N.J.A.C. 5:70-3, 604.1	New	473 Broadway,BLDG
09/15/2025		System shall be Operational at all times. Fire Alarm Systems- Tested annually	N.J.A.C. 5:70-3, 901.6	New	473 Broadway,BLDG
07/14/2025			N.J.A.C. 5:70-3, 901.6	Unabated	483 Broadway
08/19/2025			N.J.A.C.5:70-2.1	New	990 Broadway
08/26/2025		Fire system in trouble silence	N.J.A.C. 5:70-3, 907.8	Unabated	490 Broadway,BLDG
09/11/2025			N.J.A.C. 5:70-3, 907.8.1	New	501 Broadway
04/07/2025		Service required to fix kitchen suppression system.	N.J.A.C. 5:70-3, 607.3.4	New	518 Broadway
07/31/2025			N.J.A.C. 5:70-3, 1010.4	New	9 Gertrude St,1FLR
07/31/2025			N.J.A.C. 5:70-3, 314.4	New	9 Gertrude St,1FLR
04/16/2025		Pallet storage	N.J.A.C. 5:70-3, 315.7.4	Unabated	73-75 Gould St
04/16/2025		Pallet storage	N.J.A.C. 5:70-3, 315.7.2	Unabated	73-75 Gould St
04/23/2025		Sprinkler reports	N.J.A.C. 5:70-3, 901.6	New	73-75 Gould St
06/12/2025		Kitchen Hood System	N.J.A.C. 5:70-3, 904.12.5.2	Unabated	301 Bayonne Crossing Way
06/12/2025		Kitchen hood exhaust	N.J.A.C. 5:70-3, 607.3.3.3	Unabated	301 Bayonne Crossing Way
08/26/2025			N.J.A.C. 5:70-3, 1031.10	New	313 Bayonne Crossing Way
06/13/2025			N.J.A.C. 5:70-3, 903.5	Unabated	400 Bayonne Crossing Way
06/25/2025			N.J.A.C. 5:70-3, 901.6.4	Unabated	907 Bayonne Crossing Way
06/25/2025			N.J.A.C. 5:70-3, 903.5	Unabated	907 Bayonne Crossing Way
08/28/2025			N.J.A.C.5:70-4.7	Unabated	755 Broadway,BLDG
08/28/2025			N.J.A.C. 5:70-3, 308.1.5	Unabated	755 Broadway,BLDG
09/05/2025			N.J.A.C. 5:70-3, 604.1	New	755 Broadway,BLDG
09/05/2025			N.I.A.C. 5:70-3, 906.3	New	755 Broadway,BLDG
09/05/2025			N.J.A.C. 5:70-3, 1031.7.3	New	755 Broadway,BLDG

09/05/2025			N.J.A.C. 5:70-3, 315.3.2	New	755 Broadway,BLDG
09/05/2025			N.J.A.C. 5:70-3, 308.1.4	New	755 Broadway,BLDG
08/18/2025		Maintenance of Exterior Grounds	N.J.A.C. 5:70-3, 304.1.1	New	760 Broadway,BLDG
09/23/2025		Electrical	N.J.A.C. 5:70-3, 604.1	New	41 W 54th St,BLDG
08/20/2025			N.J.A.C.5:70-2.1	New	603 Kennedy Blvd
08/20/2025			N.J.A.C.5:70-2.9	New	603 Kennedy Blvd
09/19/2025		CO Detector Maintenance	N.J.A.C. 5:70-3, 915.6	New	675 Kennedy Blvd,BLDG
09/19/2025		Means of Egress	N.J.A.C. 5:70-3, 1031.2	New	675 Kennedy Blvd,BLDG
07/11/2025			N.J.A.C. 5:70-3, 907.8.2	New	686 Kennedy Blvd,BLDG
07/11/2025			N.J.A.C. 5:70-3, 903.5	New	686 Kennedy Blvd,BLDG
08/12/2025			N.J.A.C. 5:70-3, 901.6.3	Unabated	735 Kennedy Blvd,1FLR
08/12/2025			N.J.A.C. 5:70-3, 505.1	Unabated	735 Kennedy Blvd,1FLR
08/12/2025			N.J.A.C. 5:70-3, 1031.3	Unabated	735 Kennedy Blvd,1FLR
08/12/2025			N.J.A.C.5:70-4.9	Unabated	735 Kennedy Blvd,1FLR
04/10/2025			N.J.A.C. 5:70-3, 907.8	Unabated	555 Kennedy Blvd
04/10/2025			N.J.A.C.5:70-2.9	Unabated	555 Kennedy Blvd
08/08/2025			N.J.A.C.5:70-2.6	Unabated	1159 Kennedy Blvd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	1 Lefante Way,STREET
05/20/2025			N.J.A.C. 5:70-3, 1203.4.2.1	Unabated	1 Lefante Way,STREET
09/19/2025			N.J.A.C. 5:70-3, 507.5.3	New	1 Lefante Way,STREET
06/25/2025			N.J.A.C. 5:70-3, 907.8.1	New	74 Lexington Ave,BLDG
06/05/2025			N.J.A.C. 5:70-3, 1031.7.3	Unabated	17 Linden St,BLDG
06/05/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	17 Linden St,BLDG
09/10/2025		electrical hazards	N.J.A.C. 5:70-3, 604.5	New	123 Newman Ave,BLDG
09/10/2025		outdoor cooking	N.J.A.C. 5:70-3, 308.1.4	New	123 Newman Ave,BLDG
06/25/2025			N.J.A.C. 5:70-3, 1203.4.2.1	New	110 Oak St
06/25/2025			N.J.A.C. 5:70-3, 5003.2.9.2	New	110 Oak St
06/25/2025			N.J.A.C. 5:70-3, 1031.10	New	110 Oak St
06/25/2025			N.J.A.C. 5:70-3, 1010.1.9	New	110 Oak St
06/25/2025			N.J.A.C. 5:70-3, 603.5.2	New	110 Oak St
04/11/2025		Combustible waste accumulation	N.J.A.C. 5:70-3, 304.1.1	Unabated	55 Prospect Ave
09/23/2025		Smoke Detectors	N.J.A.C. 5:70-3, 901.6	New	74 Prospect Ave,BLDG
04/16/2025		Fire extinguisher testing	N.J.A.C. 5:70-3, 906.2	New	20 Pulaski St,BLDG
04/16/2025		Pallet storage	N.J.A.C. 5:70-3, 315.7.4	Unabated	169 Pulaski St,BLDG
04/16/2025		Cardboard boxes	N.J.A.C. 5:70-3, 304.1.1	Unabated	169 Pulaski St,BLDG
04/23/2025		Dangerous conditions	N.J.A.C. 5:70-3, 103.2	Unabated	169 Pulaski St,BLDG
04/23/2025		Inspection reports	N.J.A.C. 5:70-3, 901.6	Unabated	169 Pulaski St,BLDG
04/23/2025		Firewalls	N.J.A.C. 5:70-3, 703.1	Unabated	169 Pulaski St,BLDG
04/23/2025		Fire doors	N.J.A.C. 5:70-3, 705.2	Unabated	169 Pulaski St,BLDG
04/16/2025		Pallet storage	N.J.A.C. 5:70-3, 315.7.2	Unabated	169 Pulaski St,BLDG
04/23/2025		Exit signs	N.J.A.C. 5:70-3, 1013.4	Unabated	169 Pulaski St,BLDG
04/23/2025		Means of egress	N.J.A.C. 5:70-3, 1031.1	Unabated	169 Pulaski St,BLDG
04/23/2025		Eletrical hazards	N.J.A.C. 5:70-3, 604.5	Unabated	169 Pulaski St,BLDG
04/23/2025			N.J.A.C. 5:70-3, 604.4	Unabated	169 Pulaski St,BLDG
04/23/2025			N.J.A.C. 5:70-3, 604.3	Unabated	169 Pulaski St,BLDG
04/23/2025		Commercial cooking hood	N.J.A.C. 5:70-3, 607.3.3.2	Unabated	169 Pulaski St,BLDG
04/23/2025		Exterior groundskeeping	N.J.A.C. 5:70-3, 304.1.1	Unabated	169 Pulaski St,BLDG
04/23/2025		Exit signs	N.J.A.C. 5:70-3, 403.16.4.4	Unabated	169 Pulaski St,BLDG
08/11/2025			N.J.A.C. 5:70-3, 903.5	Unabated	180 Pulaski St,BLDG

08/11/2025			N.J.A.C. 5:70-3, 907.8.2	Unabated	180 Pulaski St,BLDG
06/02/2025		Class III Standpipe	N.J.A.C. 5:70-3, 901.8.2	Unabated	13 Zabriskie Ave,BLDG
06/24/2025			N.J.A.C. 5:70-3, 315.3.5	New	38 E 17th St,BLDG
07/23/2025			N.J.A.C. 5:70-3, 907.8.2	Unabated	175 E 22nd St
07/23/2025			N.J.A.C.5:70-4.9	Unabated	175 E 22nd St
08/19/2025			N.J.A.C. 5:70-3, 903.5	New	189 E 22nd St,BLDG
08/19/2025			N.J.A.C. 5:70-3, 907.8.5	New	189 E 22nd St,BLDG
09/16/2025		Up to date sprinkler test report needed	N.J.A.C. 5:70-3, 903.5	New	193 E 22nd St
09/16/2025		Fire extinguishers must be serviced and tested	N.J.A.C. 5:70-3, 906.2	New	193 E 22nd St
09/16/2025		Up to date fire alarm report needed	N.J.A.C. 5:70-3, 907.8	New	193 E 22nd St
03/28/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	197 E 22nd St
08/12/2025			N.J.A.C. 5:70-3, 903.5	New	75 E 2nd St
08/12/2025			N.J.A.C. 5:70-3, 1031.10	New	75 E 2nd St
08/12/2025			N.J.A.C. 5:70-3, 913.5	New	75 E 2nd St
08/12/2025			N.J.A.C. 5:70-3, 907.8	New	75 E 2nd St
08/12/2025			N.J.A.C. 5:70-3, 1031.10	New	75 E 2nd St
09/22/2025			N.J.A.C. 5:70-3, 311.5	New	16 E 31st St,BLDG
07/30/2025		Electrical meter/panels	N.J.A.C. 5:70-3, 604.3	New	36 E 47th St,BLDG
07/30/2025		Storage Rooms	N.J.A.C. 5:70-3, 315.3.4	New	36 E 47th St,BLDG
07/30/2025		Maintaining Exterior Ground	N.J.A.C. 5:70-3, 304.1.1	New	36 E 47th St,BLDG
07/30/2025		Storage Conditions	N.J.A.C. 5:70-3, 1031.1.1	New	36 E 47th St,BLDG
05/23/2025		Standpipe	N.J.A.C. 5:70-3, 905.1	Unabated	13 Zabriskie Ave,BLDG
06/02/2025		OpenFlame heaters and Grills	N.J.A.C. 5:70-3, 308.1.4	Unabated	13 Zabriskie Ave,BLDG
09/12/2025			N.J.A.C.5:70-2.9	New	16 E 5th St
09/12/2025			N.J.A.C. 5:70-3, 315.4	New	16 E 5th St
09/05/2025			N.J.A.C. 5:70-3, SECTION 906	New	240 E 5th St
09/05/2025			N.J.A.C. 5:70-3, SECTION 907	New	240 E 5th St
09/05/2025			N.J.A.C. 5:70-3, 903.5	New	240 E 5th St
05/20/2025			N.J.A.C. 5:70-3, 903.5	Unabated	75 W 10th St,BLDG
05/20/2025			N.J.A.C. 5:70-3, 108.2	Unabated	75 W 10th St,BLDG
05/20/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	75 W 10th St,BLDG
05/20/2025			N.J.A.C. 5:70-3, 604.3.1	Unabated	75 W 10th St,BLDG
07/31/2025			N.J.A.C.5:70-2.6	New	75 W 10th St,BLDG
03/31/2025			N.J.A.C. 5:70-3, 1031.7.3	Unabated	17 W 15th St,BLDG
08/29/2025			N.J.A.C. 5:70-3, 1031.3	New	78 W 17th St,BLDG
08/29/2025			N.J.A.C. 5:70-3, 1031.3	New	78 W 17th St,BLDG
05/23/2025		Fire Protection Systems	N.J.A.C. 5:70-3, 901.6.5	Unabated	13 Zabriskie Ave,BLDG
06/25/2025			N.J.A.C. 5:70-3, 904.12.5	Unabated	35 W 1st St,A
09/18/2025			N.J.A.C. 5:70-3, 905.1	New	40 W 20th St,BLDG
06/19/2025			N.J.A.C. 5:70-3, 604.1	Unabated	87 W 24th St
05/09/2025			N.J.A.C.5:70-4.9	Unabated	87 W 24th St
07/31/2025			N.J.A.C. 5:70-3, 604.1	New	87 W 24th St
07/31/2025			N.J.A.C. 5:70-3, 907.10	New	87 W 24th St
05/16/2025			N.J.A.C. 5:70-3, 1031.1	New	181 W 24th St,BLDG
05/16/2025			N.J.A.C. 5:70-3, 604.1	New	181 W 24th St,BLDG
05/16/2025			N.J.A.C. 5:70-3, 915.6	New	181 W 24th St,BLDG
04/21/2025			N.J.A.C. 5:70-3, 604.1	Unabated	183 W 24th St,BLDG
08/19/2025			N.J.A.C.5:70-2.9	New	17 W 25th St,B
06/02/2025		Means of egress	N.J.A.C. 5:70-3, 1001.2.1	Unabated	38 W 29th St,BLDG

08/25/2025		Electrical hazards	N.J.A.C. 5:70-3, 604.5	New	38 W 29th St,BLDG
08/25/2025		Electrical conditions	N.J.A.C. 5:70-3, 604.6	New	38 W 29th St,BLDG
08/25/2025		Electrical hazards	N.J.A.C. 5:70-3, 604.4.2	New	38 W 29th St,BLDG
08/25/2025		Means of egress	N.J.A.C. 5:70-3, 1010.1.9	New	38 W 29th St,BLDG
06/02/2025		Means of egress	N.J.A.C. 5:70-3, 1001.2.1	Unabated	42 W 29th St,BLDG
06/18/2025		Sprinkler System	N.J.A.C. 5:70-3, 901.6	New	44 W 32nd St,BLDG
06/18/2025		Fire alarm system	N.J.A.C. 5:70-3, 901.6	New	44 W 32nd St,BLDG
06/19/2025		Fire Extinguishers	N.J.A.C. 5:70-3, 906.7	New	92 W 34th St,BLDG
06/19/2025		Fire Door Operation	N.J.A.C. 5:70-3, 705.2.4	New	92 W 34th St,BLDG
06/19/2025		Maintaining Exterior Grounds	N.J.A.C. 5:70-3, 304.1.2	New	92 W 34th St,BLDG
06/18/2025		Fire alarm system	N.J.A.C. 5:70-3, 901.4.1	New	92 W 34th St,BLDG
06/18/2025		Emergency	N.J.A.C. 5:70-3, 1031.10	New	92 W 34th St,BLDG
06/18/2025		Fire doors	N.J.A.C. 5:70-3, 705.2	New	92 W 34th St,BLDG
04/24/2025		Means of Egress	N.J.A.C. 5:70-3, 1031.1.1	New	93 W 34th St,BLDG
06/12/2025			N.J.A.C.5:70-2.9	New	20 W 3rd St
04/24/2025		Smoke alarms	N.J.A.C. 5:70-3, 907.10	New	81 W 43rd St,BLDG
04/01/2025			N.J.A.C. 5:70-3, 2703.10	New	16 W 4th St
09/03/2025		Electrical hazard	N.J.A.C. 5:70-3, 604.5	Unabated	83 W 51st St,BLDG
08/04/2025			N.J.A.C. 5:70-3, 903.5	Unabated	180 W 52nd St
08/04/2025			N.J.A.C. 5:70-3, SECTION 315	Unabated	180 W 52nd St
08/26/2025			N.J.A.C.5:70-2.4	New	180 W 52nd St
09/05/2025			N.J.A.C. 5:70-3, 1010.4	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 315.3.2	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 1031.10	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 315.3.2	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 315.3.2	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 604.2	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 509.1.1	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 1031.7.3	New	135 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 901.6.4	Unabated	182 W 54th St,BLDG
09/05/2025			N.J.A.C. 5:70-3, 901.5	Unabated	182 W 54th St,BLDG
07/23/2025			N.J.A.C. 5:70-3, 304.1.2	Unabated	157 W 63rd St
07/23/2025			N.J.A.C. 5:70-3, 304.1.1	Unabated	157 W 63rd St
07/23/2025			N.J.A.C. 5:70-3, 310.3	Unabated	157 W 63rd St
09/08/2025			N.J.A.C.5:70-2.1	New	69 W 6th St,BLDG
03/28/2025			N.J.A.C.5:70-2.1	Unabated	14 W 7th St,BLDG
08/12/2025			N.J.A.C. 5:70-3, 901.6.3	Unabated	9 W 8th St
08/12/2025			N.J.A.C. 5:70-3, 901.6.3	Unabated	9 W 8th St
08/12/2025			N.J.A.C. 5:70-3, 906.9	Unabated	9 W 8th St
09/04/2025			N.J.A.C. 5:70-3, 1031.7.3	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.6	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 912.7	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.4.1	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 315.3.1	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1031.2	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 304.1.2	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 806.2	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 604.1	Unabated	582 Avenue C,BLDG

09/04/2025			N.J.A.C. 5:70-3, 1031.2	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.6	Unabated	582 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	582 Avenue C,BLDG
05/23/2025		FDC connection	N.J.A.C. 5:70-3, 903.4	Unabated	583 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1010.1.9	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1031.7.3	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 6104.3	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.6	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1031.7.1	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 3106.3.2	New	584 Avenue C,BLDG
09/04/2025			N.J.A.C. 5:70-3, 509.1.1	New	584 Avenue C,BLDG
05/30/2025			N.J.A.C. 5:70-3, 907.8	New	548 Avenue C,BLDG
05/16/2025			N.J.A.C. 5:70-3, 1031.1.1	New	552 Avenue C
05/16/2025			N.J.A.C. 5:70-3, 304.1	New	552 Avenue C
05/16/2025			N.J.A.C. 5:70-3, 319.10.2	New	552 Avenue C
05/16/2025			N.J.A.C. 5:70-3, 903.5	New	552 Avenue C
05/16/2025			N.J.A.C. 5:70-3, 505.1	New	554 Avenue C,BLDG
08/12/2025			N.J.A.C.5:70-2.1	Unabated	3 Columbus Dr,BLDG
06/04/2025		Posting LHU Registration certificate	N.J.A.C.5:70-2.6	New	1 Commerce St
06/03/2025		Fire alarm	N.J.A.C. 5:70-3, 901.6	New	1 Commerce St
06/03/2025		Sprinkler	N.J.A.C. 5:70-3, 901.6	New	1 Commerce St
06/03/2025		Storage conditions	N.J.A.C. 5:70-3, 315.3.3	New	1 Commerce St
06/03/2025		Battery charging stations	N.J.A.C. 5:70-3, 309.3	New	1 Commerce St
06/03/2025		Storage conditions	N.J.A.C. 5:70-3, 3205.4	New	1 Commerce St
06/03/2025		Exit signs	N.J.A.C. 5:70-3, 1031.4	New	1 Commerce St
06/03/2025		Fire alarm	N.J.A.C. 5:70-3, 901.6	New	2 Commerce St
08/22/2025		Storage height	N.J.A.C. 5:70-3, 315.3.1	New	7 Commerce St,BLDG
08/22/2025		Outside storage	N.J.A.C. 5:70-3, 315.4.1	New	7 Commerce St,BLDG
08/22/2025		Means of egress	N.J.A.C. 5:70-3, 1031.1	New	7 Commerce St,BLDG
08/22/2025		Fire lane	N.J.A.C. 5:70-3, 503.2.1	New	7 Commerce St,BLDG
08/22/2025		Storage conditions	N.J.A.C. 5:70-3, 315.3	New	7 Commerce St,BLDG
08/22/2025		Propane storage	N.J.A.C. 5:70-3, 6107.3	New	7 Commerce St,BLDG
06/16/2025		Dry sprinkler system	N.J.A.C. 5:70-3, 901.6	Unabated	300 Constitution Ave,BLDG
06/16/2025		Alarm system	N.J.A.C. 5:70-3, 901.6	Unabated	300 Constitution Ave,BLDG
06/02/2025		Alarm system Maintenance	N.J.A.C. 5:70-3, 901.6	Unabated	300 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 315.3.2	Unabated	301 Constitution Ave,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.6	New	301 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	301 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 907.8	Unabated	301 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 917.1	Unabated	301 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 901.6	Unabated	301 Constitution Ave,BLDG
09/04/2025			N.J.A.C. 5:70-3, 901.6	New	301 Constitution Ave,BLDG
09/04/2025			N.J.A.C. 5:70-3, 1013.1	New	301 Constitution Ave,BLDG
07/03/2025			N.J.A.C. 5:70-3, 1031.7.3	Unabated	13 Cottage St,BLDG
08/12/2025			N.J.A.C.5:70-2.1	Unabated	23 Cottage St
05/27/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	577 Broadway,BLDG
06/23/2025			N.J.A.C. 5:70-3, 901.4.1	New	577 Broadway,BLDG
05/27/2025			N.J.A.C. 5:70-3, 1031.10	New	577 Broadway,STREET
08/08/2025			N.J.A.C. 5:70-3, 901.6.3	Unabated	582 Broadway,1

08/08/2025			N.J.A.C. 5:70-3, 607.1	Unabated	582 Broadway,1
08/08/2025			N.J.A.C. 5:70-3, 901.6.3	Unabated	582 Broadway,2FLR
09/11/2025			N.J.A.C. 5:70-3, 607.3.3.2	New	589 Broadway,1FLR
09/11/2025			N.J.A.C. 5:70-3, 607.3.3	New	589 Broadway,1FLR
07/30/2025		Fees/Penalties		New	592 Broadway,BLDG
05/21/2025		Storage conditions	N.J.A.C. 5:70-3, 315.3.4	New	103 W 47th St,BLDG
05/21/2025			N.J.A.C. 5:70-3, 315.3.1	New	103 W 47th St,BLDG
05/21/2025		Storage conditions	N.J.A.C. 5:70-3, 315.3	New	103 W 47th St,BLDG
05/21/2025		Gas containers	N.J.A.C. 5:70-3, 603.4.2.3.4	New	103 W 47th St,BLDG
06/06/2025			N.J.A.C.5:70-2.16	New	53 Lord Ave,BLDG
06/30/2025			N.J.A.C. 5:70-3, 906.2	Unabated	9 W 18th St,BLDG
09/15/2025			N.J.A.C.5:70-2.6	New	35 W 52nd St,BLDG
09/11/2025		Ceiling clearance	N.J.A.C. 5:70-3, 315.3.1	Unabated	504 Kennedy Blvd
09/22/2025			N.J.A.C. 5:70-3, 5303.5.3	New	19 W 33rd St,BLDG
09/22/2025			N.J.A.C. 5:70-3, Part V	New	19 W 33rd St,BLDG
03/27/2025		Aisle maintenance	N.J.A.C. 5:70-3, 3205.4	Unabated	50 Ingham Ave,BUSN
03/27/2025		storage height	N.J.A.C. 5:70-3, 315.3.1	Unabated	50 Ingham Ave,BUSN
08/18/2025		Fire Door Openings	N.J.A.C. 5:70-3, 705.2	Unabated	50 Ingham Ave,BUSN
08/18/2025		Wet System-Sprinkler	N.J.A.C. 5:70-3, 901.6.3	Unabated	50 Ingham Ave,BUSN
08/18/2025		Extension cords	N.J.A.C. 5:70-3, 604.5	Unabated	50 Ingham Ave,BUSN
08/18/2025		Electrical Hazards	N.J.A.C. 5:70-3, 604.1	Unabated	50 Ingham Ave,BUSN
08/27/2025		Electrical conditions	N.J.A.C. 5:70-3, 604.4	New	50 Ingham Ave,BUSN
08/27/2025		Electrical conditions	N.J.A.C. 5:70-3, 604.5	New	50 Ingham Ave,BUSN
08/27/2025		Electrical conditions	N.J.A.C. 5:70-3, 604.1	New	50 Ingham Ave,BUSN
08/27/2025		Butane storage	N.J.A.C. 5:70-3, 315.3.5	New	50 Ingham Ave,BUSN
08/27/2025			N.J.A.C. 5:70-3, 309.3	New	50 Ingham Ave,BUSN
08/27/2025		FDC	N.J.A.C. 5:70-3, 912.4	New	50 Ingham Ave,BUSN
08/18/2025		Exterior grounds maintenance	N.J.A.C. 5:70-3, 304.1.1	Unabated	50 Ingham Ave,BUSN
08/18/2025		Exterior maintenance	N.J.A.C. 5:70-3, 304.1.2	Unabated	50 Ingham Ave,BUSN
08/27/2025		Electrical	N.J.A.C. 5:70-3, 604.1	New	50 Ingham Ave,BUSN
09/12/2025			N.J.A.C.5:70-2.9	New	5 Isabella Ave,BLDG
09/12/2025			N.J.A.C.5:70-2.1	New	46 Isabella Ave
09/17/2025			N.J.A.C. 5:70-3, 803.11	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 703.1	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 315.3.1	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 603.5.2	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 901.6	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 901.6	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 1031.10	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 604.4	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C.5:70-2.6	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 403.15.4.3	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 703.1	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 912.7	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 912.4.2	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 1031.2	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 315.3.3	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 703.1	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 917.1	New	56 New Hook Rd,BLDG

09/17/2025			N.J.A.C. 5:70-3, 604.4	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C. 5:70-3, 906.1	New	56 New Hook Rd,BLDG
09/17/2025			N.J.A.C.5:70-2.6	New	56 New Hook Rd,BLDG
07/11/2025			N.J.A.C. 5:70-3, 1031.1.3	New	733 Avenue A,BLDG
04/22/2025			N.J.A.C. 5:70-3, 509.1.1	Unabated	733 Avenue A,BLDG
04/22/2025			N.J.A.C. 5:70-3, 509.1.1	Unabated	733 Avenue A,BLDG
07/11/2025			N.J.A.C. 5:70-3, 315.3.2	New	733 Avenue A,BLDG
07/29/2025	Electrical		N.J.A.C. 5:70-3, 604.1	New	140 Avenue B
07/29/2025	Sprinkler head		N.J.A.C. 5:70-3, 901.6	New	140 Avenue B
07/29/2025	Sprinkler clearance		N.J.A.C. 5:70-3, 901.6	New	140 Avenue B
07/11/2025			N.J.A.C. 5:70-3, 1031.7.2	Unabated	339 Broadway,BLDG
07/11/2025			N.J.A.C. 5:70-3, 315.3.2	Unabated	339 Broadway,BLDG
07/11/2025			N.J.A.C. 5:70-3, 604.1	Unabated	339 Broadway,BLDG
07/11/2025			N.J.A.C. 5:70-3, 304.1.2	Unabated	339 Broadway,BLDG
07/11/2025			N.J.A.C. 5:70-3, 304.1.2	Unabated	339 Broadway,BLDG
09/11/2025			N.J.A.C. 5:70-3, 315.3.3	New	364 Broadway
05/23/2025	Permits		N.J.A.C. 5:70-3, 901.4	Unabated	8 Hook Rd,1FLR
05/23/2025	Fire Suppression		N.J.A.C. 5:70-3, 903.3.8.5	Unabated	8 Hook Rd,1FLR
08/27/2025	Electrical issues		N.J.A.C. 5:70-3, 604.1	Unabated	8 Hook Rd,1FLR
08/27/2025	Dangerous conditions		N.J.A.C. 5:70-3, 103.2	Unabated	8 Hook Rd,1FLR
07/24/2025	Extinguisher on 2nd fl cooking space needs to be tested		N.J.A.C. 5:70-3, 906.2	New	33 Hook Rd
07/24/2025	Deficentcy report stated multiple sprinkler heads to be installed on 2nd fl		N.J.A.C. 5:70-3, 903.1	New	33 Hook Rd
09/23/2025	Forklift charging stations		N.J.A.C. 5:70-3, 309.3	New	48 Hook Rd
09/23/2025	Storage aisles		N.J.A.C. 5:70-3, 3205.4	New	48 Hook Rd
09/23/2025	Fire Pump Access		N.J.A.C. 5:70-3, 509.2	New	48 Hook Rd
09/23/2025	Utily clearance		N.J.A.C. 5:70-3, 604.3	New	48 Hook Rd
07/09/2025	Failure to register as a LHU		N.J.A.C.5:70-2.6	New	55 Hook Rd
06/19/2025			N.J.A.C.5:70-2.6	Unabated	59 Hook Rd
08/08/2025			N.J.A.C.5:70-2.6	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 913.5	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 901.6	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 311.2.2	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 903.5	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 315.3.3	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 1031.2	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.5	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.1	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 904.8	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.6	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.1	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 912.7	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 3103.12.7	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 703.1	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 1031.2	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.1	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 703.1	Unabated	59 Hook Rd,BLDG
08/08/2025			N.J.A.C. 5:70-3, 604.1	Unabated	59 Hook Rd,BLDG
07/23/2025			N.J.A.C. 5:70-3, 904.5	Unabated	216 Broadway,1

05/28/2025			N.J.A.C. 5:70-3, SECTION 907	Unabated	234 Broadway,A
03/31/2025			N.J.A.C. 5:70-3, 901.6	Unabated	210 Broadway,BLDG
04/25/2025			N.J.A.C.5:70-4.7	Unabated	243 Broadway,BLDG
08/14/2025			N.J.A.C. 5:70-3, 901.6	Unabated	255 Broadway,BLDG
07/18/2025			N.J.A.C. 5:70-3, 915.2.1	New	148 W 30th St,BLDG
08/29/2025			N.J.A.C. 5:70-3, 1031.7.3	New	432 Avenue C,BLDG
08/29/2025			N.J.A.C. 5:70-3, 903.5	New	432 Avenue C,BLDG
08/29/2025			N.J.A.C. 5:70-3, 1031.3	New	432 Avenue C,BLDG
09/08/2025			N.J.A.C. 5:70-3, SECTION 315	New	249 Broadway,2FLR
07/17/2025		LHU registration	N.J.A.C.5:70-2.6	Unabated	816-818 Broadway
06/05/2025			N.J.A.C. 5:70-3, 901.6.4	Unabated	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 1203.4.2.1	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 1031.10	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 904.5	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 604.5	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 607.3	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 917.1	New	549 Avenue A,BLDG
07/25/2025			N.J.A.C. 5:70-3, 703.1	New	549 Avenue A,BLDG
03/27/2025		Fire alarm system	N.J.A.C. 5:70-3, 907.8.5	Unabated	550 Avenue A
03/27/2025		Fire sprinkler system	N.J.A.C. 5:70-3, 901.6	Unabated	550 Avenue A
07/01/2025		Kitchen hood system	N.J.A.C. 5:70-3, 904.5	Unabated	550 Avenue A
05/23/2025		Storage	N.J.A.C. 5:70-3, 315.3.1	Unabated	1224 Kennedy Blvd,B
05/27/2025		Fire Alarms	N.J.A.C. 5:70-3, 907.8.1	Unabated	1224 Kennedy Blvd,B
05/23/2025		Fire Extinguishers	N.J.A.C. 5:70-3, 906.2	Unabated	1224 Kennedy Blvd,B
05/23/2025		Combustible waste	N.J.A.C. 5:70-3, 304.1.1	Unabated	1224 Kennedy Blvd,B
05/23/2025		approved containers	N.J.A.C. 5:70-3, 304.3.1	Unabated	1224 Kennedy Blvd,B
05/23/2025		Electical hazards	N.J.A.C. 5:70-3, 604.1	Unabated	1224 Kennedy Blvd,B
05/23/2025		MEans of Egress	N.J.A.C. 5:70-3, 1031.1	Unabated	1224 Kennedy Blvd,B
05/27/2025		LHU Fees	N.J.A.C.5:70-2.6	Unabated	1224 Kennedy Blvd,B
05/23/2025		Electrical hazards	N.J.A.C. 5:70-3, 604.1	New	1224 Kennedy Blvd,STREET
05/23/2025		Temporary Heating	N.J.A.C. 5:70-3, 603.5.2	New	1224 Kennedy Blvd,STREET
05/23/2025		Storage Conditions	N.J.A.C. 5:70-3, 3311.2	New	1224 Kennedy Blvd,STREET
05/23/2025		Fire Extinguisher	N.J.A.C. 5:70-3, 906.2	New	1224 Kennedy Blvd,STREET
05/23/2025		means of egress	N.J.A.C. 5:70-3, 314.2	New	1224 Kennedy Blvd,STREET
05/23/2025		Electical Hazards	N.J.A.C. 5:70-3, 604.5	New	1224 Kennedy Blvd,STREET
05/27/2025		fire alarms	N.J.A.C. 5:70-3, 907.8.1	New	1224 Kennedy Blvd,STREET
05/23/2025		Electrical Hazards	N.J.A.C. 5:70-3, 604.6	New	1224 Kennedy Blvd,STREET
05/23/2025		Storage conditions	N.J.A.C. 5:70-3, 315.3.1	New	1224 Kennedy Blvd,STREET
06/05/2025			N.J.A.C. 5:70-3, 917.1	Unabated	1225 Kennedy Blvd,BLDG
06/05/2025			N.J.A.C. 5:70-3, 703.1	Unabated	1225 Kennedy Blvd,BLDG
09/05/2025			N.J.A.C. 5:70-3, 905.9	New	1225 Kennedy Blvd,BLDG
09/05/2025			N.J.A.C. 5:70-3, 901.6	New	1225 Kennedy Blvd,BLDG
09/05/2025			N.J.A.C. 5:70-3, 901.6	New	1225 Kennedy Blvd,BLDG
09/09/2025			N.J.A.C. 5:70-3, 5303.5.3	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 604.4	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 604.4	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 604.1	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 603.1.3	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 315.3.3	New	1216 Kennedy Blvd

09/09/2025			N.J.A.C. 5:70-3, 1031.2	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 901.4.1	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 604.1	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 907.8	New	1216 Kennedy Blvd
09/09/2025			N.J.A.C. 5:70-3, 509.1	New	1216 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 1031.10	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 102.3	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 806.2	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 604.10.3	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 102.3	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 315.3.3	Unabated	1325 Kennedy Blvd
05/28/2025			N.J.A.C. 5:70-3, 315.3.2	Unabated	1325 Kennedy Blvd
08/11/2025			N.J.A.C.5:70-2.6	New	406 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 901.6	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 901.6	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 904.5	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 604.4	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 604.1	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 604.1	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 5303.5.3	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 315.3.1	New	412 Broadway,BLDG
09/09/2025			N.J.A.C. 5:70-3, 304.1.2	New	81 E 24th St
09/19/2025			N.J.A.C. 5:70-3, 907.8	Unabated	534 Avenue A,BLDG
04/28/2025		Fire alarm system in trouble	N.J.A.C. 5:70-3, SECTION 704	New	431 Broadway
07/28/2025			N.J.A.C.5:70-2.1	New	434 Broadway
06/09/2025			N.J.A.C.5:70-2.9	New	434 Broadway
06/09/2025			N.J.A.C. 5:70-3, 903.5	Unabated	435 Broadway,BLDG
06/23/2025			N.J.A.C. 5:70-3, 907.8	Unabated	435 Broadway,BLDG
06/23/2025			N.J.A.C. 5:70-3, 915.6	Unabated	435 Broadway,BLDG
06/23/2025			N.J.A.C. 5:70-3, 907.8.1	New	22 Silver St,BLDG
09/12/2025			N.J.A.C. 5:70-3, 907.10.1.2	New	22 Silver St,BLDG
09/12/2025			N.J.A.C. 5:70-3, 604.5	Unabated	928 Broadway,BLDG
06/24/2025			N.J.A.C.5:70-2.9	Unabated	928 Broadway,BLDG
04/14/2025			N.J.A.C. 5:70-3, 315.3	Unabated	928 Broadway,BLDG
06/24/2025			N.J.A.C. 5:70-3, 610.1.1	Unabated	960 Broadway,BLDG
05/30/2025			N.J.A.C. 5:70-3, 907.10	Unabated	960 Broadway,BLDG
05/30/2025			N.J.A.C. 5:70-3, 1031.2	New	960 Broadway,BLDG
08/28/2025			N.J.A.C. 5:70-3, 907.10	New	960 Broadway,BLDG
08/28/2025			N.J.A.C. 5:70-3, 604.1	New	960 Broadway,BLDG
08/28/2025			N.J.A.C. 5:70-3, SECTION 915	Unabated	970 Broadway,BLDG
04/22/2025			N.J.A.C.5:70-2.9	Unabated	972 Broadway,A
06/12/2025			N.J.A.C. 5:70-3, SECTION 803	Unabated	972 Broadway,A
06/12/2025			N.J.A.C. 5:70-3, SECTION 906	Unabated	972 Broadway,A
06/12/2025			N.J.A.C. 5:70-3, 604.5	Unabated	972 Broadway,A
06/12/2025			N.J.A.C. 5:70-3, 907.8.5	Unabated	972 Broadway,BLDG
07/22/2025			N.J.A.C. 5:70-4.11.(a)	New	1044 Broadway,BLDG
08/21/2025	Building	Means of Egress - (a) Every story utilized for human occupancy having an occupant load of 500 or less shall be provided with a minimum of two exits	N.J.A.C.5:70-2.1	New	888 Avenue C
04/02/2025	Building			New	958 Kennedy Blvd,BLDG
05/09/2025	Building	Means of Egress - (a) Every story utilized for human occupancy having an occupant load of 500 or less shall be provided with a minimum of two exits		New	958 Kennedy Blvd,BLDG
05/09/2025	Building	(72 hrs to vacate) It shall be unlawful to alter a building or structure in a manner that will reduce the number of exits or the capacity of the means		New	958 Kennedy Blvd,BLDG

05/09/2025	Building	Means of Egress - (a) Every story utilized for human occupancy having an occupant load of 500 or less shall be provided with a minimum of two exits		New	958 Kennedy Blvd,BLDG
05/09/2025	Building	(72 hrs to vacate) It shall be unlawful to alter a building or structure in a manner that will reduce the number of exits or the capacity of the means of egress		New	958 Kennedy Blvd,BLDG
05/09/2025	Building	Means of Egress - (a) Every story utilized for human occupancy having an occupant load of 500 or less shall be provided with a minimum of two exits		New	958 Kennedy Blvd,BLDG
09/04/2025	Building	Means of Egress - (a) Every story utilized for human occupancy having an occupant load of 500 or less shall be provided with a minimum of two exits	N.J.A.C. 5:70-4.11.(a)	New	211 Avenue B,BLDG
09/04/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	211 Avenue B,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.b Cubicle-No person shall: (1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.b Cubicle-No person shall: (1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
08/13/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	36 W 54th St,BLDG
09/23/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	41 W 54th St,BLDG
09/23/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	74 Prospect Ave,BLDG
09/23/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	74 Prospect Ave,BLDG
09/23/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	74 Prospect Ave,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.b Cubicle-No person shall: (1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
05/09/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	958 Kennedy Blvd,BLDG
08/21/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	94 W 22nd St,BLDG
08/21/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	94 W 22nd St,BLDG
08/13/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		Unabated	78 W 18th St
03/31/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		Unabated	65 Trask Ave
03/31/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		Unabated	65 Trask Ave
08/21/2025	Special Hazards	Ord. 15-8.2.a Dwell -No person shall:(1) lease nor offer to lease; or (2) rent nor offer to rent; or (3) collect rent nor lease payments; or (4) barter for goods or services		New	1044 Broadway,BLDG
04/17/2025	Dangerous Conditions	Dangerous condition which could cause or contribute to fire spread must be removed	N.J.A.C. 5:70-3, 102.1.1.1.	New	357 Broadway,BLDG
05/05/2025	Dangerous Conditions	Dangerous condition which could cause or contribute to fire spread must be removed	N.J.A.C. 5:70-3, 103.2	Unabated	413 Avenue C,BLDG
04/07/2025	Fire Resistive Rated Assembly	Holes in ceiling, walls, floors or ceiling tiles must be repaired		New	158 W 8th St
05/22/2025	Fire Protection Systems		N.J.A.C. 5:70-3, 903.5	New	581 Broadway
06/04/2025	Fire Protection Systems	System shall be Operational at all times. Fire Alarm Systems- Tested annually	N.J.A.C. 5:70-3, 907.8.5	Unabated	7 Commerce St,BLDG
06/04/2025	Fire Protection Systems	System shall be operational at all times. Fire Sprinkler Systems- Tested Annually	N.J.A.C. 5:70-3, 901.6.3	Unabated	7 Commerce St,BLDG
03/26/2025	Fire Protection Systems		N.J.A.C.5:70-4.7	Unabated	682 Broadway,BLDG
04/10/2025	Fire Protection Systems		N.J.A.C. 5:70-3, 907.8	Unabated	7 W 9th St
06/12/2025	Fire Protection Systems	System shall be operational at all times. Fire Sprinkler Systems- Tested Annually	N.J.A.C. 5:70-3, 903.5	New	97 E 2nd St,2FLR
05/05/2025	Fire Protection Systems	System shall be Operational at all times. Fire Alarm Systems- Tested annually		New	43 E 26th St,BLDG
04/10/2025	Fire Protection Systems	System shall be Operational at all times. Fire Alarm Systems- Tested annually	N.J.A.C. 5:70-3, 907.8.5	Unabated	21 W 8th St
09/15/2025	Fire Protection Systems	System shall be Operational at all times. Fire Alarm Systems- Tested annually		New	502 Broadway,1FLR
09/15/2025	Fire Protection Systems	System shall be operational at all times. Fire Sprinkler Systems- Tested Annually		New	502 Broadway,1FLR
06/03/2025	Fire Protection Systems	Fire alarm test report needed	N.J.A.C. 5:70-3, 907.8	Unabated	1030 Broadway
09/05/2025	Fire Protection Systems		N.J.A.C. 5:70-3, 903.5	New	392 Broadway,BLDG
09/05/2025	Fire Protection Systems		N.J.A.C. 5:70-3, 907.8.2	New	392 Broadway,BLDG
04/21/2025	Fire Protection Systems	System shall be Operational at all times. Fire Alarm Systems- Tested annually	N.J.A.C. 5:70-3, 907.8	New	396 Broadway,BLDG
04/21/2025	Fire Protection Systems	System shall be operational at all times. Fire Sprinkler Systems- Tested Annually	N.J.A.C. 5:70-3, 903.5	New	396 Broadway,BLDG
09/05/2025	Fire Protection Systems		N.J.A.C. 5:70-3, 907.10.1	New	394 Broadway,BLDG
09/05/2025	Fire Protection Systems		N.J.A.C. 5:70-3, SECTION 915	New	394 Broadway,BLDG
07/16/2025	Fire Protection Systems	Deficiencies from 12/24 report must be corrected	N.J.A.C. 5:70-3, 905.1	New	535 Avenue A,BLDG
04/10/2025	Sprinklers, Standpipes, Pumps	Sprinkler system annual testing required	N.J.A.C. 5:70-3, 903.5	Unabated	7 W 9th St
05/06/2025	Sprinklers, Standpipes, Pumps		N.J.A.C. 5:70-3, 907.8	Unabated	75 Hook Rd
04/10/2025	Means of Egress		N.J.A.C. 5:70-3, 1010.1.9.5	Unabated	7 W 9th St
05/06/2025	Key Boxes	Key box (Knox Box) shall be installed to gain necessary access as required by the Fire Official		Unabated	480 Avenue C,BLDG
04/28/2025	Key Boxes	Key box (Knox Box) shall be installed to gain necessary access as required by the Fire Official		Unabated	490 Broadway,BLDG
04/10/2025	Illumination and Signs		N.J.A.C. 5:70-3, 1031.10	Unabated	7 W 9th St

04/17/2025	Storage	Outside storage must be at least 15 feet from buildings		New	682 Broadway,BLDG
04/07/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	158 W 8th St
04/22/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	731 Avenue A,BLDG
04/21/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	91 Newman Ave
03/31/2025	Local Fees and LHUs	Failure to pay permit fee		Unabated	17 W 15th St,BLDG
05/15/2025	Local Fees and LHUs	Failure to pay penalties		New	135 W 52nd St
05/15/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	135 W 52nd St
04/29/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	135 W 54th St,BLDG
05/01/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	91 E 30th St
04/29/2025	Local Fees and LHUs	Failure to pay annual Life Hazard Use Registration Fee with the Division of Fire Safety		New	1 Islandview Ct,BLDG
04/29/2025	Local Fees and LHUs	Failure to pay annual Life Hazard Use Registration Fee with the Division of Fire Safety		New	3 Islandview Ct,BLDG
04/29/2025	Local Fees and LHUs	Failure to pay annual Life Hazard Use Registration Fee with the Division of Fire Safety		New	5 Islandview Ct,BLDG
04/29/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	15 Lexington Ave,BLDG
05/08/2025	Local Fees and LHUs	Failure to pay annual Life Hazard Use Registration Fee with the Division of Fire Safety		New	25 Lexington Ave,BLDG
04/29/2025	Local Fees and LHUs	Failure to pay annual Life Hazard Use Registration Fee with the Division of Fire Safety		New	29 Lexington Ave,BLDG
04/14/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	744 Broadway,2
04/16/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	739 Broadway,A
04/04/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	434 Avenue C
04/14/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		New	395 Broadway,STREET
04/01/2025	Local Fees and LHUs	Failure to pay registration/inspection fee		Unabated	473 Broadway,311
04/11/2025	Local Fees and LHUs	Failure to pay penalties		Unabated	732 Avenue E,BLDG
05/06/2025	Retrofit Code	Windowless basements less than 3000 sq. ft. shall install a fire alarm system in accordance with UCC		Unabated	210 Broadway,1
03/31/2025	Retrofit Code	Windowless basements less than 3000 sq. ft. shall install a fire alarm system in accordance with UCC		Unabated	210 Broadway,BLDG
09/11/2025	Commercial Cooking Equipment		N.J.A.C. 5:70-3, 901.6	New	589 Broadway,1FLR
09/15/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		New	35 W 52nd St,BLDG
06/30/2025	Illegal Units	Provide certificate of occupancy for rental unit or units observed based on tax records		New	83 W 55th St,BLDG
06/30/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		New	83 W 55th St,BLDG
06/19/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		New	92 W 34th St,BLDG
09/03/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		Unabated	83 W 51st St,BLDG
09/03/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		Unabated	83 W 51st St,BLDG
09/03/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		Unabated	83 W 51st St,BLDG
09/03/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		Unabated	83 W 51st St,BLDG
09/03/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		Unabated	83 W 51st St,BLDG
06/19/2025	Illegal Units	Provide certificate of occupancy for rental unit or units observed based on tax records	N.J.A.C. 5:70-3, 102.1.1	New	92 W 34th St,BLDG
06/16/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		New	15 W 28th St
07/22/2025	Illegal Units	Provide certificate of occupancy for rental unit or units observed based on tax records		New	662 Kennedy Blvd,BLDG
07/22/2025	Illegal Units	City Ordinance 15-8.2 (a)City Ordinance 15-8.2 (b)Unlawful Residential Occupancies		New	662 Kennedy Blvd,BLDG
09/03/2025	Illegal Units	Imminent hazard present	N.J.A.C. 5:70-2.17	Unabated	26 Lincoln Pkwy,BLDG
09/03/2025	Illegal Units	"Contact Inspector when unit is vacated" in order to conduct follow up inspection	N.J.A.C. 5:70-2.2	Unabated	26 Lincoln Pkwy,BLDG
05/08/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	1 Linden St,BLDG
05/08/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	13 Linden St
05/08/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	13 Linden St
04/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	129 Lexington Ave
09/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1163 Kennedy Blvd,BLDG
09/17/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	203 Lefante Way,BLDG
09/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	123 Newman Ave,BLDG
05/01/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	104 North St,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	134 North St,BLDG
09/02/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	50 Oak St

09/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	97 Oak St
09/02/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	97 Oak St
09/02/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	97 Oak St
06/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	65 Lord Ave,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	16 Mechanic St,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	16 Mechanic St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	19 Mechanic St,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	19 Mechanic St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	27 Mechanic St,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	27 Mechanic St,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	21 New St,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	121 Newman Ave
09/17/2025	In-service	Fire Escapes: All obstructions require removal	N.J.A.C. 5:70-3, 1031.3	Unabated	56 Prospect Ave,BLDG
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	74 Prospect Ave,BLDG
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	76 Prospect Ave,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	117 Prospect Ave,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	120 Prospect Ave
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	120 Prospect Ave
05/01/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	62.5 Prospect Ave,BLDG
05/01/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	62.5 Prospect Ave,BLDG
06/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	13 Obrlen Ct,BLDG
04/29/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	178 Orient St,BLDG
04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	190 Orient St,BLDG
04/17/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	7 Story Ct,BLDG
04/17/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	7 Story Ct,BLDG
04/17/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	Unabated	7 Story Ct,BLDG
04/17/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	Unabated	7 Story Ct,BLDG
04/17/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1003.1.1	Unabated	7 Story Ct,BLDG
04/17/2025	In-service	Low battery in basement smoke detector	N.J.A.C. 5:70-3, 907.8.1	Unabated	7 Story Ct,BLDG
04/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	9 Trask Ave,BLDG
04/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	9 Trask Ave,BLDG
04/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	36 Trask Ave,BLDG
04/21/2025	In-service	Extension cords not to be used as permanent wiring	N.J.A.C. 5:70-3, 604.5	New	671 Kennedy Blvd,BLDG
04/21/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	671 Kennedy Blvd,BLDG
04/21/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	672 Kennedy Blvd,A
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	672 Kennedy Blvd,B
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	672 Kennedy Blvd,B
04/21/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	672 Kennedy Blvd,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	672 Kennedy Blvd,BLDG
04/21/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	672 Kennedy Blvd,BLDG
04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	675 Kennedy Blvd,BLDG
09/18/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	675 Kennedy Blvd,BLDG
04/23/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	680 Kennedy Blvd,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	680 Kennedy Blvd,BLDG
06/04/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	680 Kennedy Blvd,BLDG
06/04/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	680 Kennedy Blvd,BLDG
06/04/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	680 Kennedy Blvd,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	681 Kennedy Blvd
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	681 Kennedy Blvd

04/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	739 Broadway,BLDG
04/18/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	739 Broadway,BLDG
04/18/2025	In-service	Clearance needed around flame producing devices (3ft in all directions)	N.J.A.C. 5:70-3, 305.1	Unabated	739 Broadway,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	739 Broadway,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	36 W 54th St,BLDG
05/15/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	629 Kennedy Blvd,BLDG
05/15/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	629 Kennedy Blvd,BLDG
05/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	629 Kennedy Blvd,BLDG
05/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	629 Kennedy Blvd,BLDG
05/15/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	631 Kennedy Blvd,BLDG
09/11/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	655 Kennedy Blvd,BLDG
09/11/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	656 Kennedy Blvd,BLDG
09/11/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	656 Kennedy Blvd,BLDG
09/11/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	656 Kennedy Blvd,BLDG
09/11/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	657 Kennedy Blvd,BLDG
09/11/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	657 Kennedy Blvd,BLDG
09/11/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	657 Kennedy Blvd,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	585 Kennedy Blvd,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	589 Kennedy Blvd,BLDG
08/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1034 Kennedy Blvd,BLDG
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1084 Kennedy Blvd,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1084 Kennedy Blvd,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	746 Kennedy Blvd,BLDG
04/21/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	746 Kennedy Blvd,BLDG
04/21/2025	In-service	Fire protection equipment rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1	New	746 Kennedy Blvd,BLDG
04/21/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	746 Kennedy Blvd,BLDG
05/20/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	894 Kennedy Blvd,BLDG
04/29/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	930 Kennedy Blvd,BLDG
04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	930 Kennedy Blvd,STREET
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	719 Kennedy Blvd,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	719 Kennedy Blvd,BLDG
04/21/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	719 Kennedy Blvd,BLDG
04/21/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	719 Kennedy Blvd,BLDG
04/21/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	719 Kennedy Blvd,BLDG
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	721 Kennedy Blvd,BLDG
04/21/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	721 Kennedy Blvd,BLDG
04/21/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	721 Kennedy Blvd,BLDG
04/21/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	721 Kennedy Blvd,BLDG
04/21/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	721 Kennedy Blvd,BLDG
05/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	49 Juliette St,BLDG
05/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	49 Juliette St,BLDG
05/17/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	53 Humphrey Ave
05/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	53 Humphrey Ave
05/17/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	53 Humphrey Ave
08/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	50 Kennedy Blvd
08/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	40 Kennedy Blvd
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1038 Broadway,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1040 Broadway,BLDG
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	3 Colonial Dr,BLDG

04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	24 Colonial Dr,BLDG
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	34 Colonial Dr,BLDG
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	34 Colonial Dr,BLDG
05/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	41 Colonial Dr,BLDG
05/18/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	41 Colonial Dr,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	66 Cottage St,BLDG
07/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	26 Edwards Ct
05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	45 Garretson Ave,BLDG
05/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	45 Garretson Ave,BLDG
05/28/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	121 Hobart Ave,BLDG
06/13/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	121 Hobart Ave,BLDG
04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	135 Hobart Ave,BLDG
04/22/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	135 Hobart Ave,BLDG
04/22/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	135 Hobart Ave,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	45 Humphrey Ave,BLDG
05/21/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	47 Humphrey Ave
05/21/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	47 Humphrey Ave
05/21/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	47 Humphrey Ave
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1019 Broadway,A
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1019 Broadway,B
05/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1021 Broadway,BLDG
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1025 Broadway,BLDG
09/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	906 Broadway,STREET
05/06/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	910 Broadway,BLDG
04/24/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	910 Broadway,STREET
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	912 Broadway,STREET
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	915 Broadway,BLDG
05/05/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	915 Broadway,BLDG
05/05/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	915 Broadway,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	916 Broadway,BLDG
05/13/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	992 Broadway,BLDG
05/13/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	992 Broadway,BLDG
04/25/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	497 Broadway,BLDG
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	497 Broadway,BLDG
05/19/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	500 Broadway
05/19/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	484 Broadway,A
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	487 Broadway
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	488 Broadway,1FLR
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	488 Broadway,1FLR
08/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	77 Kennedy Blvd,BLDG
04/17/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	512 Broadway,2FLR
05/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	512 Broadway,BLDG
05/15/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	512 Broadway,BLDG
05/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	512 Broadway,BLDG
05/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	512 Broadway,STREET
08/26/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	313 Bayonne Crossing Way
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	48 W 54th St,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	71 W 54th St,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	73 W 54th St

04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	81 W 54th St,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	99 W 54th St,BLDG
07/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	270 Kennedy Blvd,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	305 Kennedy Blvd,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	346 Kennedy Blvd,BLDG
05/05/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	346 Kennedy Blvd,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	351 Kennedy Blvd,BLDG
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	351 Kennedy Blvd,BLDG
05/05/2025	In-service	Fire Escapes: All obstructions require removal	N.J.A.C. 5:70-3, 1031.3	New	351 Kennedy Blvd,BLDG
05/05/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	351 Kennedy Blvd,BLDG
09/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	370 Kennedy Blvd,BLDG
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	373 Kennedy Blvd,BLDG
07/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	378 Kennedy Blvd,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	389 Kennedy Blvd
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	401 Kennedy Blvd
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	411 Kennedy Blvd,BLDG
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	411 Kennedy Blvd,BLDG
05/08/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	761 Broadway,A
05/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	762 Broadway
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	776 Broadway,STREET
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	777 Broadway,BLDG
06/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	275 Avenue B,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	298 Avenue B,BLDG
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	298 Avenue B,BLDG
04/25/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	322 Avenue B,BLDG
04/25/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	322 Avenue B,BLDG
05/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	358 Avenue B,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	358 Avenue B,BLDG
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	777 Avenue E,BLDG
07/16/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	Unabated	259 Avenue E
09/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	750A Avenue E,BLDG
09/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	752A Avenue E,BLDG
09/15/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	752A Avenue E,BLDG
09/15/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	752A Avenue E,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	341 Avenue E
05/01/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	435 Avenue E,BLDG
05/01/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	435 Avenue E,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	443 Avenue E,BLDG
05/01/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	452 Avenue E,BLDG
05/01/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	452 Avenue E,BLDG
05/01/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	456 Avenue E,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	547 Avenue E,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	547 Avenue E,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	550 Avenue E,BLDG
05/13/2025	In-service	Fire Escapes: IMMEDIATE NOTIFICATION TO FIRE PREVENTION FOR STATE OF DISREPAIR	N.J.A.C. 5:70-3, 1031.7.1	New	550 Avenue E,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	661 Avenue E,BLDG
06/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	250 Avenue E,BLDG
06/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	252 Avenue E,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	165 Avenue E,BLDG

05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	233 Avenue E,BLDG
09/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	154 Avenue E,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	143 Avenue E,BLDG
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	15 Andrew St,BLDG
05/19/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	20 Andrew St
05/19/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	20 Andrew St
04/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	24 Andrew St
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	24 Andrew St
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	26 Andrew St
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	26 Andrew St
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	78 Andrew St,BLDG
04/30/2025	In-service	Clearance needed around flame producing devices (3ft in all directions)	N.J.A.C. 5:70-3, 305.1	New	78 Andrew St,BLDG
07/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	1 Flagship St,APT 1
08/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	37 E 49th St,BLDG
07/23/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	287 Avenue C
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	295 Avenue C,BLDG
08/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	336 Avenue C,2
04/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	215 Avenue B,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	215 Avenue B,BLDG
04/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	215 Avenue B,BLDG
05/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	222 Avenue B,BLDG
05/07/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	224 Avenue B,BLDG
04/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	249 Avenue B,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	249 Avenue B,BLDG
05/03/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	263 Avenue B
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	263 Avenue B
05/08/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	78 Avenue C
05/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	80 Avenue C
07/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	393 Avenue C,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	377 Avenue C,BLDG
08/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	336 Avenue C,BLDG
05/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	205 Avenue B,BLDG
09/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	752A Avenue E,BLDG
09/22/2025	In-service	Address posted and clearly visible	N.J.A.C. 5:70-3, 505.1	New	754A Avenue E,BLDG
09/22/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	754A Avenue E,BLDG
05/14/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	80 Avenue A,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	86 Avenue A,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	297 Avenue A,BLDG
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	299 Avenue A,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	299 Avenue A,BLDG
05/14/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	303 Avenue A,BLDG
05/14/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	305 Avenue A,BLDG
05/14/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	305 Avenue A,BLDG
05/14/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	305 Avenue A,BLDG
08/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	320 Avenue A,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	322 Avenue A
04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	467 Avenue A,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	515 Avenue A,BLDG
04/22/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	520 Avenue A,BLDG

04/22/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	521 Avenue A,BLDG
04/22/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	521 Avenue A,BLDG
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	662 Avenue A,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	662 Avenue A,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	534 Broadway,1FLR
04/30/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	534 Broadway,1FLR
04/30/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	534 Broadway,1FLR
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	534 Broadway,1FLR
05/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	534 Broadway,1FLR
05/16/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	534 Broadway,1FLR
04/30/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	534 Broadway,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	534 Broadway,BLDG
05/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	534 Broadway,BLDG
05/16/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	534 Broadway,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	534 Broadway,BLDG
04/30/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	534 Broadway,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	462 Broadway,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	462 Broadway,STREET
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	463 Broadway,1FLR
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	466 Broadway,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	468 Broadway,STREET
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	468 Broadway,STREET
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	473 Broadway,307
04/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	395 Broadway,STREET
04/23/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	397 Broadway,BLDG
04/23/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	397 Broadway,BLDG
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	459 Broadway
05/19/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	459 Broadway
05/19/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	Unabated	459 Broadway
09/11/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	393 Broadway,A
09/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	906 Broadway,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	559 Broadway,2
05/12/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	549 Broadway,STREET
05/05/2025	In-service	Vacant and unoccupied structures need to be secured; placard clearly visible.	N.J.A.C. 5:70-3, 311.1	New	1047 Avenue C,1FLR
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	650 Broadway
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	651 Broadway,A
05/05/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	651 Broadway,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	700 Broadway,B
05/17/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	708 Broadway,BLDG
05/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	708 Broadway,BLDG
05/17/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	708 Broadway,BLDG
05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	716 Broadway,BLDG
05/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	717 Broadway,2FLR
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	718 Broadway,BLDG
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	720 Broadway,BLDG
09/10/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	726 Broadway,STREET
05/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	811 Broadway,1FLR
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	813 Broadway,1FLR
06/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	813 Broadway,2FLR

09/11/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	840 Broadway,BLDG
04/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	846 Broadway,BLDG
05/06/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	847 Broadway,1FLR
05/06/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	847 Broadway,1FLR
05/06/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	849 Broadway,BLDG
05/06/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	849 Broadway,BLDG
05/06/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	860 Broadway
05/06/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	860 Broadway
05/06/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	867 Broadway,1FLR
04/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	868 Broadway,BLDG
04/15/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	868 Broadway,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	871 Broadway,1FLR
05/06/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	882 Broadway,2FLR
05/06/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	885 Broadway,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	892 Broadway,STREET
05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	898 Broadway
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	902 Broadway
04/26/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	902 Broadway
05/27/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	458 Avenue C,BLDG
05/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	1025 Avenue C,BLDG
05/20/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	668 Avenue C,BLDG
05/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	723 Avenue C,BLDG
04/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	1090 Avenue C,BLDG
05/22/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	1096 Avenue C,BLDG
05/22/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1096 Avenue C,BLDG
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1104 Avenue C,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1108 Avenue C
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1109 Avenue C,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1109 Avenue C,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1129 Avenue C,BLDG
04/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	69 Avenue F
05/01/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	133 Avenue F,BLDG
05/01/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	133 Avenue F,BLDG
09/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	152 Avenue F,BLDG
09/17/2025	In-service	Fire Escapes: All obstructions require removal	N.J.A.C. 5:70-3, 1031.3	New	169 Avenue F,BLDG
05/13/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	173 Avenue F,BLDG
05/13/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	173 Avenue F,BLDG
05/13/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	173 Avenue F,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	15 Broadway,BLDG
04/24/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	43 Broadway,BLDG
05/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	47 Broadway,BLDG
05/09/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	47 Broadway,BLDG
05/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	66 Broadway,BLDG
04/21/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	Unabated	148 Broadway,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	158 Broadway,A
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	170 Broadway,2
08/20/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	383 Broadway,1
08/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	383 Broadway,BLDG
09/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	387 Broadway

09/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	387 Broadway
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	1055 Avenue C,2
05/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1056 Avenue C,BLDG
04/27/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	1069 Avenue C,STREET
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	196 Broadway,1FLR
07/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	196 Broadway,2FLR
07/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	196 Broadway,A
05/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	200 Broadway
05/09/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	203 Broadway,BLDG
05/09/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	207 Broadway,1
05/09/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	207 Broadway,1
04/22/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	271 Broadway,BLDG
04/22/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	291 Broadway,BLDG
04/22/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	291 Broadway,BLDG
04/22/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	291 Broadway,BLDG
04/22/2025	In-service	Fire protection equipment rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1	New	291 Broadway,BLDG
04/22/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	291 Broadway,BLDG
04/22/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	291 Broadway,BLDG
04/22/2025	In-service	Clearance needed around flame producing devices (3ft in all directions)	N.J.A.C. 5:70-3, 305.1	New	291 Broadway,BLDG
07/28/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	303 Broadway,BLDG
08/20/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	303 Broadway,BLDG
04/24/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	322 Broadway,A
05/28/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	366 Broadway,A
05/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	366 Broadway,A
05/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	366 Broadway,A
05/06/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	121 W 28th St
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	15 W 29th St,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	35 W 29th St,BLDG
06/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	92 W 34th St,BLDG
06/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	44 W 32nd St,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	98 W 32nd St,BLDG
05/05/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	98 W 32nd St,BLDG
05/05/2025	In-service	Address posted and clearly visible	N.J.A.C. 5:70-3, 505.1	New	98 W 32nd St,BLDG
05/05/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	98 W 32nd St,BLDG
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	171 W 32nd St,BLDG
06/19/2025	In-service	Address posted and clearly visible	N.J.A.C. 5:70-3, 505.1	New	92 W 34th St,BLDG
06/19/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	92 W 34th St,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	119 W 29th St
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	125 W 29th St,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	131 W 29th St
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	136 W 29th St,BLDG
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	143 W 29th St,BLDG
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	143 W 29th St,BLDG
05/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	148 W 29th St,BLDG
08/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	81 W 2nd St,BLDG
08/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	99 W 2nd St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	26 W 30th St,BLDG
05/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	26 W 30th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	64 W 30th St,BLDG

04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	69 W 30th St
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	96 W 30th St,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	38 W 31st St
05/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	126 W 31st St,BLDG
05/08/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	126 W 31st St,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	138 W 31st St,BLDG
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	142 W 31st St,BLDG
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	147 W 31st St,BLDG
09/03/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	19 W 47th St,BLDG
05/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	78 W 48th St,BLDG
05/01/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	157 W 48th St,BLDG
05/01/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	157 W 48th St,BLDG
05/01/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	157 W 48th St,BLDG
05/01/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	157 W 48th St,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	169 W 48th St,BLDG
05/01/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	169 W 48th St,BLDG
05/01/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	169 W 48th St,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	175 W 48th St,BLDG
05/01/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	179 W 48th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	179 W 48th St,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	179 W 48th St,BLDG
05/01/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	Unabated	179 W 48th St,BLDG
04/30/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	172 W 49th St,BLDG
04/30/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	172 W 49th St,BLDG
04/30/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	172 W 49th St,BLDG
04/30/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	172 W 49th St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	41 W 41st St,BLDG
05/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	43 W 41st St,BLDG
08/25/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	21 W 42nd St,BLDG
08/25/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	21 W 42nd St,BLDG
09/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	30 W 42nd St
09/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	39 W 42nd St,BLDG
09/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	43 W 42nd St,BLDG
09/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	26 W 37th St
07/15/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	Unabated	69 W 39th St,BLDG
07/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	69 W 39th St,BLDG
07/15/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	69 W 39th St,BLDG
07/15/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	Unabated	69 W 39th St,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	43 W 53rd St,BLDG
04/29/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	135 W 54th St,BLDG
05/02/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	135 W 22nd St,BLDG
04/22/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	102 W 50th St,BLDG
04/22/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	102 W 50th St,BLDG
04/22/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	102 W 50th St,BLDG
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	167 W 5th St,BLDG
05/15/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	135 W 52nd St
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	75 W 55th St
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	81 W 55th St,BLDG
04/29/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	Unabated	135 W 54th St,BLDG

05/15/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	33 W 8th St,1FLR
07/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	33 W 8th St,1FLR
08/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	33 W 8th St,1FLR
08/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	33 W 8th St,STREET
04/07/2025	In-service	CO detectors need to be installed and operational		New	158 W 8th St
04/07/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed		New	158 W 8th St
07/25/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	13 W 8th St,BLDG
06/17/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	Unabated	13 W 8th St,BLDG
09/02/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	44 W 7th St,BLDG
09/02/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	46 W 7th St,BLDG
09/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	46 W 7th St,BLDG
05/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	79 W 6th St,BLDG
07/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	79 W 6th St,BLDG
07/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	109 W 6th St,BLDG
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	586 Avenue C,1
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	32 W 51st St,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	48 W 51st St,BLDG
04/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	48 W 51st St,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	329 Avenue A,BLDG
05/14/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	329 Avenue A,BLDG
05/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	358 Avenue A,BLDG
05/09/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	358 Avenue A,BLDG
05/09/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	358 Avenue A,BLDG
09/22/2025	In-service	Vacant and unoccupied structures need to be secured; placard clearly visible.	N.J.A.C. 5:70-3, 311.1	New	16 E 31st St,BLDG
09/22/2025	In-service	Grills used accordingly (not on decks or balconies, 10ft from combustible structure)	N.J.A.C. 5:70-3, 308.1.4	New	16 E 31st St,BLDG
09/22/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	16 E 31st St,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	18 E 29th St,BLDG
04/26/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	18 E 29th St,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	26 E 29th St,BLDG
04/26/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	28 E 29th St,BLDG
09/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	41 E 17th St,BLDG
07/08/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	10 E 21st St,BLDG
07/08/2025	In-service	Fire Escapes: IMMEDIATE NOTIFICATION TO FIRE PREVENTION FOR STATE OF DISREPAIR	N.J.A.C. 5:70-3, 1031.7.1	New	10 E 21st St,BLDG
07/08/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	10 E 21st St,BLDG
09/23/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	13 E 21st St,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	51 E 21st St,BLDG
06/19/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	53 E 21st St,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	76 E 21st St,BLDG
05/19/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	86 E 21st St,BLDG
06/27/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	68 E 22nd St,BLDG
04/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	26 E 11th St
05/01/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	Unabated	30 E 15th St,BLDG
04/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	40 E 15th St,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	40 E 15th St,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	28 E 16th St,BLDG
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	28 E 16th St,BLDG
05/05/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	29 E 16th St,BLDG
05/23/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	13 Zabriskie Ave,BLDG
04/16/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	9 W 10th St,BLDG

04/16/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	9 W 10th St,BLDG
05/02/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	121 W 10th St,BLDG
05/02/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	Unabated	133 W 10th St,BLDG
05/02/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	149 W 10th St,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	149 W 10th St,BLDG
05/15/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	161 W 10th St,BLDG
05/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	169 W 10th St,BLDG
05/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	86 W 13th St,BLDG
06/10/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	86 W 13th St,BLDG
05/16/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	9 E 50th St,BLDG
05/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	9 E 50th St,BLDG
05/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	9 E 50th St,BLDG
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	19 E 51st St,BLDG
09/15/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	29 E 37th St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	33 E 38th St,BLDG
09/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	36 E 38th St,BLDG
05/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	31 E 39th St,BLDG
08/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	28 E 47th St,BLDG
08/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	28 E 47th St,BLDG
08/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	28 E 47th St,BLDG
08/18/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	28 E 47th St,BLDG
08/18/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	28 E 47th St,BLDG
08/18/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	28 E 47th St,BLDG
07/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	36 E 47th St,BLDG
07/30/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	36 E 47th St,BLDG
07/30/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	36 E 47th St,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	87 W 18th St,BLDG
09/04/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	92 W 18th St,BLDG
05/15/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	116 W 19th St,BLDG
05/15/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	116 W 19th St,BLDG
05/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	116 W 19th St,BLDG
04/14/2025	In-service	Grills used accordingly (not on decks or balconies, 15ft from combustible structure)		New	150 W 19th St
04/25/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	174 W 19th St,BLDG
04/25/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	174 W 19th St,BLDG
08/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	78 W 17th St,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	92 W 17th St,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	92 W 17th St,BLDG
09/04/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	64 W 18th St,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	71 W 18th St,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	72 W 18th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	64 W 15th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	68 W 15th St,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	68 W 15th St,BLDG
05/01/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	68 W 15th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	91 W 15th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	130 W 15th St,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	137 W 15th St
05/05/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	30 W 16th St,BLDG
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	65 W 16th St,BLDG

04/30/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	75 W 16th St,BLDG
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	126 W 16th St,BLDG
05/05/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	126 W 16th St,BLDG
05/05/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	130 W 16th St,BLDG
09/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	9 W 17th St,BLDG
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	26 W 17th St,BLDG
08/29/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	72 W 17th St,BLDG
04/27/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	93 W 25th St
04/27/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	96 W 25th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	42 W 26th St
05/03/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	135 W 26th St,BLDG
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	135 W 26th St,BLDG
04/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	147 W 26th St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	147 W 26th St,BLDG
05/03/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	147 W 26th St,BLDG
05/03/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	147 W 26th St,BLDG
05/03/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	147 W 26th St,BLDG
04/25/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	64 W 27th St,BLDG
04/25/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	64 W 27th St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	134 W 27th St,BLDG
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	91 W 24th St
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	121 W 24th St,BLDG
05/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	135 W 24th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	135 W 24th St,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	163 W 24th St,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	163 W 24th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	167 W 24th St,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	173 W 24th St,BLDG
05/20/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	177 W 24th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	181 W 24th St,BLDG
04/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	86 W 20th St,BLDG
04/18/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	131 W 21st St,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	131 W 21st St,BLDG
04/18/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	131 W 21st St,BLDG
04/27/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	11 W 22nd St,BLDG
05/14/2025	In-service	Fire protection equipment rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1	Unabated	63-65 W 1st St,BLDG
09/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	40 W 20th St,BLDG
06/02/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	13 Zabriskie Ave,BLDG
09/11/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	589 Broadway,1FLR
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	466 Kennedy Blvd,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	478 Kennedy Blvd,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	500 Kennedy Blvd,BLDG
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	660 Broadway,BLDG
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	668 Broadway
09/22/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	679 Broadway
09/22/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	679 Broadway
09/22/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	679 Broadway
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	680 Broadway
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	680 Broadway,BLDG

05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	694 Broadway,BLDG
05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	694 Broadway,STREET
06/10/2025	In-service	Fire Escapes: IMMEDIATE NOTIFICATION TO FIRE PREVENTION FOR STATE OF DISREPAIR	N.J.A.C. 5:70-3, 1031.7.1	Unabated	2 E 33rd St
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	44 E 33rd St,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	15 W 33rd St
09/22/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	19 W 33rd St,BLDG
09/22/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	19 W 33rd St,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	24 W 33rd St
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	76 W 33rd St,BLDG
04/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	93 W 33rd St
04/15/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	93 W 33rd St
09/17/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	100 W 33rd St,BLDG
07/21/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	129 W 33rd St,BLDG
07/21/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	129 W 33rd St,BLDG
07/21/2025	In-service	Fire protection equipment rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1	Unabated	129 W 33rd St,BLDG
07/21/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	Unabated	129 W 33rd St,BLDG
07/21/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	Unabated	129 W 33rd St,BLDG
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	141 W 33rd St,BLDG
05/17/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	728 Avenue A
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	898 Avenue C,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	938 Avenue C
07/24/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	956 Avenue C,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	961 Avenue C
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	967 Avenue C,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	967 Avenue C,BLDG
05/20/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	979 Avenue C
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1005 Avenue C,BLDG
05/15/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	1011 Avenue C,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	95 W 17th St,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	13 W 18th St
05/14/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	141 W 57th St,BLDG
05/10/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	93 W 46th St,BLDG
04/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	120 W 23rd St,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	820 Avenue C,BLDG
05/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	835 Avenue C,1FLR
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	863 Avenue C,BLDG
05/01/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	877 Avenue C,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	877 Avenue C,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	116 W 47th St
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	116 W 47th St
05/12/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	116 W 47th St
05/12/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	116 W 47th St
07/28/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	Unabated	130 W 47th St,BLDG
05/05/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	130 W 47th St,BLDG
05/05/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	130 W 47th St,BLDG
05/05/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	Unabated	130 W 47th St,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	13 W 48th St,BLDG
04/23/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	14 W 48th St,BLDG
07/30/2025	In-service	Utility rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1.1	New	37 W 48th St,BLDG

04/23/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	37 W 48th St,BLDG
04/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	59 W 3rd St
04/29/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	139 Linnett St,BLDG
04/29/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	139 Linnett St,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	569 Broadway,BLDG
04/07/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational		New	158 W 8th St
08/14/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	Unabated	13 Cottage St,BLDG
08/14/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	Unabated	13 Cottage St,BLDG
08/14/2025	In-service		N.J.A.C. 5:70-3, 304.1.2	Unabated	13 Cottage St,BLDG
08/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	13 Cottage St,BLDG
07/31/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	15 Cottage St
04/26/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	16 Cottage St
04/26/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	16 Cottage St
09/11/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	583 Broadway
09/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	587 Broadway
09/11/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	589 Broadway,1FLR
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	599 Broadway,BLDG
05/01/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	602 Broadway,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	604 Broadway,BLDG
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	604 Broadway,BLDG
05/05/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	Unabated	103 W 47th St,BLDG
05/05/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	103 W 47th St,BLDG
09/11/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	589 Broadway,BLDG
09/11/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	589 Broadway,BLDG
09/11/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	589 Broadway,BLDG
09/11/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	589 Broadway,BLDG
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	568 Avenue C,BLDG
08/28/2025	In-service	Fire Escapes: All obstructions require removal.	N.J.A.C. 5:70-3, 1031.3	New	570 Avenue C,BLDG
08/28/2025	In-service	Fire Escapes: All obstructions require removal	N.J.A.C. 5:70-3, 1031.3	New	570 Avenue C,BLDG
08/28/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	570 Avenue C,BLDG
08/28/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	570 Avenue C,BLDG
09/18/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	578 Avenue C,BLDG
04/26/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	13 Cottage St,BLDG
07/03/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	13 Cottage St,BLDG
07/03/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	13 Cottage St,BLDG
07/03/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	Unabated	13 Cottage St,BLDG
05/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	212 Broadway,1FLR
04/24/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	214 Broadway,1FLR
04/24/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	214 Broadway,1FLR
04/24/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	214 Broadway,BLDG
04/25/2025	In-service		N.J.A.C. 5:70-3, 704.1	Unabated	243 Broadway,BLDG
08/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	243 Broadway,BLDG
06/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	235 Broadway,STREET
06/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	236 Broadway,BLDG
06/09/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	236 Broadway,BLDG
06/05/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	239 Broadway,BLDG
08/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	239 Broadway,BLDG
04/25/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	Unabated	243 Broadway,BLDG
04/25/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	Unabated	243 Broadway,BLDG

04/25/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	Unabated	243 Broadway,BLDG
08/29/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	432 Avenue C,BLDG
05/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1043 Broadway,BLDG
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	158 W 30th St
05/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	14 W 31st St,BLDG
05/16/2025	In-service	Fire Escapes: All obstructions require removal	N.J.A.C. 5:70-3, 1031.3	New	14 W 31st St,BLDG
05/16/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	25 W 31st St
04/25/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	260 Broadway,1
04/25/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	Unabated	260 Broadway,1
04/25/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	Unabated	260 Broadway,BLDG
08/29/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	260 Broadway,BLDG
04/26/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	135 W 30th St,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	135 W 30th St,BLDG
09/17/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	136 W 30th St,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	142 W 30th St,BLDG
08/28/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	334 Broadway,A
08/28/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	334 Broadway,STREET
08/28/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	334 Broadway,STREET
05/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	140 Avenue B
04/24/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	174 Avenue B,1FLR
04/24/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	178 Avenue B
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	178 Avenue B
06/25/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	Unabated	735 Avenue A,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	742 Avenue A,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	135 Avenue B,BLDG
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	136 Avenue B,BLDG
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	136 Avenue B,BLDG
04/17/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	357 Broadway,BLDG
04/25/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	360 Broadway,BLDG
04/25/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	361 Broadway,A
09/11/2025	In-service	Fire protection equipment rooms shall be clearly marked and identified	N.J.A.C. 5:70-3, 509.1	New	364 Broadway
09/11/2025	In-service	All electrical hazards need to be abated (open junction boxes, exposed wires, etc.)	N.J.A.C. 5:70-3, 604.1	New	364 Broadway
09/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	110 W 42nd St
09/09/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	110 W 42nd St
09/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	77 W 43rd St,BLDG
09/08/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	77 W 43rd St,BLDG
04/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	350 Broadway,A
04/17/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	353 Broadway,STREET
04/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	353 Broadway,STREET
04/25/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	355 Broadway,1
04/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	357 Broadway
04/17/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	357 Broadway
04/17/2025	In-service	Extension cords not to be used as permanent wiring	N.J.A.C. 5:70-3, 604.5	New	357 Broadway
07/24/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	7 Newark Bay Ct,BLDG
08/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		Unabated	37 Newark Bay Ct,BLDG
07/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	68 Newman Ave
05/13/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	75 Newman Ave,BLDG
04/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	433 Broadway
06/06/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	Unabated	1171 Kennedy Blvd,BLDG

06/06/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	Unabated	1171 Kennedy Blvd,BLDG
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1178 Kennedy Blvd
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1187 Kennedy Blvd
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1187 Kennedy Blvd
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	1200 Kennedy Blvd,BLDG
04/17/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	133 W 20th St,BLDG
04/17/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	133 W 20th St,BLDG
04/17/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	133 W 20th St,BLDG
04/17/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	133 W 20th St,BLDG
05/15/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	152 W 20th St,BLDG
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	39 W 21st St,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	39 W 21st St,BLDG
08/04/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	972 Broadway,A
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	947 Broadway
05/14/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	950 Broadway,BLDG
05/02/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	924 Broadway,BLDG
05/02/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	924 Broadway,BLDG
05/02/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	924 Broadway,BLDG
05/02/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	924 Broadway,BLDG
05/02/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	Unabated	972 Broadway,STREET
04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1047 Broadway,BLDG
04/21/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	1047 Broadway,BLDG
04/21/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	1047 Broadway,BLDG
05/13/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	1067 Broadway,BLDG
07/15/2025	In-service	Waste and debris accumulation prohibited on or around premises	N.J.A.C. 5:70-3, 304.1	New	527 Avenue A,BLDG
04/28/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	534 Avenue A,BLDG
04/25/2025	In-service		N.J.A.C.5:70-4.7	Unabated	250 Broadway,BLDG
05/02/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	593 Avenue A,BLDG
04/22/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	128 W 49th St,BLDG
04/22/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	128 W 49th St,BLDG
05/16/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	78 E 24th St,BLDG
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1256 Kennedy Blvd,1
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1256 Kennedy Blvd,1
04/18/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1256 Kennedy Blvd,BLDG
04/18/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		New	1256 Kennedy Blvd,BLDG
08/08/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1325 Kennedy Blvd
04/16/2025	In-service	Fire Protection Systems (alarms, detectors, panels) shall be inspected and tested (report where applicable) and operational	N.J.A.C. 5:70-3, 907.8	New	418 Broadway,BLDG
04/16/2025	In-service	Sprinklers need to be tested (need report), maintained, and unobstructed	N.J.A.C. 5:70-3, 903.5	New	418 Broadway,BLDG
04/16/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	418 Broadway,BLDG
07/28/2025	In-service	Clearance needs to be maintained around electrical panels (3ft clearance in all directions)	N.J.A.C. 5:70-3, 604.3	New	418 Broadway,STREET
06/23/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		Unabated	423 Broadway
05/12/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	427 Broadway,1
05/12/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-12[g])		New	427 Broadway,1
07/28/2025	In-service	Emergency Lights and Exit Signs shall be operational and unobstructed	N.J.A.C. 5:70-3, 1013.1	New	431 Broadway
07/28/2025	In-service	Storage needs to be kept neat and orderly and pose no threat to safety	N.J.A.C. 5:70-3, 315.3	New	431 Broadway
07/28/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	431 Broadway
04/30/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11[g])		Unabated	1347 Kennedy Blvd,1
04/21/2025	In-service	Egress doors shall operate without any special knowledge (no slide bolts or deadbolts)	N.J.A.C. 5:70-3, 1010.4	New	399 Broadway
04/21/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /	N.J.A.C. 5:70-2.1.(b)	New	403 Broadway,2FLR

04/21/2025	In-service	Failure to pay registration fees for non life hazard registration (Ordinance 19-11(g))		New	403 Broadway,BLDG
04/21/2025	In-service	CO detectors need to be installed and operational	N.J.A.C. 5:70-3, 915.6	New	403 Broadway,BLDG
04/21/2025	In-service	Extension cords not to be used as permanent wiring	N.J.A.C. 5:70-3, 604.5	New	403 Broadway,BLDG
04/21/2025	In-service	Exit and exit pathway shall be unobstructed at all times and not used for any other purpose.	N.J.A.C. 5:70-3, 1031.1	New	403 Broadway,BLDG
04/21/2025	In-service	Fire extinguishers shall be inspected, tagged, and unobstructed	N.J.A.C. 5:70-3, 906.2	New	403 Broadway,BLDG
09/09/2025	In-service	Access required for Inspection: City Ordinance 19-11 b (1) /		New	1222 Kennedy Blvd,2
04/14/2025	LHU Registration	Service - Vehicles		New	248 Avenue C,BLDG