

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 1

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/03/2025		0318	T	Globe Photo Engraving	19 A North Washington Ave.
05/05/2025		0320	P	Swagger Boat Yard	40 A North Washington Ave.
03/10/2025		0664K	R	RTR Auto Services	3 Alsan Way
03/10/2025	03/25/2025	0664K	P	RTR Auto Services	3 Alsan Way
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/25/2025
03/13/2025		0664K	O	RTR Auto Services	3 Alsan Way
03/21/2025	04/05/2025	0664K	R	RTR Auto Services	3 Alsan Way
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/05/2025
			Violation:	Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 04/05/2025
			Violation:	Fire sprinkler density cancellations required	Abate by: 04/05/2025
04/08/2025	04/23/2025	0664K	R	RTR Auto Services	3 Alsan Way
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/05/2025
			Violation:	Fire sprinkler density cancellations required	Abate by: 04/05/2025
04/25/2025	05/10/2025	0664K	R	RTR Auto Services	3 Alsan Way
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/05/2025
			Violation:	Fire sprinkler density cancellations required	Abate by: 04/05/2025
07/25/2025		0664K	T	RTR Auto Services	3 Alsan Way
07/30/2025		0664K	R	RTR Auto Services	3 Alsan Way
02/26/2025	03/13/2025	0008K	R	Brix City	4 Alsan Way
			Violation:	Carbon monoxide alarms shall be maintained in accordance with NFPA 720	Abate by: 12/12/2023
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 12/12/2023
			Violation:	Emergency lighting and exit signs shall be tested 30 seconds monthly and 1 hour or 90 minutes yearly	Abate by: 12/12/2023
			Violation:	Fire extinguishers require to be maintained per NFPA 10	Abate by: 12/12/2023
			Violation:	Compressed gas cylinders shall be secured.	Abate by: 12/12/2023
			Violation:	Combustable/flammable material must not be stored in the means of egress	Abate by: 12/12/2023
			Violation:	Clearence from heaters/ flame producing devices to combustables.	Abate by: 12/12/2023
			Violation:	30" wide x 36"deep x 75" high clearence required around electrical equipment	Abate by: 12/12/2023
			Violation:	Dangerous condition that could cause or contribute to the spread for fire	Abate by: 12/12/2023
02/26/2025	03/13/2025	0008K	F	Brix City	4 Alsan Way
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 04/08/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 2

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/29/2025		0008K	O	Brix City	4 Alsan Way
04/17/2025	05/02/2025	0663	R	J&J Tires & Wheels	1 Bergen Tpk
		Violation:		Electrical - Improper electrical	Abate by: 01/04/2025
		Violation:		Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 01/04/2025
		Violation:		Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 01/04/2025
05/03/2025		0663	R	J&J Tires & Wheels	1 Bergen Tpk
05/03/2025		0663	T	J&J Tires & Wheels	1 Bergen Tpk
05/03/2025		0663	T	J&J Tires & Wheels	1 Bergen Tpk
03/13/2025		0187	O	All In One Advanced Auto Repairs	39 Bergen Tpk
06/03/2025	06/18/2025	0187	P	All In One Advanced Auto Repairs	39 Bergen Tpk
		Violation:		Life Hazard Usage Fees Past Due	Abate by: 06/18/2025
		Violation:		General Conditions - Securing of compressed gas containers	Abate by: 06/18/2025
		Violation:		Fire Extinguishers - Outdated or discharged	Abate by: 06/18/2025
		Violation:		Fire Protection-Test on hard wire smoke alarm	Abate by: 06/18/2025
		Violation:		Fire & Smoke protection - Maintain fire rated construction	Abate by: 06/18/2025
		Violation:		Electrical - Open electrical junction boxes	Abate by: 06/18/2025
06/25/2025	07/10/2025	0187	R	All In One Advanced Auto Repairs	39 Bergen Tpk
		Violation:		Fire Protection-Test on hard wire smoke alarm	Abate by: 06/18/2025
		Violation:		Fire & Smoke protection - Maintain fire rated construction	Abate by: 06/18/2025
07/10/2025	07/25/2025	0187	R	All In One Advanced Auto Repairs	39 Bergen Tpk
		Violation:		Fire Protection-Test on hard wire smoke alarm	Abate by: 06/18/2025
		Violation:		Fire & Smoke protection - Maintain fire rated construction	Abate by: 06/18/2025
07/30/2025	08/14/2025	0187	R	All In One Advanced Auto Repairs	39 Bergen Tpk
		Violation:		Fire & Smoke protection - Maintain fire rated construction	Abate by: 06/18/2025
08/04/2025		0187	T	All In One Advanced Auto Repairs	39 Bergen Tpk
06/20/2025		0471	O	Building Inspection	46 Bergen Tpk
06/20/2025		0471	O	Building Inspection	46 Bergen Tpk
07/10/2025	07/25/2025	0471	P	Building Inspection	46 Bergen Tpk
		Violation:		Fire Department Connection Signage Required	Abate by: 07/25/2025
		Violation:		Fire Zone Required by Fire Official	Abate by: 07/25/2025
		Violation:		Electrical - Open electrical junction boxes	Abate by: 07/25/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
		Violation:		Red light required over Fire Department Connection	Abate by: 07/25/2025
		Violation:		confirm with your Fire Sprinkler contractor that both fire departments feed the same system.	Abate by: 07/25/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 3

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Sprinkler system testing and maintenance required.	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
03/31/2025		0478K	T	A Self Storage	50 Bergen Tpk
08/20/2025	09/02/2025	0002	P	Sign Avenue	53 bergen Tpk
			Violation:	No smoking sign compliance required.	Abate by: 09/02/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 09/02/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 09/02/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/02/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/02/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 09/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 09/02/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/02/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 09/02/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 09/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 09/02/2025
08/15/2025	08/30/2025	0015K	P	Scientific Design Co. Inc.	76 Bergen Tpk
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 08/30/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/30/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/30/2025
07/18/2025	08/02/2025	1026	P	Alpha Advertising Inc.	109 Bergen Tpk
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
08/07/2025	08/22/2025	1026	R	Alpha Advertising Inc.	109 Bergen Tpk
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/22/2025
			Violation:	Electrical - Extension cords	Abate by: 08/22/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/22/2025
			Violation:	Fire Protection-Test on hard wire smoke alarm	Abate by: 08/22/2025
08/19/2025		1026	R	Alpha Advertising Inc.	109 Bergen Tpk
05/27/2025	06/11/2025	0721	P	Caspian Sea Auto Sales	136 Bergen tpk
			Violation:	Quantity of Vehicles Exceeds permitted amount as stated on car lot license issued by Borough.	Abate by: 06/11/2025
			Violation:	Junkyard prohibited in the Borough of Little Ferry	Abate by: 06/11/2025
			Violation:	Fire Zone Required by Fire Official	Abate by: 06/11/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 05/28/2025
			Violation:	General Conditions - Outside storage must be 5' from building	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 06/11/2025
			Violation:	Fire protection - Maintenance on detectors	Abate by: 06/11/2025
			Violation:	Fire Protection-Test on hard wire heat detector alarms	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 4

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Utility shut off's shall be clearly labeled.	ViolaAbate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 06/11/2025
			Violation:	General Conditions - General Conditions	Abate by: 06/11/2025
				Contributing to fire	
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 06/11/2025
			Violation:	General Conditions - General Conditions	Abate by: 06/11/2025
				Contributing to fire	
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	General Conditions - Fueled	Abate by: 06/11/2025
				equipment,motocycles,lawn care,cooking ,ect.	
			Violation:	Electrical - Unused electrical	Abate by: 06/11/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 06/11/2025
			Violation:	Spraying operations required approved spray booth.	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
			Violation:	Contact building department prior to making any electrical repairs permits may be needed.	Abate by: 06/11/2025
05/28/2025	06/11/2025	0721	R	Caspian Sea Auto Sales	136 Bergen tpk
			Violation:	Quantity of Vehicles Exceeds permitted amount as stated on car lot license issued by Borough.	Abate by: 06/11/2025
			Violation:	Junkyard prohibited in the Borough of Little Ferry	Abate by: 06/11/2025
			Violation:	Fire Zone Required by Fire Official	Abate by: 06/11/2025
			Violation:	General Conditions - Outside storage must be 5' from building	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 06/11/2025
			Violation:	Fire protection - Maintenance on detectors	Abate by: 06/11/2025
			Violation:	Fire Protection-Test on hard wire heat detector alarms	Abate by: 06/11/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 06/11/2025
			Violation:	General Conditions - General Conditions	Abate by: 06/11/2025
				Contributing to fire	
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 06/11/2025
			Violation:	General Conditions - General Conditions	Abate by: 06/11/2025
				Contributing to fire	
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	General Conditions - Fueled	Abate by: 06/11/2025
				equipment,motocycles,lawn care,cooking ,ect.	
			Violation:	Electrical - Unused electrical	Abate by: 06/11/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 06/11/2025
			Violation:	Spraying operations required approved spray booth.	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
			Violation:	Contact building department prior to making any electrical repairs permits may be needed.	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 5

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/28/2025		0721	O	Caspian Sea Auto Sales	136 Bergen tpk
07/08/2025	07/23/2025	0721	R	Caspian Sea Auto Sales	136 Bergen tpk
				Violation: Junkyard prohibited in the Borough of Little Ferry	Abate by: 06/11/2025
				Violation: Fire Zone Required by Fire Official	Abate by: 06/11/2025
				Violation: General Conditions - Outside storage must be 5' from building	Abate by: 06/11/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 06/11/2025
				Violation: Fire Protection-Test on hard wire heat detector alarms	Abate by: 06/11/2025
				Violation: Electrical - Extension cords	Abate by: 06/11/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 06/11/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 06/11/2025
				Violation: General Conditions - Storage of flammable and combustible materials	Abate by: 06/11/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
04/10/2025	04/25/2025	0022	P	Dunkin Donuts	250 Bergen Tpk
				Violation: Fire Service Features - Knox box required	Abate by: 04/25/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 04/25/2025
				Violation: Electrical - Clearance	Abate by: 04/25/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 04/25/2025
04/29/2025	05/14/2025	0022	R	Dunkin Donuts	250 Bergen Tpk
				Violation: Fire Service Features - Knox box required	Abate by: 04/25/2025
04/16/2025		0022	T	Dunkin Donuts	250 Bergen Tpk
05/14/2025		0022	R	Dunkin Donuts	250 Bergen Tpk
03/06/2025		0481K	T	Building Inspection	260 Bergen Tpk
03/08/2025		0481K	F	Building Inspection	260 Bergen Tpk
08/04/2025		0481K	T	Building Inspection	260 Bergen Tpk
03/10/2025	03/25/2025	0623K	P	Tofu Tofu Inc (U-Chun)	260 Bergen Tpk
				Violation: Cooking Areas - Class "K" extinguisher	Abate by: 03/25/2025
03/17/2025		0623K	T	Tofu Tofu Inc (U-Chun)	260 Bergen Tpk
03/21/2025		0623K	R	Tofu Tofu Inc (U-Chun)	260 Bergen Tpk
03/10/2025		0626K	P	Sang's Kitchen (KOREAN)	260 Bergen Tpk
03/17/2025		0626K	T	Sang's Kitchen (KOREAN)	260 Bergen Tpk
03/10/2025	03/25/2025	0627K	P	Daegu Chicken	260 Bergen Tpk
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/25/2025
				Violation: Electrical - Clearance	Abate by: 03/25/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 6

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Electrical- Multiplug adaptor	ViolaAbate by: 03/25/2025
			Violation:	Electrical - Improper electrical	Abate by: 03/25/2025
03/17/2025		0627K	T	Daegu Chicken	260 Bergen Tpk
03/21/2025		0627K	R	Daegu Chicken	260 Bergen Tpk
03/24/2025		0627K	T	Daegu Chicken	260 Bergen Tpk
03/10/2025		0632K	P	Aritaum Little Ferry	260 Bergen Tpk
03/10/2025	03/25/2025	0658	P	Tous Les Jours (Bakery)	260 Bergen Tpk
			Violation:	Electrical - Clearance	Abate by: 03/25/2025 CV
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/25/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/25/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/25/2025
			Violation:	Electrical - Extension cords	Abate by: 03/25/2025
03/17/2025		0658	T	Tous Les Jours (Bakery)	260 Bergen Tpk
03/21/2025		0658	R	Tous Les Jours (Bakery)	260 Bergen Tpk
03/10/2025		0777K	P	Tiger Sugar	260 Bergen Tpk
03/10/2025	03/25/2025	0846	P	Jeong's Noodle (CHINESE)	260 Bergen Tpk
			Violation:	Exhaust hood required for equipment that produces grease laden vapors.	Abate by: 03/25/2025
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 03/25/2025
03/17/2025		0846	T	Jeong's Noodle (CHINESE)	260 Bergen Tpk
03/21/2025		0846	R	Jeong's Noodle (CHINESE)	260 Bergen Tpk
03/10/2025	03/25/2025	0912	P	Katsune Donkatsu	260 Bergen Tpk
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 03/25/2025
03/17/2025		0912	T	Katsune Donkatsu	260 Bergen Tpk
03/21/2025		0912	R	Katsune Donkatsu	260 Bergen Tpk
04/03/2025	04/18/2025	0025	P	Little Ferry Wine & Country	299 Bergen Tpk
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/18/2025
			Violation:	Fire protection - Maintenance on smoke detectors	Abate by: 04/18/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/18/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/18/2025
05/12/2025		0025	R	Little Ferry Wine & Country	299 Bergen Tpk

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 7

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/03/2025	06/18/2025	0026	P	bp Fuel	300 Bergen Tpk
			Violation:	Electrical - Extension cords	Abate by: 06/18/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 06/18/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/18/2025
06/25/2025		0026	R	bp Fuel	300 Bergen Tpk
06/03/2025	06/18/2025	0027	P	Rich Auto Service	300 Bergen Tpk
			Violation:	Electrical - Extension cords	Abate by: 06/18/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/18/2025
06/25/2025		0027	R	Rich Auto Service	300 Bergen Tpk
03/24/2025		0028	T	White Castle	310 Bergen Tpk
06/23/2025		0028	P	White Castle	310 Bergen Tpk
04/11/2025	04/26/2025	0997	P	Multiple Dwelling	321 Bergen Tpk
			Violation:	Fire protection-Test on battery smoke alarm	Abate by: 04/26/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/26/2025
			Violation:	Fire Extinguishers - General location	Abate by: 04/26/2025
04/12/2025		0997	T	Multiple Dwelling	321 Bergen Tpk
04/23/2025		0997	T	Multiple Dwelling	321 Bergen Tpk
04/23/2025		0997	R	Multiple Dwelling	321 Bergen Tpk
04/16/2025		1005	B	Meridia	110 Bergen Tpk Building A
04/16/2025		1005	O	Meridia	110 Bergen Tpk Building A
06/16/2025		1005	O	Meridia	110 Bergen Tpk Building A
07/04/2025		1005	O	Meridia	110 Bergen Tpk Building A
04/16/2025		1006	O	Meridia	110 Bergen Tpk Building B
07/04/2025		1006	O	Meridia	110 Bergen Tpk Building B
07/04/2025		1006	T	Meridia	110 Bergen Tpk Building B
03/05/2025	03/20/2025	0772K	P	Building Inspection	260 Bergen Tpk Pad
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 03/20/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 03/20/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 8

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address	
03/06/2025		0772K	T	Building Inspection	260 Bergen Tpk Pad	
03/06/2025		0772K	T	Building Inspection	260 Bergen Tpk Pad	
03/12/2025		0772K	R	Building Inspection	260 Bergen Tpk Pad	
03/05/2025	03/20/2025	0774K	P	Louis Castel	260 Bergen Tpk Pad Suite 2	
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025	
				Violation: Electrical - Clearance	Abate by: 03/20/2025	
				Violation: Electrical - Extention cords	Abate by: 03/20/2025	
				Violation: Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 03/20/2025	
03/21/2025		0774K	R	Louis Castel	260 Bergen Tpk Pad Suite 2	
03/05/2025		0773K	P	Bunsiknara Plus	260 Bergen Tpk Pad Suite 3	
03/10/2025	03/25/2025	0024K	P	H-Mart	260 Bergen Tpk Suite A	
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 03/25/2025	CV
				Violation: Electrical - Clearance	Abate by: 03/25/2025	
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/25/2025	
03/21/2025	04/05/2025	0024K	R	H-Mart	260 Bergen Tpk Suite A	
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 03/25/2025	CV
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/25/2025	
04/07/2025		0024K	R	H-Mart	260 Bergen Tpk Suite A	
03/05/2025	03/20/2025	0655	P	Wine and People Company	260 Bergen Tpk Suite B	
				Violation: Electrical - Clearance	Abate by: 03/20/2025	
				Violation: Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 03/20/2025	
				Violation: Electrical - Extension cords	Abate by: 03/20/2025	
				Violation: Electrical - Improper electrical	Abate by: 03/20/2025	
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025	
03/21/2025		0655	R	Wine and People Company	260 Bergen Tpk Suite B	
03/05/2025	03/20/2025	0786K	P	Cast Iron Pot Signature	260 Bergen Tpk Suite C&D	
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025	
				Violation: Electrical - Clearance	Abate by: 03/20/2025	
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025	
				Violation: Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 03/20/2025	
03/21/2025		0786K	R	Cast Iron Pot Signature	260 Bergen Tpk Suite C&D	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 9

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/05/2025	03/20/2025	0776K	P	Cafe Hased	260 Bergen Tpk Suite E
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/20/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/20/2025
			Violation:	Electrical - Improper electrical	Abate by: 03/20/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 03/20/2025
			Violation:	Fire Extinguishers - General location	Abate by: 03/20/2025
03/21/2025	04/05/2025	0776K	R	Cafe Hased	260 Bergen Tpk Suite E
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/20/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/20/2025
			Violation:	Electrical - Improper electrical	Abate by: 03/20/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 03/20/2025
			Violation:	Fire Extinguishers - General location	Abate by: 03/20/2025
04/07/2025		0776K	R	Cafe Hased	260 Bergen Tpk Suite E
03/05/2025	03/20/2025	0670K	P	Little Ferry Pharmacy	260 Bergen Tpk Suite F
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/20/2025
03/21/2025	04/05/2025	0670K	R	Little Ferry Pharmacy	260 Bergen Tpk Suite F
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/20/2025
04/07/2025	04/22/2025	0670K	R	Little Ferry Pharmacy	260 Bergen Tpk Suite F
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/20/2025
04/17/2025		0670K	R	Little Ferry Pharmacy	260 Bergen Tpk Suite F
03/05/2025	03/20/2025	0775K	P	Daiso	260 Bergen Tpk Suite G
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
03/21/2025		0775K	R	Daiso	260 Bergen Tpk Suite G
04/14/2025		0775K	O	Daiso	260 Bergen Tpk Suite G
03/05/2025	03/20/2025	0811K	P	Planet Fitness	260 Bergen Tpk Suite H
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/20/2025
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
03/21/2025		0811K	R	Planet Fitness	260 Bergen Tpk Suite H

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/05/2025	03/20/2025	0814K	P	Golfzon Range LLC	260 Bergen Tpk Suite I
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
03/21/2025	04/05/2025	0814K	R	Golfzon Range LLC	260 Bergen Tpk Suite I
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
04/07/2025	04/22/2025	0814K	R	Golfzon Range LLC	260 Bergen Tpk Suite I
			Violation:	Electrical - Clearance	Abate by: 03/20/2025
04/14/2025		0814K	O	Golfzon Range LLC	260 Bergen Tpk Suite I
05/12/2025		0814K	O	Golfzon Range LLC	260 Bergen Tpk Suite I
05/12/2025		0814K	R	Golfzon Range LLC	260 Bergen Tpk Suite I
06/07/2025		0814K	O	Golfzon Range LLC	260 Bergen Tpk Suite I
03/28/2025		0983	O	Launch Family Entertainment	260 Bergen Tpk Suite J/K
08/14/2025	08/29/2025	0983	P	Launch Family Entertainment	260 Bergen Tpk Suite J/K
			Violation:	Fire Service Features - Knox box required	Abate by: 08/29/2025
			Violation:	Electrical - Extension cords	Abate by: 08/29/2025
			Violation:	Electrical - Extension cords	Abate by: 08/29/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/29/2025
06/20/2025	07/05/2025	0528	P	J and S Divas	46 Bergen Tpk Unit 1
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
07/07/2025	07/22/2025	0528	R	J and S Divas	46 Bergen Tpk Unit 1
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
07/18/2025		0528	R	J and S Divas	46 Bergen Tpk Unit 1
06/20/2025	07/05/2025	0812	P	Sherlock Leather & Fur	46 Bergen Tpk Unit 2
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/05/2025
07/07/2025	07/22/2025	0812	R	Sherlock Leather & Fur	46 Bergen Tpk Unit 2
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/22/2025
			Violation:	Electrical - Extension cords	Abate by: 07/22/2025
			Violation:	Electrical - Extension cords	Abate by: 07/22/2025
07/29/2025	08/13/2025	0812	R	Sherlock Leather & Fur	46 Bergen Tpk Unit 2
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/22/2025
			Violation:	Electrical - Extension cords	Abate by: 07/22/2025
			Violation:	Electrical - Extension cords	Abate by: 07/22/2025
06/20/2025	07/05/2025	0474	P	Neils Pizza	46 Bergen Tpk Unit 3
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 07/05/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 11

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/07/2025		0474	R	Neils Pizza	46 Bergen Tpk Unit 3
06/20/2025	07/05/2025	0813	P	RBA Fitness	46 Bergen Tpk Unit 4/5
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
07/07/2025	07/22/2025	0813	R	RBA Fitness	46 Bergen Tpk Unit 4/5
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
07/29/2025		0813	R	RBA Fitness	46 Bergen Tpk Unit 4/5
06/20/2025	07/05/2025	0659	P	AMP Healthy Spa	46 Bergen Tpk Unit 6
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
07/07/2025		0659	R	AMP Healthy Spa	46 Bergen Tpk Unit 6
06/20/2025	07/05/2025	0014	P	Wei Chaun Kitchen	46 Bergen Tpk Unit 7
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 07/05/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 07/05/2025
			Violation:	Excessive grease building up must be removed from all surfaces.	Abate by: 07/05/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/05/2025
07/07/2025	07/22/2025	0014	R	Wei Chaun Kitchen	46 Bergen Tpk Unit 7
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 07/05/2025
07/29/2025	08/13/2025	0014	R	Wei Chaun Kitchen	46 Bergen Tpk Unit 7
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 07/05/2025
06/20/2025	07/05/2025	0477	P	Sunshine Suds	46 Bergen Tpk Unit 8
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/05/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/05/2025
			Violation:	QUESTIONS PLEASE EMAIL ME	Abate by: 07/05/2025
07/07/2025	07/22/2025	0477	R	Sunshine Suds	46 Bergen Tpk Unit 8
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/05/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/05/2025
			Violation:	QUESTIONS PLEASE EMAIL ME	Abate by: 07/05/2025
07/07/2025	07/22/2025	0477	C	Sunshine Suds	46 Bergen Tpk Unit 8
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/22/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/22/2025
			Violation:	Magnetic door locks must release from fire alarm signal	Abate by: 07/22/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 12

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/29/2025	08/13/2025	0477	R	Sunshine Suds	46 Bergen Tpk Unit 8
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/05/2025
07/29/2025	08/13/2025	0477	F	Sunshine Suds	46 Bergen Tpk Unit 8
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/22/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/22/2025
			Violation:	Magnetic door locks must release from fire alarm signal	Abate by: 07/22/2025
04/30/2025	05/15/2025	0029K	P	NJ Expanding Capabilites	31 Chamberlain Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 05/15/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/15/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/15/2025
			Violation:	Cooking Area-Type One Hood	Abate by: 05/15/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/15/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/15/2025
			Violation:	General Conditions - Vegetation	Abate by: 05/15/2025
			Violation:	General Conditions - Vegetation	Abate by: 05/15/2025
			Violation:	Electrical - Extension cords	Abate by: 05/15/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/15/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 05/15/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/15/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 05/15/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 05/15/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/15/2025
			Violation:	Electrical - Extension cords	Abate by: 05/15/2025
			Violation:	Electrical - Extension cords	Abate by: 05/15/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/15/2025
05/02/2025		0029K	B	NJ Expanding Capabilites	31 Chamberlain Ave
05/08/2025		0029K	T	NJ Expanding Capabilites	31 Chamberlain Ave
06/02/2025	06/17/2025	0029K	R	NJ Expanding Capabilites	31 Chamberlain Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/15/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 05/15/2025
			Violation:	Electrical - Extension cords	Abate by: 05/15/2025
06/08/2025		0029K	T	NJ Expanding Capabilites	31 Chamberlain Ave
08/07/2025	08/22/2025	0029K	R	NJ Expanding Capabilites	31 Chamberlain Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/15/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 05/15/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 13

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/09/2025		0498	T	Advance housing inc	1 East Gate
03/12/2025		0498	R	Advance housing inc	1 East Gate
03/13/2025		0498	O	Advance housing inc	1 East Gate
06/25/2025		0030	P	LF REC CENTER	14 Garden St
05/28/2025	06/12/2025	0063	P	EB&J Products DBA Jenda Lab Products LLC	211 Gates Rd Unit E
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Storage on racks must be neat and stable	Abate by: 06/12/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
06/28/2025		0063	O	EB&J Products DBA Jenda Lab Products LLC	211 Gates Rd Unit E
07/01/2025	07/16/2025	0063	R	EB&J Products DBA Jenda Lab Products LLC	211 Gates Rd Unit E
			Violation:	Storage on racks must be neat and stable	Abate by: 06/12/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 06/12/2025
08/07/2025		0063	B	EB&J Products DBA Jenda Lab Products LLC	211 Gates Rd Unit E
05/28/2025	06/12/2025	0065	P	Romano Consulting Enterprises	211 Gates Rd Unit G
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
06/05/2025		0065	R	Romano Consulting Enterprises	211 Gates Rd Unit G
08/08/2025		1027	P	Power & Energy Tech Solutions	200 Gates Rd. Unit A
05/23/2025		0031K	O	Gates realty	200 Gates Road
07/10/2025	07/25/2025	0031K	P	Gates realty	200 Gates Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
06/17/2025		0048K	O	Gates realty Building + Utilites	201 Gates Road
07/10/2025	07/25/2025	0048K	P	Gates realty Building + Utilites	201 Gates Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Utility shut off's shall be clearly labeled.	ViolaAbate by: 07/25/2025
07/10/2025	07/25/2025	0056	P	A Self Storage	207 Gates Road
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
07/10/2025	07/25/2025	0911	P	Building Inspection	208 Gates Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
05/28/2025		0059K	O	Gates Realty Building & Utilities & Office	211 Gates Road
07/10/2025	07/25/2025	0059K	P	Gates Realty Building & Utilities & Office	211 Gates Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
03/19/2025		0078	B	Building Itself	212 Gates Road
07/10/2025	07/25/2025	0078	P	Building Itself	212 Gates Road
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 07/25/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/25/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
04/11/2025		0999	B	VTR MOTO	214 Gates Road
04/11/2025		0999	O	VTR MOTO	214 Gates Road

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 15

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/04/2025	06/19/2025	0999	P	VTR MOTO	214 Gates Road
				Violation: Fire Service Features - Knox box required	Abate by: 06/19/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 06/19/2025
				Violation: Electrical - Improper electrical	Abate by: 06/19/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 06/19/2025
				Violation: Fire Extinguishers must not be obstructed	Abate by: 06/19/2025
				Violation: VIOLATIONS #4 AND 5 WILL REQUIRE NJSEA AND GATES APPROVAL PRIOR TO MOVING.	Abate by: 06/19/2025
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 06/19/2025
				Violation: General Conditions - Storage of flammable and combustible materials	Abate by: 06/19/2025
07/01/2025		0999	R	VTR MOTO	214 Gates Road
07/10/2025	07/25/2025	0999	C	VTR MOTO	214 Gates Road
				Violation: General Conditions - Outside storage must be 5' from building	Abate by: 07/25/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 07/25/2025
07/19/2025		0999	F	VTR MOTO	214 Gates Road
07/10/2025	07/25/2025	0082K	P	Gates realty	215 Gates Road
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
				Violation: Truss Roof and or Floor Symbol Required on structure.	Abate by: 07/25/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 07/25/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
03/19/2025		0858	T	Current Tenant	216 Gates Road
06/04/2025	06/19/2025	0858	P	Current Tenant	216 Gates Road
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/19/2025
06/24/2025		0858	R	Current Tenant	216 Gates Road
07/10/2025	07/25/2025	0115K	P	Gates Realty (Building itself)	223 Gates Road
				Violation: Fire protection-Test on fire alarm	Abate by: 07/25/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/25/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 16

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Utility shut off's shall be clearly labeled.	ViolaAbate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
07/10/2025	07/25/2025	1015	P	Gates Realty Corp	208 Gates Road Unit 1-2
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
06/08/2025		0850	T	Vision Tours Corp	208 Gates Road Unit 3
05/27/2025	06/11/2025	0049	P	Asamo Cosmetics International Corp	201 Gates Road Unit A
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
06/17/2025		0049	O	Asamo Cosmetics International Corp	201 Gates Road Unit A
07/01/2025		0049	R	Asamo Cosmetics International Corp	201 Gates Road Unit A
05/28/2025	06/12/2025	1013	P	Geo-Technology Associates Inc	211 Gates Road Unit A
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/12/2025
06/02/2025	06/17/2025	1013	P	Geo-Technology Associates Inc	211 Gates Road Unit A
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 06/17/2025
07/01/2025		1013	R	Geo-Technology Associates Inc	211 Gates Road Unit A
06/04/2025	06/19/2025	0079	P	Biotrans LLC	212 Gates Road Unit A
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/19/2025
07/05/2025		0079	O	Biotrans LLC	212 Gates Road Unit A
07/17/2025		0079	R	Biotrans LLC	212 Gates Road Unit A
07/17/2025		0079	O	Biotrans LLC	212 Gates Road Unit A
05/31/2025		1016	B	BLUE PURCHASE	215 Gates Road Unit A
06/23/2025	07/08/2025	1016	P	BLUE PURCHASE	215 Gates Road Unit A
			Violation:	Electrical - Extension cords	Abate by: 07/08/2025
07/08/2025		1016	R	BLUE PURCHASE	215 Gates Road Unit A
07/18/2025	08/02/2025	0110K	P	Feidelis corp	223 Gates Road Unit A
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/02/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/02/2025
			Violation:	Electrical - Clearance	Abate by: 08/02/2025
			Violation:	Obstructions that effect the effectiveness of Fire Sprinkler System or delay response.	Abate by: 08/02/2025
			Violation:	Prior to working on any fire protection system the	Abate by: 08/02/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 17

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				contractor must notify the police desk 2016412770	
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	Electrical - Extention cords	Abate by: 08/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/02/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/02/2025
			Violation:	"SUBPANEL IN OFFICE" SIGN FOR VIOLATION #10	Abate by: 08/02/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/02/2025
08/04/2025		0110K	T	Feidelis corp	223 Gates Road Unit A
08/14/2025	08/29/2025	0110K	R	Feidelis corp	223 Gates Road Unit A
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/02/2025
			Violation:	Electrical - Clearance	Abate by: 08/02/2025
			Violation:	Obstructions that effect the effectiveness of Fire Sprinkler System or delay response.	Abate by: 08/02/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	Electrical - Extention cords	Abate by: 08/02/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/02/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/02/2025
			Violation:	"SUBPANEL IN OFFICE" SIGN FOR VIOLATION #10	Abate by: 08/02/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/02/2025
05/23/2025	06/07/2025	0003	P	Popular Sales Inc	200 Gates Road Unit B
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
06/24/2025		0003	R	Popular Sales Inc	200 Gates Road Unit B
05/27/2025	06/11/2025	0639	P	Solar Energy Systems LLC	201 Gates Road Unit B
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025
06/02/2025	06/17/2025	0639	R	Solar Energy Systems LLC	201 Gates Road Unit B
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	General Conditions - Fueled equipment,motocycles,lawn care,cooking ,ect.	Abate by: 06/17/2025
			Violation:	Clear isle width required	Abate by: 06/17/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 06/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/17/2025
06/17/2025		0639	O	Solar Energy Systems LLC	201 Gates Road Unit B

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 18

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/28/2025		0639	O	Solar Energy Systems LLC	201 Gates Road Unit B
07/01/2025		0639	R	Solar Energy Systems LLC	201 Gates Road Unit B
05/28/2025	06/12/2025	0642	P	Collection XIIX, LTD	211 Gates Road Unit B
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
05/29/2025		0642	R	Collection XIIX, LTD	211 Gates Road Unit B
06/23/2025	07/08/2025	0501	P	The Most Collection Inc.	215 Gates Road Unit B
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Clear isle width required	Abate by: 07/08/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/08/2025
07/08/2025	07/23/2025	0501	R	The Most Collection Inc.	215 Gates Road Unit B
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/08/2025
08/06/2025	08/21/2025	0501	R	The Most Collection Inc.	215 Gates Road Unit B
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/08/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/21/2025
08/15/2025		0501	R	The Most Collection Inc.	215 Gates Road Unit B
07/18/2025		0856	P	Vacant As of 07/18/2025	223 Gates Road Unit B
07/18/2025		0856	O	Vacant As of 07/18/2025	223 Gates Road Unit B
05/23/2025	06/07/2025	0963	P	KRV Logistics Inc.	200 Gates Road Unit C
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
06/24/2025		0963	R	KRV Logistics Inc.	200 Gates Road Unit C
05/27/2025	06/11/2025	0051	P	City Design Group	201 Gates Road Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 19

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/17/2025		0051	O	City Design Group	201 Gates Road Unit C
07/01/2025	07/16/2025	0051	R	City Design Group	201 Gates Road Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025
07/17/2025	08/01/2025	0051	R	City Design Group	201 Gates Road Unit C
			Violation:	Electrical - Extension cords	Abate by: 08/01/2025
			Violation:	Electrical - Improper electrical	Abate by: 08/01/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/01/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/01/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/01/2025
08/08/2025		0051	R	City Design Group	201 Gates Road Unit C
05/28/2025	06/12/2025	0643	P	Global Distribution Trading	211 Gates Road Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/12/2025
06/28/2025		0643	O	Global Distribution Trading	211 Gates Road Unit C
07/01/2025	07/16/2025	0643	R	Global Distribution Trading	211 Gates Road Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/12/2025
06/23/2025	07/08/2025	0674	P	JR Custom Vinyls	215 Gates Road Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/08/2025		0674	R	JR Custom Vinyls	215 Gates Road Unit C
07/18/2025	08/02/2025	0112K	P	R & B Collection	223 Gates Road Unit C
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/02/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/02/2025
			Violation:	Clear isle width required	Abate by: 08/02/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 08/02/2025
08/05/2025		0112K	T	R & B Collection	223 Gates Road Unit C
08/05/2025		0112K	T	R & B Collection	223 Gates Road Unit C
08/14/2025		0112K	R	R & B Collection	223 Gates Road Unit C
05/23/2025	06/07/2025	0034	P	Bob International	200 Gates Road Unit D
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 06/07/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 06/07/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors	Abate by: 06/07/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 20

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				must be maintained	
06/24/2025	07/09/2025	0034	R	Bob International	200 Gates Road Unit D
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
07/09/2025		0034	R	Bob International	200 Gates Road Unit D
05/27/2025	06/11/2025	0785	P	Noblesse Collection Inc.	201 Gates Road Unit D
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
			Violation:	Electrical - Clearance	Abate by: 06/11/2025
06/17/2025		0785	O	Noblesse Collection Inc.	201 Gates Road Unit D
07/01/2025	07/16/2025	0785	R	Noblesse Collection Inc.	201 Gates Road Unit D
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
			Violation:	Electrical - Clearance	Abate by: 06/11/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/31/2025
07/18/2025	08/02/2025	0785	R	Noblesse Collection Inc.	201 Gates Road Unit D
			Violation:	Electrical - Improper electrical	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
07/29/2025		0785	R	Noblesse Collection Inc.	201 Gates Road Unit D
05/28/2025	06/12/2025	1014	P	Santa Cruz Coffee Company	211 Gates Road Unit D
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/12/2025
05/28/2025		1014	O	Santa Cruz Coffee Company	211 Gates Road Unit D
06/13/2025		1014	R	Santa Cruz Coffee Company	211 Gates Road Unit D
08/07/2025		1014	B	Santa Cruz Coffee Company	211 Gates Road Unit D
06/23/2025	07/08/2025	0878	P	JR Airduct Cleaning	215 Gates Road Unit D
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 21

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/08/2025	07/23/2025	0878	R	JR Airduct Cleaning	215 Gates Road Unit D
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/11/2025	07/26/2025	0878	R	JR Airduct Cleaning	215 Gates Road Unit D
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/26/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 07/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 07/26/2025
07/14/2025		0878	O	JR Airduct Cleaning	215 Gates Road Unit D
08/01/2025		0878	O	JR Airduct Cleaning	215 Gates Road Unit D
07/18/2025	08/09/2025	0857	P	Celebrity Carpet Inc.	223 Gates Road Unit D
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/09/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/09/2025
			Violation:	Fire Extinguishers - General location	Abate by: 08/09/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 08/09/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/09/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/09/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/09/2025
08/14/2025	08/29/2025	0857	R	Celebrity Carpet Inc.	223 Gates Road Unit D
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/09/2025
05/23/2025	06/07/2025	0804	P	BOB INTERNATIONAL	200 Gates Road Unit E
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
06/24/2025		0804	R	BOB INTERNATIONAL	200 Gates Road Unit E
05/27/2025	06/11/2025	0640	P	Noblesse Collection Inc.	201 Gates Road Unit E
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
06/17/2025		0640	O	Noblesse Collection Inc.	201 Gates Road Unit E
07/01/2025	07/16/2025	0640	R	Noblesse Collection Inc.	201 Gates Road Unit E
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 22

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/31/2025
07/18/2025	08/02/2025	0640	R	Noblesse Collection Inc.	201 Gates Road Unit E
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
07/29/2025		0640	R	Noblesse Collection Inc.	201 Gates Road Unit E
06/23/2025	07/08/2025	0087	P	High Tech Appliance LLC	215 Gates Road Unit E
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/29/2025		0087	R	High Tech Appliance LLC	215 Gates Road Unit E
05/23/2025		0848	P	Tostini Cafe Us Inc.	200 Gates Road Unit F
06/24/2025		0848	O	Tostini Cafe Us Inc.	200 Gates Road Unit F
07/10/2025		0848	O	Tostini Cafe Us Inc.	200 Gates Road Unit F
05/27/2025	06/11/2025	0540	P	7TY7 llc	201 Gates Road Unit F
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	General Conditions - Fueled equipment,motocycles,lawn care,cooking ,ect.	Abate by: 06/11/2025
			Violation:	Clear isle width required	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025
06/17/2025		0540	O	7TY7 llc	201 Gates Road Unit F
06/28/2025		0540	O	7TY7 llc	201 Gates Road Unit F
07/01/2025	07/16/2025	0540	R	7TY7 llc	201 Gates Road Unit F
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	General Conditions - Fueled equipment,motocycles,lawn care,cooking ,ect.	Abate by: 06/11/2025
			Violation:	Clear isle width required	Abate by: 06/11/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 06/11/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 23

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/17/2025		0540	O	7TY7 llc	201 Gates Road Unit F
08/08/2025	08/23/2025	0540	R	7TY7 llc	201 Gates Road Unit F
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/11/2025
			Violation:	Electrical - Extension cords	Abate by: 06/11/2025
05/28/2025	06/12/2025	0064	P	Khanji International LLC	211 Gates Road Unit F
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/12/2025
			Violation:	Electrical - Extention cords	Abate by: 06/12/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 06/12/2025
06/28/2025		0064	O	Khanji International LLC	211 Gates Road Unit F
07/01/2025	07/16/2025	0064	R	Khanji International LLC	211 Gates Road Unit F
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/12/2025
			Violation:	Electrical - Extention cords	Abate by: 06/12/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 06/12/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/11/2025
05/03/2025		0675	B	Legend Auto Spa	215 gates Road Unit F
06/23/2025	07/08/2025	0675	P	Legend Auto Spa	215 gates Road Unit F
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/08/2025	07/23/2025	0675	R	Legend Auto Spa	215 gates Road Unit F
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 07/23/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/23/2025
			Violation:	Electrical - Extention cords	Abate by: 07/23/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 07/23/2025
			Violation:	Electrical - Clearance	Abate by: 07/23/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 07/23/2025
			Violation:	Electrical - Improper electrical	Abate by: 07/23/2025
			Violation:	General Conditions - Accumulation of combustibile materials	Abate by: 07/23/2025
			Violation:	General Requirement - Storage in building shall be neat and orderly	Abate by: 07/23/2025
			Violation:	Accumilation of combustable dust must be kept to a minimum.	Abate by: 07/23/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 07/23/2025
			Violation:	Cutting cart requires an approved and appropriate fire extinguisher	Abate by: 07/23/2025
			Violation:	Spraying operations required approved spray booth.	Abate by: 07/23/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/23/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 24

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/08/2025		0675	O	Legend Auto Spa	215 gates Road Unit F
08/06/2025	08/21/2025	0675	R	Legend Auto Spa	215 gates Road Unit F
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/23/2025
			Violation:	Electrical - Extention cords	Abate by: 07/23/2025
			Violation:	Electrical - Clearance	Abate by: 07/23/2025
			Violation:	Electrical - Improper electrical	Abate by: 07/23/2025
			Violation:	General Conditions - Accumulation of combustibile materials	Abate by: 07/23/2025
			Violation:	General Requirement - Storage in building shall be neat and orderly	Abate by: 07/23/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 07/23/2025
			Violation:	Cutting cart requires an approved and appropriate fire extinguisher	Abate by: 07/23/2025
05/23/2025	06/07/2025	0593	P	NYBEE New York Inc	200 Gates Road Unit G
			Violation:	Electrical - Extention cords	Abate by: 06/07/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/07/2025
			Violation:	Electrical - Extention cords	Abate by: 06/07/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 06/07/2025
			Violation:	Electrical - Clearance	Abate by: 06/07/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
07/01/2025	07/16/2025	0593	R	NYBEE New York Inc	200 Gates Road Unit G
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
08/08/2025	08/23/2025	0593	R	NYBEE New York Inc	200 Gates Road Unit G
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
05/27/2025	06/11/2025	0641	P	Josephson Home LLC	201 Gates Road Unit G
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025
06/17/2025		0641	O	Josephson Home LLC	201 Gates Road Unit G
06/28/2025		0641	O	Josephson Home LLC	201 Gates Road Unit G
06/28/2025	07/12/2025	0641	R	Josephson Home LLC	201 Gates Road Unit G
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025
07/17/2025	08/01/2025	0641	R	Josephson Home LLC	201 Gates Road Unit G
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 25

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/08/2025	09/08/2025	0641	R	Josephson Home LLC	201 Gates Road Unit G
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/11/2025
05/03/2025		0089	B	JNY Corporation	215 Gates Road Unit G
06/23/2025	07/08/2025	0089	P	JNY Corporation	215 Gates Road Unit G
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 07/08/2025
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
07/08/2025	07/23/2025	0089	R	JNY Corporation	215 Gates Road Unit G
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 07/08/2025
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
07/09/2025		0089	R	JNY Corporation	215 Gates Road Unit G
08/01/2025		0089	O	JNY Corporation	215 Gates Road Unit G
08/11/2025		0089	O	JNY Corporation	215 Gates Road Unit G
05/23/2025	06/07/2025	0045	P	The Wig USA Inc.	200 Gates Road Unit H
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 06/07/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
06/17/2025		0045	O	The Wig USA Inc.	200 Gates Road Unit H
07/01/2025	07/16/2025	0045	R	The Wig USA Inc.	200 Gates Road Unit H
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 06/07/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/07/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/16/2025
08/08/2025		0045	R	The Wig USA Inc.	200 Gates Road Unit H
05/28/2025	06/12/2025	0914	P	M. TILANI ENTERPRISE	211 Gates Road Unit H
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/12/2025
06/05/2025	06/20/2025	0914	R	M. TILANI ENTERPRISE	211 Gates Road Unit H
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/20/2025
			Violation:	Electrical - Extension cords	Abate by: 06/20/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/20/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 26

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/06/2025		0914	O	M. TILANI ENTERPRISE	211 Gates Road Unit H
07/10/2025	07/25/2025	0914	R	M. TILANI ENTERPRISE	211 Gates Road Unit H
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/20/2025
07/18/2025		0914	R	M. TILANI ENTERPRISE	211 Gates Road Unit H
06/23/2025	07/08/2025	0090	P	JNY Corporation	215 Gates Road Unit H
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Electrical - Improper electrical	Abate by: 07/08/2025
07/08/2025	07/23/2025	0090	R	JNY Corporation	215 Gates Road Unit H
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
			Violation:	Electrical - Improper electrical	Abate by: 07/08/2025
07/09/2025	07/24/2025	0090	R	JNY Corporation	215 Gates Road Unit H
			Violation:	Electrical - Improper electrical	Abate by: 07/08/2025
08/01/2025		0090	O	JNY Corporation	215 Gates Road Unit H
08/06/2025		0090	R	JNY Corporation	215 Gates Road Unit H
08/11/2025		0090	O	JNY Corporation	215 Gates Road Unit H
05/23/2025	06/07/2025	0597	P	The Wig USA Inc.	200 Gates Road Unit I
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
06/17/2025		0597	O	The Wig USA Inc.	200 Gates Road Unit I
07/01/2025	07/11/2025	0597	R	The Wig USA Inc.	200 Gates Road Unit I
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/07/2025
08/05/2025		0597	T	The Wig USA Inc.	200 Gates Road Unit I
08/05/2025		0597	T	The Wig USA Inc.	200 Gates Road Unit I
08/08/2025		0597	R	The Wig USA Inc.	200 Gates Road Unit I
05/28/2025	06/12/2025	0463	P	Hana Universal	211 Gates Road Unit I
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Clear isle width required	Abate by: 06/12/2025
			Violation:	Storage on racks must be neat and stable	Abate by: 06/12/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 27

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Fire Extinguishers must not be obstructed	ViolaAbate by: 06/12/2025
			Violation:	Fire Sprinkler system must not have obstructions to diminish the effectiveness	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Electrical - Extension cords	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/12/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 06/12/2025
06/29/2025		0463	O	Hana Universal	211 Gates Road Unit I
07/01/2025	07/16/2025	0463	R	Hana Universal	211 Gates Road Unit I
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Clear isle width required	Abate by: 06/12/2025
			Violation:	Storage on racks must be neat and stable	Abate by: 06/12/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 06/12/2025
			Violation:	Fire Sprinkler system must not have obstructions to diminish the effectiveness	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Electrical - Extension cords	Abate by: 06/12/2025
			Violation:	Electrical - Clearance	Abate by: 06/12/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/12/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 06/12/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/11/2025
06/23/2025	07/08/2025	0091	P	Galdi Plumbing	215 Gates Road Unit I
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/09/2025	07/24/2025	0091	R	Galdi Plumbing	215 Gates Road Unit I
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/22/2025	08/06/2025	0091	R	Galdi Plumbing	215 Gates Road Unit I
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 28

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/07/2025	08/22/2025	0091	R	Galdi Plumbing	215 Gates Road Unit I
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
08/15/2025		0091	R	Galdi Plumbing	215 Gates Road Unit I
05/23/2025	06/07/2025	1012	P	Liberty Mercantile	200 Gates Road UNIT J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
06/17/2025		1012	O	Liberty Mercantile	200 Gates Road UNIT J
07/01/2025	07/16/2025	1012	R	Liberty Mercantile	200 Gates Road UNIT J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
08/20/2025	09/04/2025	1012	R	Liberty Mercantile	200 Gates Road UNIT J
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/04/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/04/2025
			Violation:	Clear isle width required	Abate by: 09/04/2025
			Violation:	Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 09/04/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 09/04/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 09/04/2025
05/28/2025	06/12/2025	0067	P	BDO Solutions inc	211 Gates Road Unit J
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/12/2025
			Violation:	Electrical - Extension cords	Abate by: 06/12/2025
			Violation:	General Conditions - Fueled equipment,motocycles,lawn care,cooking ,ect.	Abate by: 06/12/2025
06/28/2025		0067	O	BDO Solutions inc	211 Gates Road Unit J
07/01/2025	07/16/2025	0067	R	BDO Solutions inc	211 Gates Road Unit J
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/12/2025
			Violation:	General Conditions - Fueled equipment,motocycles,lawn care,cooking ,ect.	Abate by: 06/12/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 29

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/23/2025	07/08/2025	0594	P	United Technologies Services Inc.	215 Gates Road Unit J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/08/2025	07/23/2025	0594	R	United Technologies Services Inc.	215 Gates Road Unit J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
08/06/2025	08/21/2025	0594	R	United Technologies Services Inc.	215 Gates Road Unit J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
05/23/2025	06/07/2025	0783	P	Microtac Water	200 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
06/17/2025		0783	O	Microtac Water	200 Gates Road Unit K
06/28/2025		0783	O	Microtac Water	200 Gates Road Unit K
06/28/2025	07/12/2025	0783	R	Microtac Water	200 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
07/01/2025	07/16/2025	0783	R	Microtac Water	200 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/07/2025
08/08/2025	08/23/2025	0783	R	Microtac Water	200 Gates Road Unit K
			Violation:	Electrical - Extension cords	Abate by: 08/23/2025
06/02/2025	06/17/2025	0068	P	Geo-Technology Associates Inc	211 Gates Road Unit K
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
07/07/2025		0068	R	Geo-Technology Associates Inc	211 Gates Road Unit K
06/23/2025	07/08/2025	0810	P	Armando's Services	215 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/08/2025	07/23/2025	0810	R	Armando's Services	215 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 30

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/01/2025	08/16/2025	0810	R	Armando's Services	215 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
08/01/2025		0810	O	Armando's Services	215 Gates Road Unit K
08/06/2025	08/21/2025	0810	R	Armando's Services	215 Gates Road Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
05/23/2025	06/07/2025	0849	P	Living Spring Water LLC	200 Gates Road Unit L
			Violation:	Electrical - Clearance	Abate by: 06/07/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 06/07/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/07/2025
06/17/2025		0849	O	Living Spring Water LLC	200 Gates Road Unit L
07/01/2025	07/16/2025	0849	R	Living Spring Water LLC	200 Gates Road Unit L
			Violation:	Electrical - Clearance	Abate by: 06/07/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 06/07/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/07/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/16/2025
07/18/2025		0849	R	Living Spring Water LLC	200 Gates Road Unit L
06/02/2025	06/17/2025	0069	P	WJL INC	211 Gates Road unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
07/06/2025		0069	O	WJL INC	211 Gates Road unit L
07/07/2025	07/22/2025	0069	R	WJL INC	211 Gates Road unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
08/11/2025	08/26/2025	0069	R	WJL INC	211 Gates Road unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
06/23/2025	07/08/2025	0464	P	Peter Bengston Inc	215 Gates Road Unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
07/08/2025	07/23/2025	0464	R	Peter Bengston Inc	215 Gates Road Unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 31

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/06/2025	08/21/2025	0464	R	Peter Bengston Inc	215 Gates Road Unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
06/02/2025	06/17/2025	0070	P	ADRBA Sales	211 Gates Road Unit M
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
07/08/2025	07/23/2025	0070	R	ADRBA Sales	211 Gates Road Unit M
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
07/22/2025	08/06/2025	0070	R	ADRBA Sales	211 Gates Road Unit M
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 08/06/2025
06/24/2025	07/09/2025	0093	P	Game Express	215 Gates Road Unit M
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
07/09/2025		0093	R	Game Express	215 Gates Road Unit M
06/02/2025	06/17/2025	0071	P	Chas	211 Gates Road Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
07/05/2025		0071	O	Chas	211 Gates Road Unit N
07/08/2025	07/23/2025	0071	R	Chas	211 Gates Road Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
07/22/2025	08/06/2025	0071	R	Chas	211 Gates Road Unit N
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/06/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 08/06/2025
			Violation:	Electrical - Extention cords	Abate by: 08/06/2025
06/24/2025	07/09/2025	0094	P	Northern Ac	215 GAtes Road Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	0094	R	Northern Ac	215 GAtes Road Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 32

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/04/2025	08/19/2025	0094	R	Northern Ac	215 Gates Road Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
06/02/2025	06/17/2025	0072	P	Chapter By kohli	211 Gates Road Unit O
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Storage on racks must be neat and stable	Abate by: 06/17/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 06/17/2025
			Violation:	Electrical - Extension cords	Abate by: 06/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/17/2025
07/07/2025	07/22/2025	0072	R	Chapter By kohli	211 Gates Road Unit O
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Storage on racks must be neat and stable	Abate by: 06/17/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 06/17/2025
			Violation:	Electrical - Extension cords	Abate by: 06/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/17/2025
06/24/2025	07/09/2025	0097	P	Graves Fire Equipment	215 Gates Road Unit O
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	0097	R	Graves Fire Equipment	215 Gates Road Unit O
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
08/04/2025	08/19/2025	0097	R	Graves Fire Equipment	215 Gates Road Unit O
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
06/29/2025		0073	O	Monarch Freight	211 Gates Road Unit P
05/31/2025		0962	O	Castillo Distributors	215 Gates Road Unit P
06/24/2025	07/09/2025	0962	P	Castillo Distributors	215 Gates Road Unit P
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	0962	R	Castillo Distributors	215 Gates Road Unit P
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
08/01/2025		0962	O	Castillo Distributors	215 Gates Road Unit P

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 33

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/04/2025	08/19/2025	0962	R	Castillo Distributors	215 Gates Road Unit P
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
08/19/2025	09/03/2025	0962	R	Castillo Distributors	215 Gates Road Unit P
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 09/03/2025
			Violation:	Electrical - Clearance	Abate by: 09/03/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 09/03/2025
			Violation:	Provide proof of Borough of Little Ferry Building Department Certificate of Occupancy	Abate by: 09/03/2025
06/02/2025	06/17/2025	0854	P	Beauty Barona LLC	211 Gates Road Unit Q
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Electrical - Clearance	Abate by: 06/17/2025
			Violation:	QUESTIONS PLEASE EMAIL ME	Abate by: 06/17/2025
06/24/2025	07/09/2025	0676	P	Temptation Fashion LLC	215 Gates Road unit Q
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 07/09/2025
			Violation:	Electrical - Extension cords	Abate by: 07/09/2025
			Violation:	Electrical - Clearance	Abate by: 07/09/2025
			Violation:	Clear isle width required	Abate by: 07/09/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
07/09/2025	07/24/2025	0676	R	Temptation Fashion LLC	215 Gates Road unit Q
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 07/09/2025
			Violation:	Electrical - Extension cords	Abate by: 07/09/2025
			Violation:	Electrical - Clearance	Abate by: 07/09/2025
			Violation:	Clear isle width required	Abate by: 07/09/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/24/2025
08/06/2025	08/21/2025	0676	R	Temptation Fashion LLC	215 Gates Road unit Q
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 07/09/2025
			Violation:	Electrical - Extension cords	Abate by: 07/09/2025
			Violation:	Electrical - Clearance	Abate by: 07/09/2025
			Violation:	Clear isle width required	Abate by: 07/09/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/24/2025
06/02/2025	06/17/2025	0075	P	Miss O Creation Inc	211 Gates Road Unit R
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and	Abate by: 06/17/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 34

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				exit sign	
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
07/07/2025		0075	R	Miss O Creation Inc	211 Gates Road Unit R
06/23/2025	07/08/2025	0645	P	JNY Corporation	215 Gates Road Unit R
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
06/28/2025		0645	O	JNY Corporation	215 Gates Road Unit R
07/08/2025	07/23/2025	0645	R	JNY Corporation	215 Gates Road Unit R
			Violation:	Electrical - Clearance	Abate by: 07/08/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
07/09/2025		0645	R	JNY Corporation	215 Gates Road Unit R
08/01/2025		0645	O	JNY Corporation	215 Gates Road Unit R
08/11/2025		0645	O	JNY Corporation	215 Gates Road Unit R
06/02/2025	06/17/2025	0554	P	Lush Perfumes LLC	211 Gates Road Unit S
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 06/17/2025
06/17/2025		0554	R	Lush Perfumes LLC	211 Gates Road Unit S
04/11/2025		1000	B	Train Wreck LLC	215 Gates Road Unit S
06/24/2025	07/09/2025	1000	P	Train Wreck LLC	215 Gates Road Unit S
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	1000	R	Train Wreck LLC	215 Gates Road Unit S
			Violation:	Clear isle width required	Abate by: 07/24/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 07/24/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/24/2025
08/01/2025	08/16/2025	1000	R	Train Wreck LLC	215 Gates Road Unit S
			Violation:	Clear isle width required	Abate by: 07/24/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 07/24/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/24/2025
08/01/2025		1000	O	Train Wreck LLC	215 Gates Road Unit S
06/02/2025	06/17/2025	0666	P	Global Integrated Supply	211 Gates Road Unit T
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/17/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 35

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Fire Extinguishers - Outdated or discharged	ViolaAbate by: 06/17/2025
07/05/2025		0666	O	Global Integrated Supply	211 Gates Road Unit T
07/07/2025	07/22/2025	0666	R	Global Integrated Supply	211 Gates Road Unit T
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 06/17/2025
06/24/2025	07/09/2025	1017	P	Innovative Lab Services	215 Gates Road Unit T
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/09/2025
06/24/2025		1017	O	Innovative Lab Services	215 Gates Road Unit T
07/09/2025	07/24/2025	1017	R	Innovative Lab Services	215 Gates Road Unit T
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/09/2025
				Violation: TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/24/2025
07/22/2025		1017	R	Innovative Lab Services	215 Gates Road Unit T
06/24/2025	07/09/2025	1018	P	Innovative Lab Services	215 Gates Road Unit U
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Electrical - Extension cords	Abate by: 07/09/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
06/24/2025		1018	O	Innovative Lab Services	215 Gates Road Unit U
07/09/2025	07/24/2025	1018	R	Innovative Lab Services	215 Gates Road Unit U
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Electrical - Extension cords	Abate by: 07/09/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
07/22/2025		1018	R	Innovative Lab Services	215 Gates Road Unit U
06/24/2025	07/09/2025	0105	P	CLT Led & Maintenance LLC	215 Gates Road Unit V
				Violation: Electrical - Extention cords	Abate by: 07/09/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Electrical - Clearance	Abate by: 07/09/2025
				Violation: Storage on racks must be neat and stable	Abate by: 07/09/2025
07/09/2025	07/24/2025	0105	R	CLT Led & Maintenance LLC	215 Gates Road Unit V
				Violation: Electrical - Extention cords	Abate by: 07/09/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Electrical - Clearance	Abate by: 07/09/2025
				Violation: Storage on racks must be neat and stable	Abate by: 07/09/2025
				Violation: TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/24/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 36

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/04/2025	08/19/2025	0105	R	CLT Led & Maintenance LLC	215 Gates Road Unit V
				Violation: Electrical - Extention cords	Abate by: 07/09/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/09/2025
				Violation: Electrical - Clearance	Abate by: 07/09/2025
				Violation: Storage on racks must be neat and stable	Abate by: 07/09/2025
				Violation: TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/24/2025
06/24/2025		0106	P	DMJ Fire Protection	215 Gates Road Unit W
05/03/2025		0652	B	Crown J Corp	215 Gates Road Unit X
06/24/2025	07/09/2025	0652	P	Crown J Corp	215 Gates Road Unit X
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	0652	R	Crown J Corp	215 Gates Road Unit X
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/28/2025	08/12/2025	0652	R	Crown J Corp	215 Gates Road Unit X
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/12/2025
08/07/2025		0652	R	Crown J Corp	215 Gates Road Unit X
06/24/2025	07/09/2025	0653	P	Cube Enterprises LLC	215 Gates Road Unit Y
				Violation: Clear isle width required	Abate by: 07/09/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/09/2025
07/04/2025		0653	T	Cube Enterprises LLC	215 Gates Road Unit Y
07/09/2025		0653	R	Cube Enterprises LLC	215 Gates Road Unit Y
07/30/2025		0653	O	Cube Enterprises LLC	215 Gates Road Unit Y
02/26/2025	03/13/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
				Violation: Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 07/17/2024
				Violation: Sprinkler system testing required per NFPA 25	Abate by: 07/17/2024
				Violation: Property must be free from rubbish/ overgrown vines and excessive refuse	Abate by: 07/17/2024
				Violation: Combustable/flammable material must not be stored in the means of egress	Abate by: 07/17/2024
				Violation: Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/17/2024
				Violation: Accumilation of excessive storage of combustable materials must be removed	Abate by: 07/17/2024
				Violation: Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
				Violation: Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
				Violation: Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/26/2025	03/13/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/18/2024
				Violation: Fire protection-Test on fire alarm	Abate by: 12/18/2024
				Violation: Fire Protection System - Records of all tests	Abate by: 12/18/2024
03/21/2025	04/05/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/18/2024
				Violation: Fire protection-Test on fire alarm	Abate by: 12/18/2024
				Violation: Fire Protection System - Records of all tests	Abate by: 12/18/2024
03/21/2025	04/05/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
				Violation: Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 07/17/2024
				Violation: Sprinkler system testing required per NFPA 25	Abate by: 07/17/2024
				Violation: Combustable/flammable material must not be stored in the means of egress	Abate by: 07/17/2024
				Violation: Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/17/2024
				Violation: Accumulation of excessive storage of combustable materials must be removed	Abate by: 07/17/2024
				Violation: Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
				Violation: Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
				Violation: Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024
04/24/2025		0136	T	100 Industrial Ave LLC Building	100 Industrial
04/24/2025	05/24/2025	0136	C	100 Industrial Ave LLC Building	100 Industrial
				Violation: Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
06/16/2025	07/01/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
				Violation: Combustable/flammable material must not be stored in the means of egress	Abate by: 07/17/2024
				Violation: Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/17/2024
				Violation: Accumulation of excessive storage of combustable materials must be removed	Abate by: 07/17/2024
				Violation: Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
				Violation: Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
				Violation: Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 38

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/16/2025	07/01/2025	0136	F	100 Industrial Ave LLC Building	100 Industrial
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
06/19/2025	07/04/2025	0136	R	100 Industrial Ave LLC Building	100 Industrial
			Violation:	Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/17/2024
			Violation:	Accumilation of excessive storage of combustable materials must be removed	Abate by: 07/17/2024
06/27/2025		0136	T	100 Industrial Ave LLC Building	100 Industrial
06/19/2025		0136	F	100 Industrial Ave LLC Building	100 Industrial
02/25/2025		0122K	R	Building Inspection	16 Industrial Ave
08/15/2025	08/30/2025	0124K	P	Scientific Design Co. Inc.	25 Industrial Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 08/30/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
02/24/2025		0126K	R	Scientific Design Co. Inc.	33 industrial ave
08/15/2025	08/30/2025	0126K	P	Scientific Design Co. Inc.	33 industrial ave
			Violation:	Gas detection system required in areas with flammable gases.	Abate by: 08/30/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/30/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/30/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/30/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/30/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/30/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
02/24/2025		0127K	F	Scientific Design Co. Inc.	39 Industrial Ave
08/15/2025	08/30/2025	0127K	P	Scientific Design Co. Inc.	39 Industrial Ave
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/30/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 39

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/24/2025		0129K	F	Scientific Design Co. Inc.	49 Industrial Ave
03/13/2025	03/28/2025	0129K	C	Scientific Design Co. Inc.	49 Industrial Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 03/28/2025
			Violation:	Fire watch required while fire sprinkler system is down for repairs/maintenance	Abate by: 03/28/2025
			Violation:	Fire watch members shall remain on duty for the duration of work/repairs.	Abate by: 03/28/2025
			Violation:	Fire watch members shall be capable of performing all duties of the fire watch position.	Abate by: 03/28/2025
			Violation:	Fire watch locations and times shall be recorded and provided at the end of the fire watch.	Abate by: 03/28/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/28/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/28/2025
03/18/2025		0129K	F	Scientific Design Co. Inc.	49 Industrial Ave
03/29/2025	03/31/2025	0129K	C	Scientific Design Co. Inc.	49 Industrial Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 03/31/2025
			Violation:	Fire watch required while fire sprinkler system is down for repairs/maintenance	Abate by: 03/31/2025
			Violation:	Fire watch members shall be capable of performing all duties of the fire watch position.	Abate by: 03/31/2025
			Violation:	Fire watch locations and times shall be recorded and provided at the end of the fire watch.	Abate by: 03/31/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/31/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/31/2025
04/01/2025		0129K	F	Scientific Design Co. Inc.	49 Industrial Ave
08/15/2025	08/30/2025	0129K	P	Scientific Design Co. Inc.	49 Industrial Ave
			Violation:	Electrical - Extension cords	Abate by: 08/30/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 08/30/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/30/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/30/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 08/30/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/30/2025
02/24/2025		0130	F	Scientific Design Co. Inc.	53 Industrial ave
08/15/2025	08/30/2025	0130	P	Scientific Design Co. Inc.	53 Industrial ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
02/24/2025		0095K	O	Scientific Design Co. Inc.	59 Industrial Ave

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 40

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/24/2025		0095K	F	Scientific Design Co. Inc.	59 Industrial Ave
08/15/2025	08/30/2025	0095K	P	Scientific Design Co. Inc.	59 Industrial Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Life Hazard Usage Fees Past Due	Abate by: 08/30/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 08/30/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 08/30/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/30/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/30/2025
03/27/2025	04/11/2025	0096K	F	Major Products	66 industrial Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
04/16/2025	05/01/2025	0096K	F	Major Products	66 industrial Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
05/21/2025		0096K	F	Major Products	66 industrial Ave
05/21/2025		0096K	T	Major Products	66 industrial Ave
06/03/2025	06/05/2025	0096K	C	Major Products	66 industrial Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 06/05/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/05/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/05/2025
			Violation:	Fire watch required while fire sprinkler system is down for repairs/maintenance	Abate by: 06/05/2025
			Violation:	Fire watch members shall remain on duty for the duration of work/repairs.	Abate by: 06/05/2025
			Violation:	Fire watch locations and times shall be recorded and provided at the end of the fire watch.	Abate by: 06/05/2025
06/05/2025		0096K	F	Major Products	66 industrial Ave
03/27/2025	04/11/2025	0131	F	Major Products	74 Industrial ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2024
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2024
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 41

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/16/2025	05/01/2025	0131	F	Major Products	74 Industrial ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2024
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2024
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2024
05/21/2025		0131	F	Major Products	74 Industrial ave
05/21/2025		0131	T	Major Products	74 Industrial ave
06/24/2025	07/09/2025	0698	P	JNT Technical Services Inc	85 Industrial Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/09/2025
07/09/2025	07/24/2025	0698	R	JNT Technical Services Inc	85 Industrial Ave
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/24/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/24/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/24/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 07/24/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/24/2025
07/29/2025		0698	R	JNT Technical Services Inc	85 Industrial Ave
03/11/2025		0140K	P	Vacant as of 03/11/2025	107 Industrial Ave
03/27/2025	04/11/2025	0125	F	Major Products	32-36 Industrial Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
04/16/2025	05/01/2025	0125	F	Major Products	32-36 Industrial Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 02/23/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 02/23/2025
05/21/2025		0125	F	Major Products	32-36 Industrial Ave
05/21/2025		0125	T	Major Products	32-36 Industrial Ave
05/31/2025	06/04/2025	0125	C	Major Products	32-36 Industrial Ave
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 06/04/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/04/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/04/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 42

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/05/2025		0125	F	Major Products	32-36 Industrial Ave
06/23/2025	07/08/2025	0138K	P	Building Iteslf	101 Industrial Ave (utility/sprinkler Suite E)
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/08/2025
			Violation:	General Conditions-No storage in equipment room	Abate by: 07/08/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
07/07/2025	07/22/2025	0138K	R	Building Iteslf	101 Industrial Ave (utility/sprinkler Suite E)
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
07/24/2025		0138K	R	Building Iteslf	101 Industrial Ave (utility/sprinkler Suite E)
02/26/2025	03/13/2025	0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/18/2024
			Violation:	Fire protection-Test on fire alarm	Abate by: 12/18/2024
			Violation:	Fire Protection System - Records of all tests	Abate by: 12/18/2024
02/26/2025	03/13/2025	0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 07/17/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024
03/21/2025	04/04/2025	0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 07/17/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024
03/21/2025	04/05/2025	0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Fire Protection System - Records of all tests	Abate by: 12/18/2024
03/26/2025		0159K	T	100 Industrial Ave LLC	120 Industrial Ave Building 1
04/24/2025		0159K	T	100 Industrial Ave LLC	120 Industrial Ave Building 1
04/24/2025	05/24/2025	0159K	C	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
			Violation:	After working on any fire protection system the	Abate by: 05/24/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 43

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				contractor must notify the police desk 2016412770	
06/16/2025		0159K	T	100 Industrial Ave LLC	120 Industrial Ave Building 1
06/16/2025		0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
06/16/2025	07/01/2025	0159K	F	100 Industrial Ave LLC	120 Industrial Ave Building 1
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
06/19/2025		0159K	R	100 Industrial Ave LLC	120 Industrial Ave Building 1
06/19/2025		0159K	F	100 Industrial Ave LLC	120 Industrial Ave Building 1
06/27/2025		0159K	T	100 Industrial Ave LLC	120 Industrial Ave Building 1
03/04/2025	03/19/2025	0678	R	Building Inspection	145 Industrial Ave Building 1
			Violation:	Sprinkler system testing required per NFPA 25	Abate by: 07/27/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/27/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/27/2024
03/06/2025		0678	O	Building Inspection	145 Industrial Ave Building 1
03/19/2025		0678	T	Building Inspection	145 Industrial Ave Building 1
03/19/2025		0678	R	Building Inspection	145 Industrial Ave Building 1
07/10/2025	07/25/2025	0678	P	Building Inspection	145 Industrial Ave Building 1
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 07/25/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
02/28/2025	03/15/2025	0142K	R	Riflessi/Barocco Textile Corp.	120 Industrial Ave Building 1 1st Floor Unit 1
			Violation:	Unstable storage stacks must be removed and made safe	Abate by: 07/17/2024 CV
			Violation:	Combustable/flammable material must not be stored in the means of egress	Abate by: 07/17/2024
			Violation:	Storage must remain 2' below unsprinklered cieling and 18" or more below sprinkler head deflector.	Abate by: 07/17/2024 CV

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 44

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/28/2025	03/15/2025	0825	R	Riflessi/Barocco Textile Corp.	120 Industrial Ave Building 1 1st Floor Unit 2
			Violation:	Aisles shall be 44" or greater in occupancy loads greater than 50 people.	Abate by: 07/17/2024
			Violation:	Combustable/flammable material must not be stored in the means of egress	Abate by: 07/17/2024
03/11/2025	03/26/2025	0677K	P	Site Service Now	120 Industrial Ave Building 1 1st Floor Unit 3
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/26/2025
03/20/2025	04/04/2025	0677K	R	Site Service Now	120 Industrial Ave Building 1 1st Floor Unit 3
			Violation:	Electrical - Clearance	Abate by: 04/04/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/04/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 04/04/2025
06/23/2025		0677K	R	Site Service Now	120 Industrial Ave Building 1 1st Floor Unit 3
03/11/2025	03/26/2025	0557K	P	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 4
			Violation:	Electrical - Open electrical junction boxes	Abate by: 03/26/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 03/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/26/2025
			Violation:	Electrical - Clearance	Abate by: 03/26/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 03/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/26/2025
			Violation:	Electrical - Improper electrical	Abate by: 03/26/2025
03/31/2025		0557K	T	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 4
04/08/2025		0557K	R	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 4
03/11/2025	03/26/2025	0826	P	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 5
			Violation:	Electrical - Extension cords	Abate by: 03/26/2025
			Violation:	Fire protection-Portable fire extinguisher must be hung	Abate by: 03/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/26/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/26/2025
03/31/2025		0826	T	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 5
04/08/2025		0826	R	Clover Bags & Paper LLC	120 Industrial Ave Building 1 1st Floor Unit 5
03/11/2025	03/26/2025	0559K	P	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
			Violation:	Electrical - Extension cords	Abate by: 03/26/2025
04/14/2025		0559K	O	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 45

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/25/2025	05/10/2025	0559K	R	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
			Violation:	Electrical - Extension cords	Abate by: 03/26/2025
05/12/2025	05/27/2025	0559K	R	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
			Violation:	Electrical - Extension cords	Abate by: 03/26/2025
05/12/2025		0559K	O	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
05/30/2025		0559K	O	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
06/19/2025		0559K	R	Blue Print	120 Industrial Ave Building 1 1st Floor Unit 6
07/01/2025	07/16/2025	0988	P	Christopher Glass & Aluminum Inc.	120 Industrial Ave Building 1 1st Floor Unit 7
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/16/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/16/2025
07/06/2025		0988	B	Christopher Glass & Aluminum Inc.	120 Industrial Ave Building 1 1st Floor Unit 7
08/01/2025	08/16/2025	0988	R	Christopher Glass & Aluminum Inc.	120 Industrial Ave Building 1 1st Floor Unit 7
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/16/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/16/2025
08/01/2025		0988	O	Christopher Glass & Aluminum Inc.	120 Industrial Ave Building 1 1st Floor Unit 7
07/28/2025		0564K	P	Kwang S. Lee	120 Industrial Ave Building 1 2nd Floor Unit 10
07/28/2025		0568K	P	Kwang S. Lee	120 Industrial Ave Building 1 2nd Floor Unit 11
02/28/2025	03/15/2025	0569K	R	SMS Trading	120 Industrial Ave Building 1 2nd Floor Unit 12
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
03/20/2025	04/04/2025	0569K	R	SMS Trading	120 Industrial Ave Building 1 2nd Floor Unit 12
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
03/27/2025	04/11/2025	0569K	R	SMS Trading	120 Industrial Ave Building 1 2nd Floor Unit 12
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/11/2025
			Violation:	Electrical - Extension cords	Abate by: 04/11/2025
04/08/2025		0569K	R	SMS Trading	120 Industrial Ave Building 1 2nd Floor Unit 12

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 46

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/28/2025	03/15/2025	0942	R	Road Link Services	120 Industrial Ave Building 1 2nd Floor Unit 3
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
04/25/2025	05/10/2025	0942	R	Road Link Services	120 Industrial Ave Building 1 2nd Floor Unit 3
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
06/19/2025	07/04/2025	0942	R	Road Link Services	120 Industrial Ave Building 1 2nd Floor Unit 3
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
08/01/2025	08/16/2025	0942	R	Road Link Services	120 Industrial Ave Building 1 2nd Floor Unit 3
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/17/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/17/2024
08/01/2025		0942	O	Road Link Services	120 Industrial Ave Building 1 2nd Floor Unit 3
03/17/2025		0562K	O	A&T Limo	120 Industrial Ave Building 1 2nd Floor Unit 5
07/28/2025		0563K	P	Kwang S. Lee	120 Industrial Ave Building 1 2nd Floor Unit 6
02/28/2025	03/15/2025	0565K	R	E&Y Inc.	120 Industrial Ave Building 1 2nd Floor Unit 7
			Violation:	Extension cords shall not substitute perminant wiring	Abate by: 07/17/2024
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 07/17/2024
03/11/2025		0565K	R	E&Y Inc.	120 Industrial Ave Building 1 2nd Floor Unit 7
02/28/2025		0680	R	Ellaspocket LLC	145 Industrial Ave Building 1 Unit A
07/19/2025	08/03/2025	0680	P	Ellaspocket LLC	145 Industrial Ave Building 1 Unit A
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
04/11/2025		1001	B	One Stop German Shop	145 Industrial Ave Building 1 Unit B
07/19/2025	08/03/2025	1001	P	One Stop German Shop	145 Industrial Ave Building 1 Unit B
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 47

-----Dates-----					
Insp.	Due	Local	Type	Property name	Property address
07/30/2025		1001	R	One Stop German Shop	145 Industrial Ave Building 1 Unit B
02/28/2025	03/15/2025	0966	R	PLS USA INC.	145 Industrial Ave Building 1 Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 02/20/2025
07/19/2025	08/03/2025	0966	R	PLS USA INC.	145 Industrial Ave Building 1 Unit C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 02/20/2025
02/28/2025	03/15/2025	0683	R	Rodeo Beauty LLC	145 Industrial Ave Building 1 Unit D
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
07/19/2025	08/03/2025	0683	R	Rodeo Beauty LLC	145 Industrial Ave Building 1 Unit D
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
08/04/2025	08/19/2025	0683	R	Rodeo Beauty LLC	145 Industrial Ave Building 1 Unit D
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
08/04/2025		0683	O	Rodeo Beauty LLC	145 Industrial Ave Building 1 Unit D
02/28/2025	03/15/2025	0684	R	TK Group LLC	145 Industrial Ave Building 1 Unit E
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
07/19/2025	08/03/2025	0684	R	TK Group LLC	145 Industrial Ave Building 1 Unit E
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
08/04/2025	08/19/2025	0684	P	TK Group LLC	145 Industrial Ave Building 1 Unit E
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
08/04/2025		0684	O	TK Group LLC	145 Industrial Ave Building 1 Unit E
02/28/2025	03/15/2025	0685	R	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 07/27/2024
			Violation:	Fire extinguishers must not be blocked or rendered in operable.	Abate by: 07/27/2024
03/05/2025		0685	R	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
07/19/2025	08/03/2025	0685	P	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 48

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/01/2025	08/16/2025	0685	R	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
				Violation: Electrical - Improper electrical	Abate by: 08/16/2025
				Violation: Electrical - Extention cords	Abate by: 08/16/2025
				Violation: Electrical - Extention cords	Abate by: 08/16/2025
08/07/2025		0685	B	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
08/15/2025		0685	R	Fuja USA Embroidery Corporation	145 Industrial Ave Building 1 Unit F
02/28/2025	03/15/2025	0686	R	CITYLAB USA Inc.	145 Industrial Ave Building 1 Unit G
				Violation: Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
03/19/2025		0686	R	CITYLAB USA Inc.	145 Industrial Ave Building 1 Unit G
02/28/2025	03/15/2025	0687	R	A Belle USA	145 Industrial Ave Building 1 Unit H
				Violation: Fire extinguishers must not be blocked or rendered in operable.	Abate by: 07/27/2024
07/19/2025	08/03/2025	0687	R	A Belle USA	145 Industrial Ave Building 1 Unit H
				Violation: Fire extinguishers must not be blocked or rendered in operable.	Abate by: 07/27/2024
07/29/2025		0687	R	A Belle USA	145 Industrial Ave Building 1 Unit H
02/26/2025	03/13/2025	0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
				Violation: Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 07/17/2024
				Violation: Fire zone required by fire official. Yellow 18" letters stating fire zone 4" wide box and	Abate by: 07/17/2024
				Violation: Fire zones shall not be obstructed at any time by anyone.	Abate by: 07/17/2024
				Violation: Truss roof signage required 12"w x 6" high R for roof f for floor S for sprinklered red on white	Abate by: 07/17/2024
				Violation: Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/17/2024
				Violation: Building service equipment doors (electrical,hvac,etc.) shall be labeled.	Abate by: 07/17/2024
				Violation: Deficienciess noted on test report must be repaired.	Abate by: 07/17/2024
				Violation: Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
				Violation: Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024
02/26/2025	03/13/2025	0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/18/2024
				Violation: Fire protection-Test on fire alarm	Abate by: 12/18/2024
				Violation: Fire Protection System - Records of all tests	Abate by: 12/18/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 49

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/21/2025	04/05/2025	0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
			Violation:	Truss roof signage required 12"w x 6" high R for roof f for floor S for sprinklered red on white	Abate by: 07/17/2024
			Violation:	Building service equipment doors (electrical,hvac,etc.) shall be labeled.	Abate by: 07/17/2024
			Violation:	Deficiencies noted on test report must be repaired.	Abate by: 07/17/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/17/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/17/2024
03/21/2025	04/05/2025	0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
			Violation:	Fire protection-Test on fire alarm	Abate by: 12/18/2024
03/26/2025		0141K	T	100 Industrial Ave LLC	120 industrial ave Building 2
04/02/2025		0141K	O	100 Industrial Ave LLC	120 industrial ave Building 2
04/24/2025		0141K	T	100 Industrial Ave LLC	120 industrial ave Building 2
04/24/2025	05/24/2025	0141K	C	100 Industrial Ave LLC	120 industrial ave Building 2
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/24/2025
06/16/2025		0141K	T	100 Industrial Ave LLC	120 industrial ave Building 2
06/16/2025		0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
06/16/2025	07/01/2025	0141K	F	100 Industrial Ave LLC	120 industrial ave Building 2
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 05/24/2025
06/19/2025		0141K	F	100 Industrial Ave LLC	120 industrial ave Building 2
06/19/2025		0141K	R	100 Industrial Ave LLC	120 industrial ave Building 2
06/27/2025		0141K	T	100 Industrial Ave LLC	120 industrial ave Building 2
03/04/2025	03/19/2025	0679	R	Building Inspection	145 Industrial Ave Building 2
			Violation:	Private fire service mains and fire hydrants shall be inspected per NFPA 25	Abate by: 07/27/2024
			Violation:	Private fire hydrants shall be flow tested annually and after each operation.	Abate by: 07/27/2024
			Violation:	Sprinkler system testing required per NFPA 25	Abate by: 07/27/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/27/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/27/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 50

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/06/2025		0679	O	Building Inspection	145 Industrial Ave Building 2
03/19/2025		0679	T	Building Inspection	145 Industrial Ave Building 2
03/19/2025	04/04/2025	0679	R	Building Inspection	145 Industrial Ave Building 2
			Violation:	Private fire service mains and fire hydrants shall be inspected per NFPA 25	Abate by: 07/27/2024
			Violation:	Private fire hydrants shall be flow tested annually and after each operation.	Abate by: 07/27/2024
03/25/2025		0679	R	Building Inspection	145 Industrial Ave Building 2
03/25/2025		0679	T	Building Inspection	145 Industrial Ave Building 2
07/03/2025	07/25/2025	0679	P	Building Inspection	145 Industrial Ave Building 2
			Violation:	Red light required over Fire Department Connection	Abate by: 07/25/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025
03/12/2025	03/27/2025	0945	P	CoverSafe Inc.	120 Industrial Ave Building 2 1st Floor Unit 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
04/25/2025	05/10/2025	0945	R	CoverSafe Inc.	120 Industrial Ave Building 2 1st Floor Unit 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
05/05/2025	05/20/2025	0945	R	CoverSafe Inc.	120 Industrial Ave Building 2 1st Floor Unit 1
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/20/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 05/20/2025
05/10/2025		0945	R	CoverSafe Inc.	120 Industrial Ave Building 2 1st Floor Unit 1
03/12/2025	03/27/2025	0574K	P	Jason Minami	120 Industrial Ave Building 2 1st Floor Unit 2
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
05/23/2025	06/07/2025	0574K	R	Jason Minami	120 Industrial Ave Building 2 1st Floor Unit 2
			Violation:	Electrical - Extension cords	Abate by: 06/07/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 06/07/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 06/07/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 06/07/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 51

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/23/2025		0574K	R	Jason Minami	120 Industrial Ave Building 2 1st Floor Unit 2
03/12/2025	03/27/2025	0530K	P	Cover safe Inc.	120 Industrial Ave Building 2 1st Floor Unit 4
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
04/25/2025	05/10/2025	0530K	R	Cover safe Inc.	120 Industrial Ave Building 2 1st Floor Unit 4
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
05/05/2025	05/20/2025	0530K	R	Cover safe Inc.	120 Industrial Ave Building 2 1st Floor Unit 4
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/20/2025
05/10/2025		0530K	R	Cover safe Inc.	120 Industrial Ave Building 2 1st Floor Unit 4
03/12/2025	03/27/2025	0573K	P	J & J Resources	120 Industrial Ave Building 2 1st Floor Unit 5
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 03/27/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 03/27/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/27/2025
			Violation:	30 INCH CLEAR WIDTH ISLES REQUIRE	Abate by: 03/27/2025 CV
04/10/2025		0573K	R	J & J Resources	120 Industrial Ave Building 2 1st Floor Unit 5
03/12/2025	03/27/2025	0571K	P	Spade Supply	120 Industrial Ave Building 2 1st Floor Unit 7
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
03/31/2025	04/15/2025	0571K	R	Spade Supply	120 Industrial Ave Building 2 1st Floor Unit 7
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/27/2025
04/08/2025	04/23/2025	0571K	R	Spade Supply	120 Industrial Ave Building 2 1st Floor Unit 7
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/23/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/23/2025
04/10/2025		0571K	R	Spade Supply	120 Industrial Ave Building 2 1st Floor Unit 7
03/12/2025	03/27/2025	0944	P	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 1st Floor Unit 9
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 03/27/2025
			Violation:	Fire Extinguishers - Within 30 ft of where the hot work is performed	Abate by: 03/27/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	Electrical - Extension cords	Abate by: 03/27/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 52

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/13/2025		0944	O	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 1st Floor Unit 9
04/25/2025	05/10/2025	0944	R	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 1st Floor Unit 9
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 03/27/2025
			Violation:	Fire Extinguishers - Within 30 ft of where the hot work is performed	Abate by: 03/27/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	Electrical - Extension cords	Abate by: 03/27/2025
07/08/2025	07/23/2025	0944	R	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 1st Floor Unit 9
			Violation:	Fire Extinguishers - Within 30 ft of where the hot work is performed	Abate by: 03/27/2025
03/12/2025		0946	P	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 2
04/14/2025		0946	O	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 2
04/25/2025		0946	O	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 2
03/12/2025		0839K	P	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 4
04/14/2025		0839K	O	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 4
04/25/2025		0839K	O	Marvins Truck Tuning and Diagnostics	120 Industrial Ave Building 2 2nd Floor Unit 4
02/28/2025	03/15/2025	0688	R	Biotrans LLC	145 Industrial Ave Building 2 Unit I
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
06/04/2025	06/19/2025	0688	R	Biotrans LLC	145 Industrial Ave Building 2 Unit I
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/27/2024
07/05/2025		0688	O	Biotrans LLC	145 Industrial Ave Building 2 Unit I
07/17/2025		0688	R	Biotrans LLC	145 Industrial Ave Building 2 Unit I
07/17/2025		0688	O	Biotrans LLC	145 Industrial Ave Building 2 Unit I
02/28/2025	03/15/2025	0689	R	Lumens America LLC	145 Industrial Ave Building 2 Unit J
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 07/27/2024
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 07/27/2024
03/05/2025		0689	R	Lumens America LLC	145 Industrial Ave Building 2 Unit J
07/19/2025	08/03/2025	0689	P	Lumens America LLC	145 Industrial Ave Building 2 Unit J
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 53

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/19/2025	08/03/2025	1024	P	FM DISPLAY CONCEPTS	145 Industrial Ave Building 2 Unit K
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/23/2025		1024	O	FM DISPLAY CONCEPTS	145 Industrial Ave Building 2 Unit K
07/30/2025	08/14/2025	1024	R	FM DISPLAY CONCEPTS	145 Industrial Ave Building 2 Unit K
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/14/2025
08/02/2025		1024	B	FM DISPLAY CONCEPTS	145 Industrial Ave Building 2 Unit K
08/08/2025		1024	R	FM DISPLAY CONCEPTS	145 Industrial Ave Building 2 Unit K
07/19/2025	08/03/2025	0691	P	Shalome Brothers	145 Industrial Ave Building 2 Unit L
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/30/2025	08/14/2025	0691	R	Shalome Brothers	145 Industrial Ave Building 2 Unit L
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/14/2025
08/08/2025		0691	R	Shalome Brothers	145 Industrial Ave Building 2 Unit L
02/28/2025	03/15/2025	0692	R	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Means of Egress - Egress obstructed	Abate by: 03/15/2025
			Violation:	Electrical - Clearance	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
04/14/2025		0692	O	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
07/04/2025		0692	T	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
07/19/2025	08/03/2025	0692	R	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Means of Egress - Egress obstructed	Abate by: 03/15/2025
			Violation:	Electrical - Clearance	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
			Violation:	Electrical - Extension cords	Abate by: 03/15/2025
07/29/2025		0692	R	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
07/30/2025		0692	O	NYBEE New York Inc.	145 Industrial Ave Building 2 Unit M
07/19/2025	08/03/2025	0714	P	Taisei Lamick USA	145 Industrial Ave Building 2 Unit N
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 54

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/28/2025		0714	R	Taisei Lamick USA	145 Industrial Ave Building 2 Unit N
07/19/2025	08/03/2025	0693	P	Taisei Lamick USA	145 Industrial Ave Building 2 Unit O
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/28/2025		0693	R	Taisei Lamick USA	145 Industrial Ave Building 2 Unit O
07/29/2025		0693	O	Taisei Lamick USA	145 Industrial Ave Building 2 Unit O
07/19/2025	08/03/2025	0967	R	Gentle Astro LLC	145 Industrial Ave Building 2 Unit P
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 02/20/2025
07/19/2025	08/03/2025	1025	P	Stitch Alliance Inc	145 Industrial Ave Building 2 Unit Q
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/25/2025		1025	B	Stitch Alliance Inc	145 Industrial Ave Building 2 Unit Q
07/28/2025		1025	R	Stitch Alliance Inc	145 Industrial Ave Building 2 Unit Q
02/28/2025	03/15/2025	0968	R	Joyful Path Inc	145 Industrial Ave Building 2 Unit R
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/15/2025
07/19/2025	08/03/2025	0968	R	Joyful Path Inc	145 Industrial Ave Building 2 Unit R
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/15/2025
03/04/2025	03/19/2025	0928	R	Building Inspection	145 Industrial Ave Building 3
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 06/28/2024
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 06/28/2024
03/06/2025		0928	O	Building Inspection	145 Industrial Ave Building 3
03/19/2025		0928	T	Building Inspection	145 Industrial Ave Building 3
03/19/2025		0928	R	Building Inspection	145 Industrial Ave Building 3
07/10/2025	07/25/2025	0928	P	Building Inspection	145 Industrial Ave Building 3
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/25/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/25/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/25/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/25/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 55

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/25/2025	05/10/2025	0578K	P	Tudelu	100 Industrial Ave Building 3 Suite A
			Violation:	Electrical - Labeling of electrical rooms	Abate by: 05/10/2025
			Violation:	Electrical - Clearance	Abate by: 05/10/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/10/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 05/10/2025
05/30/2025		0578K	O	Tudelu	100 Industrial Ave Building 3 Suite A
06/19/2025	07/04/2025	0578K	R	Tudelu	100 Industrial Ave Building 3 Suite A
			Violation:	Electrical - Clearance	Abate by: 05/10/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 05/10/2025
07/08/2025	07/23/2025	0578K	R	Tudelu	100 Industrial Ave Building 3 Suite A
			Violation:	Electrical - Clearance	Abate by: 05/10/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 05/10/2025
08/08/2025	08/23/2025	0578K	R	Tudelu	100 Industrial Ave Building 3 Suite A
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 05/10/2025
04/25/2025	05/10/2025	0579K	P	Tudelu	100 Industrial Ave Building 3 Suite C,D,E
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/10/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/10/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/10/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 05/10/2025
			Violation:	Electrical - Extension cords	Abate by: 05/10/2025
			Violation:	Electrical - Extension cords	Abate by: 05/10/2025
			Violation:	Electrical - Extension cords	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 04/26/2025
05/30/2025		0579K	O	Tudelu	100 Industrial Ave Building 3 Suite C,D,E
06/19/2025	07/04/2025	0579K	R	Tudelu	100 Industrial Ave Building 3 Suite C,D,E
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/10/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 05/10/2025
			Violation:	Electrical - Extension cords	Abate by: 05/10/2025
			Violation:	Electrical - Extension cords	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
07/08/2025	07/23/2025	0579K	R	Tudelu	100 Industrial Ave Building 3 Suite C,D,E
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 56

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/08/2025	08/23/2025	0579K	R	Tudelu	100 Industrial Ave Building 3 Suite C,D,E
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 05/10/2025
04/25/2025	05/10/2025	0580K	P	Chanour	100 Industrial Ave Building 3 Suite F
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/10/2025
06/19/2025	07/04/2025	0580K	R	Chanour	100 Industrial Ave Building 3 Suite F
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/10/2025
06/23/2025		0580K	R	Chanour	100 Industrial Ave Building 3 Suite F
07/19/2025	08/03/2025	0922	P	Hip Chic Inc.	145 Industrial Ave Building 3 Unit S
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
08/04/2025	08/19/2025	0922	R	Hip Chic Inc.	145 Industrial Ave Building 3 Unit S
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/19/2025
			Violation:	Electrical - Extension cords	Abate by: 08/19/2025
			Violation:	Electrical - Extension cords	Abate by: 08/19/2025
			Violation:	Electrical - Extension cords	Abate by: 08/19/2025
			Violation:	Electrical - Extension cords	Abate by: 08/19/2025
			Violation:	Electrical - Extension cords	Abate by: 08/19/2025
07/19/2025	08/03/2025	0923	P	Royce Global	145 Industrial Ave Building 3 Unit T
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/28/2025	08/12/2025	0923	R	Royce Global	145 Industrial Ave Building 3 Unit T
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/12/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/12/2025
08/14/2025		0923	R	Royce Global	145 Industrial Ave Building 3 Unit T
07/19/2025	08/03/2025	0924	P	CX8 ENTERPRISES	145 Industrial Ave Building 3 Unit U
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
08/14/2025	08/29/2025	0924	R	CX8 ENTERPRISES	145 Industrial Ave Building 3 Unit U
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/19/2025	08/03/2025	0925	P	C&Y International Inc.	145 Industrial Ave Building 3 Unit V
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 57

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/28/2025	08/12/2025	0925	R	C&Y International Inc.	145 Industrial Ave Building 3 Unit V
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 08/12/2025
				Violation: Electrical - Extention cords	Abate by: 08/12/2025
08/06/2025		0925	R	C&Y International Inc.	145 Industrial Ave Building 3 Unit V
07/19/2025	08/03/2025	0926	P	Xtramar Cargo	145 Industrial Ave Building 3 Unit W
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
08/20/2025	09/04/2025	0926	R	Xtramar Cargo	145 Industrial Ave Building 3 Unit W
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 09/04/2025
				Violation: Electrical - Clearance	Abate by: 09/04/2025
07/19/2025	08/03/2025	0927	P	Kasla	145 Industrial Ave Building 3 Unit X
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
06/23/2025	07/08/2025	0697K	P	Geo Distribution LLC	101 Industrial Ave Suite A
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/08/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/08/2025
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 07/08/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
				Violation: General Conditions - Storage of flammable and combustibile materials	Abate by: 07/08/2025
				Violation: Fire Extinguishers - General location	Abate by: 07/08/2025
				Violation: Electrical - Clearance	Abate by: 07/08/2025
				Violation: Electrical - Extention cords	Abate by: 07/08/2025
				Violation: Electrical - Extension cords	Abate by: 07/08/2025
				Violation: Electrical - Improper electrical	Abate by: 07/08/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/08/2025
				Violation: Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 07/08/2025
				Violation: Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 07/08/2025
				Violation: Electrical - Improper electrical	Abate by: 07/08/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 07/08/2025
				Violation: Fire Extinguishers must not be obstructed	Abate by: 07/08/2025
07/08/2025		0697K	R	Geo Distribution LLC	101 Industrial Ave Suite A
04/25/2025	05/10/2025	0137K	R	Ace Industrial Supply	100 Industrial Ave Suite B
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/10/2025
				Violation: Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 05/10/2025
				Violation: General Conditions - Storage of flammable and combustibile materials	Abate by: 05/10/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 58

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/30/2025	06/14/2025	0137K	R	Ace Industrial Supply	100 Industrial Ave Suite B
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/10/2025
			Violation:	Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 05/10/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 05/10/2025
05/30/2025		0137K	O	Ace Industrial Supply	100 Industrial Ave Suite B
06/16/2025		0137K	O	Ace Industrial Supply	100 Industrial Ave Suite B
06/16/2025	07/01/2025	0137K	R	Ace Industrial Supply	100 Industrial Ave Suite B
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/10/2025
			Violation:	Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 05/10/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 05/10/2025
06/23/2025	07/08/2025	0139K	P	Peacefull Adult Medical Daycare	101 Industrial Ave Suite B&C
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/08/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/08/2025
07/01/2025		0139K	R	Peacefull Adult Medical Daycare	101 Industrial Ave Suite B&C
06/23/2025	07/08/2025	0619K	P	United Rentals Climate Control	101 Industrial Ave Suite D
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/08/2025
			Violation:	Electrical - Extention cords	Abate by: 07/08/2025
			Violation:	QUESTIONS PLEASE EMAIL ME	Abate by: 07/08/2025
07/08/2025	07/23/2025	0619K	R	United Rentals Climate Control	101 Industrial Ave Suite D
			Violation:	Electrical - Extention cords	Abate by: 07/08/2025
07/28/2025	08/12/2025	0619K	R	United Rentals Climate Control	101 Industrial Ave Suite D
			Violation:	Electrical - Extention cords	Abate by: 07/08/2025
08/14/2025		0619K	R	United Rentals Climate Control	101 Industrial Ave Suite D
02/28/2025		0809	R	J&M Collision Auto Repair LLC	10 John Street
08/20/2025	09/04/2025	0190	P	Daniel Lynn Hair Salon	55 Lberty Street
			Violation:	Fire protection-Test on fire alarm	Abate by: 09/04/2025
07/22/2025	08/06/2025	0823	P	North Park Cleaners Little Ferry	272 liberty st Suite 4
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 59

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/24/2025		0823	B	North Park Cleaners Little Ferry	272 liberty st Suite 4
08/07/2025	08/22/2025	0823	R	North Park Cleaners Little Ferry	272 liberty st Suite 4
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025
08/18/2025		0179	P	Stallion Auto Service	9 Liberty Street
05/05/2025	05/20/2025	0182K	P	Building Inspection	31 Liberty Street
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/20/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/20/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Business address (including unit number) must be clearly labeled on building.	Abate by: 05/20/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/20/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/20/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/20/2025
06/05/2025		0182K	R	Building Inspection	31 Liberty Street
06/08/2025		0182K	T	Building Inspection	31 Liberty Street
04/03/2025		0189	O	A&D Towing	46 Liberty Street
02/26/2025	03/13/2025	0193	R	American Legion Post #310	100 Liberty Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/05/2024
03/05/2025	03/20/2025	0193	P	American Legion Post #310	100 Liberty Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/05/2024
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/20/2025
			Violation:	Fire Extinguishers - General location	Abate by: 03/20/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 03/20/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/20/2025
03/18/2025		0193	T	American Legion Post #310	100 Liberty Street
03/26/2025	04/10/2025	0193	R	American Legion Post #310	100 Liberty Street
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/20/2025
			Violation:	Fire Extinguishers - General location	Abate by: 03/20/2025
			Violation:	General Conditions - Accumulation of combustible materials	Abate by: 03/20/2025
04/28/2025		0193	R	American Legion Post #310	100 Liberty Street

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 60

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/06/2025		Temp25-04P		Dobco	123 Liberty Street
05/08/2025		Temp25-040		Dobco	123 Liberty Street
03/10/2025	03/25/2025	0195K	P	Memorial School	130 Liberty Street
		Violation:		Fire protection-Test on fire alarm	Abate by: 03/25/2025
		Violation:		Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
		Violation:		Fire Extinguishers must not be obstructed	Abate by: 03/25/2025
		Violation:		Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
		Violation:		Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
		Violation:		Electrical - Extension cords	Abate by: 03/25/2025
04/17/2025		0195K	R	Memorial School	130 Liberty Street
08/04/2025		0195K	T	Memorial School	130 Liberty Street
07/19/2025	08/03/2025	0514	P	Point Break Acupuncture	159 Liberty Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
08/16/2025	08/31/2025	0514	R	Point Break Acupuncture	159 Liberty Street
		Violation:		Means of egress-Test on emergency lighting and exit sign	Abate by: 08/31/2025
		Violation:		Fire Extinguishers - Outdated or discharged	Abate by: 08/31/2025
07/19/2025	08/03/2025	1022	P	Building Inspection	159 Liberty Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/03/2025
07/19/2025		1022	O	Building Inspection	159 Liberty Street
08/16/2025	08/31/2025	1022	R	Building Inspection	159 Liberty Street
		Violation:		Fire protection-Test on fire alarm	Abate by: 08/31/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/31/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/31/2025
08/20/2025	09/04/2025	0202	P	Building Inspection	169 Liberty Street
		Violation:		Business address (including unit number) must be clearly labeled on building.	Abate by: 09/04/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 09/04/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 09/04/2025
		Violation:		Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 09/04/2025
04/29/2025	05/14/2025	0547K	P	CVS	200 Liberty Street
		Violation:		Fire protection-Test on fire alarm	Abate by: 05/14/2025
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 05/14/2025
		Violation:		Private Fire Hydrants Require Testing	Abate by: 05/14/2025
		Violation:		Fire protection-Carbon monoxide alarm or detectors	Abate by: 05/14/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 61

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				must be maintained	
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 05/14/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 05/14/2025
			Violation:	Electrical - Clearance	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
05/08/2025		0547K	T	CVS	200 Liberty Street
05/08/2025	05/23/2025	0547K	R	CVS	200 Liberty Street
			Violation:	Private Fire Hydrants Require Testing	Abate by: 05/14/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 05/14/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 05/14/2025
			Violation:	Electrical - Clearance	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
06/05/2025	05/20/2025	0547K	R	CVS	200 Liberty Street
			Violation:	Private Fire Hydrants Require Testing	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
07/07/2025	07/22/2025	0547K	R	CVS	200 Liberty Street
			Violation:	Private Fire Hydrants Require Testing	Abate by: 05/14/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/14/2025
04/08/2025		0214K	T	Wells Fargo Bank	255 Liberty Street
02/27/2025	03/27/2025	0218K	R	Gilbert Manor Apartments	269 Liberty Street
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 62

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/27/2025		0218K	R	Gilbert Manor Appartments	269 Liberty Street
07/22/2025	08/06/2025	0294K	P	Building Inspection	272 Liberty Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/06/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/06/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 08/06/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/06/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/06/2025
			Violation:	Red light required over Fire Department Connection	Abate by: 08/06/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/06/2025
			Violation:	Business address (including unit number) must be clearly labeled on building.	Abate by: 08/06/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
07/24/2025		0294K	O	Building Inspection	272 Liberty Street
08/07/2025	08/22/2025	0294K	R	Building Inspection	272 Liberty Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/06/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/06/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 08/06/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/06/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/06/2025
			Violation:	Red light required over Fire Department Connection	Abate by: 08/06/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/06/2025
			Violation:	Business address (including unit number) must be clearly labeled on building.	Abate by: 08/06/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
07/22/2025	08/06/2025	0295K	P	Mr. Bruno's Pizza	272 Liberty Street
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025
			Violation:	General Conditions - General Conditions	Abate by: 08/06/2025
				Contributing to fire	
			Violation:	Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 08/06/2025
			Violation:	Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 08/06/2025
08/07/2025	08/22/2025	0295K	R	Mr. Bruno's Pizza	272 Liberty Street
			Violation:	General Conditions - General Conditions	Abate by: 08/06/2025
				Contributing to fire	
			Violation:	Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 08/06/2025
			Violation:	Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 08/06/2025
07/22/2025	08/06/2025	0296K	P	Dairy Queen	272 Liberty Street
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/06/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/06/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 63

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/07/2025		0296K	R	Dairy Queen	272 Liberty Street
07/22/2025	08/06/2025	0297K	P	7-11	272 Liberty Street
		Violation:		Fire Service Features - Knox box required	Abate by: 08/06/2025
		Violation:		Fire & Smoke protection - Maintain fire rated construction	Abate by: 08/06/2025
08/07/2025		0297K	R	7-11	272 Liberty Street
02/27/2025	03/27/2025	0222K	R	Gilbert Manor Appartments	279 Liberty Street
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
03/27/2025		0222K	R	Gilbert Manor Appartments	279 Liberty Street
07/18/2025	08/02/2025	1021	P	RCM Ceberio LLC	281 Liberty Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
		Violation:		Provide proof of Borough of Little Ferry Building Department Certificate of Occupancy	Abate by: 08/02/2025
08/04/2025	08/19/2025	1021	R	RCM Ceberio LLC	281 Liberty Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
		Violation:		Provide proof of Borough of Little Ferry Building Department Certificate of Occupancy	Abate by: 08/02/2025
02/27/2025	03/27/2025	0215K	R	Gilbert Manor Appartments	291 Liberty Street
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
03/27/2025		0215K	R	Gilbert Manor Appartments	291 Liberty Street
02/27/2025	03/27/2025	0219K	R	Gilbert Manor Appartments	293 Liberty Street
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
		Violation:		General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
		Violation:		Electrical - Improper electrical	Abate by: 03/27/2025
03/27/2025	04/11/2025	0219K	R	Gilbert Manor Appartments	293 Liberty Street
		Violation:		Electrical - Improper electrical	Abate by: 03/27/2025
05/21/2025		0219K	R	Gilbert Manor Appartments	293 Liberty Street

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 64

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/27/2025	03/27/2025	0220K	R	Gilbert Manor Appartments	295 Liberty Street
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	Electrical - Extension cords	Abate by: 03/27/2025
03/27/2025		0220K	R	Gilbert Manor Appartments	295 Liberty Street
02/27/2025	03/27/2025	0221K	R	Gilbert Manor Appartments	297 Liberty Street
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/27/2025
03/27/2025		0221K	R	Gilbert Manor Appartments	297 Liberty Street
03/10/2025	05/21/2025	0223K	R	Evergreen Condos	333 Liberty Street
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 05/21/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/21/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 05/21/2025
03/20/2025		0223K	R	Evergreen Condos	333 Liberty Street
02/27/2025	03/14/2025	0224K	R	375 Liberty Street LLC (Strip Mall)	375 Liberty Street
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 09/01/2023
			Violation:	Sprinkler system testing required per NFPA 25	Abate by: 09/01/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 09/01/2023
			Violation:	Egress doors shall be readily openable from egress side without key or special knowledge.	Abate by: 09/01/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 09/01/2023
			Violation:	Building Addresses shall be identified 4" x 1/2" numbers.	Abate by: 09/01/2023
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 09/01/2023
			Violation:	Maintain fire rated cieling (repair all holes)	Abate by: 09/01/2023
04/17/2025	05/02/2025	0224K	R	375 Liberty Street LLC (Strip Mall)	375 Liberty Street
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 09/01/2023
			Violation:	Sprinkler system testing required per NFPA 25	Abate by: 09/01/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 09/01/2023
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordancne with NFPA72	Abate by: 09/01/2023

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 65

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/11/2025	07/26/2025	0224K	P	375 Liberty Street LLC (Strip Mall)	375 Liberty Street
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 07/26/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/26/2025
			Violation:	Magnetic door locks must release from fire alarm signal	Abate by: 07/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
			Violation:	General Conditions - Storage of flammable and combustible materials	Abate by: 07/26/2025
			Violation:	Electrical - Clearance	Abate by: 07/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
04/01/2025		0233	P	Frank Migliorino	384 Liberty Street
06/13/2025	06/28/2025	0603	P	G&S Auto Repair Inc	386 Liberty Street
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/28/2025
			Violation:	Means of Egress - Egress obstructed	Abate by: 06/28/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/28/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 06/28/2025
07/01/2025	07/16/2025	0603	R	G&S Auto Repair Inc	386 Liberty Street
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/28/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 06/28/2025
07/28/2025		0603	R	G&S Auto Repair Inc	386 Liberty Street
03/04/2025	03/19/2025	0235K	R	Palermos Bakery	389 Liberty Street
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/10/2025
03/14/2025		0235K	O	Palermos Bakery	389 Liberty Street
03/18/2025		0235K	T	Palermos Bakery	389 Liberty Street
03/18/2025		0235K	R	Palermos Bakery	389 Liberty Street
04/15/2025		0235K	T	Palermos Bakery	389 Liberty Street
03/04/2025	03/19/2025	0236K	R	Building Inspection (Palermos)	399 Liberty Street
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/10/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 66

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/04/2025	04/14/2025	0236K	C	Building Inspection (Palermos)	399 Liberty Street
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 03/19/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/19/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/19/2025
03/14/2025		0236K	O	Building Inspection (Palermos)	399 Liberty Street
03/18/2025		0236K	R	Building Inspection (Palermos)	399 Liberty Street
04/15/2025		0236K	T	Building Inspection (Palermos)	399 Liberty Street
04/15/2025	04/30/2025	0236K	F	Building Inspection (Palermos)	399 Liberty Street
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 03/19/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/19/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/19/2025
05/20/2025		0236K	T	Building Inspection (Palermos)	399 Liberty Street
05/22/2025		0236K	F	Building Inspection (Palermos)	399 Liberty Street
03/04/2025	03/19/2025	0237K	R	Palermos Cake Lounge	399 Liberty Street
03/04/2025	04/14/2025	0237K	C	Palermos Cake Lounge	399 Liberty Street
03/14/2025		0237K	O	Palermos Cake Lounge	399 Liberty Street
03/18/2025		0237K	T	Palermos Cake Lounge	399 Liberty Street
04/15/2025		0237K	T	Palermos Cake Lounge	399 Liberty Street
04/16/2025		0237K	F	Palermos Cake Lounge	399 Liberty Street
05/22/2025		0237K	F	Palermos Cake Lounge	399 Liberty Street
03/08/2025		0529K	T	Memorial School Annex (Trailers)	130 Liberty Street (Rear)
03/10/2025	03/25/2025	0529K	P	Memorial School Annex (Trailers)	130 Liberty Street (Rear)
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 03/25/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 03/25/2025
03/19/2025		0529K	R	Memorial School Annex (Trailers)	130 Liberty Street (Rear)
05/05/2025	05/20/2025	0864	P	New Laundry Fresh	31 Liberty Street Unit 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 67

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/02/2025	06/17/2025	0864	R	New Laundry Fresh	31 Liberty Street Unit 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025
06/07/2025		0864	O	New Laundry Fresh	31 Liberty Street Unit 1
07/03/2025		0864	O	New Laundry Fresh	31 Liberty Street Unit 1
03/20/2025		0984	O	Willy Munch Gourment	31 Liberty Street Unit 2
03/20/2025		0984	B	Willy Munch Gourment	31 Liberty Street Unit 2
05/05/2025	05/20/2025	0984	P	Willy Munch Gourment	31 Liberty Street Unit 2
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 05/20/2025
			Violation:	Electrical - Improper electrical	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/20/2025
			Violation:	Electrical - Extension cords	Abate by: 05/20/2025
06/02/2025	06/17/2025	0984	R	Willy Munch Gourment	31 Liberty Street Unit 2
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	Cooking Areas - Class "K" extinguisher	Abate by: 05/20/2025
			Violation:	Electrical - Improper electrical	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/20/2025
			Violation:	Electrical - Extension cords	Abate by: 05/20/2025
06/07/2025		0984	O	Willy Munch Gourment	31 Liberty Street Unit 2
06/16/2025		0984	O	Willy Munch Gourment	31 Liberty Street Unit 2
07/10/2025		0984	O	Willy Munch Gourment	31 Liberty Street Unit 2
03/04/2025		0877	O	Ron's Buy Sell Trade	375 Liberty Street Unit 2
05/12/2025	05/27/2025	0877	R	Ron's Buy Sell Trade	375 Liberty Street Unit 2
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 01/28/2025
			Violation:	Means of Egress - Readily operable	Abate by: 01/28/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 01/28/2025
			Violation:	Electrical - Improper electrical	Abate by: 01/28/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 68

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/08/2025	07/23/2025	0877	R	Ron's Buy Sell Trade	375 Liberty Street Unit 2
				Violation: Knox Box Required. Please email FIREPREVENTION@LITTLEFERRY.NJ.ORG after box is paid	Abate by: 01/28/2025
				Violation: Means of Egress - Readily operable	Abate by: 01/28/2025
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 01/28/2025
				Violation: Electrical - Improper electrical	Abate by: 01/28/2025
05/12/2025	05/27/2025	0229K	R	Vacant as of 06/02/2025	375 Liberty Street Unit 4
				Violation: Egress doors shall be readily openable from egress side without key or special knowledge.	Abate by: 10/19/2024
				Violation: Knox Box Required. Please email FIREPREVENTION@LITTLEFERRY.NJ.ORG after box is paid	Abate by: 10/19/2024
06/02/2025		0229K	R	Vacant as of 06/02/2025	375 Liberty Street Unit 4
02/28/2025		0230K	O	Vacant as of 06/02/2025	375 Liberty Street Unit 6
03/04/2025		0230K	O	Vacant as of 06/02/2025	375 Liberty Street Unit 6
05/12/2025	05/27/2025	0230K	R	Vacant as of 06/02/2025	375 Liberty Street Unit 6
				Violation: Building Department Certificate of Occupancy Required	Abate by: 05/15/2024
				Violation: Storage must remain 2' below unsprinklered ceiling and 18" or more below sprinkler head deflector.	Abate by: 05/15/2024
				Violation: Means of egress shall not be obstructed	Abate by: 05/15/2024
				Violation: Portable fire extinguishers required.	Abate by: 05/15/2024
				Violation: Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/15/2024
06/02/2025		0230K	R	Vacant as of 06/02/2025	375 Liberty Street Unit 6
02/28/2025	03/15/2025	0231K	R	Yuki Hana	375 Liberty Street Unit 7
				Violation: Electrical - Extension cords	Abate by: 02/26/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 02/26/2025
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 02/26/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 02/26/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 02/26/2025
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 02/26/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 02/26/2025
				Violation: Fire protection-Portable fire extinguisher must be hung	Abate by: 02/26/2025
				Violation: Electrical - Improper electrical	Abate by: 02/26/2025
03/17/2025		0231K	O	Yuki Hana	375 Liberty Street Unit 7
04/01/2025		0231K	R	Yuki Hana	375 Liberty Street Unit 7

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 69

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/04/2025		0203	T	Ben's Bagel Barn	169 Liberty Street Unit A
08/20/2025	09/04/2025	0203	P	Ben's Bagel Barn	169 Liberty Street Unit A
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 09/04/2025
02/27/2025	03/14/2025	0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 02/27/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 05/10/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 05/10/2023
03/22/2025	04/06/2025	0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 02/27/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 05/10/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 05/10/2023
03/21/2025	04/06/2025	0781K	F	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 10/07/2024
			Violation:	CONTACT FIRE PREVENTION WITHIN 48 HOURS OF THIS LETTER TO SCHEDULE A FIRE INSPECTION	Abate by: 10/07/2024
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 10/19/2024
			Violation:	Building Addresses shall be identified 4" x 1/2" numbers.	Abate by: 10/19/2024
			Violation:	All windows, glass doors/doors with glass openings must remain at all times eighty (80%)unobstructed	Abate by: 10/19/2024
04/16/2025		0781K	O	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
04/28/2025	05/13/2025	0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 02/27/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Extension cords shall not substitute permanent wiring	Abate by: 05/10/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 05/10/2023

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 70

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/08/2025	06/23/2025	0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 02/27/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Extension cords shall not substitute perminent wiring	Abate by: 05/10/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 05/10/2023
06/08/2025		0781K	O	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
06/08/2025		0781K	O	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
07/03/2025		0781K	O	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
07/03/2025	07/18/2025	0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 02/27/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Exit signs shall be maintained visible and illuminated at all times.	Abate by: 05/10/2023
			Violation:	Extension cords shall not substitute perminent wiring	Abate by: 05/10/2023
			Violation:	Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 05/10/2023
07/17/2025		0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
07/17/2025		0781K	F	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
07/17/2025	08/01/2025	0781K	P	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/01/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 08/01/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 08/01/2025
07/23/2025		0781K	R	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
07/23/2025		0781K	O	St. Anthony's South Bergen Mens Club	375 Liberty Street Unit#5
08/20/2025	09/04/2025	0204	P	Nail Time	169 Liberty Unit B
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 09/04/2025
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 09/04/2025
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 09/04/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 09/04/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 71

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/18/2025		0243K	O	H&K Transportation	33 Ludwig Street
03/06/2025		0248	T	Appartment Buildings	26 Main Street
04/11/2025	04/26/2025	0248	R	Appartment Buildings	26 Main Street
			Violation:	Carbon monoxide alarms shall be maintained in accordance with NFPA 720	Abate by: 04/26/2025
			Violation:	Approved self closing/ hold open devices on smoke & fire doors shall be maintained.	Abate by: 04/26/2025
			Violation:	Combustable/flammable material must not be stored in the means of egress	Abate by: 04/26/2025
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 04/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/26/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/26/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 04/26/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/26/2025
			Violation:	General Conditions - Accumulation of combustibile materials	Abate by: 04/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/26/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/26/2025
05/12/2025		0248	O	Appartment Buildings	26 Main Street
06/11/2025	06/26/2025	0248	R	Appartment Buildings	26 Main Street
			Violation:	Carbon monoxide alarms shall be maintained in accordance with NFPA 720	Abate by: 04/26/2025
			Violation:	Approved self closing/ hold open devices on smoke & fire doors shall be maintained.	Abate by: 04/26/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/26/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 04/26/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/26/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/26/2025
07/25/2025		0248	T	Appartment Buildings	26 Main Street
08/15/2025	08/30/2025	0249K	P	Building Inspection	38 Main Street
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/30/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/30/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 08/30/2025
			Violation:	Provide proof of Borough of Little Ferry Building Department Certificate of Occupancy	Abate by: 08/30/2025
			Violation:	Business address (including unit number) must be clearly labeled on building.	Abate by: 08/30/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/30/2025
			Violation:	General Conditions - Accumulation of combustibile materials	Abate by: 08/30/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 72

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/11/2025		0254K	R	Mayer's Auto Body	111 Main Street
07/18/2025	08/02/2025	0256	P	Apartment Building	121 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
			Violation:	Gas powered appliances are not allowed on balconies	Abate by: 08/02/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/02/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/02/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 08/02/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/02/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/02/2025
07/21/2025		0256	O	Apartment Building	121 Main Street
08/08/2025	08/23/2025	0256	R	Apartment Building	121 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
			Violation:	Gas powered appliances are not allowed on balconies	Abate by: 08/02/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/02/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/02/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 08/02/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/02/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/02/2025
08/14/2025	08/29/2025	0256	R	Apartment Building	121 Main Street
			Violation:	Gas powered appliances are not allowed on balconies	Abate by: 08/02/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 08/02/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/02/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 08/02/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 08/02/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/02/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 08/29/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 73

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/18/2025	08/02/2025	0257	P	Lash On Main	121 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
08/08/2025	08/23/2025	0257	R	Lash On Main	121 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/02/2025
08/18/2025	09/02/2025	0257	R	Lash On Main	121 Main Street
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 09/02/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 09/02/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 09/02/2025
03/31/2025	04/15/2025	0475K	P	Building Inspection	139 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
05/11/2025		0475K	O	Building Inspection	139 Main Street
05/11/2025	05/26/2025	0475K	R	Building Inspection	139 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
07/07/2025	07/22/2025	0475K	R	Building Inspection	139 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
07/17/2025	08/01/2025	0475K	R	Building Inspection	139 Main Street
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 08/01/2025
			Violation:	Carbon Monoxide alarms in apartments maintenance/ proof of operation.	Abate by: 08/01/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/01/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/01/2025
			Violation:	Electrical - Extension cords	Abate by: 08/01/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 08/01/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 08/01/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/01/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 08/01/2025
08/04/2025		0475K	T	Building Inspection	139 Main Street
07/17/2025		0704K	P	VACANT AS OF 07/17/2025	139 Main Street
04/16/2025	05/01/2025	0604K	P	Zonk's Pop Culture World	171 Main Street
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/01/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/01/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 74

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/21/2025		0604K	R	Zonk's Pop Culture World	171 Main Street
03/11/2025	03/26/2025	0667K	C	Ghost Mart Inc.	187 Main Street
				Violation: Fire protection-Test on fire alarm	Abate by: 03/26/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 03/26/2025
				Violation: Fire Extinguishers - Proper mounting	Abate by: 03/26/2025
				Violation: Fire Extinguishers - General location	Abate by: 03/26/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 03/26/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/26/2025
				Violation: Exhaust hood required for equipment that produces grease laden vapors.	Abate by: 03/26/2025
				Violation: Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 03/26/2025
				Violation: Excessive grease building up must be removed from all surfaces.	Abate by: 03/26/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 03/26/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 03/26/2025
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/26/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/26/2025
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
				Violation: Cooking Areas - Wet chemical - 6 mo. Inspection	Abate by: 03/26/2025
				Violation: Means of Egress - Doors	Abate by: 03/26/2025
				Violation: Means of Egress - Doors	Abate by: 03/26/2025
				Violation: Fire Extinguishers - General location	Abate by: 03/26/2025
				Violation: Electrical - Extension cords	Abate by: 03/26/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 03/26/2025
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
				Violation: Electrical - Improper electrical	Abate by: 03/26/2025
				Violation: Electrical - Improper electrical	Abate by: 03/26/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 03/26/2025
04/01/2025		0667K	R	Ghost Mart Inc.	187 Main Street
04/01/2025	04/16/2025	0667K	F	Ghost Mart Inc.	187 Main Street
				Violation: Fire protection-Test on fire alarm	Abate by: 03/26/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 03/26/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 03/26/2025
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
				Violation: Fire Extinguishers - General location	Abate by: 03/26/2025
				Violation: General Conditions - General Conditions	Abate by: 03/26/2025
				Contributing to fire	
04/02/2025		0667K	T	Ghost Mart Inc.	187 Main Street
04/02/2025		0667K	T	Ghost Mart Inc.	187 Main Street

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 75

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/08/2025		0667K	T	Ghost Mart Inc.	187 Main Street
04/17/2025		0667K	F	Ghost Mart Inc.	187 Main Street
04/28/2025		0281K	T	Victorias	201 Main Street
08/20/2025	09/04/2025	0606	P	Deon Design	204 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 09/04/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 09/04/2025
03/31/2025	04/15/2025	0701	P	Bergen County Realty	228 Main Street
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/15/2025
			Violation:	Fire Protection-Test on hard wire smoke alarm	Abate by: 04/15/2025
			Violation:	General Conditions - General Conditions	Abate by: 04/15/2025
				Contributing to fire	
			Violation:	Electrical - Improper electrical	Abate by: 04/15/2025
04/17/2025		0701	R	Bergen County Realty	228 Main Street
03/31/2025	04/15/2025	0778	P	Building Inspection	228 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
04/11/2025	04/26/2025	0778	R	Building Inspection	228 Main Street
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/26/2025
			Violation:	Fire protection-Test on battery smoke alarm	Abate by: 04/26/2025
			Violation:	General Conditions - General Conditions	Abate by: 04/26/2025
				Contributing to fire	
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/26/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/26/2025
04/12/2025		0778	T	Building Inspection	228 Main Street
04/23/2025		0778	T	Building Inspection	228 Main Street
04/23/2025		0778	R	Building Inspection	228 Main Street
03/31/2025	04/15/2025	0290	P	All that Glitters	230 Main Street
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
04/09/2025		0290	R	All that Glitters	230 Main Street
02/27/2025	03/27/2025	0299K	R	Gilbert Manor Apartments	258 Main Street
			Violation:	General Conditions - General Conditions	Abate by: 03/27/2025
				Contributing to fire	
			Violation:	General Conditions - General Conditions	Abate by: 03/27/2025
				Contributing to fire	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 76

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/27/2025		0299K	R	Gilbert Manor Apartments	258 Main Street
07/02/2025		0300	P	VACANT (AS OF 07/02/2025)	274 Main Street
02/26/2025	03/13/2025	0302K	R	Verizon	282 Main Street
		Violation:		Fire protection-Test on fire alarm	Abate by: 12/26/2024
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 12/26/2024
03/08/2025		0302K	K	Verizon	282 Main Street
03/10/2025		0302K	R	Verizon	282 Main Street
03/26/2025		0302K	T	Verizon	282 Main Street
03/26/2025		0302K	T	Verizon	282 Main Street
07/02/2025	07/17/2025	0303K	P	Building Inspection	315 Main Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 07/17/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
07/25/2025		0303K	O	Building Inspection	315 Main Street
08/07/2025	08/22/2025	0303K	R	Building Inspection	315 Main Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 07/17/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
08/18/2025	09/02/2025	0303K	R	Building Inspection	315 Main Street
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 09/02/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 09/02/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 09/02/2025
07/02/2025	07/17/2025	0617K	P	Apartment Building	325 Main Street
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025
		Violation:		Fire protection-Test on fire alarm	Abate by: 07/17/2025
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 07/17/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		Fire Service Features - Knox box required	Abate by: 07/17/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 77

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/11/2025	07/26/2025	0617K	R	Apartment Building	325 Main Street
				Violation: Fire protection-Test on fire alarm	Abate by: 07/26/2025
				Violation: Sprinkler system testing and maintenance required.	Abate by: 07/26/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/26/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/26/2025
				Violation: Fire Service Features - Knox box required	Abate by: 07/26/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 07/26/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 07/26/2025
07/13/2025		0617K	O	Apartment Building	325 Main Street
04/30/2025	05/15/2025	0310	P	World Video	401 Main Street
				Violation: Fire Protection-Test on hard wire smoke alarm	Abate by: 05/15/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 05/15/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 05/15/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 05/15/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 05/15/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 05/15/2025
06/02/2025		0310	R	World Video	401 Main Street
06/08/2025		0310	T	World Video	401 Main Street
08/20/2025	09/04/2025	1028	P	Sign Avenue	2-10 Main Street
				Violation: Borough of Little Ferry Building Department Certificate of Occupancy Required	Abate by: 09/04/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 09/04/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 09/04/2025
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 09/04/2025
				Violation: Fire Extinguishers must not be obstructed	Abate by: 09/04/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 09/04/2025
				Violation: Electrical - Extension cords	Abate by: 09/04/2025
				Violation: Electrical - Extension cords	Abate by: 09/04/2025
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 09/04/2025
				Violation: Electrical - Extension cords	Abate by: 09/04/2025
				Violation: Spraying operations required approved spray booth.	Abate by: 09/04/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 09/04/2025
				Violation: General Conditions - Storage of flammable and combustible materials	Abate by: 09/04/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 78

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/30/2025	05/15/2025	0969K	P	Melody's Kitchen Inc.	148 Main Street #1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/15/2025
05/13/2025	05/28/2025	0969K	R	Melody's Kitchen Inc.	148 Main Street #1
			Violation:	Fire Service Features - Knox box required	Abate by: 05/28/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/28/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/28/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/28/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/28/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/28/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/28/2025
			Violation:	Fire protection-Test on battery smoke alarm	Abate by: 05/28/2025
05/20/2025		0969K	T	Melody's Kitchen Inc.	148 Main Street #1
06/20/2025		0969K	R	Melody's Kitchen Inc.	148 Main Street #1
06/27/2025		0969K	O	Melody's Kitchen Inc.	148 Main Street #1
03/04/2025		0702	P	Lesley's Beauty Salon II	244 Main Street (AKA 288 Liberty Street)
07/17/2025		0702	B	Lesley's Beauty Salon II	244 Main Street (AKA 288 Liberty Street)
07/17/2025	08/01/2025	0702	P	Lesley's Beauty Salon II	244 Main Street (AKA 288 Liberty Street)
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/01/2025
07/22/2025	08/06/2025	0702	R	Lesley's Beauty Salon II	244 Main Street (AKA 288 Liberty Street)
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/01/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/06/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 08/06/2025
			Violation:	Electrical - Extention cords	Abate by: 08/06/2025
07/23/2025		0702	R	Lesley's Beauty Salon II	244 Main Street (AKA 288 Liberty Street)
07/02/2025	07/17/2025	0919	P	In-Style Hair & Nail	315 Main Street Unit 1
			Violation:	Fire Service Features - Knox box required	Abate by: 07/17/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/17/2025
			Violation:	Electrical - Extention cords	Abate by: 07/17/2025
			Violation:	TO SCHEDULE REINSPECTION PLEASE EMAIL ME	Abate by: 07/17/2025
07/07/2025		0919	R	In-Style Hair & Nail	315 Main Street Unit 1
07/02/2025	07/17/2025	0307K	P	Great Wall Restuarant	315 Main Street Unit 2
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 79

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/11/2025	07/26/2025	0307K	R	Great Wall Restuarant	315 Main Street Unit 2
				Violation: Electrical - Extension cords	Abate by: 07/26/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 07/26/2025
				Violation: Excessive grease building up must be removed from all surfaces.	Abate by: 07/26/2025
				Violation: Fire Extinguishers - Proper mounting	Abate by: 07/26/2025
				Violation: Electrical - Extension cords	Abate by: 07/26/2025
				Violation: Electrical - Extension cords	Abate by: 07/26/2025
06/20/2025	07/05/2025	0950	P	Scrub's	315 Main Street Unit 4
				Violation: Electrical - Extension cords	Abate by: 07/05/2025
				Violation: Electrical - Multi plug adapters	Abate by: 07/05/2025
07/02/2025	07/17/2025	0950	R	Scrub's	315 Main Street Unit 4
				Violation: Electrical - Extension cords	Abate by: 07/05/2025
				Violation: Electrical - Multi plug adapters	Abate by: 07/05/2025
07/17/2025		0950	R	Scrub's	315 Main Street Unit 4
04/30/2025	05/15/2025	0920	P	Guacamole House	315 Main Street Unit 5
				Violation: Fire Service Features - Knox box required	Abate by: 05/15/2025
06/02/2025		0920	R	Guacamole House	315 Main Street Unit 5
04/16/2025	05/01/2025	0312K	P	Appartment Building	145 Marshal Ave
				Violation: Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/01/2025
				Violation: Fire protection - Maintenance on smoke detectors	Abate by: 05/01/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/01/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 05/01/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/01/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/01/2025
05/03/2025		0312K	O	Appartment Building	145 Marshal Ave
05/08/2025		0312K	T	Appartment Building	145 Marshal Ave
05/13/2025	05/28/2025	0312K	R	Appartment Building	145 Marshal Ave
				Violation: Fire protection-Test on fire alarm	Abate by: 05/01/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/01/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/01/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/28/2025
				Violation: Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/28/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 05/28/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 80

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/25/2025		0312K	R	Appartment Building	145 Marshal Ave
07/06/2025		0312K	T	Appartment Building	145 Marshal Ave
07/09/2025	07/24/2025	0467K	P	Multiple Dwelling	106 Marshall Ave
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/24/2025
07/09/2025	07/24/2025	0466K	P	Multiple Dwelling	108 Marshall Ave
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/24/2025
08/19/2025	09/03/2025	0313	P	Little Ferry Wine and Liquors	66 Marshall Ave.
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 09/03/2025
07/02/2025	07/17/2025	0703	P	Royale Village	1-24 Matt Fenton Drive
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025
		Violation:		Fire protection-Test on fire alarm	Abate by: 07/17/2025
		Violation:		Sprinkler system testing and maintenance required.	Abate by: 07/17/2025
		Violation:		Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 07/17/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 07/17/2025
02/28/2025		0314	R	Zabransky Mechanical Corp.	44 Mehrhof Road
04/07/2025	04/22/2025	0992	P	One Adult Day Care	136 Mehrhof Road
		Violation:		Means of Egress - Must be Free from Obstruction	Abate by: 04/22/2025
		Violation:		Means of Egress - Readily operable	Abate by: 04/08/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 04/22/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 04/22/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 04/22/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 04/22/2025
		Violation:		Utility shut off's shall be clearly labeled.	Abate by: 04/22/2025
		Violation:		Fire Service Features - Knox box required	Abate by: 04/22/2025
		Violation:		Fire Prevention will provide door lock code for all coded doors. We also need ALL key copies	Abate by: 04/22/2025
04/08/2025		0992	O	One Adult Day Care	136 Mehrhof Road
04/08/2025		0992	R	One Adult Day Care	136 Mehrhof Road
04/04/2025		0992	B	One Adult Day Care	136 Mehrhof Road
04/13/2025		0992	O	One Adult Day Care	136 Mehrhof Road
06/13/2025	06/28/2025	0992	C	One Adult Day Care	136 Mehrhof Road
		Violation:		Deficiencies noted on fire alarm test report must be repaired.	Abate by: 06/28/2025
		Violation:		Fire Service Features - Knox box required	Abate by: 06/28/2025
		Violation:		Fire Service Features - Knox box required	Abate by: 06/28/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 81

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Fire Service Features - Knox box required	ViolaAbate by: 06/28/2025
06/28/2025	07/12/2025	0992	F	One Adult Day Care	136 Mehrhof Road
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 06/28/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 06/28/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 06/28/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 06/28/2025
07/07/2025		0992	F	One Adult Day Care	136 Mehrhof Road
04/07/2025	04/22/2025	0993K	P	Korean American Family Love Counseling Center	136 Mehrhof Road
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/22/2025
04/08/2025		0993K	R	Korean American Family Love Counseling Center	136 Mehrhof Road
03/26/2025		0880	T	Osprey Point (Building Inspection)	250 Mehrhof Road
03/25/2025		0880	F	Osprey Point (Building Inspection)	250 Mehrhof Road
03/25/2025	04/10/2025	0880	R	Osprey Point (Building Inspection)	250 Mehrhof Road
			Violation:	Private Fire Hydrants Require Testing	Abate by: 12/24/2024
			Violation:	Area of refuge systems require annual testing and reporting or maintenance.	Abate by: 12/24/2024
			Violation:	Area of refuge systems require annual testing and reporting or maintenance.	Abate by: 12/24/2024
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 12/24/2024
04/06/2025		0880	T	Osprey Point (Building Inspection)	250 Mehrhof Road
04/24/2025		0880	T	Osprey Point (Building Inspection)	250 Mehrhof Road
04/29/2025	05/14/2025	0880	R	Osprey Point (Building Inspection)	250 Mehrhof Road
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 12/24/2024
02/27/2025	03/14/2025	0958	F	CSPNJ Office	250 Mehrhof Road
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 12/24/2024
			Violation:	General Conditions-No storage in equipment room	Abate by: 12/24/2024
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/24/2024
03/26/2025	04/10/2025	0958	F	CSPNJ Office	250 Mehrhof Road
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 12/24/2024
04/29/2025	05/14/2025	0958	F	CSPNJ Office	250 Mehrhof Road
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 12/24/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 82

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/04/2025	04/19/2025	0899	C	The Arc of Bergen and Passaic Counties Inc.	250 Mehrhof Road Apt. 120
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/19/2025
04/29/2025	05/14/2025	0899	F	The Arc of Bergen and Passaic Counties Inc.	250 Mehrhof Road Apt. 120
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/14/2025
05/14/2025	05/29/2025	0899	F	The Arc of Bergen and Passaic Counties Inc.	250 Mehrhof Road Apt. 120
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 05/14/2025
06/05/2025		0899	F	The Arc of Bergen and Passaic Counties Inc.	250 Mehrhof Road Apt. 120
07/25/2025		0905	B	The Arc of Bergen and Passaic Counties Inc.	250 Mehrhof Road Apt. 225
06/05/2025		0323	P	Caring House Projects	118 Neihaus Ave.
06/08/2025		0323	T	Caring House Projects	118 Neihaus Ave.
06/08/2025		0323	T	Caring House Projects	118 Neihaus Ave.
03/26/2025		0618	T	PSEG Sub Station	5 Poplar Ave
05/03/2025		0618	T	PSEG Sub Station	5 Poplar Ave
02/27/2025	05/28/2025	0325K	R	Building Inspection	18 Redneck Ave
			Violation:	Fire zone required by fire official. Yellow 18" letters stating fire zone 4" wide box and	Abate by: 05/04/2024
			Violation:	"Fire Zone No Parking" sign required.18in metal sign white back ground and 2" red reflective	Abate by: 05/04/2024
06/19/2025		0325K	R	Building Inspection	18 Redneck Ave
02/27/2025		0326K	R	CJ'S Pizza Box	18 Redneck Ave
02/27/2025	03/14/2025	0601K	R	Lucky Stop 99c & Up	18 Redneck Ave
			Violation:	Open junction boxes, missing covers, and open splices are prohibited	Abate by: 05/04/2024 CV
			Violation:	Type 1 commercial hood and exhaust systems shall be maintained	Abate by: 05/04/2024 CV
04/03/2025		0601K	R	Lucky Stop 99c & Up	18 Redneck Ave
04/09/2025	04/24/2025	0330K	P	Lombart Instrument	195 Redneck Ave
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 04/24/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
04/13/2025		0330K	T	Lombart Instrument	195 Redneck Ave

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 83

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/16/2025		0330K	T	Lombart Instrument	195 Redneck Ave
04/24/2025		0330K	T	Lombart Instrument	195 Redneck Ave
04/29/2025		0330K	R	Lombart Instrument	195 Redneck Ave
04/09/2025	04/24/2025	0822	P	Dae Ryung Framing Inc.	203 Redneck Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/24/2025
04/29/2025	05/14/2025	0822	R	Dae Ryung Framing Inc.	203 Redneck Ave
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/14/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/14/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/14/2025
			Violation:	Electrical - Clearance	Abate by: 05/14/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 05/14/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/14/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/14/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 05/14/2025
05/14/2025	05/29/2025	0822	R	Dae Ryung Framing Inc.	203 Redneck Ave
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 05/14/2025
06/05/2025	06/20/2025	0822	R	Dae Ryung Framing Inc.	203 Redneck Ave
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 05/14/2025
06/19/2025		0822	R	Dae Ryung Framing Inc.	203 Redneck Ave
04/09/2025	04/24/2025	0520K	P	Bigsply	205 Redneck Ave
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/24/2025
04/29/2025	05/14/2025	0520K	R	Bigsply	205 Redneck Ave
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
05/11/2025		0520K	O	Bigsply	205 Redneck Ave

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 84

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/14/2025	05/29/2025	0520K	R	Bigsply	205 Redneck Ave
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
05/30/2025		0520K	O	Bigsply	205 Redneck Ave
06/05/2025		0520K	R	Bigsply	205 Redneck Ave
04/09/2025	04/24/2025	0621K	P	C&L Express NY Inc.	207 Redneck Ave
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 04/24/2025
			Violation:	Electrical - Clearance	Abate by: 04/24/2025
			Violation:	Means of Egress - Egress obstructed	Abate by: 04/24/2025
04/29/2025		0621K	R	C&L Express NY Inc.	207 Redneck Ave
02/27/2025		0549	R	Laundry Room/ Abanes Capital Group LLC	18-6 Redneck Ave
04/09/2025	04/24/2025	0835	P	Via Touch	209 Redneck Ave Unit A.
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 04/24/2025
04/29/2025	05/14/2025	0835	R	Via Touch	209 Redneck Ave Unit A.
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 04/24/2025
05/11/2025		0835	O	Via Touch	209 Redneck Ave Unit A.
05/14/2025	05/29/2025	0835	R	Via Touch	209 Redneck Ave Unit A.
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 04/24/2025
06/05/2025	06/20/2025	0835	R	Via Touch	209 Redneck Ave Unit A.
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	Electrical - Extension cords	Abate by: 04/24/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 04/24/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 85

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/08/2025	07/23/2025	0835	R	Via Touch	209 Redneck Ave Unit A.
				Violation: Electrical - Extension cords	Abate by: 04/24/2025
				Violation: Electrical - Extension cords	Abate by: 04/24/2025
04/09/2025	04/24/2025	0519K	P	Pretzables	209 Redneck Ave Unit B
				Violation: Electrical - Extention cords	Abate by: 04/24/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 04/24/2025
				Violation: Electrical - Clearance	Abate by: 04/24/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/24/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
04/29/2025	05/14/2025	0519K	R	Pretzables	209 Redneck Ave Unit B
				Violation: Electrical - Extention cords	Abate by: 04/24/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 04/24/2025
				Violation: Electrical - Clearance	Abate by: 04/24/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/24/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
05/11/2025		0519K	O	Pretzables	209 Redneck Ave Unit B
05/14/2025	05/29/2025	0519K	R	Pretzables	209 Redneck Ave Unit B
				Violation: Electrical - Extention cords	Abate by: 04/24/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 04/24/2025
				Violation: Electrical - Clearance	Abate by: 04/24/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/24/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025
06/05/2025	06/20/2025	0519K	R	Pretzables	209 Redneck Ave Unit B
				Violation: Electrical - Extention cords	Abate by: 04/24/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 04/24/2025
				Violation: Electrical - Clearance	Abate by: 04/24/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/24/2025
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 04/24/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 04/24/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 86

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/08/2025	07/23/2025	0519K	R	Pretzables	209 Redneck Ave Unit B
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 04/24/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 04/24/2025
04/29/2025	05/14/2025	0332K	P	Early Learners	201 Redneck Ave.
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/14/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 05/14/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/14/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/14/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/14/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/14/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 05/14/2025
05/08/2025		0332K	T	Early Learners	201 Redneck Ave.
05/10/2025		0332K	O	Early Learners	201 Redneck Ave.
05/14/2025		0332K	R	Early Learners	201 Redneck Ave.
04/09/2025	04/24/2025	0331K	P	Building Inspection	201-209 Redneck Ave.
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 04/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/24/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/24/2025
			Violation:	Fire Zone Required by Fire Official	Abate by: 04/24/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/24/2025
04/29/2025	05/14/2025	0331K	R	Building Inspection	201-209 Redneck Ave.
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 04/24/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/24/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/24/2025
			Violation:	Fire Zone Required by Fire Official	Abate by: 04/24/2025
05/01/2025		0331K	T	Building Inspection	201-209 Redneck Ave.
05/08/2025		0331K	R	Building Inspection	201-209 Redneck Ave.
04/02/2025	04/17/2025	0337K	P	New Cal Aviation	14 Riser Road
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/17/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/17/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 04/17/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/17/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/17/2025
			Violation:	Fire Extinguishers - Proper mounting	Abate by: 04/17/2025
			Violation:	Electrical - Extension cords	Abate by: 04/17/2025
			Violation:	Electrical - Clearance	Abate by: 04/17/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 87

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Electrical - Open electrical junction boxes	ViolaAbate by: 04/17/2025
			Violation:	Cutting cart requires an approved and appropriate fire extinguisher	Abate by: 04/17/2025
			Violation:	Fire Extinguishers must not be obstructed	Abate by: 04/17/2025
			Violation:	Fire protection-Smoke detector required	Abate by: 04/17/2025
			Violation:	violation #12 may required building department permits. Contact alarm company/bld dept for	Abate by: 04/17/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 04/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/17/2025
04/05/2025		0337K	O	New Cal Aviation	14 Riser Road
04/16/2025		0337K	T	New Cal Aviation	14 Riser Road
04/16/2025		0337K	T	New Cal Aviation	14 Riser Road
04/17/2025	05/02/2025	0337K	R	New Cal Aviation	14 Riser Road
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/17/2025
			Violation:	Electrical - Extension cords	Abate by: 04/17/2025
			Violation:	Fire protection-Smoke detector required	Abate by: 04/17/2025
			Violation:	violation #12 may required building department permits. Contact alarm company/bld dept for	Abate by: 04/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/17/2025
05/11/2025		0337K	O	New Cal Aviation	14 Riser Road
05/12/2025	05/27/2025	0337K	R	New Cal Aviation	14 Riser Road
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/17/2025
			Violation:	Electrical - Extension cords	Abate by: 04/17/2025
			Violation:	Fire protection-Smoke detector required	Abate by: 04/17/2025
			Violation:	violation #12 may required building department permits. Contact alarm company/bld dept for	Abate by: 04/17/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/17/2025
04/03/2025	04/18/2025	0342K	R	Samsung & Hanul Corp.	210 Riser Road
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 01/04/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 01/04/2025
05/12/2025	05/27/2025	0342K	R	Samsung & Hanul Corp.	210 Riser Road
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 01/04/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 01/04/2025
07/07/2025	07/22/2025	0342K	R	Samsung & Hanul Corp.	210 Riser Road
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 01/04/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 01/04/2025

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address	
07/23/2025		0342K	T	Samsung & Hanul Corp.	210 Riser Road	
07/23/2025		0342K	T	Samsung & Hanul Corp.	210 Riser Road	
07/23/2025		0342K	T	Samsung & Hanul Corp.	210 Riser Road	
07/23/2025		0342K	T	Samsung & Hanul Corp.	210 Riser Road	
07/23/2025		0342K	R	Samsung & Hanul Corp.	210 Riser Road	
07/23/2025		0341K	T	Dassault Falcon Jet	200-210 Riser Road	
07/23/2025		0341K	T	Dassault Falcon Jet	200-210 Riser Road	
07/23/2025		0341K	T	Dassault Falcon Jet	200-210 Riser Road	
07/23/2025		0341K	T	Dassault Falcon Jet	200-210 Riser Road	
04/03/2025	04/18/2025	0339K	R	Otto Tile	100 Riser Road Unit A.	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
				Violation: Electrical - Improper electrical	Abate by: 12/20/2024	
				Violation: Electrical - Clearance	Abate by: 12/20/2024	CV
				Violation: Fire Extinguishers must not be obstructed	Abate by: 12/20/2024	
				Violation: Smoking around flammable or combustible equipment prohibited.	Abate by: 12/20/2024	
				Violation: No smoking sign compliance required.	Abate by: 12/20/2024	
05/12/2025	05/27/2025	0339K	R	Otto Tile	100 Riser Road Unit A.	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
06/02/2025		0339K	R	Otto Tile	100 Riser Road Unit A.	
04/03/2025	04/18/2025	0340K	R	Castillo Distributor	100 Riser Road Unit B	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 12/20/2024	
				Violation: Fire Extinguishers must not be obstructed	Abate by: 12/20/2024	
05/12/2025	05/27/2025	0340K	R	Castillo Distributor	100 Riser Road Unit B	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
				Violation: Means of Egress - Exit signs/directional signs	Abate by: 12/20/2024	
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 12/20/2024	
06/02/2025		0340K	R	Castillo Distributor	100 Riser Road Unit B	
06/07/2025	06/22/2025	0345	C	North Village	1-22 River Street	
				Violation: Deficiencies noted on fire alarm test report must be repaired.	Abate by: 06/22/2025	
				Violation: Fire watch required while fire alarm system is down for repairs/maintenance	Abate by: 06/22/2025	
				Violation: Fire watch members shall be capable of performing all duties of the fire watch position.	Abate by: 06/22/2025	
				Violation: Fire watch locations and times shall be recorded and provided at the end of the fire watch.	Abate by: 06/22/2025	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 89

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				Prior to working on any fire protection system thela	Abate by: 06/22/2025
				contractor must notify the police desk 2016412770	
			Violation:	After working on any fire protection system the	Abate by: 06/22/2025
				contractor must notify the police desk 2016412770	
06/07/2025		0345	O	North Village	1-22 River Street
06/12/2025		0345	F	North Village	1-22 River Street
04/17/2025		0347	R	J&J Tires & Wheels	Route 46 Circle W/B AKA 1 Bergen Tpk.
07/04/2025		0347	T	J&J Tires & Wheels	Route 46 Circle W/B AKA 1 Bergen Tpk.
03/04/2025		0535	O	Sunoco (Vacant)	95 Route 46 East
06/03/2025	06/03/2026	0535	P	Sunoco (Vacant)	95 Route 46 East
			Violation:	Life Hazard Usage Fees Past Due	Abate by: 06/18/2025
04/03/2025	04/18/2025	0357K	R	Popeye's	146 Route 46 East
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
			Violation:	Fire Protection System - Maintenance	Abate by: 01/04/2025
			Violation:	Cooking Areas - Carbon dioxide System - 12 mo. Inspection	Abate by: 01/04/2025
			Violation:	Cooking Areas - Carbon dioxide System - 12 mo. Inspection	Abate by: 01/04/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 01/04/2025
05/12/2025	05/27/2025	0357K	R	Popeye's	146 Route 46 East
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
			Violation:	Fire Protection System - Maintenance	Abate by: 01/04/2025
06/25/2025	07/10/2025	0357K	R	Popeye's	146 Route 46 East
			Violation:	Fire protection-Test on fire alarm	Abate by: 01/04/2025
06/28/2025		0357K	T	Popeye's	146 Route 46 East
06/28/2025		0357K	R	Popeye's	146 Route 46 East
07/06/2025		0357K	T	Popeye's	146 Route 46 East
07/06/2025		0357K	T	Popeye's	146 Route 46 East
04/29/2025	05/14/2025	0596	P	Building Inspection	191 Route 46 East
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/14/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
05/14/2025	05/29/2025	0596	R	Building Inspection	191 Route 46 East
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/14/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 90

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/02/2025	06/17/2025	0596	R	Building Inspection	191 Route 46 East
				Violation: Fire protection-Test on fire alarm	Abate by: 05/14/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
06/19/2025	07/04/2025	0596	R	Building Inspection	191 Route 46 East
				Violation: Fire protection-Test on fire alarm	Abate by: 05/14/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
06/23/2025	07/08/2025	0596	R	Building Inspection	191 Route 46 East
				Violation: Fire protection-Test on fire alarm	Abate by: 05/14/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/14/2025
07/04/2025		0596	T	Building Inspection	191 Route 46 East
07/07/2025		0596	R	Building Inspection	191 Route 46 East
03/13/2025		0779	O	Fuel 4	261 Route 46 East
08/20/2025		0779	P	Fuel 4	261 Route 46 East
03/31/2025	04/15/2025	0989	P	Fleet One Little Ferry LLC	315 Route 46 East
				Violation: Fire Service Features - Knox box required	Abate by: 04/15/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 04/15/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025
				Violation: Clear isle width required	Abate by: 04/15/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/15/2025
				Violation: Electrical - Extension cords	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025
04/05/2025		0989	O	Fleet One Little Ferry LLC	315 Route 46 East
04/17/2025	05/02/2025	0989	R	Fleet One Little Ferry LLC	315 Route 46 East
				Violation: Fire Service Features - Knox box required	Abate by: 04/15/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 04/15/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025
				Violation: Clear isle width required	Abate by: 04/15/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/15/2025
				Violation: Electrical - Extension cords	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 91

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/11/2025		0989	O	Fleet One Little Ferry LLC	315 Route 46 East
05/12/2025	05/27/2025	0989	R	Fleet One Little Ferry LLC	315 Route 46 East
				Violation: Fire Service Features - Knox box required	Abate by: 04/15/2025
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 04/15/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions	Abate by: 04/15/2025
				Contributing to fire	
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/15/2025
				Violation: General Conditions - General Conditions	Abate by: 04/15/2025
				Contributing to fire	
06/01/2025		0989	O	Fleet One Little Ferry LLC	315 Route 46 East
06/07/2025		0989	O	Fleet One Little Ferry LLC	315 Route 46 East
03/31/2025	04/15/2025	0404	P	Mcdonald's	319 Route 46 East
				Violation: Truss Roof and or Floor Symbol Required on structure.	Abate by: 04/15/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 04/15/2025
				Violation: Fire protection-Test on fire alarm	Abate by: 04/15/2025
				Violation: Sprinkler system testing and maintenance required.	Abate by: 04/15/2025
				Violation: Means of Egress - Must be Free from Obstruction	Abate by: 04/15/2025
				Violation: Electrical - Open electrical junction boxes	Abate by: 04/15/2025
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 04/15/2025
04/01/2025		0404	T	Mcdonald's	319 Route 46 East
04/17/2025		0404	T	Mcdonald's	319 Route 46 East
04/17/2025	05/02/2025	0404	R	Mcdonald's	319 Route 46 East
				Violation: Truss Roof and or Floor Symbol Required on structure.	Abate by: 04/15/2025
04/17/2025		0404	T	Mcdonald's	319 Route 46 East
04/23/2025		0404	R	Mcdonald's	319 Route 46 East
07/02/2025	07/17/2025	0408K	P	Dunkin Donuts	429 Route 46 East
				Violation: Fire protection-Test on fire alarm	Abate by: 07/17/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/17/2025
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 07/17/2025
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/17/2025
07/22/2025		0408K	R	Dunkin Donuts	429 Route 46 East
07/25/2025		0408K	T	Dunkin Donuts	429 Route 46 East

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 92

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/02/2025	07/17/2025	1020	P	Auto Spot Service LLC	435 Route 46 East
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/17/2025
			Violation:	Each individual life hazard usage shall be required to be registered with this office.	Abate by: 07/17/2025
			Violation:	QUESTIONS PLEASE EMAIL ME	Abate by: 07/17/2025
07/25/2025		1020	O	Auto Spot Service LLC	435 Route 46 East
08/14/2025	08/29/2025	1020	R	Auto Spot Service LLC	435 Route 46 East
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 08/29/2025
			Violation:	Electrical - Extension cords	Abate by: 08/29/2025
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 08/29/2025
			Violation:	Electrical - Extention cords	Abate by: 08/29/2025
02/24/2025		0410K	T	Teterboro Chrysler	469 Route 46 East
03/09/2025		0410K	O	Teterboro Chrysler	469 Route 46 East
04/29/2025	05/14/2025	1007	P	Zeta Industry Inc.	191 Route 46 East Unit A
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/14/2025
05/14/2025	05/29/2025	1007	R	Zeta Industry Inc.	191 Route 46 East Unit A
			Violation:	Fire Service Features - Knox box required	Abate by: 05/29/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 05/29/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/29/2025
05/30/2025		1007	O	Zeta Industry Inc.	191 Route 46 East Unit A
06/02/2025	06/17/2025	1007	R	Zeta Industry Inc.	191 Route 46 East Unit A
			Violation:	Fire Service Features - Knox box required	Abate by: 05/29/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 05/29/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/29/2025
06/02/2025		1007	O	Zeta Industry Inc.	191 Route 46 East Unit A
06/18/2025		1007	O	Zeta Industry Inc.	191 Route 46 East Unit A
07/04/2025		1007	T	Zeta Industry Inc.	191 Route 46 East Unit A
04/29/2025		0546K	R	Bagel Box	191 Route 46 East Unit B
04/29/2025	05/14/2025	0546K	P	Bagel Box	191 Route 46 East Unit B
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/14/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/14/2025
			Violation:	Electrical - Improper electrical	Abate by: 05/14/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 05/14/2025
05/14/2025		0546K	R	Bagel Box	191 Route 46 East Unit B

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 93

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/01/2025		0546K	O	Bagel Box	191 Route 46 East Unit B
07/03/2025		0546K	O	Bagel Box	191 Route 46 East Unit B
07/04/2025		0546K	T	Bagel Box	191 Route 46 East Unit B
04/03/2025	04/18/2025	0800K	R	JJS OWN	191 Route 46 East Unit C
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/25/2024
		Violation:		Fire Service Features - Knox box required	Abate by: 12/25/2024
04/29/2025	05/14/2025	0800K	R	JJS OWN	191 Route 46 East Unit C
		Violation:		Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/25/2024
		Violation:		Fire Service Features - Knox box required	Abate by: 12/25/2024
05/08/2025	05/23/2025	0800K	R	JJS OWN	191 Route 46 East Unit C
		Violation:		Fire Service Features - Knox box required	Abate by: 05/23/2025
		Violation:		Electrical - Clearance	Abate by: 05/23/2025
05/14/2025		0800K	R	JJS OWN	191 Route 46 East Unit C
07/04/2025		0800K	T	JJS OWN	191 Route 46 East Unit C
02/28/2025		0486K	R	7-11	200 Route 46 West
02/28/2025	03/15/2025	0363	R	United Auto Mart Inc.	210 Route 46 West
		Violation:		Spraying operations required approved spray booth.	Abate by: 01/10/2025
		Violation:		Fire Extinguishers - Outdated or discharged	Abate by: 01/10/2025
		Violation:		Each individual life hazard usage shall be required to be registered with this office.	Abate by: 01/10/2025
		Violation:		Life Hazard Usage Fees Past Due	Abate by: 01/10/2025
07/08/2025	07/23/2025	0363	R	United Auto Mart Inc.	210 Route 46 West
		Violation:		Each individual life hazard usage shall be required to be registered with this office.	Abate by: 01/10/2025
		Violation:		Life Hazard Usage Fees Past Due	Abate by: 01/10/2025
07/30/2025	08/14/2025	0363	R	United Auto Mart Inc.	210 Route 46 West
		Violation:		Each individual life hazard usage shall be required to be registered with this office.	Abate by: 01/10/2025
		Violation:		Life Hazard Usage Fees Past Due	Abate by: 01/10/2025
02/28/2025		0397	R	Luke Oil	270 Route 46 West
06/03/2025	06/18/2025	0397	P	Luke Oil	270 Route 46 West
		Violation:		Fire Extinguishers - Outdated or discharged	Abate by: 06/18/2025
		Violation:		Electrical - Clearance	Abate by: 06/18/2025
		Violation:		General Conditions - Storage of flammable and combustible materials	Abate by: 06/18/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 94

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/19/2025	07/04/2025	0397	R	Luke Oil	270 Route 46 West
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/18/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 06/18/2025
07/07/2025	07/22/2025	0397	R	Luke Oil	270 Route 46 West
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/18/2025
			Violation:	General Conditions - Storage of flammable and combustibile materials	Abate by: 06/18/2025
07/22/2025	08/08/2025	0397	R	Luke Oil	270 Route 46 West
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 06/18/2025
08/08/2025		0397	R	Luke Oil	270 Route 46 West
04/01/2025	04/15/2025	0400	P	Starbuck's	300 Route 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
			Violation:	Electrical - Clearance	Abate by: 04/15/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/15/2025
04/17/2025	05/02/2025	0400	R	Starbuck's	300 Route 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
05/11/2025		0400	O	Starbuck's	300 Route 46 West
06/01/2025		0400	O	Starbuck's	300 Route 46 West
06/11/2025		0400	O	Starbuck's	300 Route 46 West
07/09/2025	07/24/2025	0400	R	Starbuck's	300 Route 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/24/2025
08/07/2025	08/22/2025	0400	R	Starbuck's	300 Route 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/24/2025
04/01/2025	04/16/2025	0401	P	Jakes Wayback Burger	302 Route 46 West
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 04/16/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/16/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/16/2025
04/17/2025	05/02/2025	0401	R	Jakes Wayback Burger	302 Route 46 West
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 04/16/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/16/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/16/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 95

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
05/12/2025	06/12/2025	0401	R	Jakes Wayback Burger	302 Route 46 West
			Violation:	Cooking Areas - Kitchen Exhaust Hood	Abate by: 04/16/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 04/16/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/16/2025
05/12/2025		0401	O	Jakes Wayback Burger	302 Route 46 West
06/07/2025		0401	O	Jakes Wayback Burger	302 Route 46 West
06/11/2025		0401	O	Jakes Wayback Burger	302 Route 46 West
07/08/2025		0401	O	Jakes Wayback Burger	302 Route 46 West
02/24/2025		0789K	R	Currently Vacant	314 Route 46 West
04/01/2025	04/16/2025	0990	P	Building Inspection	300-302 Route 46 West
			Violation:	Fire Service Features - Knox box required	Abate by: 04/16/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/16/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 04/16/2025
04/17/2025	05/02/2025	0990	R	Building Inspection	300-302 Route 46 West
			Violation:	Fire Service Features - Knox box required	Abate by: 04/16/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 04/16/2025
			Violation:	Truss Roof and or Floor Symbol Required on structure.	Abate by: 04/16/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/16/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/16/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/02/2025
05/11/2025		0990	O	Building Inspection	300-302 Route 46 West
06/11/2025		0990	O	Building Inspection	300-302 Route 46 West
07/11/2025	07/26/2025	0990	R	Building Inspection	300-302 Route 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/16/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 04/16/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 05/02/2025
04/03/2025		0801K	P	Vacant as of 04/03/2025	415 RT 46 East
02/24/2025		0240K	F	Ledgewood Terrace	460 to 470 Liberty Street
04/11/2025		0532K	T	Rayco 2	309-311 US 46 East

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address	
04/17/2025	05/02/2025	0532K	R	Rayco 2	309-311 US 46 East	
				Violation: Life Hazard Usage Fees Past Due	Abate by: 01/14/2025	
				Violation: Windowless basement over 10,000 square feet shall require centrally monitored fire sprinkler system.	Abate by: 01/30/2025	CV
				Violation: Requirements for firefighter window access	Abate by: 01/30/2025	
				Violation: Means of Egress - Exit Capacity	Abate by: 01/30/2025	
				Violation: Owner shall have the responsibility to comply with the code.	Abate by: 01/30/2025	
				Violation: Building department permits/approval required prior to any work.	Abate by: 01/30/2025	
06/20/2025	07/05/2025	0661	P	Buzzz Rite Liquor & Bar	269 US 46 Unit 3/4	
				Violation: Life Hazard Usage Fees Past Due	Abate by: 07/05/2025	
				Violation: Fire Extinguishers - Outdated or discharged	Abate by: 07/05/2025	
				Violation: Electrical - Extension cords	Abate by: 07/05/2025	
				Violation: Electrical- Multiplug adaptor	Abate by: 07/05/2025	
				Violation: Electrical - Clearance	Abate by: 07/05/2025	
				Violation: Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/05/2025	
				Violation: General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 07/05/2025	
				Violation: Electrical - Open electrical junction boxes	Abate by: 07/05/2025	
07/07/2025	07/22/2025	0661	R	Buzzz Rite Liquor & Bar	269 US 46 Unit 3/4	
				Violation: Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/05/2025	
				Violation: Electrical - Open electrical junction boxes	Abate by: 07/05/2025	
02/27/2025	03/14/2025	0631K	R	Building Inspection	269 US 46 West	
				Violation: Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 09/01/2023	
				Violation: Sprinkler system testing required per NFPA 25	Abate by: 09/01/2023	
				Violation: Knox Box Required. Please email FIREPREVENTION@LITTLEFERRYNJ.ORG after box is paid	Abate by: 09/01/2023	
				Violation: Locking arrangements in the means of egress that restrict control must be installed and maintained.	Abate by: 09/01/2023	
				Violation: Egress doors shall be readily openable from egress side without key or special knowledge.	Abate by: 09/01/2023	
				Violation: Maintain fire rated ceiling (repair all holes)	Abate by: 09/01/2023	
				Violation: Fire protection control room (fire sprinkler and fire alarm)doors shall be labeled.	Abate by: 09/01/2023	
				Violation: Fire protection control room (fire sprinkler and fire alarm)doors shall be labeled.	Abate by: 09/01/2023	
				Violation: Rooms containing utility equipment shall be identified.	Abate by: 09/01/2023	
				Violation: Rooms containing utility equipment shall be identified.	Abate by: 09/01/2023	
				Violation: Dangerous conditions that can cause or contribute to the spread of fire or endanger occupants.	Abate by: 09/01/2023	
				Violation: Accumilation of excessive storage of combustable materials must be removed	Abate by: 09/01/2023	
				Violation: Combustable/flammable material must not be stored in the means of egress	Abate by: 09/01/2023	
				Violation: Exit signs shall be maintained visible and illuminated at all times.	Abate by: 09/01/2023	
				Violation: Maintain fire rated ceiling (repair all holes)	Abate by: 09/01/2023	
				Violation: Building Addresses shall be identified 4" x 1/2"	Abate by: 09/01/2023	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 97

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				numbers.	
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 09/01/2023
04/17/2025	05/02/2025	0631K	R	Building Inspection	269 US 46 West
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 09/01/2023
			Violation:	Sprinkler system testing required per NFPA 25	Abate by: 09/01/2023
			Violation:	Locking arrangements in the means of egress that restrict control must be installed and maintained.	Abate by: 09/01/2023
			Violation:	Egress doors shall be readily openable from egress side without key or special knowledge.	Abate by: 09/01/2023
			Violation:	Maintain fire rated ceiling (repair all holes)	Abate by: 09/01/2023
			Violation:	Fire protection control room (fire sprinkler and fire alarm) doors shall be labeled.	Abate by: 09/01/2023
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 09/01/2023
07/11/2025	07/26/2025	0631K	P	Building Inspection	269 US 46 West
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	Sprinkler system testing and maintenance required.	Abate by: 07/26/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/26/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/26/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Locking arrangements in the means of egress that restrict control must be installed and maintained	Abate by: 07/26/2025
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/26/2025
02/27/2025	03/14/2025	0770K	R	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor
			Violation:	Fire extinguishers require to be maintained per NFPA 10	Abate by: 07/06/2024
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 07/06/2024
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/06/2024
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/06/2024
			Violation:	Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/06/2024
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 07/06/2024
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 07/06/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 98

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address	
03/10/2025	03/25/2025	0770K	R	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor	
			Violation:	Fire extinguishers require to be maintained per NFPA 10	Abate by: 07/06/2024	
			Violation:	Fire alarm and fire detection systems shall be maintained and tested in accordance with NFPA72	Abate by: 07/06/2024	
			Violation:	Police desk must be notified prior to work being done on the fire protection system.	Abate by: 07/06/2024	
			Violation:	Police Desk must be notified after work is done being performed on the fire protection system.	Abate by: 07/06/2024	
			Violation:	Dangerous condition that could cause or contribute to the spread for fire	Abate by: 07/06/2024	
			Violation:	Rooms containing utility equipment shall be identified.	Abate by: 07/06/2024	
04/16/2025		0770K	O	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor	
06/25/2025	07/10/2025	0770K	P	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor	
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/10/2025	
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/10/2025	CV
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/10/2025	
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/10/2025	
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/10/2025	CV
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/10/2025	CV
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/10/2025	CV
			Violation:	Magnetic door locks must release from fire alarm signal	Abate by: 07/10/2025	CV
			Violation:	PLEASE EMAIL ME TO SCHEDULE INPERSON FIRE INSPECTION	Abate by: 07/10/2025	
07/10/2025	07/25/2025	0770K	R	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor	
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/10/2025	
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/10/2025	CV
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/10/2025	
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/10/2025	
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 07/10/2025	CV
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 07/10/2025	CV
			Violation:	Egress doors shall be readily operable from egress side with out key or special knowledge	Abate by: 07/10/2025	CV
			Violation:	Magnetic door locks must release from fire alarm signal	Abate by: 07/10/2025	CV
			Violation:	PLEASE EMAIL ME TO SCHEDULE INPERSON FIRE INSPECTION	Abate by: 07/10/2025	
07/30/2025	08/14/2025	0770K	R	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor	
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/10/2025	CV
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/10/2025	
			Violation:	After working on any fire protection system the	Abate by: 07/10/2025	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 99

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				contractor must notify the police desk 2016412770	
			Violation:	General Conditions - General Conditions	Abate by: 07/10/2025 CV
				Contributing to fire	
			Violation:	Egress doors shall be readily operable from egress	Abate by: 07/10/2025 CV
				side with out key or special knowledge	
			Violation:	Magnetic door locks must release from fire alarm	Abate by: 07/10/2025 CV
				signal	
			Violation:	Means of Egress - Exit signs/directional signs	Abate by: 08/14/2025
07/30/2025		0770K	O	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor
08/05/2025		0770K	T	Phenix Salon Suites (Unit Inspection)	269 US 46 West 2nd Floor
04/08/2025	04/23/2025	0994	P	PMU Atelier LLC	269 US 46 West 2nd Floor Suite 102
			Violation:	Fire Prevention requires access to the property to	Abate by: 04/23/2025
				perform a fire inspection	
04/23/2025		0994	B	PMU Atelier LLC	269 US 46 West 2nd Floor Suite 102
04/23/2025		0994	O	PMU Atelier LLC	269 US 46 West 2nd Floor Suite 102
04/25/2025	05/10/2025	0994	R	PMU Atelier LLC	269 US 46 West 2nd Floor Suite 102
			Violation:	Fire Prevention requires access to the property to	Abate by: 04/23/2025
				perform a fire inspection	
04/29/2025		0994	R	PMU Atelier LLC	269 US 46 West 2nd Floor Suite 102
03/04/2025	03/19/2025	0867	R	My Place	269 US 46 West 2nd Floor Suite 110
			Violation:	Fire prevention is required to gain access to	Abate by: 07/06/2024
				building for fire inspection.	
			Violation:	FAILURE TO CONTACT THE OFFICE COULD RESULT IN A	Abate by: 07/06/2024
				MONITARY PENALTY.	
03/11/2025		0867	B	My Place	269 US 46 West 2nd Floor Suite 110
03/27/2025		0867	R	My Place	269 US 46 West 2nd Floor Suite 110
03/04/2025	03/19/2025	0972	P	Concepcuts	269 US 46 West 2nd Floor Suite 112
			Violation:	Fire Prevention requires access to the property to	Abate by: 03/19/2025
				perform a fire inspection	
04/07/2025	04/22/2025	0972	R	Concepcuts	269 US 46 West 2nd Floor Suite 112
			Violation:	Fire Prevention requires access to the property to	Abate by: 03/19/2025
				perform a fire inspection	
04/08/2025		0972	R	Concepcuts	269 US 46 West 2nd Floor Suite 112
04/08/2025	04/23/2025	0995	P	Clawed By Lay	269 US 46 West 2nd Floor Suite 117
			Violation:	Fire Prevention requires access to the property to	Abate by: 04/23/2025
				perform a fire inspection	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 00

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/23/2025		0995	O	Clawed By Lay	269 US 46 West 2nd Floor Suite 117
04/25/2025		0995	R	Clawed By Lay	269 US 46 West 2nd Floor Suite 117
05/08/2025		0995	B	Clawed By Lay	269 US 46 West 2nd Floor Suite 117
05/08/2025		1009	B	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 120
05/08/2025	05/23/2025	1009	P	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 120
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/23/2025
05/13/2025		1009	R	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 120
06/16/2025		1009	O	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 120
05/08/2025		1010	B	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 122
05/08/2025	05/23/2025	1010	P	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 122
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/23/2025
05/13/2025		1010	R	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 122
06/16/2025		1010	O	I Am Me Barber Shop	269 US 46 West 2nd Floor Suite 122
04/08/2025		0996	P	Face and Body by Era	269 US 46 West 2nd Floor Suite 126
03/04/2025	03/19/2025	0982	P	NBL NAILS BY LES	269 US 46 West 2nd Floor Suite 127
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
04/07/2025	04/22/2025	0982	R	NBL NAILS BY LES	269 US 46 West 2nd Floor Suite 127
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
04/08/2025		0982	R	NBL NAILS BY LES	269 US 46 West 2nd Floor Suite 127
05/11/2025		0982	O	NBL NAILS BY LES	269 US 46 West 2nd Floor Suite 127
03/04/2025	03/19/2025	0750K	R	KD Massage and Wellness	269 US 46 West 2nd Floor Suite 128
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024
04/07/2025	04/22/2025	0750K	R	KD Massage and Wellness	269 US 46 West 2nd Floor Suite 128
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 01

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/25/2025	05/10/2025	0750K	R	KD Massage and Wellness	269 US 46 West 2nd Floor Suite 128
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024
03/04/2025	03/19/2025	0978	P	CURRENT TENANT (CURRENTLY OCCUPIED)	269 US 46 West 2nd Floor Suite 129
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
07/08/2025	07/23/2025	0978	R	CURRENT TENANT (CURRENTLY OCCUPIED)	269 US 46 West 2nd Floor Suite 129
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
03/26/2025		0986	B	Darisbel Herrera Pure Beauty	269 US 46 West 2nd Floor Suite 130
04/08/2025	04/23/2025	0986	P	Darisbel Herrera Pure Beauty	269 US 46 West 2nd Floor Suite 130
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/22/2025
04/25/2025	05/10/2025	0986	R	Darisbel Herrera Pure Beauty	269 US 46 West 2nd Floor Suite 130
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/22/2025
05/27/2025		0986	R	Darisbel Herrera Pure Beauty	269 US 46 West 2nd Floor Suite 130
03/04/2025	03/19/2025	0979	P	Perfect Monment by Lizzie	269 US 46 West 2nd Floor Suite 131
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
04/08/2025	04/23/2025	0979	R	Perfect Monment by Lizzie	269 US 46 West 2nd Floor Suite 131
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
04/25/2025	05/10/2025	0979	R	Perfect Monment by Lizzie	269 US 46 West 2nd Floor Suite 131
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
05/27/2025	06/11/2025	0979	R	Perfect Monment by Lizzie	269 US 46 West 2nd Floor Suite 131
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
06/06/2025		0979	R	Perfect Monment by Lizzie	269 US 46 West 2nd Floor Suite 131
03/04/2025	03/19/2025	0980	P	REJUVENATE	269 US 46 West 2nd Floor Suite 132
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 02

-----Dates-----					
Insp.	Due	Local	Type	Property name	Property address
03/10/2025		0980	O	REJUVENATE	269 US 46 West 2nd Floor Suite 132
03/18/2025		0980	B	REJUVENATE	269 US 46 West 2nd Floor Suite 132
03/20/2025		0980	R	REJUVENATE	269 US 46 West 2nd Floor Suite 132
04/07/2025		0991	B	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
04/07/2025	04/22/2025	0991	P	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
			Violation:	Fire Prevention requires access to the property to perform a fire inspection Abate by: 04/22/2025	
04/25/2025	05/10/2025	0991	R	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
			Violation:	Fire Prevention requires access to the property to perform a fire inspection Abate by: 04/22/2025	
05/11/2025	05/26/2025	0991	R	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
			Violation:	Fire Prevention requires access to the property to perform a fire inspection Abate by: 04/22/2025	
05/14/2025	05/29/2025	0991	R	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
			Violation:	Fire Prevention requires access to the property to perform a fire inspection Abate by: 04/22/2025	
05/27/2025		0991	R	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
05/30/2025		0991	O	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
06/16/2025		0991	O	The Queen Dior Palace	269 US 46 West 2nd Floor Suite 135
06/19/2025		0956	P	Yasmine Aesthetics	269 US 46 West 2nd Floor Suite 136
03/04/2025	03/19/2025	0948	R	Fade Department	269 US 46 West 2nd Floor Suite 138
			Violation:	Fire prevention is required to gain access to building for fire inspection. Abate by: 07/06/2024	
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES. Abate by: 07/06/2024	
04/07/2025	04/22/2025	0948	R	Fade Department	269 US 46 West 2nd Floor Suite 138
			Violation:	Fire prevention is required to gain access to building for fire inspection. Abate by: 07/06/2024	
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES. Abate by: 07/06/2024	
04/08/2025		0948	R	Fade Department	269 US 46 West 2nd Floor Suite 138
03/24/2025	04/08/2025	0985	P	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
			Violation:	Fire Prevention requires access to the property to perform a fire inspection Abate by: 04/08/2025	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 03

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/08/2025	04/23/2025	0985	R	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/23/2025
04/25/2025	05/10/2025	0985	R	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/23/2025
05/11/2025		0985	O	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
05/11/2025	05/26/2025	0985	R	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/23/2025
05/27/2025	06/11/2025	0985	R	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/23/2025
06/07/2025		0985	O	Slayed by Celeste/ Illmatic Beauty LLC	269 US 46 West 2nd Floor Suite 140
03/04/2025	03/19/2025	0960	R	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 01/18/2025
03/13/2025		0960	B	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
04/07/2025	04/22/2025	0960	P	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/22/2025
04/08/2025		0960	R	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
05/12/2025		0960	O	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
06/07/2025		0960	O	Clavel Unisex	269 US 46 West 2nd Floor Suite 143
02/24/2025		0766K	R	The Alba Salon	269 US 46 West 2nd Floor Suite 144
03/04/2025	03/19/2025	0768K	R	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024
03/10/2025		0768K	O	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
03/19/2025		0768K	B	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
04/08/2025	04/23/2025	0768K	R	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 04

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/25/2025	05/10/2025	0768K	R	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024
05/11/2025		0768K	O	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
05/11/2025	05/26/2025	0768K	R	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/06/2024
			Violation:	FAILURE TO CONTACT OFFICE COULD RESULT IN MONITARY PENALTIES.	Abate by: 07/06/2024
05/27/2025		0768K	R	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
05/30/2025		0768K	O	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
06/07/2025		0768K	O	SLAYED BY SYD	269 US 46 West 2nd Floor Suite 146
03/04/2025	03/19/2025	0981	P	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
03/10/2025		0981	O	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
04/08/2025	04/23/2025	0981	R	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
04/25/2025	05/10/2025	0981	R	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
05/11/2025		0981	O	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
05/11/2025	05/26/2025	0981	R	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
05/27/2025	06/11/2025	0981	R	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 03/19/2025
05/30/2025		0981	O	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
06/16/2025		0981	O	CREATED TO CREATE	269 US 46 West 2nd Floor Suite 147
03/04/2025	03/19/2025	0629K	P	Wingstop	269 US 46 West Unit 5
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
			Violation:	Electrical - Clearance	Abate by: 03/19/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 05

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
04/01/2025	04/16/2025	0629K	R	Wingstop	269 US 46 West Unit 5
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
			Violation:	Electrical - Clearance	Abate by: 03/19/2025
04/17/2025	05/02/2025	0629K	R	Wingstop	269 US 46 West Unit 5
			Violation:	Electrical - Clearance	Abate by: 03/19/2025
05/12/2025		0629K	R	Wingstop	269 US 46 West Unit 5
03/04/2025	03/19/2025	0628K	P	Jersey Mikes Subs	269 US 46 West Unit 6
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/19/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 03/19/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 03/19/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
04/01/2025	04/16/2025	0628K	R	Jersey Mikes Subs	269 US 46 West Unit 6
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/19/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 03/19/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 03/19/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
04/14/2025		0628K	O	Jersey Mikes Subs	269 US 46 West Unit 6
04/17/2025	05/02/2025	0628K	R	Jersey Mikes Subs	269 US 46 West Unit 6
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/19/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 03/19/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 03/19/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
05/12/2025	05/27/2025	0628K	R	Jersey Mikes Subs	269 US 46 West Unit 6
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 03/19/2025
			Violation:	Fire Extinguishers - Size and distribution	Abate by: 03/19/2025
			Violation:	General Conditions - Securing of compressed gas containers	Abate by: 03/19/2025
			Violation:	General Conditions-Ceiling clearance 18" with sprinklers	Abate by: 03/19/2025
06/02/2025		0628K	R	Jersey Mikes Subs	269 US 46 West Unit 6
06/29/2025		0412	O	Capri Inn	1 Valley Road
06/03/2025	06/18/2025	0511K	P	Garden Shabu	1 Valley Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 06/18/2025
			Violation:	Fire Protection System - Maintenance	Abate by: 06/18/2025
			Violation:	General Conditions - Clearance of storage 24" below ceiling	Abate by: 06/18/2025
			Violation:	Means of egress-Test on emergency lighting and	Abate by: 06/18/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 06

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
				exit sign	
			Violation:	Exit, Exit Access, and Exit Discharge must be free of obstructions, and continiously maintained.	Abate by: 06/18/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 06/18/2025
			Violation:	Means of Egress - Must be Free from Obstruction	Abate by: 06/18/2025 CV
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/18/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 06/18/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 06/18/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/18/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 06/18/2025
06/08/2025		0511K	T	Garden Shabu	1 Valley Road
06/29/2025		0511K	O	Garden Shabu	1 Valley Road
07/08/2025	07/23/2025	0511K	R	Garden Shabu	1 Valley Road
			Violation:	Fire protection-Test on fire alarm	Abate by: 06/18/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/18/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 06/18/2025
05/05/2025	05/20/2025	0416K	P	Meadowlands family Success Center	100 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/20/2025
			Violation:	Means of egress-Test on emergency lighting and exit sign	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
			Violation:	Fire Extinguishers - Outdated or discharged	Abate by: 05/20/2025
			Violation:	General Conditions - Accumulation of combustibile materials	Abate by: 05/20/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 05/20/2025
			Violation:	Electrical - Open electrical junction boxes	Abate by: 05/20/2025
06/06/2025		0416K	T	Meadowlands family Success Center	100 Washington Ave
06/02/2025	06/17/2025	0416K	R	Meadowlands family Success Center	100 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 05/20/2025
06/06/2025		0416K	R	Meadowlands family Success Center	100 Washington Ave
06/16/2025		0416K	O	Meadowlands family Success Center	100 Washington Ave
05/05/2025	05/20/2025	0417	P	Bible House	105 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025
06/02/2025	06/17/2025	0417	R	Bible House	105 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 07

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
06/19/2025	07/04/2025	0417	R	Bible House	105 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025
07/06/2025	07/21/2025	0417	R	Bible House	105 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025
08/16/2025	08/31/2025	0417	R	Bible House	105 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 05/20/2025
04/03/2025	04/18/2025	0799	P	Hans Chicken	107 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/18/2025
			Violation:	Cooking Areas - Kitchen Exhaust Hood Cleaning Required	Abate by: 04/18/2025
			Violation:	Excessive grease building up must be removed from all surfaces.	Abate by: 04/18/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 04/18/2025
			Violation:	Electrical - Multi plug adapters	Abate by: 04/18/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 04/18/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 04/18/2025
04/25/2025	05/10/2025	0799	R	Hans Chicken	107 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/18/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 04/18/2025
05/12/2025	05/27/2025	0799	R	Hans Chicken	107 Washington Ave
			Violation:	Fire Service Features - Knox box required	Abate by: 04/18/2025
05/14/2025		0799	T	Hans Chicken	107 Washington Ave
06/02/2025	07/02/2025	0799	R	Hans Chicken	107 Washington Ave
			Violation:	Fire Service Features - Knox box required	Abate by: 04/18/2025
07/22/2025	08/06/2025	0799	R	Hans Chicken	107 Washington Ave
			Violation:	Fire Service Features - Knox box required	Abate by: 04/18/2025
08/07/2025	08/22/2025	0799	R	Hans Chicken	107 Washington Ave
02/28/2025	03/15/2025	0419	R	Multiple Dwelling	121 Washington Ave
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/23/2024
			Violation:	Fire Protection System - Maintenance	Abate by: 12/23/2024
			Violation:	It shall be unlawful to tamper with fire protection systems.	Abate by: 12/23/2024

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/27/2025	04/08/2025	0419	R	Multiple Dwelling	121 Washington Ave
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/23/2024
			Violation:	Fire Protection System - Maintenance	Abate by: 12/23/2024
			Violation:	It shall be unlawful to tamper with fire protection systems.	Abate by: 12/23/2024
05/12/2025	05/27/2025	0419	R	Multiple Dwelling	121 Washington Ave
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/23/2024
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 12/23/2024
			Violation:	Fire Protection System - Maintenance	Abate by: 12/23/2024
			Violation:	It shall be unlawful to tamper with fire protection systems.	Abate by: 12/23/2024
05/12/2025		0419	O	Multiple Dwelling	121 Washington Ave
06/18/2025		0419	T	Multiple Dwelling	121 Washington Ave
07/25/2025		0425K	T	Candy Restaurant and Deli	147 Washington Ave
03/31/2025	04/15/2025	0427K	P	147 Washington Ave Building Inspection	147 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
			Violation:	Fire protection-Test on fire alarm	Abate by: 04/15/2025
05/11/2025		0427K	O	147 Washington Ave Building Inspection	147 Washington Ave
05/11/2025	05/26/2025	0427K	R	147 Washington Ave Building Inspection	147 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
07/07/2025	07/22/2025	0427K	R	147 Washington Ave Building Inspection	147 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 04/15/2025
07/17/2025	08/01/2025	0427K	R	147 Washington Ave Building Inspection	147 Washington Ave
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 08/01/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 08/01/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 08/01/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 09

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address	
08/04/2025		0427K	T	147 Washington Ave Building Inspection	147 Washington Ave	
08/04/2025		0427K	T	147 Washington Ave Building Inspection	147 Washington Ave	
03/10/2025	03/25/2025	0430K	R	Whiskey Roads	152 Washington Ave	
				Violation: Fire protection-Test on fire alarm	Abate by: 12/24/2024	CV
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/24/2024	
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/24/2024	
				Violation: Electrical - Extension cords	Abate by: 12/24/2024	
				Violation: General Conditions - General Conditions	Abate by: 12/24/2024	CV
				Contributing to fire		
				Violation: Electrical - Unused electrical	Abate by: 12/24/2024	
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 12/24/2024	
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 12/24/2024	
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 12/24/2024	
				Violation: General Conditions - General Conditions	Abate by: 12/24/2024	
				Contributing to fire		
				Violation: Electrical - Extension cords	Abate by: 12/24/2024	
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 12/24/2024	
05/12/2025	05/27/2025	0430K	R	Whiskey Roads	152 Washington Ave	
				Violation: Fire protection-Test on fire alarm	Abate by: 12/24/2024	CV
				Violation: Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/24/2024	
				Violation: After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 12/24/2024	
				Violation: Electrical - Extension cords	Abate by: 12/24/2024	
				Violation: General Conditions - General Conditions	Abate by: 12/24/2024	CV
				Contributing to fire		
				Violation: Electrical - Unused electrical	Abate by: 12/24/2024	
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 12/24/2024	
				Violation: General Conditions - Securing of compressed gas containers	Abate by: 12/24/2024	
				Violation: General Conditions - Accumulation of combustible materials	Abate by: 12/24/2024	
				Violation: General Conditions - General Conditions	Abate by: 12/24/2024	
				Contributing to fire		
				Violation: Electrical - Extension cords	Abate by: 12/24/2024	
				Violation: Means of egress-Test on emergency lighting and exit sign	Abate by: 12/24/2024	
05/30/2025		0430K	O	Whiskey Roads	152 Washington Ave	
06/08/2025		0553K	T	Torino's Pizzeria	153 Washington Ave	
07/18/2025		0437	P	VACANT AS OF 07/18/2025	209 Washington Ave	

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 10

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
08/18/2025	09/02/2025	0438	P	Multiple Dwelling	209 Washington Ave
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 09/02/2025
				Violation: Utility shut off's shall be clearly labeled.	Abate by: 09/02/2025
				Violation: Self closing doors require maintenance/ proof of operation.	Abate by: 09/02/2025
				Violation: Fire protection - Maintenance on smoke detectors	Abate by: 09/02/2025
03/10/2025	03/25/2025	0165	P	Washington Square	213 Washington Ave
				Violation: Business address (including unit number) must be clearly labeled on building.	Abate by: 03/25/2025
				Violation: Fire Zone Required by Fire Official	Abate by: 03/25/2025
				Violation: Red light required over Fire Department Connection	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
				Violation: Fire Service Features - Knox box required	Abate by: 03/25/2025
				Violation: Sprinkler system testing and maintenance required.	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
03/17/2025		0165	O	Washington Square	213 Washington Ave
04/14/2025		0165	O	Washington Square	213 Washington Ave
07/16/2025	07/31/2025	0165	R	Washington Square	213 Washington Ave
				Violation: Business address (including unit number) must be clearly labeled on building.	Abate by: 03/25/2025
				Violation: Fire Zone Required by Fire Official	Abate by: 03/25/2025
				Violation: Red light required over Fire Department Connection	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
				Violation: Fire Service Features - Knox box required	Abate by: 03/25/2025
				Violation: Sprinkler system testing and maintenance required.	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
08/07/2025	08/22/2025	0165	R	Washington Square	213 Washington Ave
				Violation: Fire Service Features - Knox box required	Abate by: 03/25/2025
				Violation: Sprinkler system testing and maintenance required.	Abate by: 03/25/2025
				Violation: General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
03/05/2025	03/20/2025	0168	R	Nikki's Bar & Grill LLC	213 Washington Ave
				Violation: Fire Service Features - Knox box required	Abate by: 01/14/2024
				Violation: Life Hazard Usage Fees Past Due	Abate by: 01/14/2024
				Violation: Fire protection-Test on fire alarm	Abate by: 01/14/2024
				Violation: Cooking Areas - Kitchen Exhaust Hood	Abate by: 01/14/2024
				Violation: Electrical - Improper electrical	Abate by: 01/14/2024
05/12/2025	05/27/2025	0168	R	Nikki's Bar & Grill LLC	213 Washington Ave
				Violation: Fire Service Features - Knox box required	Abate by: 01/14/2024
				Violation: Life Hazard Usage Fees Past Due	Abate by: 01/14/2024
				Violation: Fire protection-Test on fire alarm	Abate by: 01/14/2024

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 11

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
02/28/2025	03/15/2025	0454K	C	Building Inspection	216 Washington Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 03/15/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/15/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/15/2025
			Violation:	Provide copy of repair receipt when the repair is completed.	Abate by: 03/15/2025
03/22/2025	04/06/2025	0454K	F	Building Inspection	216 Washington Ave
			Violation:	Fire Protection System - Maintenance	Abate by: 03/15/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/15/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 03/15/2025
			Violation:	Provide copy of repair receipt when the repair is completed.	Abate by: 03/15/2025
07/01/2025	07/16/2025	0454K	P	Building Inspection	216 Washington Ave
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/16/2025
07/11/2025	07/26/2025	0454K	R	Building Inspection	216 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/26/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 07/26/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/26/2025
07/20/2025	07/21/2025	0454K	C	Building Inspection	216 Washington Ave
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 07/21/2025
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 07/21/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/21/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 07/21/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/21/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/21/2025
07/29/2025	08/13/2025	0454K	R	Building Inspection	216 Washington Ave
			Violation:	Fire protection-Test on fire alarm	Abate by: 07/26/2025
			Violation:	Utility shut off's shall be clearly labeled.	Abate by: 07/26/2025
			Violation:	Self closing doors require maintenance/ proof of operation.	Abate by: 07/26/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/26/2025

Little Ferry
Condensed Inspection Reports
02/22/2025 to 08/22/2025
Printed: 08/22/2025 Page: 12

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
07/29/2025	08/13/2025	0454K	F	Building Inspection	216 Washington Ave
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 07/21/2025
			Violation:	Deficiencies noted on fire alarm test report must be repaired.	Abate by: 07/21/2025
			Violation:	Fire protection-Carbon monoxide alarm or detectors must be maintained	Abate by: 07/21/2025
			Violation:	Prior to working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/21/2025
			Violation:	After working on any fire protection system the contractor must notify the police desk 2016412770	Abate by: 07/21/2025
08/01/2025		0454K	O	Building Inspection	216 Washington Ave
07/22/2025	08/06/2025	1023	P	O'Brien's Construction	147 Washington Ave Rear
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/06/2025
08/04/2025		1023	O	O'Brien's Construction	147 Washington Ave Rear
08/08/2025	08/23/2025	1023	R	O'Brien's Construction	147 Washington Ave Rear
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 08/06/2025
07/01/2025	07/16/2025	0455K	P	Allstate	216 Washington Ave Unit 1
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/16/2025
07/11/2025		0455K	R	Allstate	216 Washington Ave Unit 1
08/01/2025		0455K	O	Allstate	216 Washington Ave Unit 1
07/01/2025		1019	B	Joie's World LLC.	216 Washington Ave Unit 2
07/01/2025	07/16/2025	1019	P	Joie's World LLC.	216 Washington Ave Unit 2
			Violation:	Fire Prevention requires access to the property to perform a fire inspection	Abate by: 07/16/2025
			Violation:	Fire Service Features - Knox box required	Abate by: 07/16/2025
07/11/2025		1019	R	Joie's World LLC.	216 Washington Ave Unit 2
02/27/2025	03/14/2025	0908	R	At that Space LLC	213 Washington Ave Unit A
			Violation:	Fire prevention is required to gain access to building for fire inspection.	Abate by: 07/26/2024
03/10/2025	03/25/2025	0908	R	At that Space LLC	213 Washington Ave Unit A
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
			Violation:	General Conditions - General Conditions Contributing to fire	Abate by: 03/25/2025
			Violation:	Fire & Smoke protection - Maintain fire rated construction	Abate by: 03/25/2025

-----Dates-----

Insp.	Due	Local	Type	Property name	Property address
03/17/2025		0908	R	At that Space LLC	213 Washington Ave Unit A
03/18/2025		0908	B	At that Space LLC	213 Washington Ave Unit A