

Juris	EnteredDate	Category	Action	ViolationCode	Priority	Status	StatusDate	Occupancy
HC	04/14/2026		No more than 20% combustible material on walls	N.J.A.C. 5:70-3, SECTION 314		Unabated	05/14/2026	314 Essex St
HC	04/20/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	05/20/2026	411 Hackensack Ave, 8TH FLR 805
HC	03/11/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	04/10/2026	215.5 Main St, 1
HC	04/14/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/14/2026	855 Main St
HC	04/22/2026	Extinguishers	Fire extinguisher(s) discharged. Have replaced or serviced.	N.J.A.C. 5:70-3, 906.2		New	05/22/2026	64 Prospect Ave
HC	04/22/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/22/2026	64 Prospect Ave
HC	04/22/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/22/2026	64 Prospect Ave
HC	03/23/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/22/2026	215.5 Main St, 2nd Flr
HC	03/17/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/16/2026	21 Main St, 200 EAST WING
HC	03/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/25/2026	40 Burlews Ct, 2
HC	03/03/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/02/2026	390 Hackensack Ave, 143A

HC	03/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/07/2026	123 Main St
HC	04/10/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/10/2026	193 Main St
HC	03/05/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/04/2026	333 Main St
HC	03/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/05/2026	343 S River St
HC	03/09/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/08/2026	20 Wysocki Pl
HC	03/10/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/09/2026	310 Railroad Ave
HC	03/04/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/03/2026	211 Essex St,106
HC	03/12/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/11/2026	15 Conklin Pl,Sch
HC	03/13/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/12/2026	277 Prospect Ave,Building
HC	03/10/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/09/2026	370 W Pleasantview Ave,2
HC	03/03/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/02/2026	140 Prospect Ave
HC	03/19/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/18/2026	40 Passaic St,1st Flr
HC	03/19/2026	Extinguishers	Fire extinguisher(s) discharged. Have replaced or serviced.	N.J.A.C. 5:70-3, 906.2		Abated	03/19/2026	390 Hackensack Ave,155

HC	03/05/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/04/2026	310 Hudson St,2A
HC	03/25/2026	Extinguishers	Clean agent fire extinguishing systems shall be tested as per NFPA 2001. Submit results to HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.5		New	04/24/2026	142 John St,2nd Flr
HC	03/19/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/18/2026	10 E Moonachie Rd
HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/24/2026	171 Lexington Ave
HC	03/04/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	03/26/2026	5 Linden St
HC	03/04/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	03/26/2026	5 Linden St
HC	03/12/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	03/19/2026	145 Main St,B
HC	04/22/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/22/2026	235 Main St Suite 102
HC	03/03/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	04/02/2026	14 E Camden St
HC	03/05/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	04/04/2026	12 E Mercer St
HC	04/27/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/27/2026	277 Lodi St,9

HC	04/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/21/2026	411 Hackensack Ave,1006
HC	04/28/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/28/2026	175 Lexington Ave,A
HC	03/11/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/10/2026	171 S River St
HC	04/29/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/29/2026	100 Essex St
HC	04/29/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	05/29/2026	85 Zabriskie St,Rear
HC	05/01/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	05/31/2026	205 State St,Police
HC	03/19/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/18/2026	390 Hackensack Ave,212
HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/24/2026	382 Main St,2nd Flr Rear
HC	03/25/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Unabated	04/24/2026	382 Main St,2nd Flr Rear
HC	05/04/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/03/2026	360 River St
HC	03/06/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	05/05/2026	26 Johnson Ave

HC	05/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/05/2026	515 Essex St
HC	05/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/05/2026	175 Terrace Pl
HC	04/23/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/06/2026	45 Essex St,201
HC	05/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/05/2026	450 Hackensack Ave,17
HC	05/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/06/2026	127 Hudson St
HC	05/07/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	06/06/2026	80 Hobart St
HC	05/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/06/2026	40 Jefferson St,BLDG
HC	05/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/06/2026	450 Hackensack Ave,3
HC	05/07/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	06/06/2026	450 Hackensack Ave,3
HC	05/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/06/2026	246 Main St
HC	05/07/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	06/06/2026	246 Main St

HC	04/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/06/2026	401 Hackensack Ave,503
HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/24/2026	401 Hackensack Ave,LL
HC	04/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/07/2026	2-4 Prospect Ave
HC	04/07/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/07/2026	6-8 Prospect Ave
HC	05/11/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/10/2026	77 Anderson St,2
HC	04/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/06/2026	401 Hackensack Ave,4TH FLR
HC	03/11/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/14/2026	141 Main St,B
HC	03/11/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	04/14/2026	141 Main St,B
HC	05/12/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/11/2026	34 George St
HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/24/2026	411 Hackensack Ave,6TH FLR 602-603
HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/24/2026	433 Hackensack Ave,L104
HC	03/31/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/30/2026	687 Main St

HC	04/01/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/01/2026	157 Hobart St
HC	04/10/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/13/2026	123 Sussex St
HC	03/17/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/16/2026	90 Main St,205
HC	05/13/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/12/2026	90 Hackensack Ave,Shop
HC	03/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/13/2026	219 Sussex St
HC	03/26/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	05/13/2026	219 Sussex St
HC	04/01/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/01/2026	370 W Pleasantview Ave,14A
HC	05/14/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/13/2026	145 Lodi St
HC	03/11/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	04/10/2026	390 Hackensack Ave,245A
HC	05/14/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/13/2026	183 Main St
HC	05/11/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	06/10/2026	61 Grove St

HC	03/25/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Withdrawn	04/24/2026	540 Main St
HC	04/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/06/2026	78 Lawrence St
HC	04/14/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/14/2026	200 Passaic St,FLR 3
HC	04/16/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	05/16/2026	100 Commerce Way,3
HC	03/31/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/30/2026	106 S State St
HC	05/20/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/19/2026	45 Hudson St
HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	214 Main St,A
HC	05/21/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	06/20/2026	172 Johnson Ave
HC	04/13/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/13/2026	339 Main St
HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	389 Main St,1
HC	05/21/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		New	06/20/2026	389 Main St,1

HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	210 River St,12
HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	390 Hackensack Ave,147A
HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	390 Hackensack Ave,106
HC	05/21/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/20/2026	275 Main St
HC	04/22/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Unabated	05/22/2026	50 Main St,1
HC	05/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/25/2026	27 E Kennedy St
HC	05/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/25/2026	18 Dicarolis Ct
HC	05/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/25/2026	130 S State St,Gas
HC	05/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/25/2026	21 Main St,255
HC	05/26/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/25/2026	190 Moore St,400
HC	04/20/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/20/2026	189 Central Ave,2nd flr
HC	04/21/2026	Extinguishers	Fire extinguisher(s) discharged. Have replaced or serviced.	N.J.A.C. 5:70-3, 906.2		Unabated	05/21/2026	183 Bloom St

HC	04/16/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/19/2026	3 Banta Pl
HC	04/16/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Unabated	05/16/2026	3 Banta Pl
HC	04/20/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	05/20/2026	500 S River St,1
HC	05/27/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/26/2026	274 State St
HC	05/27/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/26/2026	50 Johnson Ave,1
HC	04/23/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	05/21/2026	218 Main St,4TH FLR
HC	04/02/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Unabated	05/02/2026	288B Main St
HC	04/02/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	05/02/2026	288B Main St
HC	05/28/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	06/27/2026	336 Main St
HC	03/20/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/19/2026	1 State St
HC	04/14/2026	Extinguishers	Fire extinguisher(s) discharged. Have replaced or serviced.	N.J.A.C. 5:70-3, 906.2		Abated	05/14/2026	110 Anderson St
HC	03/23/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/29/2026	205 Essex St,REAR

HC	03/23/2026	Extinguishers	Fire extinguisher(s) need to be mounted in a visible location for occupant access, Extinguishers shall be immediately available for use. Locate extinguisher(s) near exit(s), mounted at 42 inches to neck with approved hardware.	N.J.A.C. 5:70-3, 906.5		Abated	04/29/2026	205 Essex St, REAR
HC	03/17/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	04/17/2026	78 Johnson Ave
HC	04/06/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Abated	06/01/2026	260 Hudson St
HC	03/04/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		Unabated	04/03/2026	411 Hackensack Ave, 1003
HC	06/02/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	07/02/2026	259 Main St
HC	06/02/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	07/02/2026	199 Lee Pl
HC	06/03/2026	Extinguishers	Fire extinguisher(s) shall be inspected and tested in accordance with NFPA 10, Current certification expired.	N.J.A.C. 5:70-3, 906.2		New	07/03/2026	263 S River St, 2
HC	06/03/2026	Stairs & Doors	Sliding and rolling fire doors shall be maintained, tested and inspected.	N.J.A.C. 5:70-3, 103.2		New	07/03/2026	450 Hackensack Ave, 1
HC	03/17/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		Abated	04/16/2026	78 Johnson Ave
HC	04/27/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		Abated	05/28/2026	206 Central Ave
HC	04/27/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	05/28/2026	206 Central Ave
HC	05/01/2026	Stairs & Doors	Approved self-closing devices shall be maintained, Do Not Chock Open Fire Door.	N.J.A.C. 5:70-3, 705.2.3		Abated	05/31/2026	43 Maple Ave
HC	05/27/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	06/26/2026	50 Johnson Ave, 1
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave, Building

HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/28/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/27/2026	125 Prospect Ave,Building
HC	05/27/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	06/26/2026	274 State St
HC	04/02/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	05/02/2026	15 Salem St,1
HC	05/22/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/21/2026	260 Union St,1
HC	05/21/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	06/20/2026	390 Hackensack Ave,106
HC	04/15/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	05/15/2026	335 Union St
HC	05/18/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	04/21/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		Abated	05/21/2026	231 Midtown Pl
HC	03/06/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		Abated	04/20/2026	390 Hackensack Ave,L/L
HC	05/08/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	06/07/2026	50 Second St
HC	03/04/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		Abated	04/03/2026	336 Prospect Ave
HC	03/31/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	04/30/2026	85 Atlantic St
HC	05/12/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	05/12/2026	382 Main St,1

HC	05/12/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		New	06/11/2026	481 Hackensack Ave
HC	05/07/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	06/06/2026	211 S Newman St
HC	04/07/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		Abated	05/07/2026	2-4 Prospect Ave
HC	04/09/2026	Stairs & Doors	Approved self-closing devices shall be maintained, Do Not Chock Open Fire Door.	N.J.A.C. 5:70-3, 705.2.3		Abated	05/07/2026	67 S Prospect Ave
HC	05/07/2026	Stairs & Doors	Approved self-closing devices shall be maintained, Do Not Chock Open Fire Door.	N.J.A.C. 5:70-3, 705.2.3		New	06/06/2026	40 Jefferson St,BLDG
HC	04/27/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		Unabated	05/27/2026	20 Jefferson St
HC	05/06/2026	Stairs & Doors	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 315.3.2		New	06/05/2026	175 Terrace Pl
HC	03/09/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	04/08/2026	221 Main St,2nd & 3rd Flr
HC	04/10/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		Unabated	05/10/2026	92 Second St,Building
HC	04/07/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	05/07/2026	204 Railroad Ave
HC	04/01/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Stairs & Doors	Approved self-closing devices shall be maintained, Do Not Chock Open Fire Door.	N.J.A.C. 5:70-3, 705.2.3		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	05/01/2026	360 Union St
HC	04/01/2026	Stairs & Doors	The means of egress shall be maintained in a safe condition.	N.J.A.C. 5:70-3, 1003.1.1		New	05/01/2026	360 Union St
HC	04/17/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	05/04/2026	25 E Salem St,Building
HC	04/22/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	05/22/2026	64 Prospect Ave
HC	04/02/2026	Stairs & Doors	Approved self-closing devices shall be maintained, Do Not Chock Open Fire Door.	N.J.A.C. 5:70-3, 705.2.3		Abated	05/02/2026	52 First St
HC	04/21/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	05/21/2026	70 Longview Ave

HC	04/21/2026	Stairs & Doors	All fire doors must close and latch, Repair or Replace fire doors.	N.J.A.C. 5:70-3, 705.2.4		New	05/21/2026	70 Longview Ave
HC	04/02/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/02/2026	52 First St
HC	04/21/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/21/2026	70 Longview Ave
HC	04/21/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/21/2026	70 Longview Ave
HC	03/17/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/17/2026	21 Main St,253
HC	03/17/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/16/2026	21 Main St,253
HC	03/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/25/2026	40 Burlews Ct,2
HC	03/03/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/02/2026	360 Essex St,3
HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/07/2026	204 Railroad Ave
HC	03/05/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/04/2026	333 Main St
HC	03/03/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	04/02/2026	140 Prospect Ave
HC	03/13/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	04/12/2026	277 Prospect Ave,Building
HC	03/12/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/11/2026	141 Main St,A
HC	03/19/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/31/2026	150 Hudson St
HC	03/19/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/31/2026	150 Hudson St
HC	03/19/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/31/2026	150 Hudson St
HC	03/04/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/26/2026	5 Linden St

HC	03/04/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/26/2026	5 Linden St
HC	03/04/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/26/2026	5 Linden St
HC	03/24/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	03/25/2026	278 River St
HC	03/25/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	04/24/2026	142 John St,2nd Flr
HC	03/10/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/26/2026	300 S Summit Ave
HC	03/16/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	03/24/2026	70 Hackensack Ave
HC	03/05/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/04/2026	310 Hudson St,2A
HC	03/04/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	04/03/2026	390 Hackensack Ave,146B
HC	03/19/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	04/18/2026	40 Passaic St,1st Flr
HC	03/19/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	03/19/2026	390 Hackensack Ave,155
HC	05/06/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/05/2026	515 Essex St
HC	03/05/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/13/2026	125 Main St
HC	04/14/2026	Emergency Lighting	Exit signs shall be illuminated at all times	N.J.A.C. 5:70-3, 1013.1		Abated	05/14/2026	3 University Plz,1ST FLOOR
HC	04/30/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/30/2026	155 Poor St
HC	05/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/06/2026	80 Hobart St
HC	04/09/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/07/2026	67 S Prospect Ave
HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/07/2026	6-8 Prospect Ave

HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/07/2026	2-4 Prospect Ave
HC	04/07/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/07/2026	6-8 Prospect Ave
HC	04/06/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/06/2026	401 Hackensack Ave,503
HC	05/01/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/31/2026	225 State St
HC	03/25/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/30/2026	110 Commerce Way
HC	05/01/2026	Emergency Lighting	Exit signs shall be illuminated at all times	N.J.A.C. 5:70-3, 1013.1		New	05/31/2026	65 Central Ave
HC	04/29/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/29/2026	82 Temple Ave
HC	04/29/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/29/2026	82 Temple Ave
HC	04/30/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Unabated	05/30/2026	171 S Newman St, UNIT B
HC	04/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/22/2026	294-298 State St,1
HC	03/03/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/02/2026	390 Hackensack Ave,259B
HC	04/13/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Unabated	05/13/2026	215 Union St
HC	03/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/10/2026	171 S River St
HC	04/29/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/29/2026	100 Essex St
HC	04/02/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/02/2026	189 Central Ave,1st flr
HC	03/05/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	04/04/2026	774 Main St,BLDG
HC	03/12/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/16/2026	171 Main St,302

HC	03/05/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/04/2026	12 E Mercer St
HC	03/23/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/22/2026	240 Prospect Ave 1
HC	03/23/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	04/22/2026	240 Prospect Ave 1
HC	03/23/2026	Emergency Lighting	Exit signs shall be maintained as installed.	N.J.A.C. 5:70-3, 1013.1		Unabated	04/22/2026	240 Prospect Ave 1
HC	03/09/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/08/2026	110 Hobart St
HC	04/01/2026	Emergency Lighting	Exit signs shall be maintained as installed.	N.J.A.C. 5:70-3, 1013.1		Abated	05/01/2026	81 Hobart St
HC	03/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/13/2026	219 Sussex St
HC	05/14/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/13/2026	5 Pangborn Pl
HC	05/14/2026	Emergency Lighting	Exit signs shall be maintained as installed.	N.J.A.C. 5:70-3, 1013.1		New	06/13/2026	150 Atlantic St,2
HC	05/14/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/13/2026	150 Atlantic St,2
HC	03/25/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/24/2026	450 Hackensack Ave,24
HC	03/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/25/2026	100 Commerce Way,2
HC	05/12/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/11/2026	92 Summit Ave
HC	05/12/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/11/2026	481 Hackensack Ave
HC	05/12/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/11/2026	34 George St
HC	05/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/10/2026	77 Anderson St,2
HC	03/04/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/03/2026	185 Kenneth St
HC	03/19/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/18/2026	454 Passaic St

HC	03/06/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	04/20/2026	390 Hackensack Ave,L/L
HC	05/15/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/14/2026	390 Hackensack Ave,274
HC	05/14/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/13/2026	104 Johnson Ave,BLDG
HC	03/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/10/2026	390 Hackensack Ave,245A
HC	05/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	06/10/2026	241 Hudson St
HC	05/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	06/10/2026	241 Hudson St
HC	04/20/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	05/20/2026	135 English St
HC	04/06/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/06/2026	78 Lawrence St
HC	05/18/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	04/29/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/15/2026	1 University Plz,307
HC	04/16/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/19/2026	100 Commerce Way,3
HC	04/16/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/19/2026	100 Commerce Way,3
HC	04/16/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/19/2026	100 Commerce Way,3
HC	04/15/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/15/2026	335 Union St
HC	04/15/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/15/2026	335 Union St
HC	04/28/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Unabated	05/28/2026	281 Park St

HC	04/14/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/14/2026	200 Passaic St,FLR 3
HC	04/28/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Unabated	05/28/2026	281 Park St
HC	05/21/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/20/2026	390 Hackensack Ave,106
HC	05/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/21/2026	420 Passaic St
HC	05/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/21/2026	420 Passaic St
HC	05/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/21/2026	420 Passaic St
HC	05/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/21/2026	420 Passaic St
HC	03/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/29/2026	500 S River St,21
HC	05/21/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/20/2026	275 Main St
HC	04/20/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/20/2026	140 Prospect Ave,17
HC	05/21/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/20/2026	172 Johnson Ave
HC	05/20/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	06/19/2026	95 Anderson St
HC	05/20/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/19/2026	75 Atlantic St
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	27 E Kennedy St
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	18 Dicarolis Ct
HC	03/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/10/2026	87 Summit Ave,1st Flr
HC	03/11/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	04/10/2026	87 Summit Ave,1st Flr
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	170 Sussex St,Hall
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	170 Sussex St,Hall

HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	170 Sussex St,Hall
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	21 Main St,255
HC	04/22/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/26/2026	176 Summit Ave
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	300 Hudson St
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	300 Hudson St
HC	05/26/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/25/2026	5 Summit Ave,204
HC	04/29/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	05/21/2026	500 S River St,22
HC	04/29/2026	Emergency Lighting	Exit signs shall be illuminated at all times	N.J.A.C. 5:70-3, 1013.1		Unabated	05/29/2026	500 S River St,22
HC	04/29/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Withdrawn	05/29/2026	500 S River St,22
HC	05/27/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/26/2026	274 State St
HC	04/24/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	05/24/2026	685 Main St
HC	04/02/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/27/2026	15 Salem St,1
HC	04/23/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Unabated	05/23/2026	137.5 Main St
HC	05/27/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/26/2026	1 University Plz,402
HC	05/27/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/26/2026	274 State St
HC	05/01/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		Abated	05/31/2026	43 Maple Ave
HC	05/28/2026	Emergency Lighting	Exit signs shall be illuminated at all times	N.J.A.C. 5:70-3, 1013.1		New	06/27/2026	336 Main St
HC	05/28/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		New	06/27/2026	336 Main St
HC	06/01/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	06/01/2026	390 Hackensack Ave,70

HC	06/03/2026	Emergency Lighting	Annual emergency/exit lighting annual test is required. Submit documentation of completion of 1 hour test.	N.J.A.C. 5:70-3, 1031.10.2		New	07/03/2026	450 Hackensack Ave,1
HC	04/13/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/14/2026	385 Prospect Ave,312
HC	04/13/2026	Emergency Lighting	Repair exit/emergency light fixture to illuminate when test button is pressed.	N.J.A.C. 5:70-3, 1031.10		Abated	05/13/2026	385 Prospect Ave,312
HC	06/03/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	07/03/2026	450 Hackensack Ave,1
HC	04/16/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Abated	05/20/2026	1 State St
HC	03/17/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Abated	04/16/2026	78 Johnson Ave
HC	03/17/2026	Compressed Gases	CO2 Detection systems shall be tested and certified at least annually. Forward results of last annual test. HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 5003.2.9.1		Abated	04/28/2026	78 Johnson Ave
HC	04/06/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Unabated	05/06/2026	260 Hudson St
HC	06/02/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	07/02/2026	51 Cleveland St
HC	03/25/2026	Compressed Gases	CO2 Detection systems shall be tested and certified at least annually. Forward results of last annual test. HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 5003.2.9.1		Abated	04/29/2026	540 Main St
HC	05/14/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/12/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	06/11/2026	16 Marion St,2
HC	05/12/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	06/11/2026	450 Hackensack Ave,14
HC	04/01/2026	Compressed Gases	CO2 Detection systems shall be tested and certified at least annually. Forward results of last annual test. HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 5003.2.9.1		Unabated	05/01/2026	290 Polifly Rd
HC	04/27/2026	Compressed Gases	LP Compressed gas cylinder exchange cabinets shall not be within 5 feet of any exterior building opening. Relocate cabinet.	N.J.A.C. 5:70-3, 6109.12		New	05/27/2026	150 Hobart St

HC	04/28/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	05/28/2026	175 Lexington Ave,A
HC	03/24/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Unabated	04/23/2026	30 Newman St
HC	05/04/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	06/03/2026	283 Main St
HC	05/07/2026	Compressed Gases	CO2 Detection systems shall be tested and certified at least annually. Forward results of last annual test. HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 5003.2.9.1		New	06/06/2026	450 Hackensack Ave,3
HC	05/07/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	06/06/2026	80 Hobart St
HC	05/07/2026	Compressed Gases	Compressed gas containers, cylinders, tanks and systems that could be exposed to physical damage from vehicles shall be protected by guard posts. Install same.	N.J.A.C. 5:70-3, 5303.5.2		New	06/06/2026	80 Hobart St
HC	03/27/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	04/26/2026	30 Prospect Ave,12
HC	03/27/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	04/26/2026	30 Prospect Ave,12
HC	03/27/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	04/26/2026	30 Prospect Ave,12
HC	03/27/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		New	04/26/2026	30 Prospect Ave,12
HC	03/24/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Abated	04/23/2026	53 E Camden St
HC	03/17/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Unabated	04/01/2026	180 Hackensack Ave
HC	03/11/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Abated	04/10/2026	133 Commerce Way
HC	04/10/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Unabated	05/10/2026	92 Second St,Building
HC	04/09/2026	Compressed Gases	CO2 Detection systems shall be tested and certified at least annually. Forward results of last annual test. HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 5003.2.9.1		New	05/09/2026	341 Essex St
HC	04/10/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Unabated	05/10/2026	92 Second St,Building

HC	03/09/2026	Compressed Gases	Compressed gas cylinders must be secured, restrain with chain to wall or enclose in cage or vented cabinet.	N.J.A.C. 5:70-3, 5303.5.3		Abated	04/08/2026	294-298 State St,1-2A
HC	04/14/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/14/2026	575 Main St,2
HC	04/14/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/14/2026	116 Kansas St,1st Flr
HC	03/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/10/2026	190 Moore St,Building
HC	03/04/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/03/2026	212 Prospect Ave
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/03/2026	212 Prospect Ave
HC	03/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/08/2026	160 Hobart St
HC	03/23/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/13/2026	215.5 Main St,2nd Flr
HC	03/23/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/22/2026	215.5 Main St,2nd Flr
HC	04/09/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/09/2026	25 Kansas St
HC	03/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		Abated	04/10/2026	68 Summit Ave,1st Flr

			HFD FP@Hackensack.org Indicate which inspector is requesting the document.					
HC	04/09/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	05/09/2026	450 Hackensack Ave,20
HC	04/14/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		Abated	05/14/2026	855 Main St
HC	04/14/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/14/2026	855 Main St
HC	04/20/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/20/2026	411 Hackensack Ave,Building
HC	04/15/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/20/2026	417 Main St
HC	04/16/2026	Alarm System	Fire Watch Ordered. Building rep to maintain fire watch in areas where alarm/sprinkler is impaired. Fax log with entries every 30 min to FD at 201-646-7594. Watch is only terminated with permission of the Fire Official.	N.J.A.C. 5:70-3, 901.7		Abated	04/20/2026	417 Main St
HC	04/16/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/16/2026	417 Main St
HC	04/02/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/02/2026	52 First St
HC	03/23/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/22/2026	240 Prospect Ave 1
HC	04/10/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/10/2026	92 Second St,Building
HC	04/10/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/10/2026	92 Second St,Building

HC	04/10/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	05/10/2026	92 Second St,Building
HC	03/16/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	04/15/2026	171 Atlantic St
HC	03/16/2026	Alarm System	Fire Watch Ordered. Building rep to maintain fire watch in areas where alarm/sprinkler is impaired. Fax log with entries every 30 min to FD at 201-646-7594. Watch is only terminated with permission of the Fire Official.	N.J.A.C. 5:70-3, 901.7		Unabated	04/15/2026	171 Atlantic St
HC	03/24/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/23/2026	161 Union St
HC	03/24/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/23/2026	161 Union St
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/14/2026	142 John St,3rd Flr
HC	04/02/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/09/2026	341 Essex St
HC	04/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/09/2026	341 Essex St
HC	04/06/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/06/2026	139 Hudson St,A
HC	04/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/07/2026	204 Railroad Ave
HC	03/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/25/2026	133 West St

HC	03/05/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/04/2026	64 Madison St
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/30/2026	191 Second St
HC	03/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/25/2026	139 Hudson St,A
HC	03/03/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/02/2026	390 Hackensack Ave,143A
HC	03/03/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/02/2026	360 Essex St,3
HC	04/01/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		New	04/16/2026	29 Shafer Pl
HC	04/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/01/2026	105 Grand Ave
HC	04/01/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/01/2026	360 Union St
HC	04/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/01/2026	360 Union St
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/03/2026	357 Prospect Ave
HC	04/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/01/2026	261 Maple Hill Dr

HC	04/01/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	05/01/2026	39 Euclid Ave
HC	03/12/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/11/2026	15 Conklin Pl,Sch
HC	03/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/08/2026	66 Jackson Ave
HC	03/09/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/08/2026	66 Jackson Ave
HC	03/13/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	04/12/2026	189 Main St
HC	03/13/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	04/12/2026	277 Prospect Ave,Building
HC	03/13/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/13/2026	277 Prospect Ave,Building
HC	03/09/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	04/08/2026	221 Main St,2nd & 3rd Flr
HC	03/10/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/09/2026	310 Railroad Ave
HC	03/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		New	04/08/2026	106 Hobart St

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	03/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/05/2026	66 Moore St
HC	03/06/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		New	04/05/2026	66 Moore St
HC	03/06/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	04/05/2026	66 Moore St
HC	03/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/08/2026	20 Wysocki Pl
HC	03/17/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	03/19/2026	180 Hackensack Ave
HC	03/19/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/18/2026	291 Second St
HC	03/19/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	04/18/2026	291 Second St
HC	03/19/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	04/18/2026	291 Second St
HC	03/19/2026	Alarm System	Repair Red/Blue light over Master Fire Box	N.J.A.C. 5:70-3, 108.1		New	04/18/2026	291 Second St
HC	03/03/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/02/2026	140 Prospect Ave
HC	03/10/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/09/2026	36 Railroad Ave

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	03/05/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/04/2026	84 Main St
HC	03/10/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/09/2026	370 W Pleasantview Ave,2
HC	03/11/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	03/17/2026	290 Third St
HC	03/17/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/16/2026	411 Hackensack Ave,10TH FLR 1005
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	04/17/2026	11 Berkshire Pl
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/17/2026	11 Berkshire Pl
HC	03/19/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	04/17/2026	90 Arcadia Rd
HC	03/19/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/17/2026	90 Arcadia Rd
HC	03/16/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	04/15/2026	30 Prospect Ave,12
HC	03/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/26/2026	170 Lexington Ave
HC	03/03/2026	Alarm System	Reinstate Central Station Monitoring, forward certificate of monitoring to Fire Prevention, HFD@Hackensack.org	N.J.A.C. 5:70-3, 108.1		Abated	03/05/2026	614 Main St

HC	03/19/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Abated	03/31/2026	150 Hudson St
HC	03/19/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/31/2026	150 Hudson St
HC	03/12/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/11/2026	145 Main St,B
HC	03/12/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	03/19/2026	145 Main St,B
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/31/2026	421 Jackson Ave
HC	03/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/26/2026	185 S Newman St
HC	03/27/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	04/26/2026	185 S Newman St
HC	03/27/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	04/26/2026	185 S Newman St
HC	03/26/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		New	04/25/2026	750 Main St
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/26/2026	5 Linden St
HC	03/19/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Withdrawn	04/18/2026	11 Atlantic St,2

HC	03/20/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	04/19/2026	11 Atlantic St
HC	03/20/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	04/19/2026	11 Atlantic St
HC	03/19/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	04/18/2026	40 Passaic St,1st Flr
HC	03/19/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/19/2026	390 Hackensack Ave,155
HC	03/13/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	03/23/2026	163 Central Ave
HC	03/13/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/12/2026	163 Central Ave
HC	03/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/16/2026	145 English St
HC	03/11/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	03/16/2026	145 English St
HC	03/17/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/16/2026	302 Union St,2ND FLR
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/05/2026	390 Hackensack Ave,146B
HC	03/25/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	04/24/2026	171 Lexington Ave

HC	05/07/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/06/2026	80 Hobart St
HC	05/07/2026	Alarm System	Replace missing Carbon Monoxide detector.	N.J.A.C. 5:70-3, 108.1		New	06/06/2026	450 Hackensack Ave,26
HC	05/07/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/06/2026	40 Jefferson St,BLDG
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/06/2026	40 Jefferson St,BLDG
HC	05/07/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		New	06/06/2026	127 Hudson St
HC	05/07/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	06/06/2026	127 Hudson St
HC	05/07/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/06/2026	80 Hobart St
HC	04/27/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Unabated	05/27/2026	20 Jefferson St
HC	04/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/06/2026	20 Jefferson St
HC	04/30/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/30/2026	155 Poor St

HC	05/06/2026	Alarm System	Reinstate Central Station Monitoring, forward certificate of monitoring to Fire Prevention, HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 108.1		Abated	06/05/2026	70 Anderson St
HC	03/05/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/04/2026	6 Grand Ave
HC	03/05/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/04/2026	6 Grand Ave
HC	04/20/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	05/20/2026	390 Hackensack Ave,50
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/05/2026	309 Essex St,1st Flr
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/06/2026	127 Hudson St
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	720 Summit Ave
HC	03/18/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/17/2026	720 Summit Ave
HC	03/05/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/13/2026	125 Main St
HC	03/05/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Void	04/04/2026	125 Main St

HC	03/05/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/13/2026	125 Main St
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/05/2026	140 Hobart St
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/05/2026	175 Terrace Pl
HC	05/04/2026	Alarm System	Fire Watch Ordered. Building rep to maintain fire watch in areas where alarm/sprinkler is impaired. Fax log with entries every 30 min to FD at 201-646-7594. Watch is only terminated with permission of the Fire Official.	N.J.A.C. 5:70-3, 901.7		Abated	05/06/2026	414 Hackensack Ave,1000
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/05/2026	450 Hackensack Ave,2
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/05/2026	206 S Park St
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	110 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	110 Arcadia Rd
HC	04/30/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/30/2026	400 River St
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		New	06/06/2026	246 Main St

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	05/07/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		New	06/06/2026	246 Main St
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	520 Essex St
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	520 Essex St
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/07/2026	60 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	60 Arcadia Rd
HC	03/18/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/17/2026	60 Arcadia Rd
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/06/2026	466 Hackensack Ave
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/05/2026	50 Passaic St,A
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	03/04/2026	185 Kenneth St
HC	04/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/07/2026	2-4 Prospect Ave

HC	04/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/07/2026	6-8 Prospect Ave
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/06/2026	450 Hackensack Ave,3
HC	05/07/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/06/2026	40 Jefferson St,BLDG
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	70 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	70 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	75 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	75 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	80 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	80 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	500 Essex St

			checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit					
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	500 Essex St
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	66 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	66 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	50 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	50 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	12 Berkshire Pl
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	12 Berkshire Pl
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	84 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	84 Arcadia Rd

HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	100 Arcadia Rd,OFFICE
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	100 Arcadia Rd,OFFICE
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	67 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	67 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	44 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	44 Arcadia Rd
HC	03/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/17/2026	105 Arcadia Rd
HC	03/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/17/2026	105 Arcadia Rd
HC	05/04/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/03/2026	320 Hamilton Pl
HC	05/04/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/03/2026	320 Hamilton Pl
HC	05/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		New	06/03/2026	277 Main St

			HFDFP@Hackensack.org Indicate which inspector is requesting the document.					
HC	05/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/03/2026	283 Main St
HC	05/04/2026	Alarm System	All Fire Protection systems shall be maintained in an operative condition at all times in accordance with the original installation standards for that system. Alterations require a permit from the building department.	N.J.A.C. 5:70-3, 901.4		New	06/03/2026	283 Main St
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/30/2026	100 S Main St
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/24/2026	110 Commerce Way
HC	05/01/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	05/31/2026	205 State St, Police
HC	05/01/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	05/31/2026	65 Central Ave
HC	04/30/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	05/30/2026	245 Central Ave
HC	05/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/31/2026	215 State St
HC	05/01/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Void	05/31/2026	215 State St
HC	05/01/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions.	N.J.A.C. 5:70-3, 901.6		Abated	05/01/2026	225 State St

			Repair/replace defective detector or replace missing detector.					
HC	05/01/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	05/31/2026	225 State St
HC	04/13/2026	Alarm System	Fire Watch Ordered. Building rep to maintain fire watch in areas where alarm/sprinkler is impaired. Fax log with entries every 30 min to FD at 201-646-7594. Watch is only terminated with permission of the Fire Official.	N.J.A.C. 5:70-3, 901.7		Unabated	05/13/2026	215 Union St
HC	03/24/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/29/2026	30 Newman St
HC	03/24/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/29/2026	30 Newman St
HC	04/13/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/16/2026	215 Union St
HC	04/13/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	05/13/2026	215 Union St
HC	04/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/28/2026	290 Vincent Ave,4th Flr
HC	04/30/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	05/30/2026	171 S Newman St, UNIT B
HC	04/30/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/30/2026	170 kenneth
HC	04/30/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/30/2026	171 S Newman St, UNIT B

HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	03/23/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/30/2026	493 Essex St
HC	04/28/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/30/2026	30 Shafer Pl
HC	04/28/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		Abated	04/30/2026	30 Shafer Pl
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	139 First St
HC	03/12/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/16/2026	171 Main St,302
HC	04/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/28/2026	28 Van Orden Pl

HC	03/20/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/19/2026	873 Main St
HC	03/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/10/2026	171 S River St
HC	03/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/28/2026	294-298 State St,1
HC	04/29/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	05/29/2026	110 Clarendon Pl
HC	04/29/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	05/29/2026	110 Clarendon Pl
HC	04/21/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/28/2026	70 Hobart St
HC	03/05/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Withdrawn	04/04/2026	774 Main St,BLDG
HC	03/05/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/21/2026	774 Main St,BLDG
HC	04/13/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	05/13/2026	279 Second St
HC	03/09/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/08/2026	110 Hobart St
HC	03/05/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		Abated	04/04/2026	12 E Mercer St

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	04/01/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Abated	05/01/2026	370 W Pleasantview Ave,14A
HC	03/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/25/2026	219 Sussex St
HC	05/08/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/07/2026	50 Second St
HC	03/10/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	04/09/2026	36 Kennedy St
HC	03/10/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/09/2026	36 Kennedy St
HC	05/13/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/12/2026	275.5 Main St
HC	04/13/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	05/13/2026	207 Central Ave,1ST FLR
HC	05/14/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/13/2026	150 Atlantic St,2
HC	05/14/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/13/2026	5 Pangborn PI
HC	05/14/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/13/2026	5 Pangborn PI

HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/30/2026	85 Atlantic St
HC	03/31/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	85 Atlantic St
HC	05/12/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/11/2026	98 Anderson St
HC	04/28/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/12/2026	403 Washington Ave
HC	04/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Void	05/28/2026	403 Washington Ave
HC	03/25/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/24/2026	450 Hackensack Ave,24
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/15/2026	111 Hackensack Ave
HC	03/25/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/24/2026	111 Hackensack Ave
HC	05/12/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/11/2026	34 George St
HC	05/12/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning	N.J.A.C. 5:70-4.9.(d)		New	06/11/2026	34 George St

			appliances or vehicle parking. Two floors up, and down, at first HVAC vent					
HC	03/17/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/16/2026	203A Main St
HC	03/11/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/14/2026	141 Main St,B
HC	05/12/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/11/2026	92 Summit Ave
HC	04/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/07/2026	60 Burlews Ct
HC	05/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/10/2026	57 Grove St
HC	05/11/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/10/2026	181 Main St
HC	05/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/10/2026	131 Clinton Pl
HC	05/11/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	06/10/2026	131 Clinton Pl
HC	04/13/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/12/2026	88 Clinton Pl
HC	03/20/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has	N.J.A.C. 5:70-2.2.(a)		Abated	04/19/2026	9 State St

			checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit					
HC	04/10/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org .	N.J.A.C. 5:70-3, 901.6		Unabated	05/10/2026	161 Main St
HC	04/10/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org .	N.J.A.C. 5:70-3, 901.6		Unabated	05/10/2026	161 Main St
HC	05/14/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD FP@Hackensack.org .	N.J.A.C. 5:70-3, 901.6		New	06/13/2026	107 Hudson St
HC	03/06/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		Abated	04/20/2026	390 Hackensack Ave,L/L
HC	05/14/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/10/2026	61 Grove St
HC	05/14/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/13/2026	390 Hackensack Ave,L/L
HC	03/30/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD FP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/15/2026	390 Hackensack Ave,274
HC	05/14/2026	Alarm System	Repair Red/Blue light over Master Fire Box	N.J.A.C. 5:70-3, 108.1		New	06/13/2026	390 Hackensack Ave,L/L
HC	03/17/2026	Alarm System	All Fire Protection systems shall be maintained in an operative condition at all times in accordance with the original installation standards for that system. Alterations require a permit from the building department.	N.J.A.C. 5:70-3, 901.4		Abated	04/16/2026	163 Hudson St
HC	03/17/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/16/2026	163 Hudson St

HC	03/27/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/18/2026	245 Prospect Ave
HC	03/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/18/2026	245 Prospect Ave
HC	05/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	05/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/24/2026	540 Main St
HC	05/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/10/2026	241 Hudson St
HC	05/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	06/17/2026	405 Rte 17 S
HC	05/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/17/2026	547 Main St
HC	04/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/19/2026	281 Park St
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		Abated	05/07/2026	301 Union St

			HFDFP@Hackensack.org Indicate which inspector is requesting the document.					
HC	05/19/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/18/2026	110 River St,1
HC	04/16/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/16/2026	100 Commerce Way,3
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/30/2026	106 S State St
HC	03/31/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	04/30/2026	106 S State St
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/30/2026	144 Lexington Ave
HC	03/17/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Abated	04/16/2026	62 Summit Ave,2
HC	05/18/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	04/22/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/22/2026	235 Moore St,3RD FLR
HC	04/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/28/2026	450 Hackensack Ave,6

HC	05/28/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/27/2026	450 Hackensack Ave,6
HC	04/27/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/28/2026	206 Central Ave
HC	05/28/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/27/2026	336 Main St
HC	04/23/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/28/2026	218 Main St,4TH FLR
HC	04/22/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/22/2026	235 Moore St,3RD FLR
HC	04/23/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Unabated	05/23/2026	218 Main St,4TH FLR
HC	05/28/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	05/28/2026	111 Central Ave
HC	05/28/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/28/2026	111 Central Ave
HC	05/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/31/2026	43 Maple Ave
HC	05/01/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/31/2026	43 Maple Ave

HC	05/29/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/29/2026	201 Essex St,1
HC	05/29/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/28/2026	202 Main St
HC	05/29/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/28/2026	202 Main St
HC	03/20/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Unabated	04/19/2026	1 State St
HC	05/22/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/28/2026	199 Washington Ave
HC	03/30/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	03/30/2026	7 E Ward St
HC	03/30/2026	Alarm System	Fire Watch Ordered. Building rep to maintain fire watch in areas where alarm/sprinkler is impaired. Fax log with entries every 30 min to FD at 201-646-7594. Watch is only terminated with permission of the Fire Official.	N.J.A.C. 5:70-3, 901.7		Abated	03/30/2026	7 E Ward St
HC	05/06/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	06/05/2026	7 E Ward St
HC	05/06/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/05/2026	7 E Ward St
HC	05/28/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	06/27/2026	111 Central Ave
HC	03/25/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/19/2026	115 Polifly Rd
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		Abated	05/19/2026	115 Polifly Rd

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	05/28/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/02/2026	146 Rte 17 N,2
HC	05/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/26/2026	50 Johnson Ave,1
HC	05/27/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	06/26/2026	50 Johnson Ave,1
HC	05/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/26/2026	238 High St
HC	04/02/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/27/2026	15 Salem St,1
HC	04/24/2026	Alarm System	Replace missing Carbon Monoxide detector.	N.J.A.C. 5:70-3, 108.1		New	05/24/2026	685 Main St
HC	04/24/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	04/28/2026	157 Central Ave
HC	04/14/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	05/14/2026	214 State St,Building
HC	05/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/26/2026	274 State St
HC	05/27/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/26/2026	274 State St
HC	05/27/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	06/26/2026	274 State St
HC	05/27/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning	N.J.A.C. 5:70-4.9.(d)		New	06/26/2026	274 State St

			appliances or vehicle parking. Two floors up, and down, at first HVAC vent					
HC	04/02/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/02/2026	15 Salem St,1
HC	04/29/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/26/2026	500 S River St,22
HC	05/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/25/2026	170 Sussex St,Hall
HC	04/22/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/22/2026	176 Summit Ave
HC	05/26/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/25/2026	414 Hackensack Ave,2000
HC	05/26/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	06/25/2026	18 Dicarolis Ct
HC	03/04/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	04/03/2026	370 W Pleasantview Ave,13
HC	05/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/25/2026	159 Summit Ave
HC	05/26/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/25/2026	149 Main St
HC	05/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to	N.J.A.C. 5:70-3, 907.8.5		New	06/25/2026	149 Main St

			HFD@Hackensack.org Indicate which inspector is requesting the document.					
HC	05/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/25/2026	27 E Kennedy St
HC	05/26/2026	Alarm System	Reinstate Central Station Monitoring, forward certificate of monitoring to Fire Prevention, HFD@Hackensack.org	N.J.A.C. 5:70-3, 108.1		New	06/25/2026	163 Liberty St
HC	03/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/03/2026	137 Hudson St
HC	03/04/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	04/03/2026	137 Hudson St
HC	05/22/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/21/2026	420 Passaic St
HC	03/31/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Unabated	04/30/2026	1 Coles Ave
HC	03/31/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/30/2026	1 Coles Ave
HC	03/06/2026	Alarm System	All Fire Protection systems shall be maintained in an operative condition at all times in accordance with the original installation standards for that system. Alterations require a permit from the building department.	N.J.A.C. 5:70-3, 901.4		Abated	04/27/2026	260 Union St,1
HC	05/20/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFD@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	05/20/2026	340 Hudson St,BLDG
HC	05/20/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/19/2026	103 Johnson Ave

HC	05/20/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		New	06/19/2026	95 Anderson St
HC	05/20/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/19/2026	95 Anderson St
HC	05/13/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/21/2026	340 S River St
HC	05/07/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/06/2026	29 Pangborn Pl
HC	05/20/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/19/2026	75 Atlantic St
HC	05/21/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/20/2026	863 Main St,1
HC	05/21/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/20/2026	380 W Pleasantview Ave,2
HC	05/21/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/20/2026	380 W Pleasantview Ave,2
HC	03/26/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/14/2026	500 S River St,21
HC	04/20/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	06/04/2026	120 River St,1D

HC	05/22/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	05/22/2026	37 E Broadway
HC	04/13/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/13/2026	339 Main St
HC	06/02/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	07/02/2026	51 Cleveland St
HC	03/30/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	06/19/2026	75 Anderson St
HC	06/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	07/01/2026	269 Passaic St
HC	05/11/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	07/02/2026	228 River St
HC	03/17/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Abated	03/26/2026	228 River St
HC	03/30/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		Unabated	07/02/2026	228 River St
HC	05/29/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		New	06/28/2026	1 State St
HC	05/14/2026	Alarm System	Maintenance of safeguards. Reduction of protection prohibited. Any installed level protection shall be continuously maintained.	N.J.A.C. 5:70-3, 108.1		Abated	06/13/2026	84 Euclid Ave
HC	06/01/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	07/01/2026	406 Prospect Ave
HC	03/23/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Abated	04/29/2026	205 Essex St, REAR

HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/24/2026	390 Hackensack Ave,70
HC	05/29/2026	Alarm System	Reinstate Central Station Monitoring, forward certificate of monitoring to Fire Prevention, HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 108.1		New	06/28/2026	184 Main St
HC	05/29/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	06/28/2026	179 Main St,3
HC	04/14/2026	Alarm System	Battery operated smoke alarms shall be maintained. Replace missing/defective alarm	N.J.A.C. 5:70-3, 907.10		Abated	05/14/2026	110 Anderson St
HC	04/14/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Abated	05/14/2026	110 Anderson St
HC	04/14/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/28/2026	110 Anderson St
HC	04/16/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Abated	05/20/2026	1 State St
HC	05/29/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	06/28/2026	59 Main St,1
HC	05/29/2026	Alarm System	Replace missing Carbon Monoxide detector.	N.J.A.C. 5:70-3, 108.1		New	06/28/2026	500 S River St,5
HC	06/03/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	07/03/2026	450 Hackensack Ave,1
HC	06/03/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		New	07/03/2026	450 Hackensack Ave,1

HC	06/03/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		New	07/03/2026	450 Hackensack Ave,1
HC	06/03/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		New	07/03/2026	263 S River St,2
HC	06/03/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	07/03/2026	263 S River St,2
HC	03/27/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Unabated	04/26/2026	89 Old River St
HC	06/03/2026	Alarm System	Make repairs to Fire Alarm system. Forward repair report to Fire Prevention, HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 901.6		New	07/03/2026	2 Kinderkamack Rd
HC	06/02/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/03/2026	342A Main St
HC	03/25/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/12/2026	230 Central Ave
HC	05/04/2026	Alarm System	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/Safety Affidavit	N.J.A.C. 5:70-2.2.(a)		Abated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Unabated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Alarm System	Replace missing Smoke Alarm	N.J.A.C. 5:70-3, 108.1		Unabated	06/03/2026	25 Zabriskie St

HC	05/18/2026	Alarm System	Fire Alarm and Fire Detection systems shall be tested as per NFPA 72, submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/29/2026	153 Lawrence St
HC	05/18/2026	Alarm System	Carbon Monoxide detectors shall be maintained as per NFPA 720 and the manufacturers instructions. Repair/replace defective detector or replace missing detector.	N.J.A.C. 5:70-3, 901.6		Unabated	06/17/2026	153 Lawrence St
HC	05/18/2026	Alarm System	Carbon monoxide alarms shall be installed in all spaces and all adjoining spaces containing fuel burning appliances or vehicle parking. Two floors up, and down, at first HVAC vent	N.J.A.C. 5:70-4.9.(d)		Unabated	06/17/2026	153 Lawrence St
HC	05/18/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Unabated	06/17/2026	153 Lawrence St
HC	04/14/2026	Building	Emergency responder radio coverage system shall be inspected and tested annually. Submit results of last inspection to HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 510.6.1		Abated	05/07/2026	2 Kinderkamack Rd
HC	03/27/2026	Building	Access to fire protection equipment must be labeled	N.J.A.C. 5:70-3, 509.1		Abated	06/03/2026	89 Old River St
HC	06/03/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		New	07/03/2026	450 Hackensack Ave,1
HC	04/30/2026	Building	Make Repairs to the Emergency responder radio coverage system. Submit the results to HFDFP@Hackensack.org.	510.6		Withdrawn	05/04/2026	160 River St,BLDG
HC	06/01/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		New	07/01/2026	406 Prospect Ave
HC	03/31/2026	Building	Address number missing/blocked, Have address numbers installed or cleared on building.	N.J.A.C. 5:70-3, 505.1		Unabated	04/30/2026	1 Coles Ave
HC	05/26/2026	Building	Emergency responder radio coverage system shall be inspected and tested annually. Submit results of last inspection to HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 510.6.1		New	06/25/2026	149 Main St

HC	05/28/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Unabated	06/27/2026	111 Central Ave
HC	03/25/2026	Building	Access to fire protection equipment must be labeled	N.J.A.C. 5:70-3, 509.1		Unabated	04/24/2026	540 Main St
HC	05/14/2026	Building	Emergency responder radio coverage system, Additional Frequencies. The building owner shall modify or expand the emergency responder radio coverage system at his or her expense in the event frequency changes are required	510.6.2		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/14/2026	Building	Make Repairs to the Emergency responder radio coverage system. Submit the results to HFDFP@Hackensack.org.	510.6		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/11/2026	Building	Address number missing/blocked, Have address numbers installed or cleared on building.	N.J.A.C. 5:70-3, 505.1		New	06/10/2026	77 Anderson St,2
HC	04/07/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	05/07/2026	60 Burlews Ct
HC	03/10/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	04/09/2026	8 W Camden St
HC	05/12/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		New	06/11/2026	126 State St,2ND FLR
HC	04/10/2026	Building	Overcrowded conditions or obstructions in aisles, passageways or other means of egress is prohibited.	N.J.A.C. 5:70-3, 108.6		Abated	05/13/2026	123 Sussex St
HC	04/28/2026	Building	Address number missing/blocked, Have address numbers installed or cleared on building.	N.J.A.C. 5:70-3, 505.1		New	05/28/2026	175 Lexington Ave,A
HC	03/18/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	04/17/2026	520 Essex St

HC	03/18/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	04/17/2026	110 Arcadia Rd
HC	03/10/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	03/26/2026	300 S Summit Ave
HC	03/10/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		Abated	04/09/2026	300 S Summit Ave
HC	03/19/2026	Building	Rooms containing equipment controls shall be identified. Label Door(s) leading to rooms "Fire Alarm" "Sprinkler"" "HVAC" "Electrical" "Boiler" etc as necessary	N.J.A.C. 5:70-3, SECTION 509		New	04/18/2026	291 Second St
HC	04/28/2026	Construction	TRUSS placard required to be installed at main entrance to building.	N.J.A.C. 5:70-2.20		Abated	05/28/2026	180 Central Ave,1
HC	04/20/2026	Miscellaneous	Remove all Fueled equipment from building.	N.J.A.C. 5:70-3, 313.1		Abated	04/20/2026	409 Rte 17 S
HC	05/12/2026	Miscellaneous	Curtains, draperies, fabric hangings and other similar combustible materials suspended from walls or ceilings shall be tested for flame propagation. Submit results from last test.	N.J.A.C. 5:70-3, 807.3		Abated	06/11/2026	409 Rte 17 S
HC	05/27/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		New	06/26/2026	78 Trinity Pl
HC	05/27/2026	Miscellaneous	Conditions affecting the safety of fire fighters during emergency operations are prohibited.	N.J.A.C. 5:70-3, 101.2		Unabated	06/26/2026	70 Polifly Rd
HC	05/14/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	06/13/2026	15 Salem St,1
HC	05/20/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/27/2026	274 State St
HC	05/21/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Unabated	05/20/2026	500 S River St,1

HC	05/20/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	05/27/2026	55 Essex St,B
HC	04/24/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Unabated	06/26/2026	157 Central Ave
HC	05/21/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/28/2026	292 Main St,Building
HC	05/06/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/20/2026	7 E Ward St
HC	05/18/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	05/28/2026	104 Elm Ave
HC	05/26/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		New	06/25/2026	149 Main St
HC	03/12/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	04/11/2026	133 Hudson St
HC	05/20/2026	Miscellaneous	Remove all Fueled equipment from building.	N.J.A.C. 5:70-3, 313.1		New	06/19/2026	95 Anderson St
HC	05/21/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	06/20/2026	925 Main St
HC	05/07/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/21/2026	135 Kansas St,1st Flr
HC	03/03/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	03/03/2026	390 Hackensack Ave,313
HC	04/14/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	04/28/2026	36 Kennedy St
HC	03/10/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	04/09/2026	61 S State St,2nd Flr

HC	05/12/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	06/11/2026	390 Hackensack Ave,XD
HC	05/12/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/11/2026	126 State St,2ND FLR
HC	05/12/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/11/2026	16 Marion St,2
HC	03/06/2026	Miscellaneous	Conditions affecting the safety of fire fighters during emergency operations are prohibited.	N.J.A.C. 5:70-3, 101.2		Abated	04/20/2026	390 Hackensack Ave,L/L
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	377-379 W Pleasantville Ave,1
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	377-379 W Pleasantville Ave,1
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	377-379 W Pleasantville Ave,1
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	377-379 W Pleasantville Ave,1
HC	05/14/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	06/13/2026	200 Passaic St,FLR 3
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	355-357 W Pleasantville Ave,2
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	355-357 W Pleasantville Ave,2
HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	355-357 W Pleasantville Ave,2
HC	04/08/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	05/18/2026	360 W Pleasantville Ave,BLDG

HC	05/18/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	03/06/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	04/05/2026	220 Gracie Pl
HC	03/06/2026	Miscellaneous	Conditions affecting the safety of fire fighters during emergency operations are prohibited.	N.J.A.C. 5:70-3, 101.2		Abated	04/05/2026	220 Gracie Pl
HC	03/06/2026	Miscellaneous	Hazardous Conditions-electrical.	N.J.A.C. 5:70-3, 103.2		Abated	04/05/2026	220 Gracie Pl
HC	03/06/2026	Miscellaneous	Remove accumulations of rubbish.	N.J.A.C. 5:70-3, 103.2		Abated	04/05/2026	220 Gracie Pl
HC	03/16/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	03/26/2026	25 Main St,103
HC	03/04/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	04/03/2026	100 Second St
HC	03/26/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	04/25/2026	101 Hobart St
HC	03/10/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	03/10/2026	246 First St
HC	04/01/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		New	05/01/2026	165 State St,2-D
HC	03/30/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Unabated	04/29/2026	29 Shafer Pl
HC	03/30/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1(b)		Abated	04/01/2026	29 Shafer Pl
HC	04/17/2026	Miscellaneous	Remove all Fueled equipment from building.	N.J.A.C. 5:70-3, 313.1		New	05/04/2026	25 E Salem St,Building
HC	03/11/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	03/23/2026	215.5 Main St,2nd Flr

HC	04/29/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	05/29/2026	21 Main St,3RD FLR WEST
HC	04/07/2026	Miscellaneous	Remove all Fueled equipment from building.	N.J.A.C. 5:70-3, 313.1		Abated	05/07/2026	6-8 Prospect Ave
HC	03/13/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	04/09/2026	67 S Prospect Ave
HC	04/01/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1(b)		Abated	04/09/2026	67 S Prospect Ave
HC	04/01/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	04/09/2026	67 S Prospect Ave
HC	04/28/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Unabated	05/28/2026	140 Hobart St
HC	05/06/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	06/05/2026	2 University Plz,502
HC	05/07/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	06/06/2026	80 Hobart St
HC	04/28/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	05/28/2026	116 S Newman St
HC	04/14/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	04/22/2026	294-298 State St,1
HC	03/23/2026	Miscellaneous	Provide a technical opinion and report by a certified professional to determine the acceptability of technologies, processes, products, facilities, materials and uses on premise. Send report to FireOfficial@Hackensack.org	N.J.A.C. 5:70-3, 104.7.2		Unabated	04/22/2026	240 Prospect Ave 1
HC	04/20/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	04/23/2026	141 Lincoln St

HC	04/23/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	05/23/2026	45 Essex St,109
HC	04/27/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/26/2026	25 E Salem St,3RD FLR
HC	04/29/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		New	05/29/2026	110 Clarendon Pl
HC	04/29/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		Abated	04/29/2026	946 Main St,1
HC	04/29/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			New	05/14/2026	59 Oak St,59
HC	03/19/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	04/18/2026	390 Hackensack Ave,212
HC	05/26/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	06/25/2026	20 Banta Pl,203
HC	04/16/2026	Miscellaneous	Any dangerous condition liable to cause or contribute to the spread of fire or endanger occupants shall be prohibited.	N.J.A.C. 5:70-3, 103.2		Abated	05/20/2026	1 State St
HC	05/04/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	05/20/2026	1 State St
HC	06/03/2026	Miscellaneous	Provide access for re-inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.	N.J.A.C. 5:70-2.1.(b)		New	07/03/2026	400 Summit Ave,1
HC	05/13/2026	Miscellaneous	Provide access for inspection, Call 201-646-7685 to schedule inspection. Failure to do so may result in Penalties being issued.			Abated	06/12/2026	241 Main St,610
HC	03/05/2026	Dangerous Conditions	Fueled equipment (motorcycles, lawn care, cooking, etc.) shall not be stored or operated within a building	N.J.A.C. 5:70-3, 313.1		Abated	04/13/2026	125 Main St
HC	03/05/2026	Dangerous Conditions	Dangerous condition which could cause or contribute to fire spread must be removed	N.J.A.C. 5:70-3, 102.1.1.1.		Abated	04/13/2026	125 Main St
HC	04/22/2026	Dangerous Conditions	Fueled equipment (motorcycles, lawn care, cooking, etc.) shall not be stored or operated within a building	N.J.A.C. 5:70-3, 313.1		New	05/22/2026	64 Prospect Ave

HC	05/26/2026	Dangerous Conditions	Accumulation of combustible materials must be removed	N.J.A.C. 5:70-3, 102.1.1.6.		New	06/25/2026	18 Dicarolis Ct
HC	04/29/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	05/29/2026	500 S River St,22
HC	05/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/20/2026	925 Main St
HC	05/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/20/2026	925 Main St
HC	05/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/20/2026	925 Main St
HC	05/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/20/2026	925 Main St
HC	05/20/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/19/2026	95 Anderson St
HC	05/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/20/2026	390 Hackensack Ave,106
HC	05/06/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Abated	05/20/2026	7 E Ward St
HC	05/22/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	06/21/2026	199 Washington Ave
HC	05/27/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/26/2026	274 State St
HC	05/27/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	06/26/2026	70 Polifly Rd
HC	05/27/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	06/26/2026	70 Polifly Rd

HC	05/27/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	06/26/2026	370 Park St
HC	04/28/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	05/28/2026	281 Park St
HC	04/28/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	05/28/2026	281 Park St
HC	04/28/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	05/28/2026	281 Park St
HC	04/28/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		Unabated	05/28/2026	281 Park St
HC	05/18/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	06/17/2026	355-357 W Pleasantview Ave,2
HC	03/25/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	04/24/2026	111 Hackensack Ave
HC	03/31/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	04/30/2026	687 Main St
HC	04/01/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	05/01/2026	370 W Pleasantview Ave,14A
HC	04/13/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	05/14/2026	156 S Main St
HC	03/16/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	04/15/2026	115 Lawrence St
HC	04/14/2026	Fire Resistive Rated Assembly	The hanging of decorative materials from an acoustical ceiling system is prohibited. Remove materials.	N.J.A.C. 5:70-3, 701.2.1		Unabated	05/14/2026	314 Essex St
HC	04/14/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	05/14/2026	314 Essex St

HC	04/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/21/2026	70 Longview Ave
HC	04/14/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/14/2026	116 Main St
HC	04/17/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/04/2026	25 E Salem St,Building
HC	03/03/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	04/02/2026	360 Essex St,3
HC	03/26/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	04/25/2026	139 Hudson St,A
HC	04/07/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/07/2026	204 Railroad Ave
HC	03/03/2026	Fire Resistive Rated Assembly	Fire resistive coatings and sprayed fire resistant materials applied to structural members and fire resistant joint systems, shall be maintained.	703.1		New	04/02/2026	140 Prospect Ave
HC	03/03/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	04/02/2026	140 Prospect Ave
HC	03/31/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	04/30/2026	614 Main St
HC	05/07/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		New	06/06/2026	40 Jefferson St,BLDG
HC	05/07/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		New	06/06/2026	40 Jefferson St,BLDG
HC	05/07/2026	Fire Resistive Rated Assembly	Fire doors must be maintained, Make repairs to fire/smoke doors as per NFPA 80	N.J.A.C. 5:70-3, 705.2		New	06/06/2026	40 Jefferson St,BLDG
HC	04/21/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	05/21/2026	70 Hobart St

HC	03/23/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Unabated	04/22/2026	240 Prospect Ave 1
HC	04/29/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/29/2026	110 Clarendon Pl
HC	04/28/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		New	05/28/2026	175 Lexington Ave,A
HC	03/12/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	04/16/2026	171 Main St,302
HC	03/20/2026	Fire Resistive Rated Assembly	Holes in ceilings, walls, floors or missing ceiling tiles must be repaired/replaced.	N.J.A.C. 5:70-3, 701.1		Abated	05/20/2026	1 State St
HC	05/26/2026	Fire Protection Systems	Fire protection systems shall be maintained in an operative condition	N.J.A.C. 5:70-3, 901.6		New	06/25/2026	18 Dicarolis Ct
HC	05/26/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/25/2026	149 Main St
HC	03/31/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/30/2026	1 Coles Ave
HC	05/22/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/21/2026	420 Passaic St
HC	05/21/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	06/20/2026	500 S River St,22
HC	05/26/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/25/2026	170 Sussex St,Hall

HC	04/29/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/21/2026	500 S River St,22
HC	05/21/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/20/2026	172 Johnson Ave
HC	05/20/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/19/2026	95 Anderson St
HC	05/20/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/19/2026	95 Anderson St
HC	05/20/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/19/2026	103 Johnson Ave
HC	05/21/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/20/2026	50 Polifly Rd
HC	05/21/2026	Sprinklers, Standpipes, Pumps	Sprinkler systems shall be maintained as installed.	N.J.A.C. 5:70-3, 901.4		New	06/20/2026	925 Main St
HC	05/27/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Unabated	06/26/2026	370 Park St
HC	05/27/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/26/2026	50 Johnson Ave,1
HC	04/28/2026	Sprinklers, Standpipes, Pumps	Access to Fire Department Connections (FDCs) shall be maintained at all times.	N.J.A.C. 5:70-3, 912.4		Abated	05/28/2026	180 Central Ave,1

HC	03/11/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Unabated	02/22/2026	14 Bergen St, Building
HC	05/06/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	06/05/2026	7 E Ward St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/28/2026	115 Polifly Rd
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/28/2026	115 Polifly Rd
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Fire pumps shall be inspected, tested and maintained as per NFPA 20.	N.J.A.C. 5:70-3, 913.1		Abated	05/28/2026	115 Polifly Rd
HC	05/28/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	06/27/2026	115 Polifly Rd
HC	05/29/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/28/2026	30 Euclid Ave
HC	05/29/2026	Sprinklers, Standpipes, Pumps	A working space of not less than 36" X 36" X 78"H shall be provided around Fire Department Connections (FDC).	N.J.A.C. 5:70-3, 912.4.2		New	06/28/2026	30 Euclid Ave
HC	04/22/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/22/2026	235 Moore St, 3RD FLR
HC	04/23/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/28/2026	218 Main St, 4TH FLR
HC	04/23/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Unabated	05/23/2026	218 Main St, 4TH FLR

HC	05/08/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/07/2026	50 Second St
HC	03/26/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/25/2026	219 Sussex St
HC	04/10/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/13/2026	123 Sussex St
HC	03/31/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Abated	04/30/2026	85 Atlantic St
HC	03/04/2026	Sprinklers, Standpipes, Pumps	Replace painted or missing escutcheon plates as per NFPA 25 5.2.1.1.5. Send repair report when completed.	N.J.A.C. 5:70-3, 901.6.1		Abated	03/19/2026	336 Prospect Ave
HC	04/13/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	05/12/2026	88 Clinton Pl
HC	05/12/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	06/11/2026	60 Burlews Ct
HC	04/07/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/07/2026	60 Burlews Ct
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	04/10/2026	535 S River St,1
HC	04/16/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	05/16/2026	403 W Pleasantview Ave

HC	03/25/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/07/2026	301 Union St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/07/2026	301 Union St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Access to Fire Department Connections (FDCs) shall be maintained at all times.	N.J.A.C. 5:70-3, 912.4		Abated	05/20/2026	301 Union St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	A working space of not less than 36" X 36" X 78"H shall be provided around Fire Department Connections (FDC).	N.J.A.C. 5:70-3, 912.4.2		Abated	05/20/2026	301 Union St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Have underground piping for exterior fire department connections (FDC) inspected and flushed in accordance with NFPA 25. Forward inspection report to Fire Prevention HFDFP@Hackensack.org. Notify immediately if FDC is unusable.	N.J.A.C. 5:70-3, 912.7		Abated	05/20/2026	301 Union St
HC	04/24/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/12/2026	22 Fairmount Ave
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	03/27/2026	Sprinklers, Standpipes, Pumps	Fire pumps shall be inspected, tested and maintained as per NFPA 20.	N.J.A.C. 5:70-3, 913.1		Unabated	04/26/2026	245 Prospect Ave
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	06/17/2026	405 Rte 17 S
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/17/2026	547 Main St

HC	05/14/2026	Sprinklers, Standpipes, Pumps	Fire pumps shall be inspected, tested and maintained as per NFPA 20.	N.J.A.C. 5:70-3, 913.1		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/14/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	06/13/2026	390 Hackensack Ave,L/L
HC	03/06/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	06/14/2026	390 Hackensack Ave,L/L
HC	05/15/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/14/2026	390 Hackensack Ave,274
HC	03/12/2026	Sprinklers, Standpipes, Pumps	5 Year sprinkler Internal inspection due as per NFPA 25. Send results to HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 901.6.1		Abated	04/11/2026	171 Main St,302
HC	03/12/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	04/16/2026	171 Main St,302
HC	04/14/2026	Sprinklers, Standpipes, Pumps	5 Year sprinkler Internal inspection due as per NFPA 25. Send results to HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 901.6.1		Abated	04/28/2026	294-298 State St,1
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/10/2026	171 S River St
HC	03/05/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/21/2026	774 Main St,BLDG
HC	03/05/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	04/21/2026	774 Main St,BLDG
HC	03/09/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/08/2026	110 Hobart St

HC	04/27/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/27/2026	277 Lodi St,9
HC	03/06/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	04/27/2026	109 First St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	03/31/2026	29 Linden St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Fire pumps shall be inspected, tested and maintained as per NFPA 20.	N.J.A.C. 5:70-3, 913.1		Abated	04/24/2026	29 Linden St
HC	05/01/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/31/2026	215 State St
HC	04/13/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/29/2026	215 Union St
HC	05/07/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/06/2026	450 Hackensack Ave,3
HC	03/04/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/04/2026	185 Kenneth St
HC	05/08/2026	Sprinklers, Standpipes, Pumps	Sprinkler systems shall be maintained as installed.	N.J.A.C. 5:70-3, 901.4		New	06/07/2026	30 Prospect Ave,7
HC	05/07/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/06/2026	466 Hackensack Ave
HC	03/18/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to	N.J.A.C. 5:70-3, 901.6.3		Abated	04/17/2026	720 Summit Ave

			HFD@Hackensack.org Indicate which inspector is requesting the document					
HC	05/06/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/05/2026	206 S Park St
HC	05/06/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	06/05/2026	206 S Park St
HC	05/04/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	05/06/2026	414 Hackensack Ave,1000
HC	05/06/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	06/05/2026	515 Essex St
HC	05/07/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/06/2026	40 Jefferson St,BLDG
HC	04/27/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	05/27/2026	20 Jefferson St
HC	04/27/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	05/27/2026	20 Jefferson St
HC	04/27/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		Unabated	05/27/2026	20 Jefferson St
HC	03/04/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/26/2026	5 Linden St
HC	03/10/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFD@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/23/2026	285 Passaic St,1

HC	03/13/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	04/12/2026	107 First St,BLDG
HC	03/05/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/11/2026	88 Polifly Rd
HC	03/24/2026	Sprinklers, Standpipes, Pumps	5 Year sprinkler Internal inspection due as per NFPA 25. Send results to HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 901.6.1		New	04/23/2026	405 Rte 17 S,SUITE #2
HC	03/24/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	04/23/2026	405 Rte 17 S,SUITE #2
HC	03/03/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	04/02/2026	140 Prospect Ave
HC	03/03/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	04/02/2026	140 Prospect Ave
HC	03/19/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	04/18/2026	291 Second St
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/11/2026	146 English St
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	04/10/2026	146 English St
HC	03/10/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	04/09/2026	40 Railroad Ave
HC	03/12/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	04/11/2026	15 Conklin Pl,Sch

HC	03/13/2026	Sprinklers, Standpipes, Pumps	5 Year Standpipe Flow Test Required as per NFPA 25, forward results to HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 901.6.1		Abated	03/13/2026	277 Prospect Ave,Building
HC	03/13/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/13/2026	277 Prospect Ave,Building
HC	03/13/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	03/13/2026	277 Prospect Ave,Building
HC	03/13/2026	Sprinklers, Standpipes, Pumps	Fire pumps shall be inspected, tested and maintained as per NFPA 20.	N.J.A.C. 5:70-3, 913.1		Abated	03/13/2026	277 Prospect Ave,Building
HC	03/06/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	04/05/2026	66 Moore St
HC	03/06/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	04/05/2026	66 Moore St
HC	04/07/2026	Sprinklers, Standpipes, Pumps	Sprinkler systems shall be maintained as installed.	N.J.A.C. 5:70-3, 901.4		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Sprinklers, Standpipes, Pumps	Sprinkler systems shall be maintained as installed.	N.J.A.C. 5:70-3, 901.4		New	05/07/2026	204 Railroad Ave
HC	04/10/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/10/2026	92 Second St,Building
HC	04/10/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	05/10/2026	92 Second St,Building

HC	04/01/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/01/2026	261 Maple Hill Dr
HC	03/04/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/03/2026	212 Prospect Ave
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Unabated	04/10/2026	250 River St
HC	03/11/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/10/2026	58 Main St,Building
HC	04/14/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	05/14/2026	130 Main St
HC	04/08/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	05/08/2026	407 Rte 17 S
HC	03/10/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		New	04/09/2026	516 Main St
HC	03/16/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	04/14/2026	115 Lawrence St
HC	03/23/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/22/2026	240 Prospect Ave 1
HC	03/23/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/22/2026	240 Prospect Ave 1

HC	03/23/2026	Sprinklers, Standpipes, Pumps	Occupant-Use Fire Hose shall be tested as per NFPA 1962. Testing intervals 5 Years from date of manufacture and 3 years thereafter.	N.J.A.C. 5:70-3, 901.6.1		Unabated	04/22/2026	240 Prospect Ave 1
HC	05/29/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	06/28/2026	500 S River St,5
HC	06/01/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	06/14/2026	55 Midtown Bridge Approach,2
HC	06/01/2026	Sprinklers, Standpipes, Pumps	Access to Fire Department Connections (FDCs) shall be maintained at all times.	N.J.A.C. 5:70-3, 912.4		New	07/01/2026	406 Prospect Ave
HC	06/01/2026	Sprinklers, Standpipes, Pumps	Fire sprinkler systems may not be obstructed.	N.J.A.C. 5:70-3, 903.3.3		New	07/01/2026	406 Prospect Ave
HC	06/01/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Abated	06/01/2026	260 Railroad Ave
HC	06/01/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		New	07/01/2026	269 Passaic St
HC	05/11/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Unabated	07/02/2026	228 River St
HC	05/11/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	07/02/2026	228 River St
HC	04/02/2026	Sprinklers, Standpipes, Pumps	Make repairs to sprinkler/standpipe system, Send repair report to: HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6		Unabated	07/02/2026	228 River St
HC	03/25/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	05/12/2026	230 Central Ave
HC	03/27/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to	N.J.A.C. 5:70-3, 901.6.3		Unabated	04/26/2026	89 Old River St

			HFDFP@Hackensack.org Indicate which inspector is requesting the document					
HC	06/03/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		New	07/03/2026	450 Hackensack Ave,1
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	06/03/2026	153 Lawrence St
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Repair/Replace Red light over Fire Department Connection (FDC) as per IFC and city ord #166-10	N.J.A.C. 5:70-3, 108.1		Unabated	06/17/2026	153 Lawrence St
HC	05/18/2026	Sprinklers, Standpipes, Pumps	Replace missing caps on the Fire Department Connection (FDC).	N.J.A.C. 5:70-3, 901.4		Unabated	06/17/2026	153 Lawrence St
HC	05/12/2026	Sprinklers, Standpipes, Pumps	5 Year Standpipe Flow Test Required as per NFPA 25, forward results to HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 901.6.1		Abated	06/11/2026	230 Central Ave
HC	05/12/2026	Sprinklers, Standpipes, Pumps	Have underground piping for exterior fire department connections (FDC) inspected and flushed in accordance with NFPA 25. Forward inspection report to Fire Prevention HFDFP@Hackensack.org. Notify immediately if FDC is unusable.	N.J.A.C. 5:70-3, 912.7		Abated	06/11/2026	230 Central Ave
HC	05/04/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual sprinkler system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Sprinklers, Standpipes, Pumps	Current NFPA annual standpipe system report requested. Submit last annual report to HFDFP@Hackensack.org Indicate which inspector is requesting the document	N.J.A.C. 5:70-3, 901.6.3		Abated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Sprinklers, Standpipes, Pumps	Occupant-Use Fire Hose shall be tested as per NFPA 1962. Testing intervals 5 Years from date of manufacture and 3 years thereafter.	N.J.A.C. 5:70-3, 901.6.1		Abated	06/03/2026	25 Zabriskie St
HC	06/02/2026	Commercial Cooking Systems	Excessive grease must be removed and hood cleaned.	N.J.A.C. 5:70-3, 607.3.3.2		Unabated	07/02/2026	342A Main St

HC	06/02/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Unabated	07/02/2026	342A Main St
HC	03/25/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	04/09/2026	390 Hackensack Ave,70
HC	03/25/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	04/09/2026	390 Hackensack Ave,70
HC	05/29/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		New	06/28/2026	59 Main St,1
HC	04/09/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	04/09/2026	450 Hackensack Ave,20
HC	04/09/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	05/09/2026	341 Essex St
HC	04/09/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	05/09/2026	341 Essex St
HC	03/12/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	04/11/2026	15 Conklin Pl,Sch
HC	03/12/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	04/11/2026	15 Conklin Pl,Sch
HC	03/03/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		Abated	03/24/2026	184 Hudson St
HC	05/06/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/05/2026	515 Essex St

HC	05/06/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	06/05/2026	515 Essex St
HC	03/31/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		Abated	04/30/2026	125 Main St
HC	03/05/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	04/13/2026	125 Main St
HC	03/05/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	03/31/2026	125 Main St
HC	03/04/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	03/04/2026	185 Kenneth St
HC	03/04/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	03/04/2026	185 Kenneth St
HC	05/07/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (dry chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.6		New	06/06/2026	450 Hackensack Ave,3
HC	04/02/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		Abated	05/02/2026	189 Central Ave,1st flr
HC	03/05/2026	Commercial Cooking Systems	Excessive grease creating a fire hazard shall be removed and kitchen equipment cleaned, including appliances, walls, floors, etc.	N.J.A.C. 5:70-3, 103.2		Abated	04/21/2026	774 Main St,BLDG
HC	03/05/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	04/21/2026	774 Main St,BLDG
HC	03/05/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (dry chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.6		Abated	04/21/2026	774 Main St,BLDG
HC	03/05/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report	N.J.A.C. 5:70-3, 607.3.3		Abated	04/04/2026	12 E Mercer St

			shall indicate that ALL areas of the hood/duct have been cleaned.					
HC	03/05/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	04/04/2026	12 E Mercer St
HC	03/17/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	04/16/2026	163 Hudson St
HC	05/18/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/17/2026	547 Main St
HC	05/18/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	06/17/2026	547 Main St
HC	03/25/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	05/07/2026	301 Union St
HC	03/25/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	05/07/2026	301 Union St
HC	04/10/2026	Commercial Cooking Systems	Fryer/open flame baffle Required: All deep fat fryers shall be installed with at least a 16" space between the fryer and surface flames from adjacent cooking equipment as per NFPA 96 12.1.2.5, Or a baffle shall be installed between.	N.J.A.C. 5:70-3, 103.2		Unabated	05/10/2026	37 Fair St
HC	05/11/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New		37 Fair St
HC	05/11/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New		37 Fair St
HC	05/11/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		New	06/10/2026	181 Main St

HC	05/11/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	06/10/2026	181 Main St
HC	05/05/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	05/13/2026	111 Anderson St,1
HC	05/12/2026	Commercial Cooking Systems	Fryer/open flame baffle Required: All deep fat fryers shall be installed with at least a 16" space between the fryer and surface flames from adjacent cooking equipment as per NFPA 96 12.1.2.5, Or a baffle shall be installed between.	N.J.A.C. 5:70-3, 103.2		New	06/11/2026	98 Anderson St
HC	04/13/2026	Commercial Cooking Systems	Fryer/open flame baffle Required: All deep fat fryers shall be installed with at least a 16" space between the fryer and surface flames from adjacent cooking equipment as per NFPA 96 12.1.2.5, Or a baffle shall be installed between.	N.J.A.C. 5:70-3, 103.2		Unabated	05/13/2026	156 S Main St
HC	05/29/2026	Commercial Cooking Systems	Excessive grease must be removed and hood cleaned.	N.J.A.C. 5:70-3, 607.3.3.2		New	06/28/2026	337 Main St
HC	05/29/2026	Commercial Cooking Systems	Kitchen hood cleaning schedule shall be submitted, indicating the method and intervals between cleanings	N.J.A.C. 5:70-3, 607.3.3.1.1		New	06/28/2026	337 Main St
HC	04/23/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Unabated	05/23/2026	137.5 Main St
HC	04/29/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	05/18/2026	500 S River St,22
HC	04/29/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (dry chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.6		Abated	05/21/2026	500 S River St,22
HC	05/21/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/20/2026	50 Polifly Rd

HC	05/21/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (dry chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.6		New	06/20/2026	50 Polifly Rd
HC	03/17/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	04/16/2026	29A State St
HC	03/17/2026	Commercial Cooking Systems	Required hood filters shall be properly placed at all times hood is in use.	N.J.A.C. 5:70-3, 607.3.1		Abated	04/22/2026	29A State St
HC	05/21/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/20/2026	390 Hackensack Ave,185
HC	05/22/2026	Commercial Cooking Systems	Cooking Operations shall be equipped with a ventilating hood, duct and automatic fire suppression system. Obtain Permits and have installed or remove cooking appliance.	N.J.A.C. 5:70-3, 607.2		Unabated	06/05/2026	37 E Broadway
HC	04/29/2026	Commercial Cooking Systems	Commercial cooking hood suppression systems shall be maintained.	N.J.A.C. 5:70-3, 904.12		Unabated	05/29/2026	500 S River St,22
HC	04/29/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	05/18/2026	500 S River St,22
HC	04/29/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		Abated	05/21/2026	500 S River St,22
HC	04/29/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		Abated	05/18/2026	500 S River St,22
HC	05/26/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/25/2026	170 Sussex St,Hall
HC	05/26/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (wet chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.5		New	06/25/2026	170 Sussex St,Hall

HC	05/22/2026	Commercial Cooking Systems	Have hood system cleaned and submit cleaning report to Fire Prevention HFDFP@Hackensack.org. Report shall indicate that ALL areas of the hood/duct have been cleaned.	N.J.A.C. 5:70-3, 607.3.3		New	06/21/2026	260 Union St,1
HC	05/22/2026	Commercial Cooking Systems	Cooking suppression system 6 month inspection required (dry chemical systems), submit report HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 904.6		New	06/21/2026	260 Union St,1
HC	05/26/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/25/2026	331 Summit Ave
HC	04/17/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/17/2026	37 E Broadway
HC	05/21/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/20/2026	390 Hackensack Ave,106
HC	04/21/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/12/2026	409 Rte 17 S
HC	03/20/2026	Means of Egress	A Lithium-ion powered personal device may not be stored or charged in any egress, below grade or in any attic or within 10 feet of any egress in any business or multiple dwelling.	88		Abated	04/16/2026	1 State St
HC	05/08/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/07/2026	30 Prospect Ave,9
HC	05/01/2026	Means of Egress	Each floor of a stairwell shall have a sign indicating a stairwell designation and the floor number (i.e. Stair 1, Floor 2). Have signs posted on each level in each stairwell.	N.J.A.C. 5:70-3, 1031.9		Abated	05/31/2026	43 Maple Ave
HC	05/01/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/31/2026	43 Maple Ave
HC	05/08/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/07/2026	30 Prospect Ave,9
HC	03/06/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Unabated	05/17/2026	390 Hackensack Ave,313
HC	03/26/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/13/2026	219 Sussex St
HC	04/01/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/01/2026	370 W Pleasantview Ave,14A

HC	04/28/2026	Means of Egress	Fire Escapes shall be certified by a registered design professional every 5 years.	N.J.A.C. 5:70-3, 1031.7.3		Unabated	05/28/2026	403 Washington Ave
HC	05/12/2026	Means of Egress	Elevator Lobby Signs - All floor levels shall have an approved sign reading "Use Stairways in case of fire - DO NOT USE ELEVATORS"	N.J.A.C. 5:70-4.14.(b)		New	06/11/2026	126 State St,2ND FLR
HC	04/01/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/01/2026	81 Hobart St
HC	03/31/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/30/2026	85 Atlantic St
HC	04/13/2026	Means of Egress	Fire Escapes shall be certified by a registered design professional every 5 years.	N.J.A.C. 5:70-3, 1031.7.3		Unabated	05/13/2026	88 Clinton Pl
HC	05/12/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/11/2026	16 Marion St,2
HC	05/12/2026	Means of Egress	Area of Refuge two way communication systems shall be inspected and tested annually , submit testing results to HFDFFP@Hackensack.org.	N.J.A.C. 5:70-3, 1031.8		New	06/11/2026	92 Summit Ave
HC	05/12/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/11/2026	450 Hackensack Ave,14
HC	03/31/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/30/2026	106 S State St
HC	05/18/2026	Means of Egress	Fire Escapes shall be certified by a registered design professional every 5 years.	N.J.A.C. 5:70-3, 1031.7.3		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	05/18/2026	Means of Egress	Fire Escapes shall be certified by a registered design professional every 5 years.	N.J.A.C. 5:70-3, 1031.7.3		New	06/17/2026	355-357 W Pleasantview Ave,2
HC	04/21/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/21/2026	231 Midtown Pl
HC	03/06/2026	Means of Egress	Each floor of a stairwell shall have a sign indicating a stairwell designation and the floor number (i.e. Stair 1, Floor 2). Have signs posted on each level in each stairwell.	N.J.A.C. 5:70-3, 1031.9		Unabated	06/14/2026	390 Hackensack Ave,L/L
HC	03/06/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/20/2026	390 Hackensack Ave,L/L

HC	03/30/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/15/2026	390 Hackensack Ave,274
HC	03/06/2026	Means of Egress	Means of egress shall be illuminated at all times the space is occupied. Repair fixture.	N.J.A.C. 5:70-3, 403.15.4.3		Abated	05/14/2026	390 Hackensack Ave,L/L
HC	03/06/2026	Means of Egress	Combustible or flammable material shall not be stored, placed or kept in any portion of an exit, at the bottom of a stairway, fire escape or other means of escape. Remove all storage.	N.J.A.C. 5:70-3, 1031.1.1		Abated	04/20/2026	390 Hackensack Ave,L/L
HC	04/27/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/27/2026	150 Hobart St
HC	03/05/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/21/2026	774 Main St,BLDG
HC	03/05/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/21/2026	774 Main St,BLDG
HC	05/04/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/03/2026	283 Main St
HC	05/04/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/03/2026	277 Main St
HC	04/09/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/07/2026	67 S Prospect Ave
HC	05/07/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/21/2026	211 S Newman St
HC	03/18/2026	Means of Egress	Fire Escapes shall be certified by a registered design professional every 5 years.	N.J.A.C. 5:70-3, 1031.7.3		Abated	04/17/2026	720 Summit Ave
HC	05/06/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/05/2026	206 S Park St
HC	05/06/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/05/2026	3 University Plz,Build
HC	05/06/2026	Means of Egress	Combustible or flammable material shall not be stored, placed or kept in any portion of an exit, at the bottom of a stairway, fire escape or other means of escape. Remove all storage.	N.J.A.C. 5:70-3, 1031.1.1		New	06/05/2026	3 University Plz,Build
HC	03/11/2026	Means of Egress	Exterior egress (fire escapes and ladders, doors, pathways, etc.) shall be clear of snow and ice or any obstruction that would prevent its use.	N.J.A.C. 5:70-3, 1031.3		Abated	04/10/2026	145 English St

HC	03/04/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	03/05/2026	390 Hackensack Ave,146B
HC	03/31/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	04/15/2026	614 Main St
HC	03/11/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/10/2026	133 Commerce Way
HC	03/09/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	04/08/2026	106 Hobart St
HC	03/09/2026	Means of Egress	Combustible or flammable material shall not be stored, placed or kept in any portion of an exit, at the bottom of a stairway, fire escape or other means of escape. Remove all storage.	N.J.A.C. 5:70-3, 1031.1.1		New	04/08/2026	221 Main St,2nd & 3rd Flr
HC	03/10/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	04/09/2026	370 W Pleasantview Ave,2
HC	04/07/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/07/2026	204 Railroad Ave
HC	03/03/2026	Means of Egress	Fire escape appears to be in a state of deterioration and in need of repair. Submit report from certified professional results from load test or documentation of repairs made with an indication that the fire escape is sound and useable.	N.J.A.C. 5:70-3, 1031.7.1		Abated	04/02/2026	60 Prospect Ave
HC	03/03/2026	Means of Egress	Fire escapes must be kept clear at all times, remove storage.	N.J.A.C. 5:70-3, 1031.1.1		Abated	04/01/2026	60 Prospect Ave
HC	04/01/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	05/01/2026	261 Maple Hill Dr
HC	04/17/2026	Means of Egress	Means of egress shall be illuminated at all times the space is occupied. Repair fixture.	N.J.A.C. 5:70-3, 403.15.4.3		New	05/04/2026	25 E Salem St,Building
HC	04/17/2026	Means of Egress	Combustible or flammable material shall not be stored, placed or kept in any portion of an exit, at the bottom	N.J.A.C. 5:70-3, 1031.1.1		New	05/04/2026	25 E Salem St,Building

			of a stairway, fire escape or other means of escape. Remove all storage.					
HC	03/03/2026	Means of Egress	Fire escapes must be kept clear at all times, remove storage.	N.J.A.C. 5:70-3, 1031.1.1		Abated	04/02/2026	64 Prospect Ave
HC	03/03/2026	Means of Egress	Fire escape appears to be in a state of deterioration and in need of repair. Submit report from certified professional results from load test or documentation of repairs made with an indication that the fire escape is sound and useable.	N.J.A.C. 5:70-3, 1031.7.1		Abated	04/02/2026	64 Prospect Ave
HC	06/01/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	06/14/2026	55 Midtown Bridge Approach,2
HC	04/16/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/20/2026	1 State St
HC	04/16/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/20/2026	1 State St
HC	06/01/2026	Means of Egress	Remove air conditioner from window(s) serving fire escape(s)	N.J.A.C. 5:70-3, 1031.1		New	07/01/2026	406 Prospect Ave
HC	03/25/2026	Means of Egress	Fire escape appears to be in a state of deterioration and in need of repair. Submit report from certified professional results from load test or documentation of repairs made with an indication that the fire escape is sound and useable.	N.J.A.C. 5:70-3, 1031.7.1		Abated	05/29/2026	5 Moonachie Rd
HC	04/29/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Abated	05/29/2026	205 Essex St,REAR
HC	03/27/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		Unabated	04/26/2026	89 Old River St
HC	06/03/2026	Means of Egress	Means of egress may not be obstructed, remove obstruction.	N.J.A.C. 5:70-3, 1031.1		New	07/03/2026	263 S River St,2
HC	04/16/2026	Egress Doors	Egress doors shall be readily openable from the egress side without the use of a key, special knowledge or effort.	N.J.A.C. 5:70-3, 1010.1.9		Abated	05/20/2026	1 State St
HC	03/09/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		New	04/08/2026	106 Hobart St
HC	03/09/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		New	04/08/2026	20 Wysocki Pl
HC	05/07/2026	Egress Doors	All doors, passageways and stairways that do not provide for a means of egress that can easily be	N.J.A.C. 5:70-3, 1031.5		New	06/06/2026	40 Jefferson St,BLDG

			mistaken for a means of egress shall Post a sign indicating "NOT AN EXIT"					
HC	05/15/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		New	06/14/2026	155 State St,1
HC	05/18/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		New	06/17/2026	355-357 W Pleasantview Ave,2
HC	05/18/2026	Egress Doors	Interior stairway doors must be openable from both sides. Remove lock.	N.J.A.C. 5:70-3, 1010.1.9.12		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	05/18/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	04/20/2026	Egress Doors	Make necessary repairs to means of egress devices and safeguards to ensure it is functioning properly.	N.J.A.C. 5:70-3, 1031.4		Unabated	05/20/2026	500 S River St,1
HC	05/20/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		New	06/19/2026	340 Hudson St,BLDG
HC	04/24/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		Unabated	05/24/2026	22 Fairmount Ave
HC	04/27/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		Abated	05/27/2026	75 State St
HC	04/30/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		New	05/30/2026	171 S Newman St, UNIT B
HC	04/14/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		New	05/14/2026	268 Main St,2
HC	06/01/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		Abated	06/01/2026	160 River St,BLDG
HC	05/11/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		Unabated	07/02/2026	228 River St
HC	06/03/2026	Key Boxes	Knox Box keys need to be updated, contact Fire Prevention to arrange for an appointment to access box and replace keys. 201-646-7685	N.J.A.C. 5:70-3, 506.2		Abated	06/03/2026	324 Main St

HC	06/03/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	07/03/2026	450 Hackensack Ave,1
HC	03/25/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Abated	05/12/2026	230 Central Ave
HC	05/04/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Abated	06/03/2026	25 Zabriskie St
HC	04/01/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	05/01/2026	261 Maple Hill Dr
HC	04/10/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	05/10/2026	92 Second St,Building
HC	03/13/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	04/12/2026	277 Prospect Ave,Building
HC	03/03/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	04/02/2026	140 Prospect Ave
HC	03/31/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Abated	03/31/2026	421 Jackson Ave
HC	05/01/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	05/31/2026	65 Central Ave
HC	04/27/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Unabated	05/27/2026	20 Jefferson St
HC	03/27/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Abated	05/18/2026	245 Prospect Ave
HC	05/26/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		New	06/25/2026	149 Main St
HC	04/29/2026	Emergency Generators	Generator test required annually under load conditions as per NFPA 110 & NFPA 111	604.4.1.3		Abated	05/21/2026	500 S River St,22
HC	05/20/2026	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2		New	06/19/2026	75 Atlantic St
HC	04/13/2026	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2		Unabated	05/13/2026	88 Clinton Pl
HC	04/07/2026	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2		Abated	05/07/2026	2-4 Prospect Ave
HC	03/18/2026	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2		Abated	04/17/2026	60 Arcadia Rd

HC	03/18/2026	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2		Abated	04/17/2026	105 Arcadia Rd
HC	05/07/2026	Storage	Remove storage from utility room/s.	N.J.A.C. 5:70-3, 315.3.3		New	06/06/2026	450 Hackensack Ave,3
HC	05/07/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	06/06/2026	466 Hackensack Ave
HC	05/07/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	06/06/2026	450 Hackensack Ave,26
HC	05/06/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	06/05/2026	206 S Park St
HC	05/06/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	06/05/2026	175 Terrace Pl
HC	05/06/2026	Storage	No storage is allowed in exposed roof joints, attics, under floors or in concealed spaces unless the storage side is protected with 1 hour fire rated construction. (building not sprinklered)	N.J.A.C. 5:70-3, 315.3.4		New	06/05/2026	140 Hobart St
HC	05/01/2026	Storage	Remove storage from utility room/s.	N.J.A.C. 5:70-3, 315.3.3		New	05/31/2026	225 State St
HC	05/01/2026	Storage	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 1031.1.1		New	05/31/2026	225 State St
HC	05/01/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		New	05/31/2026	205 State St,Police
HC	05/04/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	06/03/2026	283 Main St
HC	05/04/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	06/03/2026	283 Main St
HC	05/04/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	06/03/2026	283 Main St

HC	03/25/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Unabated	04/24/2026	382 Main St,2nd Flr Rear
HC	04/29/2026	Storage	Outside storage must be at least 15 feet from buildings	N.J.A.C. 5:70-3, 315.4		New	05/29/2026	85 Zabriskie St,Rear
HC	04/29/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	05/29/2026	110 Clarendon Pl
HC	04/28/2026	Storage	Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.	N.J.A.C. 5:70-3, 304.1		New	05/28/2026	175 Lexington Ave,A
HC	03/05/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Abated	04/04/2026	12 E Mercer St
HC	04/23/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	05/23/2026	500 S River St,6A
HC	03/24/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Abated	04/23/2026	320 River St
HC	03/25/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	04/24/2026	171 Lexington Ave
HC	03/05/2026	Storage	No storage is allowed in exposed roof joints, attics, under floors or in concealed spaces unless the storage side is protected with 1 hour fire rated construction. (building not sprinklered)	N.J.A.C. 5:70-3, 315.3.4		Abated	04/04/2026	88 Polifly Rd
HC	03/05/2026	Storage	Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.	N.J.A.C. 5:70-3, 304.1		Abated	04/04/2026	88 Polifly Rd
HC	03/17/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Unabated	04/01/2026	180 Hackensack Ave
HC	03/10/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Abated	04/09/2026	370 W Pleasantvie w Ave,2

HC	04/10/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Unabated	05/10/2026	92 Second St,Building
HC	04/01/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Storage	Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.	N.J.A.C. 5:70-3, 304.1		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	05/01/2026	39 Euclid Ave
HC	04/01/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	04/16/2026	29 Shafer Pl
HC	04/01/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		New	04/16/2026	29 Shafer Pl
HC	04/01/2026	Storage	Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.	N.J.A.C. 5:70-3, 304.1		New	04/16/2026	29 Shafer Pl
HC	03/11/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		Abated	03/23/2026	215.5 Main St,2nd Flr
HC	03/16/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Abated	04/15/2026	115 Lawrence St
HC	05/12/2026	Storage	Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.	N.J.A.C. 5:70-3, 304.1		New	06/11/2026	16 Marion St,2
HC	05/12/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	06/11/2026	16 Marion St,2
HC	05/12/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	06/11/2026	92 Summit Ave

HC	03/31/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		Abated	04/30/2026	85 Atlantic St
HC	04/27/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Abated	05/27/2026	75 State St
HC	05/14/2026	Storage	Remove storage from utility room/s.	N.J.A.C. 5:70-3, 315.3.3		New	06/13/2026	390 Hackensack Ave,L/L
HC	04/13/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		Abated	05/14/2026	71 Main St,1st Flr
HC	05/14/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		New	06/13/2026	390 Hackensack Ave,L/L
HC	05/14/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	06/13/2026	390 Hackensack Ave,L/L
HC	03/06/2026	Storage	Outside storage must be at least 15 feet from buildings	N.J.A.C. 5:70-3, 315.4		Abated	04/05/2026	220 Gracie Pl
HC	03/06/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		Abated	04/05/2026	220 Gracie Pl
HC	04/06/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		Unabated	05/06/2026	137 Hudson St
HC	04/27/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		Abated	05/28/2026	206 Central Ave
HC	04/27/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		Abated	05/28/2026	206 Central Ave
HC	05/18/2026	Storage	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 1031.1.1		Abated	06/17/2026	104 Elm Ave
HC	05/28/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		New	06/27/2026	336 Main St
HC	05/28/2026	Storage	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 1031.1.1		New	06/27/2026	336 Main St
HC	05/28/2026	Storage	Improper Storage, Remove all combustible or flammable storage from in and around stairwells.	N.J.A.C. 5:70-3, 1031.1.1		New	06/27/2026	336 Main St

HC	05/04/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		Unabated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Unabated	06/03/2026	25 Zabriskie St
HC	05/04/2026	Storage	Remove storage from utility room/s.	N.J.A.C. 5:70-3, 315.3.3		Unabated	06/03/2026	25 Zabriskie St
HC	05/18/2026	Storage	Storage of combustible materials in buildings shall be neat and orderly. Organize area and/or reduce amount of storage.	N.J.A.C. 5:70-3, 315.3		Unabated	06/17/2026	153 Lawrence St
HC	05/18/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Unabated	06/17/2026	153 Lawrence St
HC	06/03/2026	Storage	No storage is allowed in exposed roof joints, attics, under floors or in concealed spaces unless the storage side is protected with 1 hour fire rated construction. (building not sprinklered)	N.J.A.C. 5:70-3, 315.3.4		New	07/03/2026	450 Hackensack Ave,1
HC	06/03/2026	Storage	Storage of combustible and/or flammable materials shall be confined to approved storage areas.	N.J.A.C. 5:70-3, 315.3.5		New	07/03/2026	450 Hackensack Ave,1
HC	06/02/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	07/02/2026	199 Lee Pl
HC	06/02/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	07/02/2026	51 Cleveland St
HC	03/20/2026	Storage	Storage must be maintained orderly with 24 inch clearance below ceiling (unsprinklered). Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		Abated	04/16/2026	1 State St
HC	05/29/2026	Storage	Storage must be maintained orderly with 18 inch clearance below sprinkler head deflector. Remove high storage.	N.J.A.C. 5:70-3, 315.3.1		New	06/28/2026	500 S River St,5
HC	06/01/2026	Storage	Storage of materials shall be removed from the area to maintain adequate clearance around equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		New	06/14/2026	55 Midtown Bridge Approach,2

HC	05/06/2026	Smoking Conditions	Smoking is Prohibited in rooming units. Discontinue smoking or penalties/court summons will be issued!	N.J.A.C. 5:70-3, 320.1.2		New	06/05/2026	175 Terrace Pl
HC	04/23/2026	Local Fees and LHUs	Court Summons Issued	N.J.A.C. 5:70-2.12(f)		New	05/23/2026	14 E Camden St
HC	04/02/2026	Local Fees and LHUs	State of NJ current Life Hazard Use Certificate shall be posted. Provide a copy of current cert. to the Fire Official. Obtain certificate from NJ DCA. FireOfficial@Hackensack.org	N.J.A.C. 5:70-2.6.(c)		Abated	04/30/2026	139 First St
HC	04/14/2026	Local Fees and LHUs	Failure to pay registration/inspection fee	88 88-5		New	05/14/2026	142 John St,3rd Flr
HC	03/24/2026	Local Fees and LHUs	Failure to pay registration/inspection fee	88 88-5		Unabated	11/01/2025	162 Hudson St,1ST FLR
HC	05/27/2026	Local Fees and LHUs	Court Summons Issued	N.J.A.C. 5:70-2.12(f)		New	06/26/2026	685 Main St
HC	05/26/2026	Local Fees and LHUs	Failure to pay registration/inspection fee	88 88-5		New	06/25/2026	10 Banta Pl,106
HC	05/26/2026	Local Fees and LHUs	Due to unabated violations a Penalty has been issued for this registration. Failure to pay Penalty may result in a court summons. Contact the Fire Official for Further information 201-646-3939, FireOfficial@Hackensack.org.	N.J.A.C. 5:70-2.12		New	06/25/2026	183 Bloom St
HC	05/26/2026	Local Fees and LHUs	Failure to pay registration/inspection fee	88 88-5		New	06/25/2026	3 Banta Pl
HC	03/24/2026	Local Fees and LHUs	Failure to pay registration/inspection fee	88 88-5		Abated	05/26/2026	1 University Plz,301
HC	05/12/2026	Local Fees and LHUs	State of NJ current Life Hazard Use Certificate shall be posted. Provide a copy of current cert. to the Fire Official. Obtain certificate from NJ DCA. FireOfficial@Hackensack.org	N.J.A.C. 5:70-2.6.(c)		New	06/11/2026	16 Marion St,2
HC	03/06/2026	Fire Drills & Evacuation	Fire Safety Drills shall be conducted in accordance with Table 405.2	404.2		Unabated	06/14/2026	390 Hackensack Ave,L/L
HC	04/02/2026	Fire Drills & Evacuation	Fire Safety Drills shall be conducted in accordance with Table 405.2	404.2		Abated	04/30/2026	139 First St
HC	03/03/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	04/02/2026	390 Hackensack Ave,259B
HC	03/03/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		New	04/02/2026	14 E Camden St

HC	03/12/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	04/16/2026	171 Main St,302
HC	03/12/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Abated	04/16/2026	171 Main St,302
HC	04/14/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	04/22/2026	294-298 State St,1
HC	04/29/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		New	05/29/2026	110 Clarendon Pl
HC	04/29/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	05/29/2026	110 Clarendon Pl
HC	03/05/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	04/13/2026	125 Main St
HC	04/07/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/07/2026	6-8 Prospect Ave
HC	04/09/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/07/2026	67 S Prospect Ave
HC	04/07/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	05/07/2026	204 Railroad Ave
HC	04/07/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	05/07/2026	204 Railroad Ave
HC	03/26/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Unabated	04/25/2026	139 Hudson St,A
HC	04/22/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	05/22/2026	64 Prospect Ave
HC	04/14/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		Unabated	05/14/2026	314 Essex St
HC	04/21/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	05/21/2026	70 Longview Ave
HC	04/21/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		New	05/21/2026	70 Longview Ave
HC	04/16/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	05/16/2026	280 Summit Ave,Building
HC	03/18/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	04/17/2026	11 Berkshire Pl

HC	03/17/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	04/01/2026	180 Hackensack Ave
HC	03/03/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		New	04/02/2026	140 Prospect Ave
HC	03/09/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		New	04/08/2026	20 Wysocki Pl
HC	03/09/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	04/08/2026	20 Wysocki Pl
HC	03/12/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		New	04/11/2026	15 Conklin Pl,Sch
HC	03/31/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		New	04/15/2026	614 Main St
HC	04/21/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/18/2026	231 Midtown Pl
HC	03/06/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		Abated	04/05/2026	220 Gracie Pl
HC	03/06/2026	Electrical	Storage of materials shall be removed from the front of electrical service equipment. Clearance shall be 30 inches width, 36 inches depth and 78 inches height.	N.J.A.C. 5:70-3, 604.3		Abated	04/05/2026	220 Gracie Pl
HC	04/15/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/15/2026	335 Union St
HC	05/18/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	03/25/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	04/24/2026	401 Hackensack Ave,502
HC	03/11/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	04/14/2026	141 Main St,B
HC	03/11/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	04/14/2026	141 Main St,B

HC	03/11/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	04/10/2026	141 Main St,B
HC	03/31/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	04/30/2026	687 Main St
HC	03/31/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	04/30/2026	687 Main St
HC	03/26/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/13/2026	219 Sussex St
HC	03/26/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/13/2026	219 Sussex St
HC	03/26/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/13/2026	219 Sussex St
HC	03/26/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/13/2026	219 Sussex St
HC	04/27/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/27/2026	75 State St
HC	04/01/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	05/01/2026	157 Hobart St
HC	03/26/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/13/2026	219 Sussex St
HC	03/10/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	04/09/2026	36 Kennedy St
HC	04/01/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/01/2026	370 W Pleasantvie w Ave,12
HC	04/01/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Abated	05/01/2026	370 W Pleasantvie w Ave,12
HC	05/14/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	06/13/2026	156 S Main St
HC	05/14/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/14/2026	150 Atlantic St,2
HC	04/13/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	05/13/2026	71 Main St,1st Flr
HC	05/26/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	06/25/2026	300 Hudson St
HC	05/26/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	06/25/2026	75 Summit Ave,200

HC	05/26/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	06/25/2026	18 Dicarolis Ct
HC	05/20/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		New	06/19/2026	286 Union St,1
HC	05/20/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		New	06/19/2026	286 Union St,1
HC	05/20/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		New	06/19/2026	95 Anderson St
HC	05/21/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		New	06/20/2026	275 Main St
HC	03/26/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	03/26/2026	500 S River St,21
HC	04/24/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		Unabated	06/26/2026	157 Central Ave
HC	04/24/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Unabated	06/26/2026	157 Central Ave
HC	04/24/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	06/26/2026	157 Central Ave
HC	05/27/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Unabated	06/26/2026	70 Polifly Rd
HC	04/02/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	05/02/2026	15 Salem St,1
HC	04/02/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/02/2026	15 Salem St,1
HC	04/02/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Abated	05/02/2026	15 Salem St,1
HC	04/02/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	05/02/2026	15 Salem St,1
HC	04/02/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/02/2026	15 Salem St,1
HC	04/02/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Abated	05/02/2026	15 Salem St,1
HC	04/21/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/21/2026	409 Rte 17 S

HC	04/21/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/12/2026	409 Rte 17 S
HC	05/27/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		New	06/26/2026	50 Johnson Ave,1
HC	05/27/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	06/26/2026	50 Johnson Ave,1
HC	05/27/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Unabated	06/26/2026	70 Polifly Rd
HC	04/22/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/22/2026	235 Moore St,3RD FLR
HC	04/22/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Abated	05/22/2026	235 Moore St,3RD FLR
HC	05/28/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		New	06/27/2026	336 Main St
HC	04/27/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		Abated	05/28/2026	206 Central Ave
HC	04/27/2026	Electrical	Multiplug adapters and unfused plug strips prohibited, remove same.	N.J.A.C. 5:70-3, 604.4		Abated	05/28/2026	206 Central Ave
HC	04/27/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Abated	05/28/2026	206 Central Ave
HC	04/23/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		Unabated	05/23/2026	254 Main St
HC	04/23/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		Unabated	05/23/2026	254 Main St
HC	05/08/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		New	06/07/2026	30 Prospect Ave,9
HC	05/08/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		New	06/07/2026	30 Prospect Ave,9
HC	04/16/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		Withdrawn	05/16/2026	1 State St
HC	04/16/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/20/2026	1 State St
HC	04/16/2026	Electrical	Electrical hazards shall be abated.	N.J.A.C. 5:70-3, 604.1		Unabated	05/16/2026	1 State St

HC	04/16/2026	Electrical	Remove or properly secure open junction boxes and splices	N.J.A.C. 5:70-3, 604.6		Abated	05/20/2026	1 State St
HC	06/03/2026	Electrical	Surge protection devices shall be plugged directly into a receptacle, they may not be plugged into an extension cord or piggy-backed.	N.J.A.C. 5:70-3, 604.4.2		New	07/03/2026	450 Hackensack Ave,1
HC	06/03/2026	Electrical	Extension cords shall not substitute for permanent wiring, remove cord.	N.J.A.C. 5:70-3, 604.5		New	07/03/2026	450 Hackensack Ave,1
HC	05/18/2026	Electrical	Clearance required around electrical service equipment (30 in wide x 36 in deep x 78 in height). Remove objects/storage in front of equipment.	N.J.A.C. 5:70-3, 604.3		Unabated	06/17/2026	153 Lawrence St
HC	04/14/2026	Open Flame / Precautions Against Fire	Remove stored combustible materials that are within 3 ft. of unit heaters, radiant space heaters, water heaters, flues etc..	N.J.A.C. 5:70-3, 315.3		Abated	05/14/2026	110 Anderson St
HC	05/12/2026	Open Flame / Precautions Against Fire	Liquefied-petroleum gas fueled cooking devices and/or cylinders (Propane Grills) shall not be stored or used on or in any portion of a building or within 10 feet of combustible construction.	88 88-6		New	06/11/2026	16 Marion St,2
HC	05/12/2026	Open Flame / Precautions Against Fire	Unvented fuel fired heaters prohibited. Remove Heating equipment.	N.J.A.C. 5:70-3, 603.4		New	06/11/2026	16 Marion St,2
HC	04/08/2026	Open Flame / Precautions Against Fire	Outdoor Open Flame Devices i.e. Grills, torches, fireplaces, etc. shall be prohibited on combustible decks or within 5 feet of combustible construction. Exception, electric grills.	N.J.A.C. 5:70-3, 308.1.4		Abated	05/18/2026	360 W Pleasantview Ave,BLDG
HC	03/24/2026	Open Flame / Precautions Against Fire	Repair chimney/flu pipe connection. Submit repair report to HFDFFP@Hackensack.org.	N.J.A.C. 5:70-3, 603.6		Abated	04/23/2026	278 River St
HC	03/19/2026	Multiple Dwelling	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/SafetyAffidavit	N.J.A.C. 5:70-2.2.(a)		New	04/17/2026	90 Arcadia Rd
HC	03/19/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	04/17/2026	90 Arcadia Rd

HC	03/23/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/22/2026	215.5 Main St,2nd Flr
HC	03/13/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		Abated	04/12/2026	109 Lodi St
HC	03/16/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		Abated	03/31/2026	115 Lawrence St
HC	05/07/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	06/06/2026	40 Jefferson St,BLDG
HC	04/29/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	05/29/2026	110 Clarendon Pl
HC	04/30/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		New	05/30/2026	245 Central Ave
HC	05/18/2026	Multiple Dwelling	Emergency exit/emergency lights shall be tested annually for a duration of 1 hour. Submit documentation of results. Forward to Fire Prevention HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 1031.10.2		New	06/17/2026	360 W Pleasantvie w Ave,BLDG
HC	05/18/2026	Multiple Dwelling	Current NFPA annual sprinkler and or standpipe report requested. Forward to Fire Prevention HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 903.5		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Multiple Dwelling	Provide a copy of NFPA annual Fire Alarm report to Fire Prevention. (201)646-7594 (fax) or HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 907.8		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Multiple Dwelling	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/SafetyAffidavit	N.J.A.C. 5:70-2.2.(a)		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Multiple Dwelling	Emergency exit/emergency lights shall be tested annually for a duration of 1 hour. Submit documentation of results. Forward to Fire Prevention HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 1031.10.2		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Multiple Dwelling	Emergency generator annual load test required. Forward report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 1203.4.2.1		New	06/17/2026	355-357 W Pleasantvie w Ave,2
HC	05/18/2026	Multiple Dwelling	Emergency generator annual load test required. Forward report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 1203.4.2.1		New	06/17/2026	360 W Pleasantvie w Ave,BLDG

HC	05/18/2026	Multiple Dwelling	Current NFPA annual sprinkler and or standpipe report requested. Forward to Fire Prevention HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 903.5		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	05/18/2026	Multiple Dwelling	Provide a copy of NFPA annual Fire Alarm report to Fire Prevention. (201)646-7594 (fax) or HFDFP@Hackensack.org	N.J.A.C. 5:70-3, 907.8		New	06/17/2026	360 W Pleasantview Ave,BLDG
HC	04/28/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/28/2026	281 Park St
HC	04/28/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		Unabated	05/28/2026	281 Park St
HC	05/18/2026	Multiple Dwelling	Emergency generator annual load test required. Forward report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 1203.4.2.1		New	06/17/2026	377-379 W Pleasantview Ave,1
HC	04/28/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		Unabated	05/28/2026	403 Washington Ave
HC	04/27/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		Abated	05/28/2026	206 Central Ave
HC	05/27/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	06/26/2026	70 Polifly Rd
HC	05/27/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	06/26/2026	370 Park St
HC	05/28/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	06/27/2026	125 Prospect Ave,Building
HC	05/22/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		New	06/21/2026	420 Passaic St
HC	05/22/2026	Multiple Dwelling	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/SafetyAffidavit	N.J.A.C. 5:70-2.2.(a)		New	06/21/2026	420 Passaic St
HC	05/22/2026	Multiple Dwelling	Install or replace missing stairwell reflectors. Green Reflector indicates stairwell leads to a rooftop Opening, Red indicates stairwell does not.	88 88-6		New	06/21/2026	420 Passaic St
HC	05/22/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFDFP@Hackensack.org.	N.J.A.C. 5:70-3, 907.8.5		New	06/21/2026	420 Passaic St

HC	05/13/2026	Multiple Dwelling	Complete and submit the provided Residential unit safety affidavit stating a building representative has checked all units. A copy of the form can be found at Hackensack.org/SafetyAffidavit	N.J.A.C. 5:70-2.2.(a)		Abated	06/12/2026	150 Grand Ave
HC	05/13/2026	Multiple Dwelling	Wired unit smoke detectors shall be certified annually by a licensed professional. Forward current report to Fire Prevention HFD FP@Hackensack.org .	N.J.A.C. 5:70-3, 907.8.5		Abated	06/12/2026	150 Grand Ave
HC	03/25/2026	Multiple Dwelling	Clothes dryer vents must be cleaned regularly to prevent the buildup of lint.	N.J.A.C. 5:70-3, 610.1.2		Abated	05/12/2026	230 Central Ave