

3-8-72 - Use to
7-5-79 - not w/
H. Ketter re problem
leading out
7 yrs. 4 mos.
6 children

BOARD OF HEALTH
Township of Washington
County of Morris

No 226

PERMIT TO LOCATE AND CONSTRUCT OR ALTER
AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM

In Accordance with Chapter 199 Public Laws of 1954 as Adopted by
Ordinance of the Board of Health

Permission is hereby granted Paula Ace (D. Harring)
Name of Owner or Contractor

Address

☒ Locate and construct or to ☐ Alter

AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM

Map Name if any _____

Location: Section I Block No. 42A Lot No. 13 Street 197 Lintlock Ave -

as shown on Application for Permit to Locate and Construct or Alter an Individual
Sewage Disposal System Number _____

IN ACCORDANCE WITH Chapter 199 Public Laws of 1954, the Standards of the
New Jersey State Department of Health, the Ordinances of the Township of Wash-
ington and the Ordinances of the Board of Health of the Township of Washington.

Neither the issuance of this permit nor the issuance of an occupancy permit shall be
construed as a guarantee or representation by the Board of Health that the Sewage
Disposal System will operate properly.

BOARD OF HEALTH OF WASHINGTON TOWNSHIP

Date 8-25-71

[Signature]
For the Board of Health

Fee: \$20.00

(P)

BOARD OF HEALTH
TOWNSHIP OF WASHINGTON
County of Morris

**APPLICATION FOR PERMIT TO LOCATE AND CONSTRUCT OR ALTER
AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM**

In Accordance with Chapter 199 Public Laws of 1954 as Adopted by Ordinance.

Installation: New ☒ Alteration _____ Date August 24, 1971

Location: Address of Building 19 FLINTLOCK DRIVE

Map Name if any PARKER ACRES

Section No. I Block No. 42A Lot No. 13

Owner's Name (print) PARKER ACRES, INC.

Owner's Address CHESTER, NEW JERSEY

Name and Address of Contractor if any _____

Type of Building to be served: Dwelling ☒ Garage _____ Occupied 12 months per year

Other—Type of Building _____ Gals. per person per day _____

Dwelling Unit—No. of Bed Rooms 3 Expansion Attic—Yes _____ No ☒

No. of Persons to occupy premises _____

Check: Type of Facilities: Sink _____ Tub _____ Basin _____ Toilet _____ Shower _____ Other _____

Size of Lot 130 X 240 Area sq. ft. 31,578.23

Septic Tank NOTE: 4 in. cast iron pipe to be used from building to septic tank.

Liquid Capacity 1000 Gals. Material: Steel _____ or Concrete ☒

Width - - ft. Length - - ft. Diameter 6'-4" ft.

Liquid depth 5'-4" Distance from liquid level to underside of top 5"

Check:

Liquid Disposal

Disposal Trenches _____ Disposal Bed _____ Seepage Pits ☒ Cesspool _____ Vault _____

Disposal Trenches

Width _____ ft.; Depth _____ ft.; Lin. Feet of Pipe _____; Distance between lines _____

Type of pipe: Tile _____ Orangeburg _____ Others _____

Disposal Bed

Width _____ ft.; Length _____ ft.; Area sq. ft. _____; Lin. ft. of pipe _____; Distance between lines _____

Type of pipe: Tile _____ Orangeburg _____ Others _____

Seepage Pits

When a single seepage pit is specified, two or more seepage pits may be used provided the combined volume is at least equal to the volume of the single pit specified herein.

Number 2 Diameter 10 ft.; Depth below inlet 7.5 ft.; Distance between pits 30 ft.

Shape of Pits circular Construction material: Cinder Blocks ☒ Others _____

Cesspool: Depth _____ feet Diameter _____ feet. Vault: Dimensions _____

Material _____

Remarks: WELL MUST BE LOCATED 100 FEET FROM ANY COMPONENT OF THE SEPTIC SYSTEM AND ADJOINING WELLS.

Depth of Permeable Material to be Penetrated _____

PERCOLATION TEST RESULTS


Hole No.	Stabilized Rate	No. of Tests to Determine Saturation	Depth	Type of Soil Encountered Depth of Each Type
<u>1</u>	<u>15</u>	<u>2</u>	<u>96"</u>	<u>0-4" Top Soil</u>

BRANDES ENGINEERING COMPANY

455 EAST MAIN STREET
CHESTER, NEW JERSEY, 07930
P. O. BOX 351

F. A. BRANDES
P. E. & L. S. 12122

TELEPHONE
201 - 879-7333



- NOTES**
- ① DEWENWAY TO BE CONSTRUCTED TO TOWNSHIP SPECIFICATIONS.
 - ② WELL MUST BE 100 FT FROM SEPTIC SYSTEM AND ADJACENT WELLS.

PROPERTY OF

SITE PLAN

PARKER ACRES SECTION I

WASHINGTON TOWNSHIP, MORRIS COUNTY,
NEW JERSEY

SCALE 1" = 40'

JANUARY, 1970

Fred A. Brandes
FRED A. BRANDES P. E. & L. S. 12122