



Cranford Township
Property Maintenance Code Enforcement
8 Springfield Avenue
Cranford Township, NJ 07016

Violation # CPMV-18-00066

NOTIFICATION OF ABATEMENT

MURRAY: THOMAS
702 SPRINGFIELD AVE
CRANFORD, NJ 07016

Re: 702 SPRINGFIELD AVE

☒ Issued to Owner
☐ Issued to Tenant

Block 198 Lot 44 Qual

This is to acknowledge that the listed violation has conformed to the requirements of the municipality and is Closed

Inspection Date: 11/4/2018

Abate by: 12/2/2018

Closed: 5/15/2019

The following violation(s) were found

Section 302.7

Title Accessory Structures

Accessory structures, including detached garages, fences and walls, shall be maintained structurally sound and in good repair

Summary of infraction

Please repair detached garage to be structurally sound and secure all doors to prevent infestation of rodents.

You may call the Code Enforcement office if you have any further questions concerning this matter at (908) 709-7240

John Cleary

Date Printed 2/12/2022