

Inspection Report
Borough of Hasbrouck Heights
Fire Prevention Bureau

Local ID: 0098
Registration #:

Date: June 22, 2023
Inspector:

LHU Class: BOCA Use: B
Occupancy load:

Business: On Sai Services LLC
454 Boulevard

Phone: 201-257-8799

Business Owner: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

Phone: 973-975-5858

Emerg. Contacts: #1: Joe Torre (landlord)
#2: Pratik Dhruve
#3:

Phone: 201-394-9659
Phone: 973-975-5858
Phone:

[] -Annual [] -Quarterly [] -Complaint

Attic () yes () no	Exit Signs () yes () no	# of Stories _____	Area (in Sq. Ft.)
Basement () yes () no	Emergency Lights () yes () no		Building _____
Roof Hatches () yes () no	Fire Escapes () yes () no		LHU _____
Skylights () yes () no	Elevators () yes () no		Basement _____
	Elevator Recall () yes () no	Exits per Floor _____	

Extinguishers () yes () no	Fire Detection System () yes () no Smoke Detectors - Hard Wired () yes () no Smoke Detectors - Battery () yes () no Heat Detectors () yes () no Manual Pull () yes () no Alarm () Local () Central System	PERMITS () Annual () Temporary Type: _____ _____ _____ _____ _____ Date Issued _____ Date of Expiration _____ Permit Number _____
Test Records () yes () no		
Cooking Protected () yes () no () n/a		
Test Records () yes () no		
Sprinklers () yes () no () n/a () full () basement () partial () spray booth	Standpipes () yes () no () wet () dry Test Records () yes () no Fire Department Connection () yes () no Alarm () yes () no () Local () Central	
Test Records () yes () no		
Fire Pump () yes () no		
Test Records () yes () no		
Fire Dept. Connection () yes () no		
Sprinkler Alarm () yes () no () local () central		
Date of Last Inspection _____	Date of Last Inspection _____	

Emergency Generator () yes () no () n/a **Records** () yes () no

Floor Construction	[] Concrete	[] Wood				
Bearing Walls	[] Concrete	[] Block	[] Wood	[] Brick	[] Metal	[] Other
Ceiling	[] Plaster	[] Sheet Rock	[] Wood	[] Acoustic	[] Metal	[] Other
Roof Construction	[] Concrete	[] Reinf. Concrete	[] Wood	[] Trusses	[] Metal	[] Other
Heating [] Oil	[] Gas	[] Electric	[] Other	[] Hot Water	[] Hot Air	[] Steam
Electric	[] Fuses	[] Circuit Breakers		Wiring	[] Good	[] Poor

Inspector (print)

Certification #

Reviewed by

Number of Violations

Maint.

Retro

Inspection Date

Premises: On Sai Services LLC
454 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0098
Inspection Date: April 8, 2019
Initial Inspector: _____
Print Name: Robert Knobloch
Page number: 1

Owner/Agent: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 1 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: middle over dryers Nature: Means of Egress - Egress Lighting Code Section: N.J.A.C. 5:70-3,1008.2	04/23/2019			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.

Premises: On Sai Services LLC
454 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0098
Inspection Date: June 30, 2020
Initial Inspector: _____
Print Name: Robert Knobloch
Page number: 1

Owner/Agent: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 4 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: over dryer 30 Nature: Means of Egress - Exit signs/directional signs Code Section: N.J.A.C. 5:70-3,1013.1	07/14/2020			
2.	Location: Front Door Nature: Means of Egress - Egress Lighting Code Section: N.J.A.C. 5:70-3,1008.2	07/14/2020			
3.	Location: FIRE ALARM Nature: Fire Protection System - Records of all tests Code Section: N.J.A.C. 5:70-3,901.6.2	07/14/2020			
4.	Location: Electric panel P1 Nature: Electrical - Open electrical junction boxes Code Section: N.J.A.C. 5:70-3,605.6	07/14/2020			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.

Premises: On Sai Services LLC
454 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0098
Inspection Date: April 13, 2021
Initial Inspector: _____
Print Name: Robert Knobloch
Page number: 1

Owner/Agent: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 1 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: rear exit Nature: Means of Egress - Exit signs/directional signs Code Section: N.J.A.C. 5:70-3,1013.1	04/27/2021			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.

Premises: On Sai Services LLC
454 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0098
Inspection Date: May 20, 2022
Initial Inspector: _____
Print Name: Ed Carter
Page number: 1

Owner/Agent: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 4 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Rear Nature: Repair exit light Code Section: N.J.A.C. 5:70-3,1013.1	06/03/2022 *CV*			
2.	Location: Premise Nature: Fire Extinguishers shall be inspected annually, current inspection past due Code Section: N.J.A.C. 5:70-3,906.2	06/03/2022			
3.	Location: Premise Nature: Clean walkway behind dryers, remove debris and build up of lint Code Section: N.J.A.C. 5:70-3,304.1	06/03/2022			
4.	Location: Meter room and behind dryers Nature: Replace covers on open electrical boxes Code Section: N.J.A.C. 5:70-3,605.6	06/03/2022			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.

Premises: On Sai Services LLC
454 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0098
Inspection Date: April 11, 2023
Initial Inspector: _____
Print Name: Marc Pagan
Page number: 1

Owner/Agent: Pratic Dhruve
26 Cobb Pl.
Morristown, NJ 07960

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 3 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Electrical room Nature: Electrical - Open electrical junction boxes Code Section: N.J.A.C. 5:70-3,605.6	04/25/2023			
2.	Location: rear exit Nature: Fire Extinguishers shall be inspected annually, current inspection past due Code Section: N.J.A.C. 5:70-3,906.2	04/25/2023			
3.	Location: Electrical room Nature: Fire Extinguishers shall be inspected annually, current inspection past due Code Section: N.J.A.C. 5:70-3,906.2	04/25/2023			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.

"U" Unabated - Violation uncorrected.

"A" Abated - Violation corrected.

Inspection Report
Borough of Hasbrouck Heights
Fire Prevention Bureau

Local ID: 0291
Registration #:

Date: June 22, 2023
 Inspector:

LHU Class: BOCA Use: B
 Occupancy load:

Business: Washingtoun Launderette
 208 Boulevard

Phone: 201-426-5566

Business Owner: Thomas Cerwas
 584 Palisade Ave.
 Garfield, NJ 07026

Phone: 551-404-3426

Emerg. Contacts: #1: Thomas Cerwas
 #2: [REDACTED]
 #3: [REDACTED]

Phone: 551-404-3426
 Phone: [REDACTED]
 Phone: [REDACTED]

[]-Annual []-Quarterly []-Complaint

Attic () yes () no	Exit Signs () yes () no	# of Stories _____	Area (in Sq. Ft.)
Basement () yes () no	Emergency Lights () yes () no		Building _____
Roof Hatches () yes () no	Fire Escapes () yes () no		LHU _____
Skylights () yes () no	Elevators () yes () no		Basement _____
	Elevator Recall () yes () no	Exits per Floor _____	

Extinguishers () yes () no Test Records () yes () no Cooking Protected () yes () no () n/a Test Records () yes () no	Fire Detection System () yes () no Smoke Detectors - Hard Wired () yes () no Smoke Detectors - Battery () yes () no Heat Detectors () yes () no Manual Pull () yes () no Alarm () Local () Central System	PERMITS () Annual () Temporary Type: _____ _____ _____ _____ _____ Date Issued _____ Date of Expiration _____ Permit Number _____
Sprinklers () yes () no () n/a () full () basement () partial () spray booth Test Records () yes () no Fire Pump () yes () no Test Records () yes () no Fire Dept. Connection () yes () no Sprinkler Alarm () yes () no () local () central Date of Last Inspection _____	Standpipes () yes () no () wet () dry Test Records () yes () no Fire Department Connection () yes () no Alarm () yes () no () Local () Central Date of Last Inspection _____	

Emergency Generator () yes () no () n/a Records () yes () no

Floor Construction	[] Concrete	[] Wood				
Bearing Walls	[] Concrete	[] Block	[] Wood	[] Brick	[] Metal	[] Other
Ceiling	[] Plaster	[] Sheet Rock	[] Wood	[] Acoustic	[] Metal	[] Other
Roof Construction	[] Concrete	[] Reinf. Concrete	[] Wood	[] Trusses	[] Metal	[] Other
Heating [] Oil	[] Gas	[] Electric	[] Other	[] Hot Water	[] Hot Air	[] Steam
Electric	[] Fuses	[] Circuit Breakers		Wiring	[] Good	[] Poor

Inspector (print)

Certification #

Reviewed by

Number of Violations

Maint.

Retro


Inspection Date

BOROUGH OF HASBROUCK HEIGHTS

FIRE PREVENTION BUREAU

248 HAMILTON AVENUE

HASBROUCK HEIGHTS, NJ 07604



Robert Knobloch
Fire Official

(201) 288-4110
FAX: (201) 288-9217

Date: 06/22/2023

Page: .1

To: Washington Launderette
208 Boulevard
Hasbrouck Heights, NJ 07604

STATUS OF FIRE CODE VIOLATIONS and PENALTIES

Registration No.: 0291
Premises: Washington Launderette
Date of Review: June 22, 2023

- [X] According to the Borough of Hasbrouck Heights Fire Prevention Bureau records, as of February 13, 2019 there are no unabated violations or unpaid penalties pertaining to the above premises.


Fire Official

BOROUGH OF HASBROUCK HEIGHTS

FIRE PREVENTION BUREAU

248 HAMILTON AVENUE

HASBROUCK HEIGHTS, NJ 07604



Robert Knobloch
Fire Official

(201) 288-4110
FAX: (201) 288-9217

Date: 06/22/2023

Page: 1

To: Washington Launderette
208 Boulevard
Hasbrouck Heights, NJ 07604

STATUS OF FIRE CODE VIOLATIONS and PENALTIES

Registration No.: 0291
Premises: Washington Launderette
Date of Review: June 22, 2023

[X] According to the Borough of Hasbrouck Heights Fire Prevention Bureau records, as of February 19, 2020 there are no unabated violations or unpaid penalties pertaining to the above premises.

Fire Official

Premises: Washingtown Launderette
208 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0291
Inspection Date: February 22, 2021
Initial Inspector: _____
Print Name: Robert Knobloch
Page number: 1

Owner/Agent: Thomas Cerwas
584 Palisade Ave.
Garfield, NJ 07026

VIOLATIONS

Date:

Inspector:

The violations cited on the above premises are as follows:

Number	Description (Maintenance: 1 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Premises Nature: Fire Extinguishers - Outdated or discharged Code Section: N.J.A.C. 5:70-3,906.2	03/08/2021			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.

Premises: Washingtown Launderette
208 Boulevard

Hasbrouck Heights, NJ 07604

Registration No. 0291
Inspection Date: March 25, 2022
Initial Inspector: _____
Print Name: Ed Carter
Page number: 1

Owner/Agent: Thomas Cerwas
584 Palisade Ave.
Garfield, NJ 07026

VIOLATIONS

Date:			
Inspector:			

The violations cited on the above premises are as follows:


Number	Description (Maintenance: 1 Retrofit: 0)	Abate by	U/A	U/A	U/A
1.	Location: Premise Nature: Fire Extinguishers shall be inspected annually, current inspection past due Code Section: N.J.A.C. 5:70-3,906.2	04/08/2022			

Key: The numbering of violations is for identification purposes only and shall not be construed as bearing in any way on the seriousness of any violation.
"U" Unabated - Violation uncorrected.
"A" Abated - Violation corrected.

BOROUGH OF HASBROUCK HEIGHTS

FIRE PREVENTION BUREAU

248 HAMILTON AVENUE
HASBROUCK HEIGHTS, NJ 07604



Robert Knobloch
Fire Official

(201) 288-4110
FAX: (201) 288-9217

Date: 06/22/2023
Page: 1

To: Washington Launderette
208 Boulevard
Hasbrouck Heights, NJ 07604

STATUS OF FIRE CODE VIOLATIONS and PENALTIES

Registration No.: 0291
Premises: Washington Launderette
Date of Review: June 22, 2023

[X] According to the Borough of Hasbrouck Heights Fire Prevention Bureau records, as of February 6, 2023 there are no unabated violations or unpaid penalties pertaining to the above premises.

Fire Official