



Ramsey Fire Prevention
33 North Central Ave.
Ramsey NJ 07446
Phone# (201) 825-3400 Fax# (201) 825-0123
Attn: Darryl J. DeMott

Inspection History Report

Printed On: 05/16/23 14:17

System ID# : 819

State Reg# :

Local ID : 00823

Business/Occupancy Information

Occupancy Name : Village Square Laundry

Phone : (201) 934-3540

Address : 33 W Main St, Ramsey, NJ 07446

Primary Contact :

Phone :

Inspection History

Start Date Time	Type	Status	Inspector1	End Date Time
04/06/19 13:51	Re-inspectionPeriodic	No Violation Found	Carbone, Rocco	04/06/19 13:53

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	Main	Front Entrance	Portable Fire Extinguishers	Fire extinguisher need to be inspected, maintained and tested in accordance with NFPA 10	N.J.A.C. 5:70-3, 906.2	Service discharged fire extinguisher
	Main	Store & furnace room	Retrofit Code	Carbon Monoxide Detection Equipment Required as per SubChapter 4 5:70-4.9	N.J.A.C. 5:70-4.9.(d)	Install (2) carbone monoxide detectors. 10 yr. sealed battery or plug-in devices.
	Main	Rear wall in store	Fire Resistive Rated Assembly	Holes in ceiling, walls, floors or ceiling tiles must be repaired	N.J.A.C. 5:70-3, 703.1	Repair void in wall using rated materials not less than existing.
	Main	Rear store access door	Electrical	Clearance required around electrical equipment (30 in wide x 36 in deep x 78 in height)	N.J.A.C. 5:70-3, 605.3	Remove storage from electrical panels
	Main	Access room behind dryers	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2	Provide letter indicating cleaning around dryer appliances
	Main	Exterior water heater closet	Illumination and Signs		N.J.A.C. 5:70-3, 703.2.1	Post permanent sign red with white letters not less than 1" in height "WATER HEATER"

03/06/19 18:08	Periodic	6 Violations	Carbone, Rocco	03/06/19 18:44
----------------	----------	--------------	----------------	----------------

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	Main	Front Entrance	Portable Fire Extinguishers	Fire extinguisher need to be inspected, maintained and tested in accordance with NFPA 10	N.J.A.C. 5:70-3, 906.2	Service discharged fire extinguisher
	Main	Store & furnace room	Retrofit Code	Carbon Monoxide Detection Equipment Required as per SubChapter 4 5:70-4.9	N.J.A.C. 5:70-4.9.(d)	Install (2) carbone monoxide detectors. 10 yr. sealed battery or plug-in devices.



Ramsey Fire Prevention
33 North Central Ave.
Ramsey NJ 07446
Phone# (201) 825-3400 Fax# (201) 825-0123
Attn: Darryl J. DeMott

Inspection History Report

Printed On: 05/16/23 14:17

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	Main	Rear wall in store	Fire Resistive Rated Assembly	Holes in ceiling, walls, floors or ceiling tiles must be repaired	N.J.A.C. 5:70-3, 703.1	Repair void in wall using rated materials not less than existing.
	Main	Rear store access door	Electrical	Clearance required around electrical equipment (30 in wide x 36 in deep x 78 in height)	N.J.A.C. 5:70-3, 605.3	Remove storage from electrical panels
	Main	Access room behind dryers	Chimneys & Heating Appliances	Dryer vents shall be cleaned and maintained	N.J.A.C. 5:70-3, 603.5.2	Provide letter indicating cleaning around dryer appliances
	Main	Exterior water heater closet	Illumination and Signs		N.J.A.C. 5:70-3, 703.2.1	Post permanent sign red with white letters not less than 1" in height "WATER HEATER"

04/07/18 13:32 Periodic No Violation Found Carbone, Rocco 04/07/18 13:39

05/13/17 11:05 Re-inspectionPeriodic No Violation Found Carbone, Rocco 05/13/17 11:07

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Front entrance	Portable Fire Extinguishers		N.J.A.C. 5:70-3, 906.5	Restore fire extinguisher to station
	General	Exterior-hot water shed	Chimneys & Heating Appliances		N.J.A.C. 5:70-3, 305.1	Remove storage from water heater appliances
	General	Rear utility room	Electrical		N.J.A.C. 5:70-3, 510.1	Identify electrical breaker

04/05/17 17:21 Periodic 3 Violations Carbone, Rocco 04/05/17 17:45

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Front entrance	Portable Fire Extinguishers		N.J.A.C. 5:70-3, 906.5	Restore fire extinguisher to station
	General	Exterior-hot water shed	Chimneys & Heating Appliances		N.J.A.C. 5:70-3, 305.1	Remove storage from water heater appliances
	General	Rear utility room	Electrical		N.J.A.C. 5:70-3, 510.1	Identify electrical breaker