



Ramsey Fire Prevention
33 North Central Ave.
Ramsey NJ 07446
Phone# (201) 825-3400 Fax# (201) 825-0123
Attn: Darryl J. DeMott

Inspection History Report

Printed On: 05/16/23 14:17

System ID# : 3193

State Reg# :

Local ID :

Business/Occupancy Information

Occupancy Name : Tony's Laundromat

Phone : (201) 995-3035

Address : 33 W Main St, STE 1, Ramsey, NJ 07446

Primary Contact : Farkh, Anthony

Phone : (201) 995-3035

Inspection History

Start Date Time	Type	Status	Inspector1	End Date Time
04/20/23 12:35	Periodic	No Violation Found	Kelly, David	04/20/23 12:40

07/27/22 14:48 Re-inspectionPeriodic No Violation Found Taylor, Shelby 07/27/22 14:48

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Storage Area	Key Boxes	Tenant must provide new tenant key for Fire Department Key box (Knox Box)	N.J.A.C. 5:70-3, 506.2	Keys provided to Fire Prevention do not allow access to utility closet. Please provide new keys.
	General		Dangerous Conditions	Dangerous condition which could cause or contribute to fire spread must be removed	N.J.A.C. 5:70-3, 102.1.1.1.	Provide documentation that dryer vents are cleaned from the device to point of discharge.

07/15/22 11:09 Periodic 2 Violations Taylor, Shelby 07/15/22 11:12

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Storage Area	Key Boxes	Tenant must provide new tenant key for Fire Department Key box (Knox Box)	N.J.A.C. 5:70-3, 506.2	Keys provided to Fire Prevention do not allow access to utility closet. Please provide new keys.
	General		Dangerous Conditions	Dangerous condition which could cause or contribute to fire spread must be removed	N.J.A.C. 5:70-3, 102.1.1.1.	Provide documentation that dryer vents are cleaned from the device to point of discharge.

03/12/21 18:59 Re-inspectionPeriodic No Violation Found Carbone, Rocco 03/12/21 19:04

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Rear exit	Portable Fire Extinguishers	Fire extinguisher need to be inspected, maintained and tested in accordance with NFPA 10	N.J.A.C. 5:70-3, 906.2	Provide current inspection
	General	Rear exit	Portable Fire Extinguishers	Fire extinguisher needs to be mounted in a visible location for occupant access	N.J.A.C. 5:70-3, 906.2	Mount on inside wall at rear exit

03/06/21 10:58 Periodic 2 Violations Carbone, Rocco 03/06/21 11:13



Ramsey Fire Prevention
33 North Central Ave.
Ramsey NJ 07446
Phone# (201) 825-3400 Fax# (201) 825-0123
Attn: Darryl J. DeMott

Inspection History Report

Printed On: 05/16/23 14:17

Violation Detail :	Floor	Location	Category	Action	Violation Code	Notes
	General	Rear exit	Portable Fire Extinguishers	Fire extinguisher need to be inspected, maintained and tested in accordance with NFPA 10	N.J.A.C. 5:70-3, 906.2	Provide current inspection
	General	Rear exit	Portable Fire Extinguishers	Fire extinguisher needs to be mounted in a visible location for occupant access	N.J.A.C. 5:70-3, 906.2	Mount on inside wall at rear exit