



WASHINGTON TOWNSHIP

MUNICIPAL OFFICES
MORRIS COUNTY
LONG VALLEY, N. J. 07853

43 Schooley's Mtn. Rd.
P. O. Box 216

Area Code 201
876-3315

WELL INFORMATION TO BE RETURNED TO BOARD OF HEALTH OFFICE BEFORE A WATER SAMPLE CAN BE TAKEN AND FINAL CERTIFICATE OF OCCUPANCY ISSUED.

PERMIT NO. 24-27558 DATE INSTALLATION COMPLETED 10/29/93
DRILLER'S NAME AND ADDRESS D & L WELL DRILLING & PUMP CO., P. O. Box 5139
CLINTON, NJ 08809 TELEPHONE NO. 534-4475
DRILLER'S LICENSE NO. 1020 TYPE OF LICENSE JOURNEYMAN
DEPTH 205 FT. DIAMETER OF CASING 6"
GEOLOGICAL FORMATION 0-40' SANDY CLAY; 40-205' HARD GRAY GRANITE
STATIC WATER LEVEL 3 FT. CASED DEPTH 64 FT.
ELEVATION AT GROUND SURFACE _____ DEPTH TO BEDROCK 44 FT.
PUMPING LEVEL 80 FT. G. P. M. 20
DRAWDOWN _____ BIT SIZE START 10"
HOURS PUMPED 4 BIT SIZE FINISH 6"
SPECIFIC CAPACITY (YIELD/DRAWDOWN) 20 GPM
DEPTH AT WHICH CASING CEMENTED IN ROCK 64 FT.
AMOUNT OF CEMENT AND MIXTURE OF CEMENT 8 DRIVE SHOE USED YES
TYPE OF PUMP SUBMERSIBLE H.P. 1/2 FT. OF DROP PIPE _____
PRESSURE TANK SIZE 82 GAL. STORAGE DEPTH OF SETTING 80 FT.
WELL VENTED YES SCREEN SPECS: _____
NAME AND ADDRESS OF OWNER STATELINE CONSTRUCTION CO., INC.
170 CHANGE BRIDGE RD., MONTVILLE, NJ 07045
LOCATION OF WELL: STREET W. VALLEY BROOK RD. BLOCK 59 LOT 60.05
PUMP INSTALLER'S SIGNATURE EDWARD DELCARLO *Edward DelCarlo*
DRILLER'S SIGNATURE GLENN R. LANE *Glenn R. Lane*
WATER SAMPLE TAKEN _____ SAMPLE RETURNED _____

