



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Inspection Activity Report

Inspections for Permit Number 22-0868

Tracking Number
C-22-000347

					Owner				
Inspection Date	Inspection Type	Inspector		Subcode	Result	Location	Work Type	Work Description	Inspection Comments
06/20/2022	Final	Kenneth Kiseli		Building	Pass	MACIEL TELLO ZAVALETA 941 CYPRESS AVE.	Alteration	SOLAR PANELS	
06/20/2022	Final	Thomas Olson InActive		Electrical	Fail	MACIEL TELLO ZAVALETA 941 CYPRESS AVE.	Alteration	SOLAR PANELS	Agent: SUNTIVITY ELECTRIC LLC Phone: (732) 979-2400/ Bushing missing on 1 inch P V C out side Pitchers of deck box on roof missing K O seal
06/20/2022	Final	Richard Orlando		Fire	Pass	MACIEL TELLO ZAVALETA 941 CYPRESS AVE.	Alteration	SOLAR PANELS	Agent: SUNTIVITY ELECTRIC LLC Phone: (732) 979-2400/
07/13/2022	Final	Stuart Safeer		Electrical	Pass	MACIEL TELLO ZAVALETA 941 CYPRESS AVE.	Alteration	SOLAR PANELS	