

Pamela Castle

From: Karen Stallings
Sent: Thursday, April 26, 2018 2:04 PM
To: Pamela Castle; Kim Erickson; Gianna Perrone
Cc: Anthony Cirz
Subject: FW: Open Public Records Act request - Permits- VFW

Follow Up Flag: Follow up
Flag Status: Flagged

Below is a request for Public Records the response is due no later than May 7, 2018

-----Original Message-----

From: Beverly Carle
Sent: Thursday, April 26, 2018 2:01 PM
To: Karen Stallings
Subject: FW: Open Public Records Act request - Permits- VFW

-----Original Message-----

From: David Schlick [mailto:opra+request-1561-d0eb3f66@requests.opramachine.com]
Sent: Thursday, April 26, 2018 2:00 PM
To: Beverly Carle
Subject: Open Public Records Act request - Permits- VFW

Dear Berkeley Township,

This is a request for public records made under OPRA and the common law right of access. Please acknowledge receipt of this message.

Records requested:

All permits and inspection reports for the Bayville Twp VFW located at 383 Veterans Blvd. since 2016

Yours faithfully,
David Schlick

Please use this email address for all replies to this request:
opra+request-1561-d0eb3f66@requests.opramachine.com

Is townshipclerk@twp.berkeley.nj.us the wrong address for Open Public Records Act requests to Berkeley Township? If so, please contact us using this form:
https://opramachine.com/change_request/new?body=berkeley_township

Disclaimer: This message and any reply that you make will be published on the internet. Our privacy and copyright policies:
<https://opramachine.com/help/officers>

Please note that in some cases publication of requests and responses will be delayed.

If you find this service useful as an OPRA officer, please ask your web manager to link to us from your organisation's OPRA page.



Construction

Property Summary		Portal Refresh Open All
Owner:	BERKELEY TOWNSHIP V F W POST 9503	
Location:	383 VETERANS BLVD	
Block:	601	
Lot:	1	
Lead Parcel:	Yes	
Qualifier:		

▼ About the Owner...

▼ About the Property...

▼ About the Taxes...

▼ Property Address Aliases...

▼ Parcel Photo...

▼ Projects...

▲ Construction...

Applications... [Expand](#)

Permit Issue Date	Control Number	Permit Number	Work Type	Subcodes	Status	Close Date	Certificates	Total Cost	Agent
	C-17-04695		Alteration	B E F	Plan Review Pending			\$8,301	EVI INC
KITCHEN HOOD EXHAUST SYSTEM IN REJECTION NEEDS ELECTRICAL SUBCODE TECH SHEET-PJC CONTRACTOR CALLED 12/19/17-PJC									
	C-16-01159				Under Review			\$0	
ZONING PATIO COVER 3/28/16--NM									
	75607		Alteration	P	Under Review			\$0	R & T PLUMBING & HEATING, LLC
WATER SERVICE									
	2/7/2018	C-17-04832	17-2809+B	Alteration	E F	Open		\$26,000	Reliable Fire Protection
FIRE SUPPRESSION ALTERATIONS									
	1/11/2018	C-18-00037	17-2809+A	Alteration	B	Open		\$30,000	J BREUR CONSTRUCTION, LLC
FULL RELEASE BUILDING ONLY 36X16 STORAGE ADDITION ***PARTIAL RELEASE ONLY MUST UPDATE FIRE AND ELECTRIC*****									
	10/23/2017	C-17-04022	17-2809	Addition	B	Open		\$30,000	J BREUR CONSTRUCTION, LLC
COMMERCIAL ADDITION 36X16 STORAGE ADDITION ***PARTIAL RELEASE ONLY MUST UPDATE FIRE AND ELECTRIC*****									
	4/15/2016	C-16-01274	16-0811	Addition	B	CA and Close Date 5/9/2016 Issued	CA	\$6,500	JEFFERS ALUMINUM
12 x 20 PORCH COVER									
	4/15/2016	C-16-00660	16-0812	Alteration	F	Open		\$3,680	Reliable Fire Protection

FIRE SUPPRESSION ALTERATIONS UPGRADE THE EXISTING KITCHEN. FIRE SUPPRESSION SYSTEM

12/7/2015 C-15-117613 15-3052 Alteration B E CA and Close Date 4/8/2016 CA \$6,000 GIRTAIN SIGNS LLC

SIGN INSTALLATION WITH ELEC

4/16/2015 97116 20150824 Alteration B Open \$13,000 J. Breur Construction Company

Siding

Would you like to add a application to this parcel? YesInspections... Expand

Date	Control Number	Permit Number	Subcode	Type	Inspector	Result	Comment	Result Comment
4/24/2018	C-17-04022	17-2809	Building	INSULATION	Robert Obrien	Pass	GP VIA PORTAL Req: Jeffrey Breur 2014060498 jbreur@comcast.net	
4/20/2018	C-17-04832	17-2809+B	Electrical	SERVICE	Doug Mohr	Pass	Agent: Reliable Fire Protection Phone: (732) 643-0075/ DR339704179 REMOVING SERVICE ALSO DR#339704178	Get Contractor Name and Lic# for CUT-IN-CARD
4/20/2018	C-17-04832	17-2809+B	Electrical	ROUGH	Doug Mohr	Pass	Agent: Reliable Fire Protection Phone: (732) 643-0075/ VIA PORTAL-PJC VIA PORTAL-PJC Req: Jeffrey Breur 2014060498 jbreur@comcast.net	
4/19/2018	C-17-04022	17-2809	Building	FRAMING	Robert Obrien	Pass	*****ALL ROUGHS MUST BE PASSED***** Inspection confirmed by permit user 'JBREUR@COMCAST.NET' (04/18/2018 09:01 AM).	
2/20/2018	C-17-04022	17-2809	Building	SHEATHING	Robert Obrien	Pass	Jeffrey Breur 2014060498 VIA PORTAL-PJC	
1/26/2018	C-17-04022	17-2809	Building	FOOTING	Robert Obrien		GP JEFFREY 201-406-0498	
1/25/2018	C-17-04022	17-2809	Building	FOOTING	David Sanchez	Fail	VIA PORTAL-PJC Req: Jeffrey Breur 2014060498 jbreur@comcast.net	I looked all over the job site for a set of drawings . Did not see nothing. I failed this Inspection because there were no drawings on site
1/22/2018	C-17-04022	17-2809	Building	FOOTING	David Sanchez	Cancelled	VIA PORTAL-PJC Req: Jeffrey Breur 2014060498 jbreur@comcast.net Inspection cancelled by permit user 'jbreur@comcast.net' (01/21/2018 01:10 PM). Reason for cancellation: Not ready	
5/11/2016	C-16-00660	16-0812	Fire	FIRE SUPPRESSION	Bryant Curry	Fail	JIM 732-643-0075 EXT 200 KE IS REQUESTING AN AFTERNOON APPT.	pastel drawing is required for changes. Suppression systems required to be tied to fire alarm
5/6/2016	C-16-01274	16-0811	Building	Final	Robert Obrien	Pass	NM	

Violations...

There is no violation data for the selected parcel.

Would you like to add an violation to this parcel? Yes

Ongoing Applications...

There is no application data for the selected parcel.

Would you like to add an application to this parcel? Yes

- ▼ Municipal Tree...
- ▼ Pet...
- ▼ Complaints...
- ▼ Clerk...
- ▼ Health...
- ▼ Land Use...
- ▼ Engineering...
- ▼ Code Enforcement...
- ▼ Health Pro...